

WEYERHAESUER COMPANY – Pine Hill, AL

Ambient TRS Study – Phase II

April 2002

DISTRIBUTION

***	J. Stoudenmier	Pine Hill Sort 241
*	J. Emerson	Pine Hill
***	K. Mathews	Pine Hill
**	H. Larrimore	Pine Hill
***	L. Bagley	Pine Hill
***	H. Davis	Pine Hill
***	L. Sakamoto	WTC 2G2
***	M. Young	WTC 2G2
**	V. Dallons	WTC 2G2
**	M. Rast	Columbus Sort 153
*	B. Crowell	CH 3D29
**	W. Bryant	New Bern Sort 121
**	B. Barkley	New Bern Sort 121
***	ES&T File Center	WTC 2G2
***	TIC	WTC TIC

* Executive Summary Only
** Report Body
*** Report Body with Appendices



RESEARCH REPORT
EH & S Technology & Science

Technical Report
Technical Note

Trip Report
Other

Executive Summary

Project No. 721-9063
Page 1 of 30

Ambient TRS Study – Phase II

Pine Hill, Alabama

April 2002

Executive Summary

Overview

This report documents the results and findings of the second phase of an investigation to identify sources of TRS emissions that have a ground level impact on Weyerhaeuser's Pine Hill, Alabama pulp and paper complex. Phase I of the TRS ambient study focused on establishing baseline conditions prior to implementation and start-up of the MACT related projects. This first phase measurements were conducted on February 6-14, 2001.

The objective of Phase II is to quantify the reductions in TRS emissions resulting from the implementation of the MACT program. Phase II measurements were conducted from November 29 through December 9, 2001.

Results

- Implementation of MACT program has removed approximately 80 lb/hr of TRS from entering the wastewater treatment system. This accounts for approximately 11 % of the total ground level TRS emissions from the mill. This TRS would presumably be stripped to the atmosphere at the ASB if left in the system.
- The TRS emission rate changed between Phase I and Phase II at the following major TRS emission sources:

DISTRIBUTION TO TECHNICAL INFORMATION CENTER	LOCATION TIC	REVIEWED BY (Signature)	DATE
		<i>J. W. Wadsworth</i> APPROV (Name and Signature) Larry Sakamoto	5/13/02
PROJECT NO. 721-9063		APPROVED BY (Signature) <i>G. D. Hallens</i>	5/12/02



Strictly Proprietary (Red): Disclosure strictly limited to persons on a managed list. Contact:


Proprietary (Yellow): Disclosure limited to persons confidentially bound to Weyerhaeuser on a need to know basis.

Non-Proprietary (Green): Disclosure unlimited.



TRS Emission Source	Type of Sample Taken	TRS Emission Rate(lb/hr)		Percent Change from Phase I to Phase II
		Phase I average (range)	Phase II average (range)	
Polishing Pond	Air	540 (30-2300)	488 (10-2644)	- 10%
ASB	Air	270 (one sample)	not estimated	na
ASB	Effluent	113 (5-359)	195 (102-282)	+ 72%
Polishing Pond Inlet	Air	41 (one sample)	19 (10-33)	- 54%
Pulp Mill	Air	23 (17-32)	not estimated	na
Step Aerator	Air	17 (one sample)	8 (one sample)	- 53%
Primary Clarifier	Air	7 (5-12)	not estimated	na
Primary Clarifier	Effluent	no sample taken	3 (one sample)	na
Total		741	713	- 4%

- The figure below shows the amount of TRS coming from the various sources, including generation in the polishing pond. The polishing pond is the major contributor of TRS.





Conclusions

1. The MACT program resulted in a modest reduction of 80 lb/hr of TRS in the wastewater system. The mill continues to process over 700 lb/hr through the wastewater system.
2. The two most significant sources of ground level TRS emissions include the following:
 - *Polishing pond*
 - *ASB*
3. The major contributors of TRS to the wastewater treatment system include:
 - Sulfides in the recaust sewer.
 - Sulfide generation in the polishing pond due to anaerobic biological activity.
 - Note: Sulfide generation or oxidation in the ASB was not quantified during this phase of the study.

Recommendations

1. Develop means of reducing H₂S generation in the polishing pond. This may include adding aeration capacity at the wastewater treatment system. (Note: Additional control of the H₂S generation in other areas of the wastewater treatment system, e.g. ASB, primary clarifier, etc. may be required to address a total mill TRS reduction program).
2. Reduce and control the amount of TRS and high pH containing material going to the recaust sewer.
3. Evaluate effect of implementing items 1 and 2 above. This may involve documenting reduced ambient TRS impacts with the ENSR met station, and/or measuring the TRS emission reduction from the major sources using the air dispersion model approach.



1.0 Introduction and Background

1.1 Overview

The Weyerhaeuser Pine Hill, Alabama pulp and paper facility recently implemented a program to comply with the mandated Maximum Achievable Control Technology (MACT) regulation. The MACT regulation requires the collection and destruction of regulated hazardous air pollutants (HAP).

MACT technology includes collection, separation, and incineration of methanol from various process areas. Total reduced sulfur (TRS) compounds are coincidentally collected, treated, and destroyed along with the methanol. Compliance with the MACT regulation is expected to reduce TRS emissions and lower ambient TRS concentrations throughout the mill.

Two major capital projects were undertaken as part of the MACT program. The following are the two newly installed systems:

- *Condensate steam stripper system* – This system collects foul condensate from selected pulp mill process areas. The condensate is stripped with steam to remove the HAP. The HAP are sent to the noncondensable gas (NCG) thermal oxidizer for destruction.
- *Noncondensable gas thermal oxidizer* – The NCG thermal oxidizer destroys the HAP from the condensate stripper and other NCG streams from the pulp mill.

Because the MACT projects are expected to measurably reduce TRS emissions, the Pine Hill facility commissioned a study to quantify the reduction. Prior to startup of the MACT projects, an initial study was conducted to identify where ground level TRS compound were released in the mill and estimate ground level TRS emission rates prior to implementation of MACT. This first phase included onsite testing during February 6-14, 2001. The results of this study were published in an internal Weyerhaeuser report titled “Weyerhaeuser Co. – Pine Hill, Al. Ambient TRS Study – February 2001”.

After the startup of the MACT equipment, Phase II of the study was conducted to document the reduction of TRS emissions. Phase II was conducted nine months later, during November 29th through December 9th, 2001.

This report documents the results of Phase II of the TRS study conducted at the Weyerhaeuser Pine Hill facility.



1.2 *Study Objectives*

The primary objective of Phase II is to document the decrease in TRS emissions resulting from the implementation of the MACT program. As part of this documentation, the primary goals include the following:

- Compare the TRS mass emission rates between Phase I and Phase II to quantify the reductions.
- Quantify the reduction in TRS emissions from the major sources.
- Identify key opportunities that will assist in minimizing or eliminating ground level TRS emissions.



2.0 Methodology

2.1 Overview

Changes in emissions before and after MACT were assessed by two methods: estimating emissions from ground level sources by back modeling of ambient TRS concentrations measured downwind of pertinent unit operations, and measuring TRS compounds in sewers that have the potential to be stripped during waste water treatment operations.

Back modeling techniques - Ambient TRS concentrations at the Pine Hill facility were monitored using a mobile air sampling station. The mobile station was strategically positioned to allow direct TRS measurements from the suspected various TRS emission sources. The mobile station recorded pertinent meteorological data at each sampling location.

The TRS concentration information was used in an EPA approved air dispersion model to calculate the emission rate from each source. The emission rates were then compared between Phase I and Phase II to determine whether a change occurred as a result of the MACT program.

Wastewater TRS measurements - Wastewater from selected sewers were collected daily for analysis of TRS components to identify sources of reduced sulfur compounds being released from the effluent treatment systems. The samples were analyzed for: hydrogen sulfide (H_2S), methyl mercaptan (MeSH), dimethyl sulfide (DMS) and dimethyl disulfide (DMDS). Flow data was obtained for the corresponding streams from the mill and used to calculate mass flow of TRS compounds.


2.2 Air Monitoring Methodology

2.2.1 Pine Hill Facility Overview

An overview of the Weyerhaeuser Pine Hill pulp and paper facility is shown in Figure 2-1. In addition, Figure 2-1 also shows the primary areas of interest for the TRS study.



Figure 2-1. Pine Hill Pulp and Paper Facility




2.2.2 Mobile Air Monitoring Station

A mobile air monitoring station was used to collect ambient air data for the TRS study. The mobile station consisted of a two-person vehicle traveling throughout the mill collecting air data at selected sites. The data was collected on a routine schedule, normally in the early morning. The team collected air data at 38 selected locations. Figure 2-2 shows the 38 different sites. The locations of these sites were mapped to +/- 10 feet using a global positioning system (GPS) instrument.



Figure 2-2. Mobile Station Test Site Locations



The 38 sampling sites were chosen to represent a cross-section of the TRS emissions from the entire facility. At each sampling site the following information was collected:

- Wind direction
- Wind speed
- H₂S concentration
- Atmospheric stability class information (*obtained from ENSR station*)

The 38 locations were sampled nine different times over the eleven-day test period between November 29th and December 9th, 2001. In addition to the nine routine sampling sets, additional air data was collected during the following periods:

- *During the interior polishing pond liquid sampling test period* - air monitoring data was collected along the perimeter of the polishing pond.
- *During high wind periods* - data was collected at multiple inline locations (aligned with the source) to validate the dispersion model parameters.
- *During favorable wind periods* – data was collected along the mill's fenceline (these locations were typically along the mill's southern fenceline).



2.3 Air Dispersion Model

TRS mass emission rates can be estimated using the TRS concentration data and an ambient air dispersion model. The EPA approved SCREEN1 Dispersion Model was used to estimate the mass emission rates. The SCREEN1 model normally uses mass emission rates, associated physical information (source area, terrain type) and climatic data inputs (release height, wind speed, solar radiation level) to calculate ground level concentrations. For this study, the ground level concentrations from the mobile monitoring station were used to back-calculate the predicted mass rate from each emission source.

The model's input parameters have been tuned by matching model predictions with measured TRS concentrations at various locations downwind of the source. Also, only TRS data that was obtained during the appropriate climatic stability class were modeled. Stability class categories are used to describe the level of air turbulence. The most widely used category is the Pasquill Stability Classes A, B, C, D, E and F. Class A denotes the most unstable or most turbulent conditions, and Class F denotes the most stable or least turbulent conditions. Climatic conditions with a Class C and D was considered to be a stable atmospheric condition. The criteria for a Class C stability rating includes the following:

- *Stable air flow*, with minimal vertical mixing of the air
- *Steady winds*, with a minimum of around 5 mph
- *Steady wind direction*

Using the appropriate stability class ensures that TRS mixing from other sources is minimized. Therefore, only TRS emissions from the selected source are accounted for in the estimate.

2.3.1 Precision and Accuracy of the Air Dispersion Model Approach

The use of the SCREEN1 air dispersion model to estimate TRS emission rates from area sources includes several assumptions. For example, the SCREEN1 model is not suited to area sources where changes in the model configuration, such as assumed plume widths, can result in a factor of 2 or 3 difference. However, calibration of the model using multiple point readings will greatly reduce the uncertainty in the modeled results. These reading are taken at different distances from the source along the same downwind line.

Therefore, the results provided in this report should be viewed as relative values, mainly for comparison purposes, and not necessarily absolute numbers. Where possible, results are shown as averages with the ranges of readings.



2.4 Wastewater Testing Methodology

2.4.1 Daily Wastewater Samples

During both phases of the TRS study, grab wastewater samples were taken daily at selected locations throughout the mill. Phase II collected samples at the following twelve locations:

- *Pulp mill sewer*
- *Power & recovery sewer*
- *Recaust area sewer*
- *No. 1 paper machine sewer*
- *No. 2 paper machine sewer*
- *Ash pond overflow*
- *Primary clarifier inlet*
- *Primary clarifier outlet*
- *Inlet to ASB*
- *Discharge from ASB*
- *Discharge of the step aerator*
- *Discharge of the polishing pond*

The daily samples were tested for the following constituents:

- Total sulfide (as H₂S)
- Methyl mercaptan (MeSH)
- Dimethyl sulfide (DMS)
- Dimethyl disulfide (DMDS)



3.0 TRS Source Identification

3.1 *Overview*

TRS emission sources were identified using the wind direction data from the mobile air station. By using the wind direction, TRS sources upwind of the mobile station can be readily identified.

3.2 *Source Identification Using the Mobile Station*

One of the major benefits of using a mobile station is its ability to directly identify the TRS sources during most atmospheric conditions. This is because the mobile station can place itself in a downwind position next to the suspected TRS source. Therefore, any TRS detected can be attributed to the suspected source if the other atmospheric conditions are suitable, e.g. appropriate wind stability class.

The mobile station was found to work extremely well in identifying the emission sources. Only in cases where wind turbulence around a structure or building became a factor, at low wind speeds, and winds from variable directions did source identification prove more difficult. For example, several sampling sites were located in and around the pulp digester and washing area. Although wind directions and H₂S readings identified the pulp mill area, specific TRS point sources could not be identified. This was due to the buildings in this area, which would mix and channel the wind. Consequently, precise point source identification around the pulp mill area was not often possible.

3.3 *Major TRS Emission Sources*

Sources contributing to in-mill ground level ambient TRS were identified by measuring H₂S concentrations wind speed and wind direction at selected locations throughout the facility. Mill maps with the raw data can be found in Appendix A and Appendix B.

During Phase II, the sources with the highest downwind TRS concentrations during stable atmospheric conditions are shown in Table 3-1. Note that the concentrations for each source are affected by multiple variables including wind speed, atmospheric stability (vertical mixing and consistency of wind direction), terrain and structures, and distance between the source and measurement point.



Table 3-1 Major Ground Level TRS Emission Sources

Emission Source	Average TRS Concentration (measured as ppb H ₂ S)	Median TRS Concentration (measured as ppb H ₂ S)	Number of Measurements
<i>Step Aerator</i>	1222	1583	3
<i>Polishing Pond</i>	726	529	66
<i>ASB</i>	376	169	32
<i>Primary Clarifier Area</i>	97	22	8
<i>Ash Pond</i>	33	24	5
<i>Pulp Mill Area</i>	13	13	2
<i>Recaustisizing Area</i>	10	10	2
<i>Equalization Basin Area</i>	7	7	1

Note that these TRS measurements were taken during normal operation. Abnormal conditions, e.g. spills, startups, shutdowns, etc. would likely cause higher readings at the localized affected area.



4.0 TRS Emission Quantification

4.1 *Overview*

During Phase II, ambient TRS concentrations were measured from selected sample site locations. The concentration values were used in the EPA approved SCREEN1 air dispersion model to estimate the TRS emission rates from the various emission sources.

Although numerous TRS concentration measurements were taken over the eleven-day Phase II period, only a limited number could be used in the SCREEN1 model. Due to unacceptable climatic conditions, i.e. non-Class C or D atmospheric stability ratings or unfavorable wind directions, most of the measurements could not be used.

4.2 *Primary Clarifier TRS Emissions*

Unfavorable climatic conditions existed during the study period such that no valid TRS data could be collected from the primary clarifier area. Unfavorable climatic conditions could include situations such as incorrect wind direction, or inadequate wind stability class rating. Therefore, no TRS concentration data was available to estimate the TRS emission rates with the dispersion model.

4.3 *ASB TRS Emissions*

Unfavorable climatic conditions existed during the study period such that no valid TRS data could be collected from the ASB. Therefore, no TRS concentration data was available to estimate the TRS emission rates with the dispersion model.

4.4 *Pulp Mill TRS Emissions*

Unfavorable climatic conditions existed during the study period such that no valid TRS data could be collected from the pulp mill area. Therefore, no TRS concentration data was available to estimate the TRS emission rates with the dispersion model.

4.5 *Polishing Pond TRS Emissions*

TRS concentration measurements were taken from selected locations around the polishing pond. These measurements were used in the air dispersion model to predict the emission rates.

Similar to Phase I, three sections of the Pond were modeled separately. The modeled areas were designated as A, B and C. These areas are shown in Figure 4-1.



Figure 4-1. Polishing Pond Modeled Areas



Area C represents the inlet to the polishing pond. Area B is the northeast corner of the pond. Due to the internal curtain arrangement in the pond the effluent accumulates in this corner prior to entering the main pond area. Area A represents the main polishing pond region. The pond discharges near the lower east end of the pond into the Alabama River.



4.5.1 Polishing Pond - Modeling Results

Table 4-1 shows the air dispersion results for the three polishing pond areas. TRS emissions from Area A ranged from 123 to 2264 lb/hr, with an average of 621 lb/hr. Area C, the polishing pond inlet, ranged 10 to 33 lb/hr and averaged 19 lb/hr. No TRS emission rates were estimated for Area B due to unsuitable climatic data.

Table 4-1. Polishing Pond Modeling Results


Date	Time	Sample Location	Wind speed (mph)	Stability Class	Distance from source (ft)	Modeled Width (ft)	Measured H ₂ S (ppb)	Estimated H ₂ S Emissions (lb/hr)
Area A (East pond area)								
11/30	6:23	6	2.9	D	1660	2500	1438	248
11/30	15:48	6	2.5	D	1660	2500	843	123
11/30	6:26	6-2	2.7	D	1660	2500	1473	234
11/30	6:30	6a	2.9	D	1660	2500	850	147
11/30	15:41	6b	2.9	D	1660	2500	1190	206
11/30	6:18	6d	3.4	D	1660	2500	1027	204
12/8	13:50	6b	6.7	C	1660	2500	2400	1837
12/8	13:55	6e	9.3	C	1660	2500	2467	2644
12/8	13:25	6b	3.4	C	1660	2500	1640	628
Area B (West pond area) No estimates made because Area B could not be isolated during Phase II								
Area C (Inlet area of pond)								
12/9	10:12	11h	11.1	C	390	300	630	33
12/9	10:25	11i	3.8	C	390	300	670	16
12/9	12:23	11a	7.0	C	390	300	490	16
12/9	10:28	11j	4.0	C	390	300	513	10



4.5.2 Polishing Pond - TRS Emission Dependence on Wind Speed

As previously discovered in Phase I, TRS emission rates from the polishing pond are significantly affected by wind speed above the pond. This relationship is shown in Figure 4-2.

Figure 4-2. Polishing Pond Emission Rate as a Function of Wind Speed



As Figure 4-2 clearly shows the higher the wind speed the greater the emission rate. It shows that the TRS emission rate exponentially increases as a function of the wind speed.

The Phase II (December 2001) relationship shown in Figure 4-2 was used to estimate the average emission rate from the polishing pond. Note that if only the ambient TRS measurements were used with this relationship, the results would over estimate the emission rates because the ambient measurements were taken only on windy days (>5 mph). Therefore, the results would only represent the results on the right side of the relationship curve.

Therefore, to provide a more representative overall TRS emission rate, the TRS emissions equation ($y = 23x^{2.1}$) was used with the ENSR station wind speed data for the entire month of December. The average TRS emission rate was calculated to be approximately 517 lb/hr. This value is consistent with the 488 lb/hr estimated with the modeling results for the polishing pond.



5.0 Wastewater Studies

5.1 Overview

Samples of wastewater from various process areas entering and leaving the wastewater treatment system were collected and analyzed for TRS compounds. The purpose of the sampling was to identify sources of TRS entering the wastewater treatment system and points of potential loss from the wastewater treatment system. The methods used, data collected and data reduction are contained in the Appendix.

5.2 Process Sewer TRS Constituents

The TRS entering the sewer is made up of mostly sulfides, with smaller amounts of methyl mercaptan, methyl disulfide, and dimethyl disulfide. Table 5-1 shows the composition of TRS in the sewers entering the effluent treatment system.

Table 5-1. TRS Constituents in Sewers

Process Sewer	Average TRS (lb/hr as H ₂ S)	H ₂ S (%)	MESH (%)	DMS (%)	DMDS (%)
Recast Sewer ¹	163	89	10	1	0
Power and Recovery Sewer	64	66	11	2	21
Pulp Mill Sewer	11	96	2	1	1
#2 Paper Machine Sewer	0.5	42	16	0	42
#1 Paper Machine Sewer	Unknown ²	na	na	na	na
Average		73	10	1	16

¹ The recast sewer delivers approximately 575 lb/hr TRS to the ash pond. Most the TRS is oxidized in the ash pond, whereby only 163 lb/hr enters the ASB.

² no wastewater flow rate measured for #1 PM sewer.

5.3 Major TRS Contributors

As previously shown in Table 3-1, the wastewater treatment system can emit elevated levels of TRS to the atmosphere. This TRS is introduced into the wastewater system by two means. As shown in Table 5-1, substantial amounts of TRS are brought in through the process sewers. The other means of TRS entering the wastewater system is H₂S generation in the polishing pond. Note that H₂S generation in the ASB can also occur. However, during this study the H₂S generation rate from the ASB was not quantified.



Table 5-2 shows the quantity of TRS generated in the polishing pond. This value is added to the estimated amount of TRS emitted to the atmosphere to predict the total H₂S generation rate in the pond.

Table 5-2 TRS Generation in the Polishing Pond

Polishing Pond Location	Average TRS (lb/hr as H ₂ S)
<i>Polishing Pond Inlet</i>	32
<i>Polishing Pond Outlet</i>	214
TRS Increase in the Liquid	182
TRS Emitted to the Atmosphere	488
Total TRS Generated	670

H₂S is generated when sulfate and thiosulfite in the wastewater is reduced to sulfide. The generation rate is believed to be dependent upon several factors such as the oxygen level in the wastewater, BOD concentration, etc.

All of the TRS found in the wastewater treatment system is either introduced by the process sewers or generated in the polishing pond. Figure 5-1 shows the relative amounts of TRS that can be expected from the process sewers and polishing pond generation.

Figure 5-1. Sources of TRS to the Wastewater Treatment System







Figure 5-1 shows that 51% of the TRS in the wastewater treatment system is generated in the polishing pond. The recaust sewer contributes another 43%. The remaining 6% of the TRS is attributed to the other process sewers, e.g. power & recovery, pulp mill and the two paper machine sewers.

As previously mentioned, H₂S generation in the ASB may occur. Operating conditions at the ASB, such as soluble BOD content, pH and DO concentration, will influence the generation rate. However, this study did not quantify the H₂S generation rate at the ASB.

5.4 Process Sewers - TRS Mass Flows

The TRS mass flow in the pulp mill, power and recovery, and recaust sewers were measured during both Phase I and Phase II. A comparison between the two phases are summarized Figures 5-2 through 5-4 for the different sewers.


Figure 5-2. Pulp Mill Sewer - TRS Mass Flow



The pulp mill sewer showed an increase in the TRS mass flow from Phase I to Phase II. The data showed that there was an increase of around 5 lb/hr during average operating periods, and as much as 2 to 3 times higher during abnormally high TRS mass flow episodes.



Figure 5-3. Power & Recovery Sewer - TRS Mass Flow




The power and recovery process sewer experienced a decrease in the TRS mass flow from Phase I and Phase II. As Figure 5-3 shows, there is an overall decrease of approximately 70-80 lb/hr of TRS in the sewer.

It is estimated that virtually all of this reduction can be attributed to the installation of the condensate steam stripper system. The stripper system processes selected contaminated condensate streams from the pulp mill area. As will be discussed later, an evaluation of the steam stripper system will show a reduction of approximately 80 lb/hr of TRS. Prior to the steam stripper, this TRS would have entered the power and recovery sewer and eventually entered the wastewater treatment system.



Figure 5-4. Recaust Sewer - TRS Mass Flow




As Figure 5-4 shows, the recaust sewer showed an increase in the TRS mass flow between Phase I to Phase II. The recaust sewer experiences very significant releases of TRS containing material during average operating periods, and exceptionally high releases during high release periods. The recaust sewer is the main contributor of TRS to the effluent treatment system from the process sewers.

5.5 Wastewater Treatment System - TRS Mass Flows

The TRS mass flows were also measured at various points in the wastewater treatment system. Figures 5-5 and 5-6 show the TRS mass flow measurements during Phase I and Phase II respectively.



Figure 5-5. Phase I - Wastewater Treatment System TRS Mass Flow



Most of the sulfide compounds entering the ASB will be stripped to the atmosphere by the aeration system. Therefore, the difference in the mass of the sulfide entering and leaving the ASB provides a close approximation of the TRS emissions from the ASB.

However, the sulfide differential across the ASB does not fully account for the H₂S generation that maybe occurring in the ASB. TRS generation in the ASB is a function of various operational conditions, such as soluble BOD content, pH, and DO concentration. Therefore, the TRS air emissions from the ASB include the TRS introduced by the process sewers and the generated TRS.

However, the TRS generation rate in the ASB was not quantified during this study. Therefore, the estimated TRS emissions from the ASB, using only the TRS water data, may underestimate the air emission rates.



Figure 5-6. Phase II - Wastewater Treatment System TRS Mass Flow




Figure 5-6 also shows large losses of TRS between the ASB inlet and outlet. Similar to Phase I, this reduction is attributed to TRS losses to the atmosphere caused by the aeration system. Therefore, most of the difference in the TRS levels at the ASB inlet versus outlet is attributed to atmospheric losses.

The TRS in the ASB influent increased around 80 lb/hr in the Phase II study. The reason for the higher TRS mass flow is due to the greater amount of TRS entering from the recaust sewer. The TRS mass flow levels from the recaust sewer increased on average over 350 lb/hr during Phase II, as compared to Phase I. Although approximately 72% of this TRS appears to been oxidized in the ash pond, because the total mass flow was larger during Phase II, this resulted in an increase of TRS to the ASB.



6.0 TRS Source Reduction and Evaluation

6.1 Overview

The implementation of the MACT program at the Pine Hill facility is expected to reduce the overall TRS emissions from the mill. Phase I of the TRS study established baseline ambient TRS mill concentrations prior to the MACT program. The objective of Phase II is to document the TRS reductions after implementation of the MACT program.

Although Phase II measured a reduction in the overall ambient TRS concentration at the Pine Hill facility, only a portion of this could be attributed to the MACT program. As will be discussed in the following sections, there are several other key factors that have a significant impact on the ambient TRS concentrations at the mill.

6.2 Phase I and Phase II TRS Comparison

TRS emission rates for Phase I and Phase II were estimated using the air dispersion model approach, and effluent liquid tests. These emissions rates, along with the percent change before and after the MACT program, are shown in Table 6-1.

Table 6-1. Phase I and II TRS Emission Rate Comparison

TRS Emission Source	Type of Sample Taken	TRS Emission Rate(lb/hr)		Percent Change from Phase I to Phase II
		Phase I average (range)	Phase II average (range)	
Polishing Pond	Air	540 (30-2300)	488 (10-2644)	- 10%
ASB	Air	270 (one sample)	not estimated ¹	na
ASB	Effluent	113 (5-359)	195 (102-282)	+ 72%
Polishing Pond Inlet	Air	41 (one sample)	19 (10-33)	- 54%
Pulp Mill	Air	23 (17-32)	not estimated ¹	na
Step Aerator	Air	17 (one sample)	8 (one sample)	- 53%
Primary Clarifier	Air	7 (5-12)	not estimated ¹	na
Primary Clarifier	Effluent	no sample taken	3 (one sample)	na
Total		741	713	- 4 %

¹ not estimated – No TRS emission rate was calculated due to unsuitable climatic conditions, inadequate wind stability class rating, or possible TRS emission mixing from other sources.



A description of the TRS emissions from the major sources shown in Table 6-1 is provided below:

Polishing Pond – During Phase I the polishing pond was found to be the largest TRS emission source. It emitted an average of 540 lb/hr (with a range of 30 to 2300 lb/hr) during Phase I. During Phase II the emission rate was estimated to be 488 lb/hr (range of 10-2644 lb/hr). This represented an average 10 % decrease in mass emissions between the two phases.

The polishing pond continuously receives large quantities of sulfur compounds (e.g. sulfide, thiosulfite, and sulfate) from the process sewers. These sulfur compounds can convert to H₂S and be released to the atmosphere. Some of the key factors that influence TRS releases from the polishing pond include:

- pH of the wastewater
- Wind speed above the wastewater
- Dissolved oxygen (DO) concentration
- Biological oxygen demand (BOD) content
- Total sulfur based material concentration

And as previously shown, TRS generation in the pond is significant. The 488 lb/hr only represents the airborne portion of the TRS. A total of approximately 670 lb/hr is being generated in the pond.

ASB – During Phase I, the TRS emissions from the ASB were estimated to be around 270 lb/hr. The SCREEN1 dispersion model was used with the ambient air data to make this estimate. During Phase II, unsuitable wind conditions did not allow acceptable ambient air results for the use of the SCREEN1 model.

However, TRS tests were performed on the wastewater entering the ASB during both Phases. The influent tests showed 113 lb/hr of TRS for Phase I and 195 lb/hr for Phase II. This represented a 72% increase. Much of this increase was due to the increase in TRS from the recaust sewer between Phase I and Phase II.

Polishing Pond Inlet – The polishing pond inlet is the region located at the southwest end of the polishing pond, at the inlet piping to the polishing pond from the ASB. TRS measurements were taken at the locations shown in Figure 2-2 as test sites 11, 11a and 11b.

A comparison between Phase I and Phase II showed a 54 % decrease in the TRS emission rate, from 41 lb/hr to 19 lb/hr.



Pulp Mill – During Phase I, the TRS emission rate from the pulp mill was estimated to be 23 lb/hr. Unfortunately, no suitable TRS measurements were taken during Phase II. Either unacceptable climatic conditions, inadequate wind stability class rating, or TRS emission interference from other sources prevented taking suitable TRS measurements from the pulp mill area.

As a consequence no Phase I and Phase II TRS emission rate comparison was conducted.

Primary Clarifier – Phase I of the TRS study estimated the emission rate from the primary clarifier to be approximately 7 lb/hr. Again, no suitable ambient air data was available to conduct a SCREEN1 model estimate.

However, as a relative comparison, a wastewater test for TRS was conducted on the effluent. It showed 3 lb/hr TRS for Phase II.

6.3 *Implementation of the MACT Program*

The Pine Hill facility installed a condensate steam stripper system and NCG thermal oxidizer to comply with the MACT regulation. The primary purpose of this new equipment is to remove and destroy HAP (including TRS) that is contained in the pulp mill foul condensate.

The foul condensate is collected from selected processes throughout the pulp mill and stored in the steam stripper feed tank. The condensate is fed at an average rate of 400 gallons per minute (gpm) to the stripper distillation column. Virtually all of the TRS is removed from the condensate by the steam stripper.

The Pine Hill stripper feed condensate has an average concentration of 401 ppm TRS. Table 6-2 compares this concentration to condensate located at other Weyerhaeuser facilities.



Table 6-2. Stripper Feed TRS Concentration Comparison

Facility	TRS Compounds				Total TRS (ppm)
	H ₂ S (ppm)	MeSH (ppm)	DMS (ppm)	DMDS (ppm)	
Pine Hill	198	170	21	12	401
Columbus, MS	130	39	265	139	573
New Bern, NC	61	99	132	503	795
Valliant, OK	460	215	47	183	905
Plymouth, NC	214	258	348	271	1091
Average (not including Pine Hill)	216	153	198	274	841

H₂S = hydrogen sulfide

MeSH = methyl mercaptan

DMS = dimethyl sulfide

DMDS = dimethyl disulfide

As Table 6-2 shows, the TRS concentration in the Pine Hill stripper feed is less than half the average concentration of the other four Weyerhaeuser facilities. The data also shows that the Pine Hill condensate contains considerably less dimethyl sulfide (DMS) and dimethyl disulfide (DMDS) than the other facilities. The primary reason for this difference is because the Pine Hill stripper system does not receive the underflow from the turpentine decanter. Typical decanter underflow contains high concentrations of DMS and DMDS. It is expected that if the decanter underflow was sent to the stripper feed tank, the total TRS concentration would be closer to the average TRS concentration found at other Weyerhaeuser mills.

Before the condensate steam stripper was installed, the stripper condensate would have entered the power and recovery sewer, and eventually ended up at the wastewater treatment system. As a result, much of the TRS contained in the condensate could be emitted to the atmosphere from either the process sewer or wastewater treatment system.

With an average concentration of 401 ppm and a flow rate of 400 gpm, the stripper condensate contains approximately 80 lb/hr of TRS. Note that this is comparable to the 70 lb/hr estimated from the TRS mass flow measurements from the power and recovery sewer evaluation.



7.0 Conclusions

Based on the Phase I and Phase II ambient TRS study results, the following conclusions have been developed:

1. The MACT program resulted in a modest reduction of 80 lb/hr of TRS in the wastewater system. The mill continues to process over 700 lb/hr through the wastewater system.
2. The two most significant sources of ground level TRS emissions include the following:
 - *Polishing pond*
 - *ASB*
3. The major contributors of TRS to the wastewater treatment system include:
 - Sulfides in the recaust sewer.
 - Sulfide generation in the polishing pond due to anaerobic biological activity.
 - Note: Sulfide generation or oxidation in the ASB was not quantified during this phase of the study.



8.0 Recommendations

1. Develop means of reducing H₂S generation in the polishing pond. This may include adding aeration capacity at the wastewater treatment system. (Note: Additional control of the H₂S generation in other areas of the wastewater treatment system, e.g. ASB, primary clarifier, etc. may be required to address a total mill TRS reduction program).
2. Reduce and control the amount of TRS and high pH containing material going to the recaust sewer.
3. Evaluate effect of implementing items 1 and 2 above. This may involve documenting reduced ambient TRS impacts with the ENSR met station, and/or measuring the TRS emission reduction from the major sources using the air dispersion model approach.

Appendix

***H₂S Measurements
Field Data
Emission Models
ENSR Weather Summary
Phase II Process Sewer Flow Data
Wastewater Lab Test Results***

PINE HILL TRS STUDY - PHASE II

H₂S Measurements

Pine Hill - Ambient H₂S Odor Study Data

November / December 2001 Tests

Site	2001.4 Test Period		Jerome - ambient measurements			Wind (360°)	Air Temp	Weather Conditions and Comments - Observations		
	ID #	Date	Time	H ₂ S ppb		Avg	direction	mph	°F	WEATHER : 11/30/01 - 1/2
6C	30-Nov	6:04	10	9	9	9	210	1.4	51	slight mill odor
6B	30-Nov	6:13	260	500	340	367	40 S	0.2		ASB
6B-2	30-Nov	6:18	1100	1400	580	1027	320	3.4		From inlet PP
6B-3	30-Nov	6:20	1400	1100	1006	1169	330	1.8		
6	30-Nov	6:23	1500	1114	1700	1438	330	2.9		
6-2	30-Nov	6:26	1400	1118	1900	1473	320	2.7		
6A	30-Nov	6:30	580	570	1400	850	320	2.9		
5A	30-Nov	6:34	510	420	660	528	210	2.7		4th reading - 520 ppb
5	30-Nov	6:40	68	50	32	50	215	1.7		
4C	30-Nov	6:45	3	3	3	3	--	0.0		
4	30-Nov	6:51	3	3	3	3	-- S	0.4		Road - mid pt
4B	30-Nov	6:55	3	3	3	3	--	0.0		
4A	30-Nov	6:58	3	3	3	3	0	1.9		
3C	30-Nov	7:01	120	260	190	190	45	3.9		Clar - strong
11D	30-Nov	7:03	52	48	450	183	330	4.5		Clar
11C	30-Nov	7:08	11	9	9	10	330	3.0		Kiln - upwind
11B	30-Nov	7:11	54	23	27	35	350	5.7		
11A	30-Nov	7:13	19	9	10	13	340	7.7		
11	30-Nov	7:16	2000	2400	400	1600	340	2.4		Riffler
11F	30-Nov	7:21	17	21	54	31	330	1.4		Across all ASB
11E	30-Nov	7:25	46	30	30	35	320	1.9		Inlet ASB
3	30-Nov	7:40	12	12	3	9	215	3.8		
3A	30-Nov	7:43	3	6	8	6	240	3.6		
8B	30-Nov	7:47	3	3	6	4	330	5.1		
10A	30-Nov	7:50	3	3	3	3	330	5.1		
10	30-Nov	7:53	3	3	3	3	355	6.9		
10B	30-Nov	7:55	3	3	3	3	330	5.3		
10C	30-Nov	7:57	3	4	4	4	325	4.4		
10D	30-Nov	7:59	3	3	3	3	325	3.2		
12	30-Nov	8:01	3	3	3	3	220	1.6		
8	30-Nov	8:20	3	3	3	3	280	6.1		
8A	30-Nov	8:22	3	3	3	3	260	10.1		
7A	30-Nov	8:27	3	3	3	3	200	1.7		
7	30-Nov	8:31	2	2	2	2	270	5.1		ENSR
1A	30-Nov	8:40	2	2	2	2	200	5.3		
2	30-Nov	8:44	2	2	2	2	260	3.4		
2A	30-Nov	8:47	3	3	3	3	240	6.4		
2B	30-Nov	8:49	3	5	6	5	280	8.4		
2C	30-Nov	8:52	3	6	6	5	270	2.8		

Pine Hill - Ambient H₂S Odor Study Data

November / December 2001 Tests

Site	2001.4 Test Period			Jerome - ambient measurements			Wind (360°)		Air Temp	Weather Conditions and Comments - Observations
	ID #	Date	Time	H ₂ S ppb			Avg	Direction	mph	
7	30-Nov	15:13	22	5	7	11	300	1.6	65	Winds twitchy
11E	30-Nov	15:17	120	55	54	76	350	1.2		
11C	30-Nov	15:20	6	14	54	25	320	2.7		Winds SW to N
11B	30-Nov	15:23	7	5	6	6	0	2.5		No odor
11A	30-Nov	15:26	11	60	50	40	320	1.4		Very slight PP
11	30-Nov	15:29	160	29	56	82	20	2.0		Strong organic odor, not H ₂ S
11F	30-Nov	15:32	120	23	22	55	320	4.0		Strong organic odor, not H ₂ S
6C	30-Nov	15:35	72	68	68	69	270	0.5		Dead Air
6B	30-Nov	15:38	580	520	680	593	300	0.4		PP odor
6B-1	30-Nov	15:41	670	1400	1500	1190	320	2.9		PP odor
6	30-Nov	15:44	1900	1200	1300	1467	350	5.1		strong PP odor
6-1	30-Nov	15:46	660	1400	660	907	340	2.3		strong PP odor
6	30-Nov	15:48	1500	460	570	843	320	2.5		strong PP odor
5A	30-Nov	15:51	4	3	5	4	--	0.0		
5	30-Nov	15:53	4	4	3	4	340	1.9		
4C	30-Nov	15:56	3	3	3	3	330	0.1		
4	30-Nov	15:58	3	3	3	3	340	0.6		
4B	30-Nov	16:01	3	3	3	3	10	0.9		
4A	30-Nov	16:04	23	20	120	54	350	0.2		
11D	30-Nov	16:05	107	150	54	104	0	2.0		Clar on + off ENE
11E	30-Nov	16:08	16	58	47	40	330	2.1		Clarifier -winds direct from clarifier but vapor plume going West due to wind swirl in bowl
3A	30-Nov	16:12	8	9	4	7	40	3.0		
3	30-Nov	16:14	100	140	5	82	350	1.8		Stinky ash pond
2B	30-Nov	16:18	3	3	2	3	0	1.3		
2A	30-Nov	16:20	3	2	3	3	0	2.1		
2C	30-Nov	16:23	8	5	7	7	340	1		Cross BL storage
2	30-Nov	16:26	3	3	3	3	10	0.7		
1	30-Nov	16:30	3	3	3	3	320	2.7		
12	30-Nov	16:34	18	28	27	24	70	2.8		Main stacks all N
10B	30-Nov	16:40	8	8	8	8	90 S	0.1		
10C	30-Nov	16:42	5	15	4	8	270	1.2		Oily smell
10D	30-Nov	16:43	4	4	3	4	--	0.0		
10	30-Nov	16:45	18	29	15	21	10	1.0		Clar odor
10A	30-Nov	16:47	11	2	5	6	340	1.0		slight clar
8	30-Nov	16:55	4	4	4	4	45	2.3		
8A	30-Nov	17:00	15	15	10	13	340	2.2		
8B	30-Nov	17:10	8	4	4	5	0	1.9		Thru mill
7C	30-Nov	17:11	56	230	200	162	0	1.3		

WEATHER : 11/30/01 - 2/2

.....
Sunny and mild with very light, variable winds mostly from the NW then turning predominantly N / NE after 16:20
C class, then D class after 17:00

groundlevel winds very light, swirling and from variable

Pine Hill - Ambient H₂S Odor Study Data

November / December 2001 Tests

Site	2001.4 Test Period			Jerome - ambient measurements			Wind (360°)	Air Temp	Weather Conditions and Comments - Observations	
	ID #	Date	Time	H ₂ S ppb		Avg				
6C	1-Dec	5:46	300	330	330	320	320	0.2	39	Odor present but non-directional
6B	1-Dec	5:50	350	410	420	393	--	0.0		
6	1-Dec	5:52	460	550	540	517	--	0.0		
6A	1-Dec	5:57	350	350	310	337	--	0.0		
5A	1-Dec	6:00	14	12	28	18	--	0.0		
5	1-Dec	6:03	1	1	1	1	40	0.2		
4C	1-Dec	6:07	1	1	1	1	200	0.0		
4	1-Dec	6:09	0	0	0	0	--	0.0		
4B	1-Dec	6:12	1	1	1	1	350	1.1		
4A	1-Dec	6:14	1	1	1	1	--	1.0		
11D	1-Dec	6:19	180	110	26	105	60	0.2		
11E	1-Dec	6:25	240	140	19	133	--	0.0		
11F	1-Dec	6:28	130	230	190	183	320	0.2		
11	1-Dec	6:30	250	240	190	227	280	0.5		
11A	1-Dec	6:34	72	77	110	86	--	0.0		
11B	1-Dec	6:36	52	57	49	53	320	0.5		
11C	1-Dec	6:39	21	35	48	35	320	0.1		
7	1-Dec	6:44	15	14	12	14	240	0.6		
7A	1-Dec	6:51	8	10	10	9	--	0.0		
12	1-Dec	6:56	3	3	3	3	260	1.4		
12A	1-Dec	6:59	3	3	3	3	260	1.4		
12B	1-Dec	7:00	7	7	2	5	220	0.5		
2	1-Dec	7:04	2	2	1	2	--	0.0		
2C	1-Dec	7:07	2	2	2	2	300	1.2		
2A	1-Dec	7:10	3	0	0	1	340	1.2		
2B	1-Dec	7:13	3	0	0	1	350	0.3		
3	1-Dec	7:15	11	2	11	8	0	2.0		
3A	1-Dec	7:19	3	3	28	11	10	2.4		
3B	1-Dec	7:23	21	14	14	16	340	1.0		
10A	1-Dec	7:26	140	128	50	106	345	1.3	Clarifier	
10	1-Dec	7:28	170	120	140	143	20	2.0	No mill odor	
10B	1-Dec	7:31	8	8	8	8	--	0.0		
10C	1-Dec	7:34	6	3	3	4	300	2.0		
10D	1-Dec	7:36	4	4	3	4	60	0.9		
1	1-Dec	7:41	11	12	12	12	--	0.0		
8	1-Dec	8:24	180	140	170	163	30	1.0	ASB/PP	
8A	1-Dec	8:27	140	50	190	127	60	0.5	PP	

Pine Hill - Ambient H₂S Odor Study Data

November / December 2001 Tests

Site	2001.4 Test Period	Jerome - ambient measurements				Wind (360°)	Air Temp	Weather Conditions and Comments - Observations		
		ID #	Date	Time	H ₂ S ppb	Avg	direction	mph	°F	
7	2-Dec	5:33	155	260	310	242	50	0.1	45	ENSR
6C	2-Dec	5:37	300	230	190	240	--	0.0		
6B	2-Dec	5:40	190	510	56	252	--	0.0	Dead air along trees	
6	2-Dec	5:45	170	52	52	91	--	0.0	Dead calm	
6A	2-Dec	5:50	950	510	780	747	320	0.5	Breeze - moves odor	
5A	2-Dec	5:56	9	4	4	6	10	0.2		
5	2-Dec	5:58	4	4	2	3	320	0.2		
4C	2-Dec	6:02	0	0	0	0	--	0.0		
4	2-Dec	6:04	0	0	2	1	20	0.6		
4B	2-Dec	6:08	2	2	2	2	0	0.1		
4A	2-Dec	6:10	340	210	240	263	350	0.1	H ₂ S smell	
4D	2-Dec	6:15	110	350	550	337	290	0.9	Clar	
11D	2-Dec	6:17	43	43	32	39	270	0.1	Mill	
11B	2-Dec	6:23	110	98	140	116	--	0.0		
11A	2-Dec	6:25	110	83	100	98	350	0.5	Old outfall	
11	2-Dec	6:27	170	110	150	143	320	0.9	Riffler	
11F	2-Dec	6:32	140	140	130	137	10	3.4	Across ASB	
11G	2-Dec	6:35	40	200	222	154	340	2.3		
11C	2-Dec	6:38	200	230	250	227	280	1.2		
10	2-Dec	6:42	14	12	12	13	10	2.6	Clar	
10A	2-Dec	6:45	8	9	9	9	0	3.8		
10E	2-Dec	6:48	150	130	44	108	0	2.4	Clar Direct 10E/10F	
10F	2-Dec	6:51	21	53	52	42	350	1.2	Further down	
3B	2-Dec	6:54	58	52	50	53	320	0.6		
3	2-Dec	7:00	3	3	5	4	350	1.7	Ash pond outfall	
2B	2-Dec	7:02	2	2	3	2	280	0.5		
2A	2-Dec	7:06	3	2	4	3	300	0.7		
2C	2-Dec	7:08	4	0	2	2	270	0.6		
2	2-Dec	7:11	2	2	2	2	--	0.0		
12B	2-Dec	7:15	2	2	2	2	260	2.5		
12A	2-Dec	7:17	2	2	2	2	260	3.2		
12	2-Dec	7:19	2	6	7	5	250	0.1		
12C	2-Dec	7:23	14	16	11	14	0	0.8		
10D	2-Dec	7:24	2	1	1	1	310	1.5		
10C	2-Dec	7:26	1	1	2	1	270	3.4		
10B	2-Dec	7:29	2	2	3	2	270	1.3		
1	2-Dec	7:35	2	2	3	2	230	1.8		
8	2-Dec	7:40	3	3	3	3	250	2		
8A	2-Dec	7:42	1	1		1	300	1.0		

Pine Hill - Ambient H₂S Odor Study Data

November / December 2001 Tests

Site	2001.4 Test Period		Jerome - ambient measurements			Wind (360°)		Air Temp	Weather Conditions and Comments - Observations
	ID #	Date	Time	H ₂ S ppb	Avg	direction	mph		
7	3-Dec	6:03	65	60	75	67	--	0.0	43
6C	3-Dec	6:06	73	--	--	73	--	0.0	Truck ex
6B	3-Dec	6:13	110	111	140	120	--	0.0	
6	3-Dec	6:15	150	160	160	157	--	0.0	Vapor sitting over PP, not moving off
6A	3-Dec	6:18	47	57	64	56	--	0.0	
5A	3-Dec	6:21	150	140	140	143	350	0.3	
5	3-Dec	6:24	34	31	16	27	--	0.0	
4C	3-Dec	6:32	0	0	0	0	--	0.0	
4	3-Dec	6:34	1	1	0	1	--	0.0	
4B	3-Dec	6:37	0	0	0	0	280	0.1	
4A	3-Dec	6:40	0	0	0	0	--	0.0	
11D	3-Dec	6:48	150	106	180	145	--	0.0	
11B	3-Dec	6:53	111	110	75	99	--	0.0	
11A	3-Dec	6:56	560	420	480	487	--	0.0	Stinks like PP
11	3-Dec	6:59	730	720	750	733	--	0.0	
11F	3-Dec	7:03	6	6	9	7	--	0.0	
11E	3-Dec	7:06	720	760	730	737	320	1.1	Stinky ASB
11C	3-Dec	7:08	590	490	540	540	280	2.4	
7A	3-Dec	7:12	12	10	7	10	320	0.3	
8A	3-Dec	7:33	3	3	2	3	--	0.0	Drove down highway 10 minimal odor
8	3-Dec	7:35	3	5	5	4	140	1.0	
12A	3-Dec	7:40	3	3	2	3	--	0.0	
10	3-Dec	7:42	2	2	6	3	--	0.0	
3A	3-Dec	7:55	12	4	8	8	--	0.0	
7	3-Dec	8:04	5	4	5	5	--	0.0	End - no wind
4B	3-Dec	11:39	200	--	--	200	25	2.5	74 gust across pp
4Ba	3-Dec	11:33	130	--	--	130	25	2.9	gust across pp
4A	3-Dec	11:44	150	--	--	150	25	3.0	gust across pp
No measureable wind at remaining sample points									

Pine Hill - Ambient H₂S Odor Study Data

November / December 2001 Tests

Site	2001.4 Test Period		Jerome - ambient measurements			Wind (360°)		Air Temp °F	Weather Conditions and Comments - Observations
	ID #	Date	Time	H ₂ S ppb	Avg	direction	mph		
7	4-Dec	14:05	6	6	6	6	100	4.1	75 Strong solar rad
6C	4-Dec	14:10	110	150	120	127	90	1.5	
6B	4-Dec	14:11	11	8	8	9	105	2.5	
6D	4-Dec	14:18	580	530	170	427	10	1.8	PP odor
6	4-Dec	14:21	110	5	2	39	180	0.5	wind variable + twitchy
6A	4-Dec	14:23	118	510	200	276	350	1.1	wind variable + twitchy
5A	4-Dec	14:27	8	8	8	8	30	0.5	
5	4-Dec	14:31	8	8	8	8	50	0.6	
4C	4-Dec	14:35	67	4	4	25	90	3.0	
4	4-Dec	14:39	270	220	130	207	95	4.3	Funky wind + stink
4B	4-Dec	14:42	510	270	180	320	80	4.1	Funkadelic
4D	4-Dec	14:46	520	540	210	423	90	3.5	Ditto - Wind steadier
4A	4-Dec	14:50	1008	1200	540	916	95	6.1	Weaker sun now
4E	4-Dec	14:57	520	540	410	490	100	4.4	
11D	4-Dec	15:00	190	170	140	167	90	3.9	
11G	4-Dec	15:10	120	150	500	257	70	3.6	ASB + PP
11H	4-Dec	15:15	1300	2700	1700	1900	75	4.1	Across ASB incl R
11I	4-Dec	15:20	430	260	300	330	75	5.3	11i @ corner of store room
11J	4-Dec	15:23	290	500	520	437	75	2.3	Mid of Str room
11K	4-Dec	15:26	270	280	210	253	80	5.2	11K end of Str room
11L	4-Dec	15:29	170	120	120	137	80	2.1	11L near PH sewer
11B	4-Dec	15:36	520	500	570	530	80	3.6	Pol pond
11A	4-Dec	15:41	270	570	540	460	85	2.8	
11	4-Dec	15:45	250	110	147	169	100	3.3	
11M	4-Dec	15:50	560	490	400	483	85	2.9	
11F	4-Dec	15:54	12	12	8	11	95	2.4	Low road data 1600 - 1615
11N	4-Dec	16:09	210	510	530	417	65	5.7	PP
4F	4-Dec	16:20	530	670	670	623	95	3.3	All PP from east along ash pond outer road - distant PP read
4G	4-Dec	16:23	1300	1400	1490	1397	95	4.9	All PP from east along ash pond outer road - distant PP read
4H	4-Dec	16:30	1200	1100	500	933	85	1.9	All PP from east along ash pond outer road - distant PP read
2	4-Dec	16:38	17	9	9	12	80	3.7	
9	6-Dec	11:28	1800	320	940	1020	220	3.7	76 16R0456425-3537826
9a	6-Dec	11:39	500	200	880	527	210	1.2	16R0456373-3537874
8	6-Dec	11:53	780	950	500	743	220	1.8	
7	6-Dec	12:08	540	580	1400	840	280	2.1	0456335-353795
6	6-Dec	12:29	560	650	1100	770	180	4.0	0456034-3538227
6a	6-Dec	12:34	880	410	320	537	190	2.5	0455934-3538370
6b	6-Dec	12:53	200	140	810	383	140	1.5	0455784-3536548
5	6-Dec	13:15	1100	750	860	983	140	1.9	0455426-3538198
4	6-Dec	13:38	420	200	510	377	180	1.5	0455451-3538232
3	6-Dec	14:01	350	300	460	370	200	2.5	0455229-3538008
2	6-Dec	14:08	350	410	830	530	190	1.9	0455134-3537911
1	6-Dec	14:12	110	420	850	460	200	1.4	80 *

WEATHER : 12/04/01 - 1/1

Very clear, warm day with a steady breeze and a full winter sun.
inversion early
C class, turning D / inversion after 17:00
Strong solar radiation winds predominantly from Easterly direction

WEATHER : 12/06/01 - 1/1

Pond Study and Sparge tests second round
Sunny, clear, very warm, with light winds with occasional gusts
C class, turning D 16:30-17:00
wind direction mostly from S/SW

Pine Hill - Ambient H₂S Odor Study Data

November / December 2001 Tests

Site ID #	2001.4 Test Period		Jerome - ambient measurements			Wind (360°)		Air Temp °F	Weather Conditions and Comments - Observations
	Date	Time	H ₂ S ppb		Avg	direction	mph		
7	8-Dec	13:11	12	60	20	31	280	7.0	74 paper mach+pm smell
7a	8-Dec	13:14	400	340	210	317	270	7.7	ASB isolatated
7b	8-Dec	13:18	730	670	440	613	300	6.9	ASB further up road
7c	8-Dec	13:20	2100	1270	1300	1557	280	7.9	ASB -edge
6c	8-Dec	13:22	260	220	520	333	270	3.9	
6b	8-Dec	13:25	520	2600	1800	1640	300	3.4	PP - off inlet area
6d	8-Dec	13:50	3200	1200	2800	2400	310	6.7	Nasty
6	8-Dec	13:32	2800	1500	2300	2200	360	7.0	Nasty
6e	8-Dec	13:35	2200	2400	2800	2467	330	9.3	Nasty
6a	8-Dec	13:37	1800	1700	630	1377	350	6.0	Not as bad
5a	8-Dec	13:43	6	7	7	7	20	2.7	Fresh as a daisy
5	8-Dec	13:45	6	6	5	6	320	2.5	
4c	8-Dec	13:48	4	5	5	5	300	2.3	
4	8-Dec	13:52	5	5	5	5	810	1.5	
4b	8-Dec	13:55	4	5	4	4	300	0.3	
4a	8-Dec	13:57	4	4	4	4	270	2.5	smells clean
4D	8-Dec	13:59	60	54	130	81	310	3.6	Ash P
4E	8-Dec	14:03	120	160	120	133	350	5.3	Ash P - more +
4F	8-Dec	14:04	140	150	120	137	330	8.2	Clar direct
11D	8-Dec	14:07	70	23	53	49	330	3.2	clar - on edge
11G	8-Dec	14:11	16	10	12	13	320	2.9	clar - on edge at times
11C	8-Dec	14:16	6	6	6	6	280	5.2	straight clar/mill
11B	8-Dec	14:18	52	14	15	27	340	4.0	good clar smell on + off
11A	8-Dec	14:22	520	550	520	530	360	8.4	right over outfall
11H	8-Dec	14:26	540	620	570	577	350	2.1	pp
11	8-Dec	14:28	1400	2000	1200	1533	320	3.9	Riff
11I	8-Dec	14:30	580	610	200	463	10	3.2	pp
3A	8-Dec	15:21	6	16	50	24	260	5.2	full sun again - low angle
3	8-Dec	15:24	2	3		3	270	4.2	
2B	8-Dec	15:27	4	4		4	290	2.9	blk liq smell
2A	8-Dec	15:30	4	4		4	280	4.0	
2C	8-Dec	15:33	3	3		3	260	3.4	
2	8-Dec	15:35	3	4		4	260	1.1	
10D	8-Dec	15:38	4	4		4	270	3.7	
10	8-Dec	15:40	6	6		6	300	9.8	
10A	8-Dec	15:42	7	8	7	7	320	6.2	
10E	8-Dec	15:44	16	16	13	15	300	3.8	
10F	8-Dec	15:47	8	2		5	300	0.8	
8B	8-Dec	16:21	52	6	5	21	280	1.9	

WEATHER : 12/08/01 - 1/1

oooooooooooooo

Fairly stable climate - Mostly
cloudy, windy day, warm, with
good gusts of steady direction
and speed

C class, close to D, inversion
early

Wind from W through the N/NE

Pine Hill - Ambient H₂S Odor Study Data

November / December 2001 Tests

Site	2001.4 Test Period			Jerome - ambient measurements			Wind (360°)		Air Temp °F	Weather Conditions and Comments - Observations
	ID #	Date	Time	H ₂ S ppb		Avg	Direction	mph		
7A	9-Dec	9:10	160	240	270	223	30	4.0	56	pp
7B	9-Dec	9:12	138	270	500	303	50	2.7		+ asb edge at end
7c	9-Dec	9:15	280	340	240	287	20	2.3		
7D	9-Dec	9:18	130	130	230	163	350	2.8		p + asb
?	9-Dec	9:30	3	14	14	10	360	9.8		P mill along
7	9-Dec	9:57	230	200	140	190	360	3.3		ensr
6D	9-Dec	10:01	500	420	580	500	300	2.4		pp - asb
11G	9-Dec	10:09	1008	610	1116	911	30	2.3		pp
11H	9-Dec	10:12	580	580	730	630	20	11.1		pp
11B	9-Dec	10:19	160	180	180	173	10	5.0		pp
11A	9-Dec	10:20	240	220	180	213	340	3.5		pp
11i	9-Dec	10:25	510	710	790	670	350	3.8		pp
11J	9-Dec	10:28	500	490	550	513	360	4.0		
11	9-Dec	10:30	520	530	550	533	360	4.2		R + PP - no H2S smell. Organic
11k	9-Dec	10:33	580	720	670	657	30	2.2		pp
11F	9-Dec	10:35	230	400	420	350	10	6.9		ASB + PP - no H2S - organic
11L	9-Dec	10:37	430	160	150	247	360	5.5		ASB + PP
11m	9-Dec	10:41	290	200	190	227	360	5.9		ASB + PP
11n	9-Dec	10:43	1400	2700	1114	1738	10	5.0		Not bad
11c	9-Dec	10:46	490	500	1111	700	10	3.8		Stinkier-funky
10e	9-Dec	11:48	380	360	170	303	10	7.1		less pungent
10f	9-Dec	11:52	48	59	8	38	350	4.3		clar
10g	9-Dec	11:55	11	14	10	12	10	2.1		not much odor
1a	9-Dec	12:03	10	9	4	8	350	7.8		not much odor, right downwind
1	9-Dec	12:06	9	10	23	14	10	4.8		thru mill
1C	9-Dec	12:09	27	57	10	31	20	3.9		"
7a	9-Dec	12:13	69	64		67	340	1.3		pulp mill smell
7e	9-Dec	12:16	120	130	130	127	10	4.0		ASB
11k	9-Dec	12:20	290	510	320	373	350	5.5		ASB
11i	9-Dec	12:23	500	590	380	490	360	7.0		PP
11a	9-Dec	12:26	280	440	130	283	360	8.6		PP
11b	9-Dec	12:29	170	120	150	147	10	3.7		
3c	9-Dec	12:34	17	21		19	350	0.3		EQ Pond
3a	9-Dec	12:36	41	25	78	48	350	7.1		Ash - E
3	9-Dec	12:39	9	5	4	6	360	3.3		Ash - W - stinky

All H2S Measurements from identifiable source, over 1 mph wind

Polishing Pond H2S Readings ; P=full reach E or W edge, P-O=Outfall Area only P-I=Inlet Area measured on south shore, N wind											
LOC	DATE	TIME	1	2	3	AVG	A	MPH	F	S	
6B-2	30-Nov	6:18	1100	1400	580	1027	320	3.4	51	P	
6B-3	30-Nov	6:20	1400	1100	1006	1169	330	1.8	51	P	
6	30-Nov	6:23	1500	1114	1700	1438	330	2.9	51	P	
6-2	30-Nov	6:26	1400	1118	1900	1473	320	2.7	51	P	
6A	30-Nov	6:30	580	570	1400	850	320	2.9	51	P	
5A	30-Nov	6:34	510	420	660	528	210	2.7	51	P-O	
5	30-Nov	6:40	68	50	32	50	215	1.7	51	P	
11D	30-Nov	7:03	52	48	450	183	330	4.5	51	P	
11	30-Nov	7:16	2000	2400	400	1600	340	2.4	51	P	
11	30-Nov	15:29	160	29	56	82	20	2.0	65	P	
11F	30-Nov	15:32	120	23	22	55	320	4.0	65	P	
6B-1	30-Nov	15:41	670	1400	1500	1190	320	2.9	65	P	
6	30-Nov	15:44	1900	1200	1300	1467	350	5.1	65	P-O	
6-1	30-Nov	15:46	660	1400	660	907	340	2.3	65	P-O	
6	30-Nov	15:48	1500	460	570	843	320	2.5	65	P	
11D	30-Nov	16:05	107	150	54	104	0	2.0	65	P	
6D	4-Dec	14:18	580	530	170	427	10	1.8	75	P	
4	4-Dec	14:39	270	220	130	207	95	4.3	75	P	
4B	4-Dec	14:42	510	270	180	320	80	4.1	75	P	
4D	4-Dec	14:46	520	540	210	423	90	3.5	75	P	
4A	4-Dec	14:50	1008	1200	540	916	95	6.1	75	P	
4E	4-Dec	14:57	520	540	410	490	100	4.4	75	P	
11G	4-Dec	15:10	120	150	500	257	70	3.6	75	P	
11H	4-Dec	15:15	1300	2700	1700	1900	75	4.1	75	P	
11I	4-Dec	15:20	430	260	300	330	75	5.3	75	P	
11J	4-Dec	15:23	290	500	520	437	75	2.3	75	P	
11K	4-Dec	15:26	270	280	210	253	80	5.2	75	P	
11L	4-Dec	15:29	170	120	120	137	80	2.1	75	P	
11B	4-Dec	15:36	520	500	570	530	80	3.6	75	P	
11A	4-Dec	15:41	270	570	540	460	85	2.8	75	P	
11N	4-Dec	16:09	210	510	530	417	-	65	5.7	75	P

Polishing Pond H2S Readings (continued)

LOC	DATE	TIME	1	2	3	AVG	A	MPH	F	S
4F	4-Dec	16:20	530	670	670	623	95	3.3	75	P
4G	4-Dec	16:23	1300	1400	1490	1397	95	4.9	75	P-O
4H	4-Dec	16:30	1200	1100	500	933	85	1.9	75	P
5	6-Dec	13:15	1100	750	860	993	140	1.9	76	P
4	6-Dec	13:38	420	200	510	377	180	1.5	76	P
6c	8-Dec	13:22	260	220	520	333	270	3.9	74	P
6b	8-Dec	13:25	520	2600	1800	1640	300	3.4	74	P
6	8-Dec	13:32	2800	1500	2300	2200	360	7.0	74	P-O
6e	8-Dec	13:35	2200	2400	2800	2467	330	9.3	74	P
6a	8-Dec	13:37	1800	1700	630	1377	350	6.0	74	P-O
6d	8-Dec	13:50	3200	1200	2800	2400	310	6.7	74	P
11A	8-Dec	14:22	520	550	520	530	360	8.4	74	P
11H	8-Dec	14:26	540	620	570	577	350	2.1	74	P
7B	9-Dec	9:12	138	270	500	303	50	2.7	56	P
6D	9-Dec	10:01	500	420	580	500	300	2.4	56	P
11G	9-Dec	10:09	1008	610	1116	911	30	2.3	56	P
11H	9-Dec	10:12	580	580	730	630	20	11.1	56	P-I
11B	9-Dec	10:19	160	180	180	173	10	5.0	56	P
11A	9-Dec	10:20	240	220	180	213	340	3.5	56	P
11i	9-Dec	10:25	510	710	790	670	350	3.8	56	P-I
11J	9-Dec	10:28	500	490	550	513	360	4.0	56	P-I
11	9-Dec	10:30	520	530	550	533	360	4.2	56	P
11k	9-Dec	10:33	580	720	670	657	30	2.2	56	P
11L	9-Dec	10:37	430	160	150	247	360	5.5	56	P
11c	9-Dec	10:46	490	500	1111	700	10	3.8	56	P
11k	9-Dec	12:20	290	510	320	373	350	5.5	56	P
11i	9-Dec	12:23	500	590	380	490	360	7.0	56	P-I
11a	9-Dec	12:26	280	440	130	283	360	8.6	56	P
11b	9-Dec	12:29	170	120	150	147	10	3.7	56	P

66

avg
med

726
529

P-I = Polishing Pond Inlet Area

avg 576 med 572

P-O = Polishing Pond Outlet Area

avg 1312 med 1387

Clarifier H2S Readings - NOTE: Ash Pond Background it Clarifier measurements from NW through NE

LOC	DATE	TIME	1	2	3	Avg	A	MPH	F	S
10	30-Nov	7:53	3	3	3	3	355	6.9	51	C/A
10	30-Nov	16:45	18	29	15	21	10	1.0	65	C/A
10A	30-Nov	16:47	11	2	5	6	340	1.0	65	C/A
3	6-Dec	14:01	350	300	460	370	200	2.5	76	C
3A	8-Dec	15:21	6	16	50	24	260	5.2	74	C
10e	9-Dec	11:48	380	360	170	303	10	7.1	56	C/A
10f	9-Dec	11:52	48	59	8	38	350	4.3	56	C/A
10g	9-Dec	11:55	11	14	10	12	10	2.1	56	C/A
8			average		97					
			median		22					

ASB H2S Readings - note: some background concentration from Polishing Pond likely at most sample points, a points, as noted, include background from Riffler emissions. Wind swirls around ASB burn, mixing ASB and Pond emissions from W/NW

LOC	DATE	TIME	1	2	3	Avg	A	MPH	F	S
11F	30-Nov	7:21	17	21	54	31	330	1.4	51	ASB/P
11F	30-Nov	7:21	17	21	54	31	330	1.4	51	ASB/P
11E	30-Nov	7:25	46	30	30	35	320	1.9	51	ASB/P
11E	30-Nov	7:25	46	30	30	35	320	1.9	51	ASB/P
11E	30-Nov	15:17	120	55	54	76	350	1.2	65	ASB/P
11E	30-Nov	15:17	120	55	54	76	350	1.2	65	ASB/P
11E	30-Nov	16:08	16	58	47	40	330	2.1	65	ASB/P
11E	30-Nov	16:08	16	58	47	40	330	2.1	65	ASB/P
7C	30-Nov	17:11	56	230	200	162	0	1.3	65	ASB/P
11D	4-Dec	15:00	190	170	140	167	90	3.9	75	ASB/P
11D	4-Dec	15:00	190	170	140	167	90	3.9	75	ASB/P
11	4-Dec	15:45	250	110	147	169	100	3.3	75	ASB
11	4-Dec	15:45	250	110	147	169	100	3.3	75	ASB
11M	4-Dec	15:50	560	490	400	483	85	2.9	75	ASB/P
11M	4-Dec	15:50	560	490	400	483	85	2.9	75	ASB/P
7	6-Dec	12:08	540	580	1400	840	280	2.1	76	ASB/P
7	8-Dec	13:11	12	60	20	31	280	7.0	74	ASB/P
7a	8-Dec	13:14	400	340	210	317	270	7.7	74	ASB/P
7c	8-Dec	13:20	2100	1270	1300	1557	280	7.9	74	ASB/P
11	8-Dec	14:28	1400	2000	1200	1533	320	3.9	74	P/RIF
11	8-Dec	14:28	1400	2000	1200	1533	320	3.9	74	P/RIF
11I	8-Dec	14:30	580	610	200	463	10	3.2	74	ASB/P
7A	9-Dec	9:10	160	240	270	223	30	4.0	56	ASB/P
7c	9-Dec	9:15	280	340	240	287	20	2.3	56	ASB/P
7D	9-Dec	9:18	130	130	230	163	350	2.8	56	ASB/P
7	9-Dec	9:57	230	200	140	190	360	3.3	56	ASB/P
11F	9-Dec	10:35	230	400	420	350	10	6.9	56	ASB/P
11m	9-Dec	10:41	290	200	190	227	360	5.9	56	ASB/P
11m	9-Dec	10:41	290	200	190	227	360	5.9	56	ASB/P
11n	9-Dec	10:43	1400	2700	1114	1738	10	5.0	56	ASB/P
7a	9-Dec	12:13	69	64	-	67	340	1.3	56	ASB/P
7e	9-Dec	12:16	120	130	130	127	10	4.0	56	ASB/P
32			average		376					
			median		169					

Equalization Basin Readings - at edge

LOC	DATE	TIME	1	2	3	Avg	A	MPH	F	S
3A	30-Nov	16:12	8	9	4	7	40	3.0	65	EQ
1					average median	7 7				

Ash Pond Area Readings at edge

LOC	DATE	TIME	1	2	3	Avg	A	MPH	F	S
3	30-Nov	16:14	100	140	5	82	350	1.8	65	ASH
3a	9-Dec	12:36	41	25	78	48	350	7.1	56	ASH
3	9-Dec	12:39	9	5	4	6	360	3.3	56	ASH
3					average median	45 48				

PulpMill, PowerHouse, Evaporator Area Readings

LOC	DATE	TIME	1	2	3	Avg	A	MPH	F	S
1	9-Dec	12:06	9	10	23	14	10	4.8	56	M
1a	9-Dec	12:03	10	9	4	8	350	7.8	56	M
1A	9-Dec	9:30	3	14	14	10	360	9.8	56	M
8B	8-Dec	16:21	52	6	5	21	280	1.9	74	M
8B	30-Nov	7:47	3	3	6	4	330	5.1	51	M
8A	30-Nov	17:00	15	15	10	13	340	2.2	65	M
12	30-Nov	16:34	18	28	27	24	70	2.8	65	pulp
12	30-Nov	8:01	3	3	3	3	220	1.6	51	Recov
7 combined area					average median	12 12				

Recausticizing Area Readings - downwind, through area

LOC	DATE	TIME	1	2	3	Avg	A	MPH	F	S
10	8-Dec	15:40				6	300	9.8	74	R
10E	8-Dec	15:44				15	300	3.8	74	R
2					average median	11 11				

List of Emission Models

Polishing Pond Measurements

MAP LOC	2001 DATE	SAMPLE TIME	H ₂ S ppb			Wind Data		Temp °F	Model	RATE Lbs/Hr
			Readings		avg	A°	mph			
4	4-Dec	14:39	270	220	130	207	95	4.3	75	
4A	4-Dec	14:50	1008	1200	540	916	95	6.1	75	2P 779
4B	4-Dec	14:42	510	270	180	320	80	4.1	75	
4D	4-Dec	14:46	520	540	210	423	90	3.5	75	
4E	4-Dec	14:57	520	540	410	490	100	4.4	75	5P 309
4F	4-Dec	16:20	530	670	670	623	95	3.3	75	
4G	4-Dec	16:23	1300	1400	1490	1397	95	4.9	75	
5A	30-Nov	6:34	510	420	660	528	210	2.7	51	
6	30-Nov	6:23	1500	1114	1700	1438	330	2.9	51	9P 248
6	30-Nov	15:44	1900	1200	1300	1467	350	5.1	65	
6	30-Nov	15:48	1500	460	570	843	320	2.5	65	11p 123
6	8-Dec	13:32	2800	1500	2300	2200	360	7.0	74	
6-1	30-Nov	15:46	660	1400	660	907	340	2.3	65	
6-2	30-Nov	6:26	1400	1118	1900	1473	320	2.7	51	14p 234
6A	30-Nov	6:30	580	570	1400	850	320	2.9	51	15p 147
6a	8-Dec	13:37	1800	1700	630	1377	350	6.0	74	
6B-1	30-Nov	15:41	670	1400	1500	1190	320	2.9	65	17p 206
6c	8-Dec	13:22	260	220	520	333	270	3.9	74	
6d	8-Dec	13:50	3200	1200	2800	2400	310	6.7	74	19p 1837
6e	8-Dec	13:35	2200	2400	2800	2467	330	9.3	74	20p 2644
7A	9-Dec	9:10	160	240	270	223	30	4.0	56	
11	4-Dec	15:45	250	110	147	169	100	3.3	75	
11A	4-Dec	15:41	270	570	540	460	85	2.8	75	
11A	9-Dec	10:20	240	220	180	213	340	3.5	56	
11a	9-Dec	12:26	280	440	130	283	360	8.6	56	
11B	4-Dec	15:36	520	500	570	530	80	3.6	75	
11B	9-Dec	10:19	160	180	180	173	10	5.0	56	
11b	9-Dec	12:29	170	120	150	147	10	3.7	56	
11D	4-Dec	15:00	190	170	140	167	90	3.9	75	
11G	9-Dec	10:09	1008	610	1116	911	30	2.3	56	
11H	8-Dec	14:26	540	620	570	577	350	2.1	74	
11H	9-Dec	10:12	580	580	730	630	20	11.1	56	32p 33
11I	8-Dec	14:30	580	610	200	463	10	3.2	74	
11i	9-Dec	10:25	510	710	790	670	350	3.8	56	34p 16
11i	9-Dec	12:23	500	590	380	490	360	7.0	56	35p 16
11J	9-Dec	10:28	500	490	550	513	360	4.0	56	36p 10
11k	9-Dec	10:33	580	720	670	657	30	2.2	56	
11k	9-Dec	12:20	290	510	320	373	350	5.5	56	
11M	4-Dec	15:50	560	490	400	483	85	2.9	75	
11N	4-Dec	16:09	210	510	530	417	65	5.7	75	
6b	8-Dec	13:25	520	2600	1800	1640	300	3.4	74	41p 628
6B-2	30-Nov	6:18	1100	1400	580	1027	320	3.4	51	42p 204
11	30-Nov	7:16	2000	2400	400	1600	340	2.4	51	
11	8-Dec	14:28	1400	2000	1200	1533	320	3.9	74	
11	9-Dec	10:30	520	530	550	533	360	4.2	56	
11A	8-Dec	14:22	520	550	520	530	360	8.4	74	

note: shaded areas; 32p, 34p, 35p and 36p line up to include the Polish Pond inlet area only, 300' W, from 320'

46

avg 810

med 555

avg	613
med	248

ASB Measurements - no models, potential for some background concentration from Pol Pond

MAP LOC	2001 DATE	SAMPLE TIME	H ₂ S ppb			Wind Data		Temp °F	Model	RATE Lbs/Hr
			Readings		avg	A°	mph			
7a	8-Dec	13:14	400	340	210	317	270	7.7	74	
7b	8-Dec	13:18	730	670	440	613	300	6.9	74	
7B	9-Dec	9:12	138	270	500	303	50	2.7	56	
11E	30-Nov	7:25	46	30	30	35	320	1.9	51	
11H	4-Dec	15:15	1300	2700	1700	1900	75	4.1	75	
11I	4-Dec	15:20	430	260	300	330	75	5.3	75	
11J	4-Dec	15:23	290	500	520	437	75	2.3	75	
11K	4-Dec	15:26	270	280	210	253	80	5.2	75	
11L	4-Dec	15:29	170	120	120	137	80	2.1	75	
		10			avg	481	med	317		

Clarifier Measurements - no models, potential for background concentration from Ash Pond

MAP LOC	2001 DATE	SAMPLE TIME	H ₂ S ppb			Wind Data		Temp °F	Model	RATE Lbs/Hr
			Readings		avg	A°	mph			
3C	30-Nov	7:01	120	260	190	190	45	3.9	51	
4F	8-Dec	14:04	140	150	120	137	330	8.2	74	
10	2-Dec	6:42	14	12	12	13	10	2.6	45	
10E	2-Dec	6:48	150	130	44	108	0	2.4	45	
10e	9-Dec	11:48	380	360	170	303	10	7.1	56	
10f	9-Dec	11:52	48	59	8	38	350	4.3	56	
11D	30-Nov	7:03	52	48	450	183	330	4.5	51	
11E	30-Nov	16:08	16	58	47	40	330	2.1	65	
11G	2-Dec	6:35	40	200	222	154	340	2.3	45	
		9			avg	130	med	137		

Ash Pond Area Measurements - no models

MAP LOC	2001 DATE	SAMPLE TIME	H ₂ S ppb			Wind Data		Temp °F	Model	RATE Lbs/Hr
			Readings		avg	A°	mph			
3	9-Dec	12:39	9	5	4	6	360	3.3	56	
3A	30-Nov	16:12	8	9	4	7	40	3.0	65	
3A	8-Dec	15:21	6	16	50	24	260	5.2	74	
3a	9-Dec	12:36	41	25	78	48	350	7.1	56	
4D	8-Dec	13:59	60	54	130	81	310	3.6	74	
		5			avg	33	med	24		

Kiln and Recast Area Measurements - no models

MAP LOC	2001 DATE	SAMPLE TIME	H ₂ S ppb				Wind Data		Temp °F	Model	RATE Lbs/Hr
			Readings			avg	A°	mph			
10	8-Dec	15:40	6	6	6	6	300	9.8	74		
10E	8-Dec	15:44	16	16	13	15	300	3.8	74		
11C	30-Nov	7:08	11	9	9	10	330	3.0	51		
3				avg	10		med		10		

Pulp Mill, PowerHouse, Evaporator Area Measurements - Downwind distance 1450'

MAP LOC	2001 DATE	SAMPLE TIME	H ₂ S ppb				Wind Data		Temp °F	Model	RATE Lbs/Hr
			Readings			avg	A°	mph			
1a	9-Dec	12:03	10	9	4	8	350	7.8	56	2m	2.3


xx end of DEC01 data xxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxxx

Polishing Pond Measurements - Inlet area from February 2001 Study, from 320'

MAP LOC	2001 DATE	SAMPLE TIME	H ₂ S ppb				Wind Data		Temp °F	Model	RATE Lbs/Hr
			Readings			avg	A°	mph			
11a	12-Feb	13:46	1900	1100	1700	1400	N	6.3	67	FEB01_a	41

PINE HILL TRS STUDY - PHASE II

Field Data



Pine Hill Odor Study

DATE: 11/30/01

general weather conditions today

CLOUDY, COOL
WINDS LIGHT
+ VAR. AB/2


NW direction
predom

D

S = SWIRLING

POINT #	SAMPLE TIME	HYDROGEN SULFIDE - ppb				WIND dir	TEMP °F	Round: 1 / 2
		a	b	c	avg			
6C 0604	10	9	9	9	9	210	1.4	
6B 0613	260	560*	340		400	90 S	0.2	
6B-2 0618	1100	1400	580	1027	320	3.4		
6B-3 0620	1400	1110	1005	1169	230	1.8		
6 0623	1500	114	1700	1438	330	2.9		
6-2 0626	1400	118	1910	1479	220	2.7		
6D 0630	580	570	1400		320	2.9		
5A 0634	510	420	660	520	210	2.7		
5 0640	68				215	1.7		
4C 0645	2	2	2	2		0		
4 0651	2	2	3	2	—	0.4		RIVIER - MIN. PT
4B 0655	3	3	2	2	—	0		
4A 0658	2	2	3	2	0	1.9		
3C 0701	120	260	190	190	45	3.9		CLAR - STRONG
HD 0703	52	48	450		330	4.5		CLAR
11C 0708	11	9	9	9	330	3.0		KIEN - VP
11B 0711	54	23	27	352	5.7			
11A 0713	79	9	10	340	7.7			
11 0716	2000	2400	400	340	2.9			RIVIER
11E 0721	17	21	57	330	1.4			ACROSS ALL ASR
11E 0725	46	30	30	320	1.9			INLET ASR
3 0740	17	12	3	215	3.8			
3A 0743	2	6	8	240	3.1			
8B 0747	2	3	6	330	5.1			
10A 0750	2	3	3	330	5.1			
10 0753	2	3	3	355	6.5			
10B 0755	3	3	3	330	5.3			
10C 0757	2	4	4	325	4.4			
10D 0759	2	3	3	325	3.2			
12 0801	2	3	3	220	1.6			
8 0810	2	3	3	280	6.7			
8A 0822	3	5	3	260	10.1			
7A 0827	2	3	2	200	1.7			
7 0831	2	2	2	270	5.1			INSR
10 0840	2	2	2	210	5.3			
2 0844	2	2	2	260	3.4			
2A 0847	3	3	3	240	6.4			
2B 0849	3	5	6	280	8.4			
2C 0852	3	6	6	270	2.8			

Date Entered Sign



Pine Hill Odor Study

DATE: 11/30/01

general weather conditions today

SUNNY, MILD

LT WINDS CLEAR
SOME GUSTS

MAIN WINDS

ALL W/NW


LATER, AFTER

1620 more N

C

POINT #	SAMPLE TIME	HYDROGEN SULFIDE - ppb				WIND dir	TEMP °F	Round: 2/2
		a	b	c	avg			
7	1513	22	5	7	7	320	1.6	
11E	1517	120	55	54	55	350	1.7	
11C	1520	6	14	54	320	2.7		
11B	1523	7	5	6	6	0	2.5	
11A	1526	11	60	50	328	1.4		
11	1529	160	29	56	28	28	2.0	
11F	1532	120	23	22	22	320	4.0	
6C	1535	72	68	68	68	320	0.3	
6C	1538	580	520	680	580	300	0.4	
6A-1	1541	170	1400	1500	1220	220	2.9	
6	1544	1800	1200	1300	1300	350	5.1	
6-1	1546	660	1400	660	660	340	2.3	
6	1548	1500	460	570	570	320	2.5	
5A	1551	4	3	5	4	0		
5	1553	4	4	5	4	340	1.9	
4C	1556	3	3	3	3	330	0.1	
4	1558	3	3	3	3	340	0.6	
4B	1601	3	3	3	3	10	0.9	
4C	1602	23	20	120	350	0.2		
11D	1605	107	150	54	54	0	2.0	
11E	1608	16	58	47	53	330	2.1	
3A	1612	8	9	4	6	40	3.0	
3	1614	120	140	5	100	350	1.8	
2B	1618	2	2	2	2	0	1.3	
2A	1620	2	2	3	2	0	2.1	
2C	1623	8	5	7	6	340	1.0	
2	1626	3	3	3	3	10	0.7	
1	1630	3	3	3	3	320	2.3	
12	1634	18	28	27	27	70	2.8	
10A	1640	8	8	8	8	90	0.1	
10Z	1642	5	5	4	5	270	1.2	
10D	1643	4	4	4	4	10	0	
10	1645	18	29	15	22	340	1.0	
10A	1647	11	2	5	5	340	1.0	
8	1655	4	4	4	4	45	2.3	
8A	1700	15	15	10	15	340	2.2	
10B	1710	8	4	4	4	0	1.9	
2	1711	56	230	207	150	0	1.3	

N-L. ↑ L-W. S-N.



Pine Hill Odor Study

DATE: 12/1/82

general weather conditions today

Cool, Fuggy
NO WIND AT
GROUNd LEVEL
Fog HEMBRE
AT DAYBREAK

X


POINT #	SAMPLE TIME	HYDROGEN SULFIDE - ppb				WIND dir	TEMP °F	Round:
		a	b	c	avg			
6C	0546	300	300	330	310	320	0.2	
6B	0550	250	250	420			0	
5	0602	460	550	540			8	
6A	0607	350	350	310			0	
5A	0610	4	12	28			0	
5	0613	1	1	1		100	0.2	
4	0617	1	1	1		200	0	
7	0621	0	0	0			0	
1A	0623	1	1	1		350	1.1	
1D	0629	180	110	26		60	0.2	
1E	0625	340	140	19			0	
1F	0629	130	230	190		320	0.2	
11	0630	250	240	190		280	0.5	
11A	0634	32	77	110			0	
11B	0636	52	57	49		320	0.5	
11C	0639	21	25	48		320	0.1	
7	0642	15	14	12		240	0.6	
7A	0651	8	19	10			0	
10	0656	3	3	3		260	1.4	
12A	0659	3	3	3		260	1.4	
12B	0700	7	7	7		220	0.5	
2	0704	2	2	1			0	
2C	0707	2	3	2		320	0.2	
2A	0710	3	0	0		340	1.2	
2D	0713	3	0	0		350	0.3	
3	0715	11	2	11			0	
3A	0719	3	3	28		10	2.4	
3B	0723	21	14	14		240	1.0	
1PA	0726	140	128	50		345	1.3	
1O	0728	170	120	140		20	2.0	
1AD	0731	8	8	8			0	
1DC	0734	5	3	3		300	2.0	
1DD	0736	↑	4	3		60	0.9	
1	0741	11	12	10			0	
8	0824	180	140	110		20	1.0	
8A	0827	140	50	190		60	0.5	

NEAR BRANCH - FWL

CLAYMORE
NO MILL ODOR!
Andrea pulp mill

ASB/PP
PP

n.l. r.L. l sk



Pine Hill Odor Study

DATE: 12/2/01


general weather conditions today

COOL, CALM
PREDMIN NORTHERN
WINDS

GROWING WINDS
VERY LIGHT
+ VARIABLE

AFTERNOON DAYBREAK
CONTINUE CLOUDY
+ COOL

POINT #	SAMPLE TIME	HYDROGEN SULFIDE - ppb				WIND dir	TEMP °F	Round: / /
		a	b	c	avg			
7	0533	155	260	310	260	50	41	notes and observations: ENVIR - 56
6C	0537	280	230	190	230	0	40	
6B	0540	190	510	320	320	0	40	DEAD AIR ALONG TRAIL
6	0542	170	510	320	320	0	40	DEAD CALM
6A	0547	950	510	780	780	320	35	SMOKE - MOVES 20m
5A	0551	9	4	2	3.2	320	32	
4C	0602	8	0	2	3.2	0	36	H2S SMALL
4	0604	0	2	2	2	20	36	CHLOR
4A	0615	340	210	240	257	0	34	MILL
4D	0615	110	450	350	300	240	34	ACROSS ASB
4E	0617	43	43	37	40	270	31	11A DUE OUTFALL
11G	0623	110	98	140	110	—	34	11I RIVER
11H	0623	110	82	100	92	350	35	
11	0717	110	110	150	120	330	34	
11F	0723	140	140	130	137	10	34	
11G	0723	170	200	222	192	340	33	
11C	0723	210	230	250	230	280	32	
11E	0723	12	12	12	12	10	26	
10E	0648	150	130	44	100	0	38	
10B	0651	21	53	52	350	1.2	40	CHLOR DUE - 102/10F
7B	0654	58	52	50	52	020	46	FLOWDOWN DOWN
3	0700	43	3	5	258	1.7	46	ASH POND OUTFALL
2B	0702	2	2	2	2	280	45	
2H	0704	3	2	4	301	0.7	46	MARK 6 ENVIR STATION
2C	0708	4	2	2	270	0.6		
2	0711	2	2	2	2	0		
12B	0715	2	2	2	260	2.5		(1) 16R 0456093
12A	0717	2	2	2	260	3.2		UTM 3517859
12	0719	2	6	7	257	0.1		
12C	0723	14	16	17	15	0	0.8	(2) 16R 0455870
10D	0724	2	1	1	310	1.5		UTM 3536968
10C	0726	1	1	2	270	3.4		
10B	0729	2	2	3	270	9.3		(3) 16R 0455691
1	0735	2	2	3	230	1.8		UTM 3536946
8B	0740	3	3	3	250	7.0		(4) 16R 0455606
8A	0742	1	1	1	300	1.0		UTM 3536933
	(5)	16R 0455550	553	6986				(5) 16R 0455548
		UTM						UTM 3536926



Pine Hill Odor Study

DATE: 12/3/01;

general weather conditions today

Cool, CALM


ALMOST NO
GROUNDS WINDS

DEAD CALM

SLIGHT N GUSTS

55
0722

POINT #	SAMPLE TIME	HYDROGEN SULFIDE - ppb			WIND		TEMP °F	Round: 1/2	notes and observations:
		a	b	c	avg	dir			
7	0605	65	60	75			0		
GC	0606	70					0		
WS	0615	70	11	140			0		
6	0620	160	160				0		
GC	0625	77	57	64			0		
5A	0630	140	140				350 0.3		
5B	0634	34	31	16			0		
4C	0640	0	0				0		
4D	0645	0	0				0		
4E	0650	0	0				0		
4F	0655	0	0				0		
4G	0700	100	130				0		
HWS	0701	110	75				0		
HWS	0702	420	450				0		
HWS	0703	720	750				0		
HWS	0704	6	6				0		
HWS	0705	7600	7300				1.1		
HC	0706	590	410	540			280 2.1		
7A	0711	12	15	7			320 0.3		
8A	0713	2	3	2			0		
8	0715	5	5	5			140 1.0		
12A	0740	5	5	2			0		
10	0747	2	2	6			0		
3A	0753	12	4	8			0		
7	0804	5	4	5			0		
									END NO WIND




Pine Hill Odor Study

DATE: 12 - 3

general weather conditions today

WIND pick up
UP STREAM
NOW AFTER
very warm
CALM DAY



Pine Hill Odor Study

DATE: 12/1/01

general weather conditions today

FULL SUN 75°
STEAMY BREEZE
FROM E

(C) WINTER
SUN

POINT #	SAMPLE TIME	HYDROGEN SULFIDE - ppb				WIND dir	TEMP mph	Round: 1/1
		a	b	c	avg			
7	1405	6	6	6	6	100	4.1	75
6C	1410	110	150	120	120	90	1.2	
6B	1411	8	8	8	8	125	2.3	
6F	1418	580	530	570	570	10	1.8	
7F	1421	110	150	120	120	180	0.7	
6A	1423	110	510	200	350	110	0.5	
5A	1427	8	8	8	8	30	0.5	
3	1431	8	8	8	8	50	0.6	
4C	1435	67	4	4	5	90	3.0	
4	1439	170	720	130	93	45		
4D	1442	510	210	180	180	80	4.1	
4A	1446	520	540	310	423	90	3.5	
4A	1450	1008	200	540	916	95	6.1	
4E	1457	520	340	411	490	100	4.4	
11D	1500	190	178	140	160	90	5.9	
11G	1510	120	150	500	70	3.6		
11H	1515	1300	2700	1700	1900	75	4.1	
11I	1520	430	260	300	300	75	2.3	
11J	1523	290	500	520	520	75	2.3	
11K	1526	270	280	210	240	80	5.2	
11L	1529	70	120	120	100	80	2.1	
11B	1536	520	500	570	540	80	3.6	
11A	1541	270	270	540	540	85	2.8	
11	1545	250	110	147	147	120	3.3	
11M	1550	560	470	400	470	85	2.9	
11F	1554	12	12	8	9	95	2.4	
11N	1559	210	510	530	530	65	5.7	
2F	1620	530	670	620	620	95	3.2	
4F	1623	1300	1400	1430	1397	95	4.9	
2H	1630	1200	1100	500	833	85	3.9	
2	1638	17	9	9	9	80	3.7	
7								


LOW ROAD ON R 1600-1615

pp

STR

SM

r! m tank SM



Pine Hill Odor Study

DATE: 2/5/01

general weather conditions today

BRIELEY

SUNNY

CURR.
1833.


卷之三

卷之三

— 1 —

APPENDIX - 2 -

-1-



Pine Hill Odor Study

DATE: 12/7/81

general weather conditions today

CLOUDY 90%,
CLOUDY WINDS
FROM S/SW
TO W AS WE
MOVE W/
SUN BREAKS

STABLE D

GOOD MODEL DAY

POINT #	SAMPLE TIME	HYDROGEN SULFIDE - ppb				WIND dir	TEMP °F	Round: 1/2
		a	b	c	avg			
1311	12	60	20		20	280	6.6	
1314	400	340	210		250	270	7.7	
1318	730	670	440		550	300	6.9	
1320	2:00	1270	1200		1200	280	7.9	
1322	260	220	220		220	270	3.9	
1325	520	2400	1800	1640	2000	300	3.4	
1330	3200	1200	2340	2400	2100	310	6.7	
1332	2800	1500	2300	2200	2200	360	7.0	
1335	7200	2400	2800	2200	3300	330	9.3	
1337	1800	1700	630	1377	1377	350	6.0	
1343	6	7	7		7	20	2.7	
1345	2	6	5		5	320	2.5	
1348	4	3	3		3	300	2.3	
1352	5	5	5		5	310	7.2	
1355	4	5	4		4	300	0.3	
1401	4	4	4		4	370	2.5	
1403	60	54	130		90	310	3.6	
1403	120	160	120		120	350	5.3	
1404	40	150	120		120	330	8.2	
1407	70	23	53		53	350	3.2	
1411	16	10	17		13	320	2.7	
1416	6	6	7		6	280	5.2	
1418	52	14	15		14	340	4.0	
1422	520	550	520		520	360	8.4	
1426	540	620	570		570	350	2.1	
1428	1400	2000	1200	1533	1533	320	3.9	
1430	580	610	200		200	30	3.2	
1521	6	16	50		260	5.2		
1524	2	16	50		270	4.2		
1527	4	4			290	3.9		
1530	4	4			280	4.0		
1533	5	3			260	3.14		
1535	1	4			260	1.1		
1538	4	4			270	1.7		
1541	6	6			290	9.8		
1542	7	8	7		320	5.2		
1544	16	16	13		300	5.8		
1547	8	2			290	9.8		
1621	52	6	5		280	1.9		


SMELLS CLEANING
ASH P
ASH P - MINE +
CLAR. OIL RIVER INSIDE RD
CLAR - OUTSIDE POINTS S+P G+
CLAR - UPSTREAM - EASE AT TIMES
SLT CURE/PIPE
9000 CUBIC FEET OVER OFFICE
RIGHT OVER OUTFALL

PP
RIPPLE
PP
1 READING ↓
FULL SUN AGAIN - LOW ANGLE

LIT SMALL
WINDS
BECOME
LIGHT + WIR


0456512
3537746 1/1

0455293 1/1
3537741 1/1



Porto WW testing

→ WIND
GUSTS



12/3
Very injury
74°
Calm surface
1 mi SWN
1144 150 mph 3 mph
GUST
1133 2.9 mph
130 mph 1125
1139 - 200 mph

~~161~~

BuLT

456042
453622
455067
4537

4510861
4533
454754
3536767

454754
3536767

454754
3536767

454754
3536767

points off
points off

4552
4536920
3537

Power Boiler / Recovery burner

454516
3537209

454516
3537310

454516
3537310


454695 (incinerator)
3537310


454677 (ungunk)
3537384

PRIMAR
CLASSIFIER

454751
3537536


071111





N


24



C


N

5P



N


9P



D

N


11P



D

N


1473



D

N


15P



D


N

17P



D


19P



C

N
↑


207p



C


N
↑

32p



N

314




INLET

C

N


35P



INLET

N


36P



INLET

N
↑


41P



C

N
↑

42p



1027


D









KOUNO #1 2/12/01
POLISH INLET

EBOR-a

6.6





PINE HILL TRS STUDY - PHASE II

Emission Models

Models of Polishing Pond- full reach

*** SCREEN-1.1 MODEL RUN ***
 *** VERSION DATED 88300 ***

Model# 2P

WEST EOE

SIMPLE TERRAIN INPUTS:

SOURCE TYPE	=	AREA
EMISSION RATE (G/S)	=	98.20
SOURCE HEIGHT (M)	=	1.00
LENGTH OF SIDE (M)	=	762.50
RECEPTOR HEIGHT (M)	=	1.00
IOPT (1=URB, 2=RUR)	=	2

779 #/HR

BUOY. FLUX = .00 M**4/S**3; MOM. FLUX = .00 M**4/S**2.

*** STABILITY CLASS 3 ONLY ***
 *** 10-METER WIND SPEED OF 2.7 M/S ONLY ***

 *** SCREEN DISCRETE DISTANCES ***

*** TERRAIN HEIGHT OF 0. M ABOVE STACK BASE USED FOR FOLLOWING DISTANCES ***

DIST (M)	CONC (UG/M**3)	U10M STAB	USTK (M/S)	MIX HT (M)	PLUME HT (M)	SIGMA Y (M)	SIGMA Z (M)	DWASH
610.	1297.	3	2.7	2.7	864.0	1.0	229.3	38.9 NO

DWASH= MEANS NO CALC MADE (CONC = 0.0)
 DWASH=NO MEANS NO BUILDING DOWNWASH USED
 DWASH=HS MEANS HUBER-SNYDER DOWNWASH USED
 DWASH=SS MEANS SCHULMAN-SCIRE DOWNWASH USED
 DWASH=NA MEANS DOWNWASH NOT APPLICABLE, X<3*LB

 *** SUMMARY OF SCREEN MODEL RESULTS ***

CALCULATION PROCEDURE	MAX CONC (UG/M**3)	DIST TO MAX (M)	TERRAIN HT (M)
SIMPLE TERRAIN	1297.	610.	0.

 ** REMEMBER TO INCLUDE BACKGROUND CONCENTRATIONS **

*** SCREEN-1.1 MODEL RUN ***
 *** VERSION DATED 88300 ***

Model# 5P

WEST EDGE

SIMPLE TERRAIN INPUTS:

SOURCE TYPE	=	AREA
EMISSION RATE (G/S)	=	38.90
SOURCE HEIGHT (M)	=	1.00
LENGTH OF SIDE (M)	=	762.50
RECEPTOR HEIGHT (M)	=	1.00
IOPT (1=URB, 2=RUR)	=	2

309 #/hr

BUOY. FLUX = .00 M**4/S**3; MOM. FLUX = .00 M**4/S**2.

*** STABILITY CLASS 3 ONLY ***
 *** 10-METER WIND SPEED OF 2.0 M/S ONLY ***

 *** SCREEN DISCRETE DISTANCES ***

*** TERRAIN HEIGHT OF 0. M ABOVE STACK BASE USED FOR FOLLOWING DISTANCES ***

DIST (M)	CONC (UG/M**3)	U10M STAB	USTK (M/S)	MIX HT (M)	PLUME HT (M)	SIGMA Y (M)	SIGMA Z (M)	DWASH
610.	693.7	3	2.0	2.0	640.0	1.0	229.3	38.9 NO

DWASH= MEANS NO CALC MADE (CONC = 0.0)
 DWASH=NO MEANS NO BUILDING DOWNWASH USED
 DWASH=HS MEANS HUBER-SNYDER DOWNWASH USED
 DWASH=SS MEANS SCHULMAN-SCIRE DOWNWASH USED
 DWASH=NA MEANS DOWNWASH NOT APPLICABLE, X<3*LB

 *** SUMMARY OF SCREEN MODEL RESULTS ***

CALCULATION PROCEDURE	MAX CONC (UG/M**3)	DIST TO MAX (M)	TERRAIN HT (M)
SIMPLE TERRAIN	693.7	610.	0.

 ** REMEMBER TO INCLUDE BACKGROUND CONCENTRATIONS **

1

02-13-**
09:17:40

*** SCREEN-1.1 MODEL RUN ***
 *** VERSION DATED 88300 ***

Model# 9P

LAST EDITION

SIMPLE TERRAIN INPUTS:

SOURCE TYPE = AREA
 EMISSION RATE (G/S) = 31.25
 SOURCE HEIGHT (M) = 1.00
 LENGTH OF SIDE (M) = 762.50
 RECEPTOR HEIGHT (M) = 1.00
 IOPT (1=URB, 2=RUR) = 2

278 #/hr

BUOY. FLUX = .00 M**4/S**3; MOM. FLUX = .00 M**4/S**2.

*** STABILITY CLASS 4 ONLY ***
 *** 10-METER WIND SPEED OF 1.3 M/S ONLY ***

 *** SCREEN DISCRETE DISTANCES ***

*** TERRAIN HEIGHT OF 0. M ABOVE STACK BASE USED FOR FOLLOWING DISTANCES ***

DIST (M)	CONC (UG/M**3)	U10M STAB	USTK (M/S)	MIX HT (M)	PLUME HT (M)	SIGMA Y (M)	SIGMA Z (M)	DWASH
506.	2033. <i>1438</i>	4	1.3	1.3	416.0	1.0	203.0	18.5 NO
793.	1314.	4	1.3	1.3	416.0	1.0	218.7	26.6 NO

ED DWASH= MEANS NO CALC MADE (CONC = 0.0)
ED DWASH=NO MEANS NO BUILDING DOWNWASH USED
ED DWASH=HS MEANS HUBER-SNYDER DOWNWASH USED
ED DWASH=SS MEANS SCHULMAN-SCIRE DOWNWASH USED
ED DWASH=NA MEANS DOWNWASH NOT APPLICABLE, X<3*LB

 *** SUMMARY OF SCREEN MODEL RESULTS ***

CALCULATION PROCEDURE	MAX CONC (UG/M**3)	DIST TO MAX (M)	TERRAIN HT (M)
SIMPLE TERRAIN	2033.	506.	0.

 ** REMEMBER TO INCLUDE BACKGROUND CONCENTRATIONS **

*** SCREEN-1.1 MODEL RUN ***
 *** VERSION DATED 88300 ***

Model# 11P

EAST EDE

SIMPLE TERRAIN INPUTS:

SOURCE TYPE	=	AREA
EMISSION RATE (G/S)	=	15.50
SOURCE HEIGHT (M)	=	1.00
LENGTH OF SIDE (M)	=	762.50
RECEPTOR HEIGHT (M)	=	1.00
IOPT (1=URB, 2=RUR)	=	2

123 ft/hr

BUOY. FLUX = .00 M**4/S**3; MOM. FLUX = .00 M**4/S**2.

*** STABILITY CLASS 4 ONLY ***
 *** 10-METER WIND SPEED OF 1.1 M/S ONLY ***

 *** SCREEN DISCRETE DISTANCES ***

*** TERRAIN HEIGHT OF 0. M ABOVE STACK BASE USED FOR FOLLOWING DISTANCES ***

DIST (M)	CONC (UG/M**3)	STAB	U10M (M/S)	USTK (M/S)	MIX HT (M)	PLUME HT (M)	SIGMA Y (M)	SIGMA Z (M)	DWASH
506.	1192. <i>843</i>	4	1.1	1.1	352.0	1.0	203.0	18.5	NO
793.	770.3 <i>545</i>	4	1.1	1.1	352.0	1.0	218.7	26.6	NO

DWASH= MEANS NO CALC MADE (CONC = 0.0)
 DWASH=NO MEANS NO BUILDING DOWNWASH USED
 DWASH=HS MEANS HUBER-SNYDER DOWNWASH USED
 DWASH=SS MEANS SCHULMAN-SCIRE DOWNWASH USED
 DWASH=NA MEANS DOWNWASH NOT APPLICABLE, X<3*LB

 *** SUMMARY OF SCREEN MODEL RESULTS ***

CALCULATION PROCEDURE	MAX CONC (UG/M**3)	DIST TO MAX (M)	TERRAIN HT (M)
SIMPLE TERRAIN	1192.	506.	0.

 ** REMEMBER TO INCLUDE BACKGROUND CONCENTRATIONS **

1

02-04-**
17:44:55*** SCREEN-1.1 MODEL RUN ***
*** VERSION DATED 88300 ***

Model# 14P

EAST EDGE

SIMPLE TERRAIN INPUTS:

SOURCE TYPE	=	AREA
EMISSION RATE (G/S)	=	29.50
SOURCE HEIGHT (M)	=	1.00
LENGTH OF SIDE (M)	=	762.50
RECEPTOR HEIGHT (M)	=	1.00
IOPT (1=URB, 2=RUR)	=	2

234#/hr

BUOY. FLUX = .00 M**4/S**3; MOM. FLUX = .00 M**4/S**2.

*** STABILITY CLASS 4 ONLY ***
*** 10-METER WIND SPEED OF 1.2 M/S ONLY ***

 *** SCREEN DISCRETE DISTANCES ***

*** TERRAIN HEIGHT OF 0. M ABOVE STACK BASE USED FOR FOLLOWING DISTANCES ***

DIST (M)	CONC (UG/M**3) <i>HS</i>	U10M STAB	USTK (M/S)	MIX HT (M)	PLUME HT (M)	SIGMA Y (M)	SIGMA Z (M)	DWASH
506.	2080. <i>1470</i>	4	1.2	1.2	384.0	1.0	203.0	18.5 NO
793.	1344. <i>950</i>	4	1.2	1.2	384.0	1.0	218.7	26.6 NO

DWASH= MEANS NO CALC MADE (CONC = 0.0)
 DWASH=NO MEANS NO BUILDING DOWNWASH USED
 DWASH=HS MEANS HUBER-SNYDER DOWNWASH USED
 DWASH=SS MEANS SCHULMAN-SCIRE DOWNWASH USED
 DWASH=NA MEANS DOWNWASH NOT APPLICABLE, X<3*LB

 *** SUMMARY OF SCREEN MODEL RESULTS ***

CALCULATION PROCEDURE	MAX CONC (UG/M**3)	DIST TO MAX (M)	TERRAIN HT (M)
SIMPLE TERRAIN	2080.	506.	0.

 ** REMEMBER TO INCLUDE BACKGROUND CONCENTRATIONS **

*** SCREEN-1.1 MODEL RUN ***
 *** VERSION DATED 88300 ***

Model# 15P

EAST DYE

SIMPLE TERRAIN INPUTS:

SOURCE TYPE	=	AREA	46.8#/hr
EMISSION RATE (G/S)	=	18.50	
SOURCE HEIGHT (M)	=	1.00	
LENGTH OF SIDE (M)	=	762.50	
RECEPTOR HEIGHT (M)	=	1.00	
IOPT (1=URB, 2=RUR)	=	2	

BUOY. FLUX = .00 M**4/S**3; MOM. FLUX = .00 M**4/S**2.

*** STABILITY CLASS 4 ONLY ***
 *** 10-METER WIND SPEED OF 1.3 M/S ONLY ***

 *** SCREEN DISCRETE DISTANCES ***

*** TERRAIN HEIGHT OF 0. M ABOVE STACK BASE USED FOR FOLLOWING DISTANCES ***

DIST (M)	CONC (UG/M**3)	HS STAB	U10M (M/S)	USTK (M/S)	MIX HT (M)	PLUME HT (M)	SIGMA Y (M)	SIGMA Z (M)	DWASH
506.	1204.	851	4	1.3	1.3	416.0	1.0	203.0	18.5 NO
793.	777.9	552	4	1.3	1.3	416.0	1.0	218.7	26.6 NO

DWASH= MEANS NO CALC MADE (CONC = 0.0)
 DWASH=NO MEANS NO BUILDING DOWNWASH USED
 DWASH=HS MEANS HUBER-SNYDER DOWNWASH USED
 DWASH=SS MEANS SCHULMAN-SCIRE DOWNWASH USED
 DWASH=NA MEANS DOWNWASH NOT APPLICABLE, X<3*LB

 *** SUMMARY OF SCREEN MODEL RESULTS ***

CALCULATION PROCEDURE	MAX CONC (UG/M**3)	DIST TO MAX (M)	TERRAIN HT (M)
SIMPLE TERRAIN	1204.	506.	0.

 ** REMEMBER TO INCLUDE BACKGROUND CONCENTRATIONS **

1

02-04-**
18:15:53

*** SCREEN-1.1 MODEL RUN ***
 *** VERSION DATED 88300 ***

Model# 17P

EAST EDGE

SIMPLE TERRAIN INPUTS:

SOURCE TYPE	=	AREA
EMISSION RATE (G/S)	=	25.90
SOURCE HEIGHT (M)	=	1.00
LENGTH OF SIDE (M)	=	762.50
RECEPTOR HEIGHT (M)	=	1.00
IOPT (1=URB, 2=RUR)	=	2

205.6 #/hr

BUOY. FLUX = .00 M**4/S**3; MOM. FLUX = .00 M**4/S**2.

*** STABILITY CLASS 4 ONLY ***
 *** 10-METER WIND SPEED OF 1.3 M/S ONLY ***

 *** SCREEN DISCRETE DISTANCES ***

*** TERRAIN HEIGHT OF 0. M ABOVE STACK BASE USED FOR FOLLOWING DISTANCES ***

DIST (M)	CONC (UG/M**3)	U10M STAB	USTK (M/S)	MIX HT (M)	PLUME HT (M)	SIGMA Y (M)	SIGMA Z (M)	DWASH
506.	1685.	1192	4	1.3	416.0	1.0	203.0	18.5 NO
793.	1089.	770	4	1.3	416.0	1.0	218.7	26.6 NO

DWASH= MEANS NO CALC MADE (CONC = 0.0)
 DWASH=NO MEANS NO BUILDING DOWNWASH USED
 DWASH=HS MEANS HUBER-SNYDER DOWNWASH USED
 DWASH=SS MEANS SCHULMAN-SCIRE DOWNWASH USED
 DWASH=NA MEANS DOWNWASH NOT APPLICABLE, X<3*LB

 *** SUMMARY OF SCREEN MODEL RESULTS ***

CALCULATION PROCEDURE	MAX CONC (UG/M**3)	DIST TO MAX (M)	TERRAIN HT (M)
SIMPLE TERRAIN	1685.	506.	0.

 ** REMEMBER TO INCLUDE BACKGROUND CONCENTRATIONS **

*** SCREEN-1.1 MODEL RUN ***
 *** VERSION DATED 88300 ***

Model# 19P

PAST EDGE

SIMPLE TERRAIN INPUTS:

SOURCE TYPE	=	AREA	836.5 #/hr
EMISSION RATE (G/S)	=	231.4	
SOURCE HEIGHT (M)	=	1.00	
LENGTH OF SIDE (M)	=	762.50	
RECEPTOR HEIGHT (M)	=	1.00	

IOPT (1=URB, 2=RUR) = 2

BUOY. FLUX = .00 M**4/S**3; MOM. FLUX = .00 M**4/S**2.

*** STABILITY CLASS 3 ONLY ***
 *** 10-METER WIND SPEED OF 3.0 M/S ONLY ***

 *** SCREEN DISCRETE DISTANCES ***

*** TERRAIN HEIGHT OF 0. M ABOVE STACK BASE USED FOR FOLLOWING DISTANCES ***

DIST (M)	CONC (UG/M**3)	U10M STAB	USTK (M/S)	MIX HT (M)	PLUME HT (M)	SIGMA Y (M)	SIGMA Z (M)	DWASH
✓ 506.	3393. 2400	3	3.0	3.0	960.0	1.0	220.3	32.8 NO
793.	2026. 1433	3	3.0	3.0	960.0	1.0	244.9	49.5 NO

DWASH= MEANS NO CALC MADE (CONC = 0.0)
 DWASH=NO MEANS NO BUILDING DOWNWASH USED
 DWASH=HS MEANS HUBER-SNYDER DOWNWASH USED
 DWASH=SS MEANS SCHULMAN-SCIRE DOWNWASH USED
 DWASH=NA MEANS DOWNWASH NOT APPLICABLE, X<3*LB

 *** SUMMARY OF SCREEN MODEL RESULTS ***

CALCULATION PROCEDURE	MAX CONC (UG/M**3)	DIST TO MAX (M)	TERRAIN HT (M)
SIMPLE TERRAIN	3393.	506.	0.

 ** REMEMBER TO INCLUDE BACKGROUND CONCENTRATIONS **

*** SCREEN-1.1 MODEL RUN ***
*** VERSION DATED 88300 ***

Model# 20P

PAST EDGE

SIMPLE TERRAIN INPUTS:

SOURCE TYPE	=	AREA
EMISSION RATE (G/S)	=	333.1
SOURCE HEIGHT (M)	=	1.00
LENGTH OF SIDE (M)	=	762.50
RECEPTOR HEIGHT (M)	=	1.00
IOPT (1=URB, 2=RUR)	=	2

2643.7 #/hr

BUOY. FLUX = .00 M**4/S**3; MOM. FLUX = .00 M**4/S**2.

*** STABILITY CLASS 3 ONLY ***
*** 10-METER WIND SPEED OF 4.2 M/S ONLY ***

*** SCREEN DISCRETE DISTANCES ***

*** TERRAIN HEIGHT OF 0. M ABOVE STACK BASE USED FOR FOLLOWING DISTANCES ***

DIST (M)	CONC (UG/M**3)	U10M (M/S)	USTK (M/S)	MIX HT (M)	PLUME HT (M)	SIGMA Y (M)	SIGMA Z (M)	DWASH
✓ 506.	3489. 2467	3	4.2	4.2	1344.0	1.0	220.3	32.8 NO
793.	2083. 1473	3	4.2	4.2	1344.0	1.0	244.9	49.5 NO

DWASH= MEANS NO CALC MADE (CONC = 0.0)
DWASH=NO MEANS NO BUILDING DOWNWASH USED
DWASH=HS MEANS HUBER-SNYDER DOWNWASH USED
DWASH=SS MEANS SCHULMAN-SCIRE DOWNWASH USED
DWASH=NA MEANS DOWNWASH NOT APPLICABLE, X<3*LB

*** SUMMARY OF SCREEN MODEL RESULTS ***

CALCULATION PROCEDURE	MAX CONC (UG/M**3)	DIST TO MAX (M)	TERRAIN HT (M)
SIMPLE TERRAIN	3489.	506.	0.

** REMEMBER TO INCLUDE BACKGROUND CONCENTRATIONS **

*** SCREEN-1.1 MODEL RUN ***
 *** VERSION DATED 88300 ***

Model# 41P

EAST EDGE

SIMPLE TERRAIN INPUTS:

SOURCE TYPE	=	AREA
EMISSION RATE (G/S)	=	79.10
SOURCE HEIGHT (M)	=	1.00
LENGTH OF SIDE (M)	=	762.50
RECEPTOR HEIGHT (M)	=	1.00
IOPT (1=URB, 2=RUR)	=	2

628[#]/m²

BUOY. FLUX = .00 M**4/S**3; MOM. FLUX = .00 M**4/S**2.

*** STABILITY CLASS 3 ONLY ***
 *** 10-METER WIND SPEED OF 1.5 M/S ONLY ***

 *** SCREEN DISCRETE DISTANCES ***

*** TERRAIN HEIGHT OF 0. M ABOVE STACK BASE USED FOR FOLLOWING DISTANCES ***

DIST (M)	CONC (UG/M**3)	STAB	U10M (M/S)	USTK (M/S)	MIX HT (M)	PLUME HT (M)	SIGMA Y (M)	SIGMA Z (M)	DWASH
506.	2320.	3	1.5	1.5	480.0	1.0	220.3	32.8	NO
793.	1385.	3	1.5	1.5	480.0	1.0	244.9	49.5	NO

DWASH= MEANS NO CALC MADE (CONC = 0.0)
 DWASH=NO MEANS NO BUILDING DOWNWASH USED
 DWASH=HS MEANS HUBER-SNYDER DOWNWASH USED
 DWASH=SS MEANS SCHULMAN-SCIRE DOWNWASH USED
 DWASH=NA MEANS DOWNWASH NOT APPLICABLE, X<3*LB

 *** SUMMARY OF SCREEN MODEL RESULTS ***

CALCULATION PROCEDURE	MAX CONC (UG/M**3)	DIST TO MAX (M)	TERRAIN HT (M)
SIMPLE TERRAIN	2320.	506.	0.

 ** REMEMBER TO INCLUDE BACKGROUND CONCENTRATIONS **

*** SCREEN-1.1 MODEL RUN ***
 *** VERSION DATED 88300 ***

Model# 42P

EPA EDO E

SIMPLE TERRAIN INPUTS:

SOURCE TYPE	=	AREA
EMISSION RATE (G/S)	=	25.70
SOURCE HEIGHT (M)	=	1.00
LENGTH OF SIDE (M)	=	762.50
RECEPTOR HEIGHT (M)	=	1.00
IOPT (1=URB, 2=RUR)	=	2

204 ft/m

BUOY. FLUX = .00 M**4/S**3; MOM. FLUX = .00 M**4/S**2.

*** STABILITY CLASS 4 ONLY ***
 *** 10-METER WIND SPEED OF 1.5 M/S ONLY ***

 *** SCREEN DISCRETE DISTANCES ***

*** TERRAIN HEIGHT OF 0. M ABOVE STACK BASE USED FOR FOLLOWING DISTANCES ***

DIST (M)	CONC (UG/M**3)	STAB	U10M (M/S)	USTK (M/S)	MIX HT (M)	PLUME HT (M)	SIGMA Y (M)	SIGMA Z (M)	DWASH
506.	1449.	4	1.5	1.5	480.0	1.0	203.0	18.5	NO
793.	936.6	4	1.5	1.5	480.0	1.0	218.7	26.6	NO

DWASH= MEANS NO CALC MADE (CONC = 0.0)
 DWASH=NO MEANS NO BUILDING DOWNWASH USED
 DWASH=HS MEANS HUBER-SNYDER DOWNWASH USED
 DWASH=SS MEANS SCHULMAN-SCIRE DOWNWASH USED
 DWASH=NA MEANS DOWNWASH NOT APPLICABLE, X<3*LB

 *** SUMMARY OF SCREEN MODEL RESULTS ***

CALCULATION PROCEDURE	MAX CONC (UG/M**3)	DIST TO MAX (M)	TERRAIN HT (M)
SIMPLE TERRAIN	1449.	506.	0.

 ** REMEMBER TO INCLUDE BACKGROUND CONCENTRATIONS **

Models of Polishing Pond Inlet

*** SCREEN-1.1 MODEL RUN ***
 *** VERSION DATED 88300 ***

PP INLET

Model# 32p

SIMPLE TERRAIN INPUTS:

SOURCE TYPE	=	AREA
EMISSION RATE (G/S)	=	4.180
SOURCE HEIGHT (M)	=	1.00
LENGTH OF SIDE (M)	=	91.50
RECEPTOR HEIGHT (M)	=	1.00
IOPT (1=URB, 2=RUR)	=	2

33.2 ft/m

BUOY. FLUX = .00 M**4/S**3; MOM. FLUX = .00 M**4/S**2.

*** STABILITY CLASS 3 ONLY ***
 *** 10-METER WIND SPEED OF 5.0 M/S ONLY ***

 *** SCREEN DISCRETE DISTANCES ***

*** TERRAIN HEIGHT OF 0. M ABOVE STACK BASE USED FOR FOLLOWING DISTANCES ***

DIST (M)	CONC (UG/M**3)	STAB	U10M (M/S)	USTK (M/S)	MIX HT (M)	PLUME HT (M)	SIGMA Y (M)	SIGMA Z (M)	DWASH
119.	891.4	3	5.0	5.0	1587.2	1.0	34.0	8.7	NO

DWASH= MEANS NO CALC MADE (CONC = 0.0)
 DWASH=NO MEANS NO BUILDING DOWNWASH USED
 DWASH=HS MEANS HUBER-SNYDER DOWNWASH USED
 DWASH=SS MEANS SCHULMAN-SCIRE DOWNWASH USED
 DWASH=NA MEANS DOWNWASH NOT APPLICABLE, X<3*LB

 *** SUMMARY OF SCREEN MODEL RESULTS ***

CALCULATION PROCEDURE	MAX CONC (UG/M**3)	DIST TO MAX (M)	TERRAIN HT (M)
SIMPLE TERRAIN	891.4	119.	0.

 ** REMEMBER TO INCLUDE BACKGROUND CONCENTRATIONS **

*** SCREEN-1.1 MODEL RUN ***
 *** VERSION DATED 88300 ***

Pp - INLET

Model# 34p

SIMPLE TERRAIN INPUTS:

SOURCE TYPE	=	AREA
EMISSION RATE (G/S)	=	2.000
SOURCE HEIGHT (M)	=	1.00
LENGTH OF SIDE (M)	=	91.50
RECEPTOR HEIGHT (M)	=	1.00
IOPT (1=URB, 2=RUR)	=	2

15.9 #/m

BUOY. FLUX = .00 M**4/S**3; MOM. FLUX = .00 M**4/S**2.

*** STABILITY CLASS 3 ONLY ***
 *** 10-METER WIND SPEED OF 1.7 M/S ONLY ***

 *** SCREEN DISCRETE DISTANCES ***

*** TERRAIN HEIGHT OF 0. M ABOVE STACK BASE USED FOR FOLLOWING DISTANCES ***

DIST (M)	CONC (UG/M**3)	STAB	U10M (M/S)	USTK (M/S)	MIX HT (M)	PLUME HT (M)	SIGMA Y (M)	SIGMA Z (M)	DWASH
119.	1244.	3	1.7	1.7	544.0	1.0	34.0	8.7	NO

DWASH= MEANS NO CALC MADE (CONC = 0.0)
 DWASH=NO MEANS NO BUILDING DOWNWASH USED
 DWASH=HS MEANS HUBER-SNYDER DOWNWASH USED
 DWASH=SS MEANS SCHULMAN-SCIRE DOWNWASH USED
 DWASH=NA MEANS DOWNWASH NOT APPLICABLE, X<3*LB

 *** SUMMARY OF SCREEN MODEL RESULTS ***

CALCULATION PROCEDURE	MAX CONC (UG/M**3)	DIST TO MAX (M)	TERRAIN HT (M)
SIMPLE TERRAIN	1244.	119.	0.

 ** REMEMBER TO INCLUDE BACKGROUND CONCENTRATIONS **

*** SCREEN-1.1 MODEL RUN ***
 *** VERSION DATED 88300 ***

PP - INLET

Model# 35p

SIMPLE TERRAIN INPUTS:

SOURCE TYPE = AREA
 EMISSION RATE (G/S) = 2.030
 SOURCE HEIGHT (M) = 1.00
 LENGTH OF SIDE (M) = 91.50
 RECEPTOR HEIGHT (M) = 1.00
 IOPT (1=URB, 2=RUR) = 2

16.1 #/hr

BUOY. FLUX = .00 M**4/S**3; MOM. FLUX = .00 M**4/S**2.

*** STABILITY CLASS 3 ONLY ***
 *** 10-METER WIND SPEED OF 3.1 M/S ONLY ***

 *** SCREEN DISCRETE DISTANCES ***

*** TERRAIN HEIGHT OF 0. M ABOVE STACK BASE USED FOR FOLLOWING DISTANCES ***

DIST (M)	CONC (UG/M**3)	U10M STAB	USTK (M/S)	MIX HT (M)	PLUME HT (M)	SIGMA Y (M)	SIGMA Z (M)	DWASH
119.	692.7	3	3.1	3.1	992.0	1.0	34.0	8.7 NO

DWASH= MEANS NO CALC MADE (CONC = 0.0)
 DWASH=NO MEANS NO BUILDING DOWNWASH USED
 DWASH=HS MEANS HUBER-SNYDER DOWNWASH USED
 DWASH=SS MEANS SCHULMAN-SCIRE DOWNWASH USED
 DWASH=NA MEANS DOWNWASH NOT APPLICABLE, X<3*LB

 *** SUMMARY OF SCREEN MODEL RESULTS ***

CALCULATION PROCEDURE	MAX CONC (UG/M**3)	DIST TO MAX (M)	TERRAIN HT (M)
SIMPLE TERRAIN	692.7	119.	0.

 ** REMEMBER TO INCLUDE BACKGROUND CONCENTRATIONS **

*** SCREEN-1.1 MODEL RUN ***
 *** VERSION DATED 88300 ***

PF-INLET

Model# 36p

SIMPLE TERRAIN INPUTS:

SOURCE TYPE	=	AREA	9.8 #/m
EMISSION RATE (G/S)	=	1.230	
SOURCE HEIGHT (M)	=	1.00	
LENGTH OF SIDE (M)	=	91.50	
RECEPTOR HEIGHT (M)	=	1.00	
IOPT (1=URB, 2=RUR)	=	2	

BUOY. FLUX = .00 M**4/S**3; MOM. FLUX = .00 M**4/S**2.

*** STABILITY CLASS 3 ONLY ***
 *** 10-METER WIND SPEED OF 1.8 M/S ONLY ***

 *** SCREEN DISCRETE DISTANCES ***

*** TERRAIN HEIGHT OF 0. M ABOVE STACK BASE USED FOR FOLLOWING DISTANCES ***

DIST (M)	CONC (UG/M**3)	STAB	U10M (M/S)	USTK (M/S)	MIX HT (M)	PLUME HT (M)	SIGMA Y (M)	SIGMA Z (M)	DWASH
119.	722.8	3	1.8	1.8	576.0	1.0	34.0	8.7	NO

DWASH= MEANS NO CALC MADE (CONC = 0.0)
 DWASH=NO MEANS NO BUILDING DOWNWASH USED
 DWASH=HS MEANS HUBER-SNYDER DOWNWASH USED
 DWASH=SS MEANS SCHULMAN-SCIRE DOWNWASH USED
 DWASH=NA MEANS DOWNWASH NOT APPLICABLE, X<3*LB

 *** SUMMARY OF SCREEN MODEL RESULTS ***

CALCULATION PROCEDURE	MAX CONC (UG/M**3)	DIST TO MAX (M)	TERRAIN HT (M)
SIMPLE TERRAIN	722.8	119.	0.

 ** REMEMBER TO INCLUDE BACKGROUND CONCENTRATIONS **

Model of PulpMill, PowerHouse, Recovery Area

*** SCREEN-1.1 MODEL RUN ***
 *** VERSION DATED 88300 ***

Model# 2m Drip Mill, Penitentiary EVAP Areas

SIMPLE TERRAIN INPUTS:

SOURCE TYPE = AREA 2.3 #/m
 EMISSION RATE (G/S) = .2900
 SOURCE HEIGHT (M) = 1.00
 LENGTH OF SIDE (M) = 152.50
 RECEPTOR HEIGHT (M) = 1.00
 IOPT (1=URB, 2=RUR) = 2

BUOY. FLUX = .00 M**4/S**3; MOM. FLUX = .00 M**4/S**2.

*** STABILITY CLASS 3 ONLY ***
 *** 10-METER WIND SPEED OF 3.5 M/S ONLY ***

 *** SCREEN DISCRETE DISTANCES ***

*** TERRAIN HEIGHT OF 0. M ABOVE STACK BASE USED FOR FOLLOWING DISTANCES ***

DIST (M)	CONC (UG/M**3)	STAB	U10M (M/S)	USTK (M/S)	MIX HT (M)	PLUME HT (M)	SIGMA Y (M)	SIGMA Z (M)	DWASH
442.	11.44	3	3.5	3.5	1116.8	1.0	79.7	29.0	NO

DWASH= MEANS NO CALC MADE (CONC = 0.0)
 DWASH=NO MEANS NO BUILDING DOWNWASH USED
 DWASH=HS MEANS HUBER-SNYDER DOWNWASH USED
 DWASH=SS MEANS SCHULMAN-SCIRE DOWNWASH USED
 DWASH=NA MEANS DOWNWASH NOT APPLICABLE, X<3*LB

 *** SUMMARY OF SCREEN MODEL RESULTS ***

CALCULATION PROCEDURE	MAX CONC (UG/M**3)	DIST TO MAX (M)	TERRAIN HT (M)
SIMPLE TERRAIN	11.44	442.	0.

 ** REMEMBER TO INCLUDE BACKGROUND CONCENTRATIONS **

1

*** SCREEN-1.1 MODEL RUN ***
 *** VERSION DATED 88300 ***

PF-INLET

02-12--*
 11:32:35

No 6.3 mph

Model# FEB01_a RUN #1 (11) ~~FEB~~ FEB 2001

SIMPLE TERRAIN INPUTS:

SOURCE TYPE = AREA
 EMISSION RATE (G/S) = 5.200
 SOURCE HEIGHT (M) = 1.00
 LENGTH OF SIDE (M) = 91.50
 RECEPTOR HEIGHT (M) = 1.00
 IOPT (1=URB, 2=RUR) = 2

41.3#/hr

2/12 13:46

1400 fpm

BUOY. FLUX = .00 M**4/S**3; MOM. FLUX = .00 M**4/S**2.

*** STABILITY CLASS 3 ONLY ***
 *** 10-METER WIND SPEED OF 2.8 M/S ONLY ***

 *** SCREEN DISCRETE DISTANCES ***

*** TERRAIN HEIGHT OF 0. M ABOVE STACK BASE USED FOR FOLLOWING DISTANCES ***

DIST (M)	CONC (UG/M**3)	STAB	U10M (M/S)	USTK (M/S)	MIX HT (M)	PLUME HT (M)	SIGMA Y (M)	SIGMA Z (M)	DWASH
119.	1964.	3	2.8	2.8	896.0	1.0	34.0	8.7	NO

DWASH= MEANS NO CALC MADE (CONC = 0.0)
 DWASH=NO MEANS NO BUILDING DOWNWASH USED
 DWASH=HS MEANS HUBER-SNYDER DOWNWASH USED
 DWASH=SS MEANS SCHULMAN-SCIRE DOWNWASH USED
 DWASH=NA MEANS DOWNWASH NOT APPLICABLE, X<3*LB

 *** SUMMARY OF SCREEN MODEL RESULTS ***

CALCULATION PROCEDURE	MAX CONC (UG/M**3)	DIST TO MAX (M)	TERRAIN HT (M)
SIMPLE TERRAIN	1964.	119.	0.

 ** REMEMBER TO INCLUDE BACKGROUND CONCENTRATIONS **

PINE HILL TRS STUDY - PHASE II

ENSR Station Weather Summary

Pine Hill Weather Station Data
November 2001

WEYERHAEUSER	TEMP	WDR	WSP	H2S	DELTAT	SOLAR	STATMP	SD1	STABILITY CLASS			°F				
									PPM	DEGC	WM2	DEGF	DEG	Sol	Inv	Class
PINE HILL	DEGC	DEG	MPH	PPM	DEGC	WM2	DEGF	DEG	Sol	Inv	Class	°F	Sol	Inv	Class	°F
11/30/2001 5:00	11.3	260.8	3.3	0.001	-0.27	0	76.9	20.6	D	D	D	52				
11/30/2001 6:00	10.8	247.9	3.8	0.000	-0.28	0	77.0	23.4	D	D	D	51				
11/30/2001 7:00	10.5	252.7	4.2	0.000	-0.30	7	76.9	18.4	D	D	D	51				
11/30/2001 8:00	10.6	285.9	4.1	0.002	-0.37	53	77.1	20.6	C	D	C	51				
11/30/2001 9:00	10.5	286.5	4.3	0.003	-0.51	95	76.7	24.1	C	D	C	51				
11/30/2001 10:00	10.2	331.8	7.5	0.012	-0.43	144	77.2	10.8	C	D	C	50				
11/30/2001 11:00	10.8	304.8	3.3	0.002	-0.70	204	76.9	39.3	C	D	C	51				
11/30/2001 12:00	11.3	331.6	3.8	0.004	-0.67	249	77.1	37.4	C	D	C	52				
11/30/2001 13:00	12.1	286.5	3.7	0.003	-0.94	319	77.1	31.0	C	D	C	54				
11/30/2001 14:00	12.7	328.6	5.7	0.007	-0.94	448	77.0	20.1	C	D	C	55				
11/30/2001 15:00	12.8	322.4	6.1	0.005	-0.85	351	77.1	15.1	C	D	C	55				
11/30/2001 16:00	12.4	329.4	5.6	0.019	-0.54	165	77.3	14.1	C	D	C	54				
11/30/2001 17:00	11.3	352.6	5.4	0.079	-0.27	15	76.9	11.7	D	D	D	52				
11/30/2001 18:00	9.8	44.0	3.7	0.138	-0.03	0	76.9	16.5	D	D	D	50				
11/30/2001 19:00	9.4	23.0	2.8	0.222	-0.01	0	76.7	14.6	D	D	D	49				

Pine Hill Weather Station Data
December 2001

Dec 01				H2S	DELTAT	SOLAR	STATMP	SD1	STABILITY CLASS			°F
WEYERHAEUSER	TEMP	WDR	WSP						Solar	Inversion	Class	
PINE HILL	DEGC	DEG	MPH	PPM	DEGC	WM2	DEGF	DEG	Solar	Inversion	Class	°F
12/1/2001 5:00	4.0	294.6	1.3	0.035	-0.40	0	77.2	43.5	D	D	D	39
12/1/2001 6:00	4.4	304.8	1.0	0.133	-0.38	0	77.2	36.5	D	D	D	40
12/1/2001 7:00	4.2	259.5	1.5	0.040	-0.52	9	77.3	23.9	D	D	D	40
12/1/2001 8:00	4.8	77.0	0.8	0.148	-0.27	84	77.3	52.9	C	D	C	41
12/1/2001 9:00	6.0	68.9	2.0	0.112	-0.29	267	76.9	36.7	C	D	C	43
12/1/2001 10:00	8.2	11.9	2.5	0.101	-0.49	466	77.1	26.3	C	D	C	47
12/1/2001 11:00	12.1	6.0	2.9	0.058	-0.61	561	77.1	32.0	C	D	C	54
12/1/2001 12:00	15.1	28.9	3.0	0.044	-0.51	581	77.3	34.2	C	D	C	59
12/1/2001 13:00	16.6	10.8	3.7	0.043	-0.53	562	77.3	32.5	C	D	C	62
12/1/2001 14:00	17.5	28.9	3.0	0.028	-0.36	464	77.5	41.3	C	D	C	64
12/1/2001 15:00	18.1	30.0	3.4	0.059	-0.31	326	77.3	26.5	C	D	C	65
12/1/2001 16:00	17.9	38.9	2.7	0.071	-0.06	134	77.4	27.0	C	D	C	64
12/1/2001 17:00	15.1	241.9	0.4	0.029	1.18	11	77.2	64.9	D	F	C	59
12/1/2001 18:00	12.3	168.2	0.5	0.022	1.46	0	77.1	46.9	D	F	C	54

Pine Hill Weather Station Data
December 2001

Dec 01				H2S	DELTAT	SOLAR	STATMP	SD1	STABILITY CLASS			°F
WEYERHAEUSER	TEMP	WDR	WSP						Solar	Inversion	Class	
PINE HILL	DEGC	DEG	MPH	PPM	DEGC	WM2	DEGF	DEG				
12/2/2001 5:00	5.8	290.8	0.5	0.028	0.51	0	77.0	37.0	D	F	D	42
12/2/2001 6:00	6.5	341.8	1.8	0.129	0.16	0	76.8	37.2	D	F	D	44
12/2/2001 7:00	6.5	341.6	1.8	0.064	-0.07	7	76.8	44.7	D	D	D	44
12/2/2001 8:00	7.3	312.4	2.9	0.036	-0.28	57	77.8	13.9	C	D	C	45
12/2/2001 9:00	9.0	324.8	3.3	0.054	-0.68	240	77.4	12.9	C	D	C	48
12/2/2001 10:00	12.0	340.7	2.8	0.032	-0.88	431	77.3	23.8	C	D	C	54
12/2/2001 11:00	14.6	13.8	2.7	0.059	-0.51	552	77.2	28.8	C	D	C	58
12/2/2001 12:00	17.2	20.0	2.4	0.041	-0.49	605	77.3	38.1	C	D	C	63
12/2/2001 13:00	19.0	17.0	4.0	0.053	-0.49	548	76.9	23.9	C	D	C	66
12/2/2001 14:00	20.2	11.9	3.7	0.050	-0.43	454	77.0	23.9	C	D	C	68
12/2/2001 15:00	21.1	351.5	4.4	0.063	-0.41	319	76.9	19.9	C	D	C	70
12/2/2001 16:00	20.8	347.8	5.1	0.099	-0.19	154	76.8	12.8	C	D	C	69
12/2/2001 17:00	19.2	336.7	4.8	0.100	0.14	13	77.2	8.3	D	F	D	67
12/2/2001 18:00	15.4	309.7	1.4	0.075	1.57	-1	77.1	39.8	D	F	D	60

Pine Hill Weather Station Data
December 2001

Dec 01 WEYERHAEUSER	TEMP	WDR	WSP	H2S					SD1	STABILITY CLASS			°F			
					DEGC	DEG	MPH	PPM		DELTAT	SOLAR	STATMP	Solar	Inversion	Class	
PINE HILL					DEGC	WM2	DEGF	DEG								
12/3/2001 5:00	6.0	345.9	1.0	0.063	0.98	0	77.5	52.5	D	F	D	43				
12/3/2001 6:00	5.7	345.6	0.5	0.093	0.75	0	77.7	59.8	D	F	D	42				
12/3/2001 7:00	5.0	217.9	1.3	0.014	0.13	11	77.7	24.9	D	F	D	41				
12/3/2001 8:00	7.2	349.7	1.1	0.165	-0.15	147	77.7	27.2	C	D	C	45				
12/3/2001 9:00	10.2	6.8	2.2	0.195	-0.45	316	77.5	19.1	C	D	C	50				
12/3/2001 10:00	13.7	359.6	2.0	0.138	-0.65	467	76.9	28.4	C	D	C	57				
12/3/2001 11:00	17.0	4.9	3.2	0.083	-0.49	555	77.3	20.2	C	D	C	63				
12/3/2001 12:00	19.6	23.8	2.8	0.028	-0.35	577	77.1	34.4	C	D	C	67				
12/3/2001 13:00	21.3	62.9	3.3	0.021	-0.48	539	77.0	37.1	C	D	C	70				
12/3/2001 14:00	22.2	91.0	3.2	0.009	-0.40	448	76.9	40.4	C	D	C	72				
12/3/2001 15:00								F 19.9	D	E	D	32				
12/3/2001 16:00	22.2	87.0	3.7	0.001	-0.02	135	77.1	< 28.9	C	D	C	72				
12/3/2001 17:00	19.9	75.9	2.5	0.003	1.06	11	77.2	8.8	D	F	D	68				
12/3/2001 18:00	16.5	65.9	1.5	0.071	1.62	-1	77.1	30.1	D	F	D	62				

Pine Hill Weather Station Data
December 2001

Dec 01	WEYERHAEUSER	TEMP	WDR	WSP	H2S						STABILITY CLASS			°F		
						DEGC	DEG	MPH	PPM	DEGC	WM2	DEGF	DEG	Solar	Inversion	Class
PINE HILL																
12/4/2001 5:00		7.2	272.4	0.3	0.199		0.28	0		77.2		30.6	D	F	D	45
12/4/2001 6:00		7.5	246.2	0.2	0.149		0.13	0		77.6		53.5	D	F	D	46
12/4/2001 7:00		6.9	58.9	0.7	0.229		0.88	10		77.4		52.9	D	F	D	44
12/4/2001 8:00		9.1	30.8	1.2	0.373		0.20	112		77.5		34.1	C	F	D	48
12/4/2001 9:00		11.7	24.1	1.8	0.358		-0.24	267		77.3		18.3	C	D	C	53
12/4/2001 10:00		16.6	141.8	2.1	0.030		-0.46	444		77.3		40.2	C	D	C	62
12/4/2001 11:00		19.9	157.1	3.0	0.001		-0.70	550		77.2		32.2	C	D	C	68
12/4/2001 12:00		21.2	157.1	2.4	0.001		-0.44	574		77.0		56.7	C	D	C	70
12/4/2001 13:00		22.2	138.8	2.4	0.000		-0.62	536		76.9		36.9	C	D	C	72
12/4/2001 14:00		23.1	110.2	2.9	0.001		-0.37	441		77.0		39.8	C	D	C	74
12/4/2001 15:00		23.3	99.9	3.8	0.001		-0.25	305		77.1		24.4	C	D	C	74
12/4/2001 16:00		22.6	94.8	3.3	0.004		-0.03	140		76.8		19.1	C	D	C	73
12/4/2001 17:00		20.2	104.0	2.3	0.001		0.78	11		77.3		12.4	D	F	D	68
12/4/2001 18:00		16.4	153.9	1.4	0.001		1.47	-1		77.1		13.2	D	F	D	62

Pine Hill Weather Station Data
December 2001

Dec 01	WEYERHAEUSER	TEMP	WDR	WSP	H2S	DELTAT	SOLAR	STATMP	SD1	STABILITY CLASS			°F			
										DEGC	WM2	DEGF	DEG	Solar	Inversion	Class
PINE HILL		DEGC	DEG	MPH	PPM											
12/5/2001 5:00		7.5	55.9	1.3	0.273	1.33	0	77.6	21.6	D	F	D	46			
12/5/2001 6:00		6.5	227.3	0.6	0.114	0.79	0	77.7	37.2	D	F	D	44			
12/5/2001 7:00		6.5	17.8	0.2	0.145	0.85	9	77.4	43.6	D	F	D	44			
12/5/2001 8:00		8.6	153.9	0.4	0.243	-0.13	142	77.6	48.0	C	D	C	47			
12/5/2001 9:00		13.0	3.0	0.8	0.201	-0.49	298	77.5	44.7	C	D	C	55			
12/5/2001 10:00		16.3	37.0	1.1	0.150	-0.52	470	77.3	35.0	C	D	C	61			
12/5/2001 11:00		19.9	148.0	3.5	0.001	-0.57	543	77.2	32.6	C	D	C	68			
12/5/2001 12:00		21.6	152.8	3.3	0.001	-0.48	578	77.0	37.8	C	D	C	71			
12/5/2001 13:00		23.0	165.2	3.7	0.001	-0.67	528	76.8	32.7	C	D	C	73			
12/5/2001 14:00		24.1	164.2	3.9	0.000	-0.53	443	77.1	29.8	C	D	C	75			
12/5/2001 15:00		24.1	159.8	4.1	0.000	-0.24	292	77.1	27.9	C	D	C	75			
12/5/2001 16:00		23.4	165.0	3.1	0.000	0.10	137	77.0	21.7	C	F	D	74			
12/5/2001 17:00		20.9	165.8	1.5	0.001	0.67	13	77.1	17.9	D	F	D	70			
12/5/2001 18:00		18.3	136.1	0.5	0.001	1.33	0	77.3	32.3	D	F	D	65			

Pine Hill Weather Station Data
December 2001

Dec 01 WEYERHAEUSER	TEMP	WDR	WSP	H2S					SD1	STABILITY CLASS			°F
					DEGC	DEG	MPH	PPM		DELTAT	SOLAR	STATMP	Solar
PINE HILL	12/6/2001 5:00	11.3	172.3	0.9	0.154	-0.13	0	77.0	34.7	D	D	D	52
	12/6/2001 6:00	11.1	186.0	0.9	0.079	-0.16	0	77.0	56.7	D	D	D	52
	12/6/2001 7:00	10.7	200.9	1.3	0.027	-0.06	9	77.1	21.2	D	D	D	51
	12/6/2001 8:00	11.3	215.2	0.4	0.013	-0.23	120	77.1	51.2	C	D	C	52
	12/6/2001 9:00	13.8	171.7	0.6	0.059	-0.46	284	77.3	58.8	C	D	C	57
	12/6/2001 10:00	17.9	216.3	1.6	0.004	-1.00	450	77.2	35.6	C	D	C	64
	12/6/2001 11:00	21.8	189.8	3.3	0.013	-0.86	545	77.3	41.6	C	D	C	71
	12/6/2001 12:00	23.9	197.9	4.1	0.001	-0.79	569	77.1	29.8	C	D	C	75
	12/6/2001 13:00	25.1	195.2	5.3	0.001	-0.81	504	77.0	27.3	C	D	C	77
	12/6/2001 14:00	25.5	222.8	4.6	0.001	-0.72	370	77.1	28.2	C	D	C	78
	12/6/2001 15:00	25.3	215.7	3.5	0.000	-0.40	247	77.1	27.0	C	D	C	78
	12/6/2001 16:00	24.5	196.3	2.2	0.000	0.05	131	77.2	19.7	C	F	D	76
	12/6/2001 17:00	21.6	180.1	1.3	0.001	0.64	12	77.2	15.6	D	F	D	71
	12/6/2001 18:00	18.7	192.2	1.0	0.001	0.95	-1	77.1	33.7	D	F	D	66

Pine Hill Weather Station Data
December 2001

Dec 01 WEYERHAEUSER	TEMP	WDR	WSP	H2S					SD1	STABILITY CLASS			°F
					DEGC	DEG	MPH	PPM		DEGC	WM2	DEGF	DEG
PINE HILL	12/7/2001 5:00	11.2	124.2	0.6	0.001	0.91	0	77.1	60.0	D	F	D	52
	12/7/2001 6:00	11.6	211.4	1.1	0.001	-0.07	0	77.1	27.2	D	D	D	53
	12/7/2001 7:00	12.4	199.3	1.3	0.001	-0.19	7	77.1	21.9	D	D	D	54
	12/7/2001 8:00	13.0	152.3	2.2	0.001	-0.19	67	77.0	15.8	C	D	C	55
	12/7/2001 9:00	14.2	189.3	1.5	0.001	-0.36	156	76.8	33.2	C	D	C	58
	12/7/2001 10:00	15.9	226.3	1.6	0.001	-0.58	284	77.0	47.5	C	D	C	61
	12/7/2001 11:00	19.2	158.2	1.9	0.008	-0.68	518	76.7	50.7	C	D	C	67
	12/7/2001 12:00	22.5	199.8	3.1	0.001	-0.91	564	75.9	32.1	C	D	C	73
	12/7/2001 13:00	24.2	7.4	3.4	0.000	0.94	532	75.8	46.3	C	F	D	76
	12/7/2001 14:00	24.8	177.1	3.4	0.000	-0.59	454	75.8	37.2	C	D	C	77
	12/7/2001 15:00	24.4	2.2	3.2	0.000	0.34	222	75.8	27.9	C	F	D	76
	12/7/2001 16:00	23.6	212.8	3.0	0.000	-0.01	116	75.8	16.7	C	D	C	74
	12/7/2001 17:00	20.7	181.7	1.5	0.001	0.92	12	75.7	14.8	D	F	D	69
	12/7/2001 18:00	17.6	168.2	1.4	0.001	0.69	0	75.6	14.8	D	F	D	64

Pine Hill Weather Station Data
December 2001

Dec 01	WEYERHAEUSER	TEMP	WDR	WSP	H2S	DELTAT	SOLAR	STATMP	SD1	STABILITY CLASS			°F			
										DEGC	WM2	DEGF	DEG	Solar	Inversion	Class
PINE HILL		DEGC	DEG	MPH	PPM											
12/8/2001 5:00		11.2	123.1	0.9	0.002		1.24	0	76.3	47.3	D	F	D	52		
12/8/2001 6:00		10.8	189.3	0.6	0.001		0.76	0	76.4	44.9	D	F	D	51		
12/8/2001 7:00		10.4	165.8	1.4	0.001		0.34	11	76.6	19.7	D	F	D	51		
12/8/2001 8:00		12.7	178.2	1.3	0.002		-0.19	135	76.3	33.0	C	D	C	55		
12/8/2001 9:00		16.7	192.8	2.9	0.004		-0.72	291	76.0	19.5	C	D	C	62		
12/8/2001 10:00		20.1	208.2	3.9	0.001		-0.91	438	75.9	19.2	C	D	C	68		
12/8/2001 11:00		23.0	212.0	5.2	0.001		-1.12	569	75.8	19.4	C	D	C	73		
12/8/2001 12:00		24.3	260.3	5.3	0.001		-1.06	430	75.9	24.1	C	D	C	76		
12/8/2001 13:00		24.1	288.4	5.8	0.002		-0.94	364	75.8	24.0	C	D	C	75		
12/8/2001 14:00		23.1	323.7	7.7	0.084		-0.66	247	75.9	13.0	C	D	C	74		
12/8/2001 15:00		22.8	307.3	5.5	0.041		-0.69	264	75.9	24.0	C	D	C	73		
12/8/2001 16:00		22.6	280.8	3.5	0.012		-0.31	137	75.7	20.1	C	D	C	73		
12/8/2001 17:00		20.9	312.4	2.2	0.047		0.39	15	75.7	24.0	D	F	D	70		
12/8/2001 18:00		17.9	181.7	0.3	0.072		1.51	0	75.7	47.4	D	F	D	64		

Pine Hill Weather Station Data
December 2001

Dec 01	WEYERHAEUSER	TEMP	WDR	WSP	H2S					SD1	STABILITY CLASS			°F		
						DEGC	DEG	MPH	PPM		DELTAT	SOLAR	STATMP	Solar	Inversion	Class
PINE HILL		DEGC	DEG	MPH	PPM					WM2	DEGF	DEG				
12/9/2001 5:00		13.3	343.7	8.4	0.124		-0.23	0		76.0	11.3	D	D	D	D	56
12/9/2001 6:00		12.5	348.6	8.1	0.121		-0.25	0		76.0	11.0	D	D	D	D	55
12/9/2001 7:00		12.3	350.7	7.2	0.111		-0.23	2		76.0	11.2	D	D	D	D	54
12/9/2001 8:00		12.6	355.6	6.3	0.119		-0.22	23		76.2	10.9	D	D	D	D	55
12/9/2001 9:00		12.8	8.9	6.6	0.138		-0.24	75		76.2	11.8	C	D	C	C	55
12/9/2001 10:00		13.1	4.9	6.2	0.137		-0.28	68		76.3	13.1	C	D	C	C	56
12/9/2001 11:00		13.2	6.0	6.2	0.135		-0.30	128		76.1	13.9	C	D	C	C	56
12/9/2001 12:00		13.5	6.8	5.3	0.114		-0.37	139		76.0	14.6	C	D	C	C	56
12/9/2001 13:00		13.8	359.9	5.7	0.104		-0.34	107		76.5	12.8	C	D	C	C	57
12/9/2001 14:00		14.2	355.9	5.2	0.100		-0.43	170		76.1	15.0	C	D	C	C	58
12/9/2001 15:00		14.7	1.9	6.1	0.118		-0.34	166		76.5	15.9	C	D	C	C	58
12/9/2001 16:00		14.6	348.8	7.2	0.119		-0.28	72		76.1	10.6	C	D	C	C	58
12/9/2001 17:00		14.1	0.8	5.5	0.156		-0.18	7		76.3	9.7	D	D	D	D	57
12/9/2001 18:00		13.7	11.9	4.2	0.194		-0.16	0		76.5	9.7	D	D	D	D	57

PINE HILL TRS STUDY - PHASE II

Process Sewer Flow Data

NOVEMBER 30

PULP MILL	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS 1.4
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
			1.8	9.7	1.9	1.2	0.18	0.1	0.19	0.1	
POWER & RECOVERY	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS 44.9
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
			4.5	9.8	17	26.6	6.3	9.9	0.77	1.2	
CAUST AREA TO ASH POND	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS 556.3
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
			1.6	>11.0	1000	556.3	0	0.0	0	0.0	
#1 PM	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS 0.1
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
			2.9	6.9	0.09	0.1	0	0.0	0	0.0	
8.2 PM	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS 0.7
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
			3.5	7.1	0.13	0.2	0.14	0.2	0	0.0	
OCC	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS 0.0
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
			1.1		0.0		0.0		0.0		
ASH POND OVERFLOW TO ASB by-pass Clarifier	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS 136.4
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
			13.1		29	132.1	0.85	4.3	0	0.0	
EQ POND DECANT	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS 0.0
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
					20	0.0		0.0		0.0	
CSSC HOTWELL	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS 0.0
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
					2.3	0.0		0.0		0.0	
KRAFT HOTWELL	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS 0.0
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
					37	0.0	69	0.0	5.2	0.0	
			TOTAL LBS / HR		716.4	14.5	1.3		7.6	739.9	

NOVEMBER 30 TREATMENT SYSTEM FLOW

PPM = mg/L

Clarifier Inlet

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS 25
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
12	8.5	3.5	14.6	0.87	3.6	0.24	1.0	1.3	5.4	6

48.0

CLARIFIER

-91.3

ASB

ASB

ASB Outlet - before Riffler

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS 5
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
18.5	8.1	0.81	5.2	0	0.0	0	0.0	0	0.0	0.81

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS 6
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
18.5	-	0.8	5.1	0.17	1.1	0	0.0	0	0.0	0.97

Polishing Pond Outlet

Flow MGD	pH	H2S		MESH		DMS		DMDS		Total TRS 51
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
18.5	7.8	7.8	50.2	0.19	1.2	0	0.0	0	0.0	7.99

Estimated average flows used, obtained from flow / sulfur balance study
Pond Outlet flows "normalized" to match inlet flowrate for comparison purposes

DECEMBER 1											
PULP MILL	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
	1.8	8.2	38	23.6	0.53	0.3	0.16	0.1	0	0.0	24.2
POWER & RECOVERY	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS
	4.5	8.5	17	26.6	4.4	1.2	1.1	1.7	7	11.0	40.5
CAUST AREA TO ASH POND	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS
	1.6	>11.0	207	115.2	0	0.0	0	0.0	0	0.0	115.2
# 1 PM	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS
	3	7.1	0	0.0	0	0.0	0	0.0	0	0.0	0.0
# 2 PM	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS
	3.5	7.6	0	0.0	0	0.0	0	0.0	0.47	0.6	0.6
OCC	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS
	1.1		0.0		0.0		0.0		0.0		0.0
ASH POND OVERFLOW TO ASB - by-pass Clarifier	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS
	13.1		83	378.1	15	6.6	0.23	1.0	0	0.0	385.9
EQ POND DECANT	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS
			0.0		0.0		0.0		0.0		0.0
CSSC HOTWELL	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS
			0.0		0.0		0.0		0.0		0.0
KRAFT HOTWELL	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS
			0.0		0.0		0.0		0.0		0.0
TOTAL LBS / HR			543.6		8.4		2.9		11.5	568.4	

lbs / hr
H₂S
gasoline

125.2
CLARIFIER

-202.9
ASB

DECEMBER 1 TREATMENT SYSTEM FLOW

PPM = mg/L

Clarifier Inlet

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS	
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR		
12	8.5	4	16.7	0.66	2.8	0.24	1.0	3.3	13.6	8	34

Clarifier Outlet

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS	
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR		
12	-	34	141.9	2	8.3	0.28	1.2	0	0.0	36	151

Ash Pond Overflow - (includes Caustic Sewer)

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS	
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR		
7.5	-	83	216.4	1.5	3.9	0.23	0.6	0	0.0	85	221

ASB Inlet

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS	
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR		
18.5	11	32	205.6	2	12.6	0	0.0	0.32	2.1	34.32	221

ASB Outlet - before Riffler

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS	
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR		
18.5	8.1	0.62	4.0	0	0.0	0	0.0	0	0.0	0.62	4

Polishing Pond Inlet - ASB outlet after Riffler

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS	
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR		
18.5	-	0.45	2.9	0.14	0.9	0	0.0	0	0.0	0.59	4

Polishing Pond Outlet

Flow MGD	pH	H2S		MESH		DMS		DMDS		Total TRS	
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR		
18.5	8.1	10	64.3	0.18	1.2	0	0.0	0	0.0	10.18	65

Estimated average flows used, obtained from flow / sulfur balance study
Pond Outlet flows 'normalized' to match inlet flowrate for comparison purposes

DECEMBER 2

PULP MILL	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS	
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
	1.8	6.7	45	28.2	0.57	0.4	0.24	0.2	0	0.0	28.67	
POWER & RECOVERY	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS	
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
	4.5	8.5	15	23.5	2.5	3.9	0.88	1.4	5.2	8.1	36.9	
CAUST AREA TO ASH POND	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS	
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
	1.6	>11.0	2300	1279.5	0	0.0	0	0.0	0	0.0	1279.5	
8:1 PM	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS	
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
	3.2	7.2		0.0		0.0		0.0		0.0		0.0
#2 PM	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS	
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
	3.5	6.4	0.13	0.2	0	0.0	0	0.0	0.46	0.8	0.7	
OCC	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS	
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
				0.0		0.0		0.0		0.0		0.0
ASH POND OVERFLOW TO ABS by-pass Clarifier	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS	
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
	13.1	80	364.4	1.2	5.5	0	0.0	0	0.0	0	369.9	
EQ POND DECAN	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS	
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
				0.0		0.0		0.0		0.0		0.0
CSSC HOTWELL	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS	
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
				0.0		0.0		0.0		0.0		0.0
KRAFT HOTWELL	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS	
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
				0.0		0.0		0.0		0.0		0.0
	TOTAL LBS / HR		1695.7		9.7		1.5		8.7		1715.7	



DECEMBER 2 TREATMENT SYSTEM FLOW

PPM = mg/L

Clarifier Inlet

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS	
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
12	8.5	7.7	32.1	1.1	4.6	0.33	1.4	4.7	19.6	14	58

193.2
CLARIFIER

Clarifier Outlet

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS	
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
12	-	54	225.3	2.5	10.4	0.3	1.3	0	0.0	57	237

Ash Pond Overflow - (Includes Caustic Sewer)

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS	
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
7.5	-	80	208.6	1.2	3.1	0	0.0	0	0.0	81	212

ASB Inlet

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS	
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
18.5	11	33	212.3	1.8	11.6	0	0.0	0.37	2.4	35.17	226

ASB Outlet - before Riffler

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS	
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
18.5	8.1	0.6	3.9	0.18	1.2	0.2	1.3	0	0.0	0.98	6

Polishing Pond Inlet - ASB outlet after Riffler

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS	
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
18.5	-	0.71	4.6	0	0.0	0	0.0	0	0.0	0.71	5

Polishing Pond Outlet

Flow MGD*	pH	H2S		MESH		DMS		DMDS		Total TRS	
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
18.5	7.9	12	77.2	0	0.0	0	0.0	0	0.0	12	77

Estimated average flows used, obtained from flow / sulfur balance study
Pond Outlet flows 'normalized' to match inlet flowrate for comparison purposes

DECEMBER 3											
PULP MILL	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS 1.6
			PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	
			18	8.3	2.6	1.6	0	0.0	0	0.0	
POWER & RECOVERY	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS 44.6
			PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	
	4.5	8.4	16	25.0	6.2	9.7	0	0.0	8.3	0.0	
CAUST AREA TO ASH POND	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS 334.5
			PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	
	1.6	>11.0	1500	334.5	0	0.0	0	0.0	0	0.0	334.5
# 1 PM	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS 0.0
			PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	
	3.1	6.4			0.0		0.0		0.0		0.0
# 2 PM	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS 0.2
			PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	
	3.5	7.1	0	0.0	0.14	0.2	0	0.0	0	0.0	0.2
OCC	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS 0.0
			PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	
					0.0		0.0		0.0		0.0
ASH POND OVERFLOW TO ASB by-pass Clarifier	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS 452.3
			PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	
	13.1		98	448.4	1.3	5.9	0	0.0	0	0.0	
EQ POND DECANT	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS 0.0
			PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	
					0.0		0.0		0.0		0.0
CSSC HOTWELL	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS 0.0
			PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	
					0.0		0.0		0.0		0.0
KRAFT HOTWELL	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS 0.0
			PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	
					0.0		0.0		0.0		0.0
			TOTAL LBS / HR	1307.5		15.8		0.0	9.9	1333.2	

DECEMBER 3 TREATMENT SYSTEM FLOW

PPM = mg/L

Clarifier Inlet

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS 27
		PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	
12	6	2.6	10.6	0.68	3.7	0.31	1.3	2.8	11.7	

193.6
CLARIFIER

Clarifier Outlet

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS 215
		PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	
12	-	49	204.4	2.2	9.2	0.36	1.6	0	0.0	

Ash Pond Overflow - (Includes Caustic Sewer)

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS 250
		PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	
7.5	-	98	253.6	1.3	3.4	0	0.0	0	0.0	

ASB inlet

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS 270
		PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	
18.5	11.2	39	250.9	2.5	16.1	0.4	2.6	0	0.0	

-239.9
ASB

ASB Outlet - before Riffler

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS 16
		PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	
18.5	8.3	1.7	10.8	0.47	3.0	0.24	1.5	0	0.0	

Polishing Pond Inlet - ASB outlet after Riffler

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS 14
		PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	
18.5	-	1.7	10.8	0.44	2.8	0	0.0	0	0.0	

Polishing Pond Outlet

Flow Mod*	pH	H2S		MESH		DMS		DMDS		Total TRS 251
		PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	
18.5	8	39	250.9	0	0.0	0	0.0	0	0.0	

Estimated average flows used, obtained from flow / sulfur balance study
Pond Outlet flows 'normalized' to match inlet flowrate for comparison purposes

DECEMBER 4

PULP MILL	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS	
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
	18	8.4	49	31	0.45	0.3	0	0.0	0.32	0.2	3.5	
POWER & RECOVERY	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS	
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
	4.5		35	54.8	11	17.2	1.3	2.0	3.9	6.1	80.1	
CAUST AREA TO ASH POND	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS	
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
	1.6	>11.0	840	467.3	0	0.0	0	0.0	0	0.0	467.3	
#1 PM	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS	
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
	3.2	6.6		0.0		0.0		0.0		0.0	0.0	
#2 PM	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS	
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
	3.5	7.1	0	0.0	0	0.0	0	0.0	0.3	0.4	0.4	
ACC	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS	
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
				0.0		0.0		0.0		0.0	0.0	
ASH POND OVERFLOW TO ASB - by-pass Clarifier	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS	
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
	13.1		140	637.7	0	0.0	0	0.0	0	0.0	637.7	
EC POND DE-SNT	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS	
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
				0.0		0.0		0.0		0.0	0.0	
CSSC HOTWELL	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS	
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
			2.1	0.0		0.0		0.0		0.0	0.0	
KRAFT HOTWELL	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS	
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
			34	0.0	33	0.0	3.8	0.0	69	0.0	0.0	
			TOTAL LBS / HR	1162.8		17.5		2.0		6.7	1189.0	



lbs/hr
H₂S
sewer flow

141.9
CLARIFIER

-259.2
ASB

246.4
POLISH
POND

DECEMBER 4 TREATMENT SYSTEM FLOW

PPM - mg/L

Clarifier Inlet

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS	
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
12	11.4	14	58.4	2.5	10.4	0.6	2.5	0.85	3.5	18	75

Clarifier Outlet

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS	
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
12	-	48	200.3	2.3	9.6	0.46	1.9	0	0.0	51	212

Ash Pond Overflow - (Includes Caustic Sewer)

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS	
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
7.5	-	140	365.1	0	0.0	0	0.0	0	0.0	140	365

ASB Inlet

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS	
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
18.5	11.7	43	276.6	2.7	17.4	0.4	2.6	0	0.0	46.1	297

ASB Outlet - before Riffler

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS	
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
18.5	8.1	1.6	10.3	0.47	3.0	0	0.0	0	0.0	2.07	13

Polishing Pond Inlet - ASB outlet after Riffler

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS	
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
18.5	-	2.7	17.4	0.61	3.9	0	0.0	0	0.0	3.31	21

Polishing Pond Outlet

Flow MGD*	pH	H2S		MESH		DMS		DMDS		Total TRS	
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
18.5	8.1	41	263.7	0	0.0	0	0.0	0	0.0	41	264

Estimated average flows used, obtained from flow / sulfur balance study
Pond Outlet Rows 'normalized' to match inlet flowrate for comparison purposes

DECEMBER 5											
PULP MILL	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
	1.8	8.4	19	11.9	0	0.0	0.3	0.2	0	0.0	12.08
POWER & RECOVERY	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS
	4.5		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
	4.5		2.7	4.2	0	0.0	0	0.0	0	0.0	4.2
CAUST AREA TO ASH POND	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS
	1.6	>11.0	900	500.7	0	0.0	0	0.0	0	0.0	LBS/HR
											500.7
# 1 PM	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS
	3.3	6.4	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
	3.3		0.0		0.0		0.0		0.0		LBS/HR
											0.0
# 2 PM	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS
	3.5	7.1	0.42	0.5	0	0.0	0	0.0	0	0.0	LBS/HR
											0.5
OCC	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
			0.0		0.0		0.0		0.0		LBS/HR
											0.0
ASH POND OVERFLOW TO ASS IN-SEWER	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS
Clarifier	13.1		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
	13.1		100	455.5	0	0.0	0	0.0	0	0.0	LBS/HR
											455.5
EQ POND DECANt	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
			0.0		0.0		0.0		0.0		LBS/HR
											0.0
CSSC HOTWELL	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
			0.0		0.0		0.0		0.0		LBS/HR
											0.0
KRAFT HOTWELL	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
			0.0		0.0		0.0		0.0		LBS/HR
											0.0
			TOTAL LBS / HR	972.8		0.0		0.2		0.0	973.0

DECEMBER 5 TREATMENT SYSTEM FLOW

PPM = mg/L
Clarifier Inlet

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
12	9.9	0.55	2.3	0	0.0	0	0.0	0	0.0	1 2

227.2
CLARIFIER

Clarifier Outlet

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
12	-	55	228.5	0.79	3.3	0	0.0	0	0.0	56 233

314.3
ASB

Ash Pond Overflow - (Includes Caustic Sewer)

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
7.5	-	100	260.8	0	0.0	0	0.0	0	0.0	100 261

ASB Inlet

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
18.5	11.7	57	366.6	0	0.0	0	0.0	0.31	2.0	57 31 369

ASB Outlet - before Riffle

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
18.5	9	10	64.3	0.33	2.1	0	0.0	0	0.0	10.33 56

Polishing Pond Inlet - ASB outlet after Riffle

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
18.5	-	8.1	52.1	0.83	5.3	0	0.0	0	0.0	8.93 57

Polishing Pond Outlet

Flow MGD*	pH	H2S		MESH		DMS		DMDS		Total TRS
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
18.5	7.0	49	315.2	0	0.0	0	0.0	0	0.0	49 315

Estimated average flows used, obtained from flow / sulfur balance study
Pond Outlet flows 'normalized' to match inlet flowrate for comparison purposes

DECEMBER 6											
PULP MILL	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS
			PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	
	1.8	8.4	6.2	3.9	0	0.0	0	0.0	0	0.0	3.88
POWER & RECOVERY	FLOW MGD	pH	H2S	MESH	DMS	DMDS					
	4.5				PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	
			24	37.6	0.95	1.5	0	0.0	6.5	10.2	49.2
CAUST AREA TO ASH POND	FLOW MGD	pH	H2S	MESH	DMS	DMDS					
	1.6	>11.0	570	484.0	0	0.0	0	0.0	0	0.0	LB/HR
											484.0
8:1 PM	FLOW MGD	pH	H2S	MESH	DMS	DMDS					
	3.3	8.4	0.51	0.6	0	0.0	0	0.0	0	0.0	LB/HR
											0.6
8:2 PM	FLOW MGD	pH	H2S	MESH	DMS	DMDS					
	3.5	7.1	0.16	0.2	0.18	0.2	0	0.0	0.28	0.3	LB/HR
											0.8
OCC	FLOW MGD	pH	H2S	MESH	DMS	DMDS					
					PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	TRS
					0.0		0.0		0.0		LB/HR
											0.0
ASH POND OVERFLOW TO ASB - Inferred Clarifier	FLOW MGD	pH	H2S	MESH	DMS	DMDS					
	13.1		41	196.7	0.41	1.9	0	0.0	0	0.0	LB/HR
											188.6
EQ POND DECANT	FLOW MGD	pH	H2S	MESH	DMS	DMDS					
					PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	TRS
					0.0		0.0		0.0		LB/HR
											0.0
CSSC HOTWELL	FLOW MGD	pH	H2S	MESH	DMS	DMDS					
					PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	TRS
					0.0		0.0		0.0		LB/HR
											0.0
KRAFT HOTWELL	FLOW MGD	pH	H2S	MESH	DMS	DMDS					
					PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	TRS
					0.0		0.0		0.0		LB/HR
											0.0
	TOTAL LBS / HR		713.0		3.6		0.0		10.5		727.0

DECEMBER 6 TREATMENT SYSTEM FLOW

PPM = mg/L

Clarifier Inlet

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS
		PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	
12	9.6	6	25.0	0.61	2.5	0.36	1.5	1.6	6.7	9 36

217.0

CLARIFIER

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS
		PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	
12	-	58	242.0	0.48	2.0	0.35	1.5	0.41	1.7	59 247

Ash Pond Overflow - (Includes Caustic Sewer)

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS
		PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	
7.5	-	41	106.9	0.41	1.1	0	0.0	0	0.0	41 108

ASB Inlet

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS
		PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	
18.5	11	58	360.2	0.77	5.0	0	0.0	0	0.0	56.77 368

-319.7 ASB

ASB Outlet - before Riffler

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS
		PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	
18.5	8.7	9.1	58.5	0	0.0	0.25	1.6	0	0.0	8.35 60

Polishing Pond Inlet - ASB outlet after Riffler

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS
		PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	
18.5	-	6.3	40.5	0.28	1.8	0.22	1.4	0	0.0	6.8 44

Polishing Pond Outlet

Flow MGD ^b	pH	H2S		MESH		DMS		DMDS		Total TRS
		PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	
18.5	8	47	302.3	0	0.0	0	0.0	0	0.0	47 302

Estimated average flows used, obtained from flow / sulfur balance study
Pond Outlet flows 'normalized' to match inlet flowrate for comparison purposes

DECEMBER 7

PULP MILL	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
			1.8	8.4	12	7.5	0.22	0.1	0	0.36	0.2
POWER & RECOVERY	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
			4.5	38	59.5	7.8	12.2	1.9	3.0	11	17.2
CAUST AREA TO ASH POND	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
			1.8	>11.0	70	38.9	0	0.0	0	0.0	0.0
8:1 PM	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
			3.3	6.4	0.56	0.6	0	0.0	0	0.0	0.0
8:2 PM	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
			3.5	7.1	0.33	0.4	0	0.0	0	0.0	0.0
OCC	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
					0.0	0.0	0.0	0.0	0.0	0.0	0.0
ASH POND OVERFLOW TO ASB - before Clarifier	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
			13.1	32	145.6	0.43	2.0	0	0.0	0	0.0
EQ POND DECAN	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
					0.0	0.0	0.0	0.0	0.0	0.0	0.0
CSSC HOTWELL	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
					0.0	0.0	0.0	0.0	0.0	0.0	0.0
KRAFT HOTWELL	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
					0.0	0.0	0.0	0.0	0.0	0.0	0.0
TOTAL LBS / HR			252.7	14.3	3.0	17.4	287.4				



DECEMBER 7 TREATMENT SYSTEM FLOW

PPM = mg/L
Clarifier Inlet

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
12	8.1	8.1	33.8	0.73	3.0	0.61	2.5	3.3	13.8	53

120.6
CLARIFIER

Clarifier Outlet

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
12	-	37	154.4	0.64	2.7	0.42	1.8	1.6	6.7	165

Ash Pond Overflow - (Includes Caustic Sewer)

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
7.5	-	32	83.4	0.43	1.1	0	0.0	0	0.0	85

ASB Inlet

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
18.5	9.8	31	199.4	0.55	3.5	0.41	2.6	1.8	11.6	337.6

ASB Outlet - before Riffler

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
18.5	7.8	14	90.1	0.24	1.5	0.27	1.7	0	0.0	145.1

Polishing Pond Outlet

Flow MGD*	pH	H2S		MESH		DMS		DMDS		Total TRS
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
18.5	8	45	205.9	0	0.0	0	0.0	0	0.0	296

Estimated average flows used, obtained from flow / sulfur balance study
Pond Outlet flows 'normalized' to match inlet flowrate for comparison purposes

GLADNEY-WY032407

DECEMBER 8												
PULP MILL	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS	
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
	1.8	8.4	31	19.4	0	0.0	0.2	0.1	0	0.0	19.53	
POWER & RECOVERY	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS	
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
	4.5		57	89.2	3.9	6.1	1.6	2.6	17	28.6	124.7	
CAUST AREA TO ASH POND	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS	
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
	1.6	>11.0	180	105.7	0	0.0	0	0.0	0	0.0	0	LBS/HR
105.7												
#1 PM	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS	
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
	3.3	8.4	0.17	0.2	0	0.0	0	0.0	0	0.0	0	LBS/HR
0.2												
#2 PM	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS	
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
	3.5	7.1	0.37	0.5	0.15	0.2	0	0.0	0	0.0	0	LBS/HR
0.6												
OCC	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS	
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
			0.0		0.0		0.0		0.0		0.0	LBS/HR
0.0												
ASH POND OVERFLOW TO ABB BY-PASS Clarifier	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS	
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
	13.1		44	200.4	0.35	1.6	0	0.0	0	0.0	0	LBS/HR
202.0												
EQ POND DECANT	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS	
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
			0.0		0.0		0.0		0.0		0.0	LBS/HR
0.0												
CSSC HOTWELL	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS	
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
			0.0		0.0		0.0		0.0		0.0	LBS/HR
0.0												
KRAFT HOTWELL	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS	
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
			0.0		0.0		0.0		0.0		0.0	LBS/HR
0.0												
TOTAL LBS / HR			415.3		7.9		2.9		28.6		452.8	

↓

DECEMBER 8

POWER & RECOVERY	FLOW MGD	pH	H2S		MESH		DMG		DMDS		TRS
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
			4.5	57	80.2	3.9	6.1	1.6	2.6	17	28.6

CAUST AREA TO ASH POND	FLOW MMQ	pH	H2S		MESH		DMS		DMDS		TRS
			PPM	LBS/HR	PPM	LEB/HR	PPM	LBS/HR	PPM	LBS/HR	
	1.6	>11.0	190	105.7	0	0	0	0.0	0	0.0	LBS/HR

ASH POND OVERFLOW TO ASS by-pass Clarifier	FLOW MMOD	pH	K2S		MESH		DMG		DMDS		TRS
			PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	PPM	LB/HR	
	13.1		44	200.4	0.35	1.6	0	0.0	0	0.0	202.0

0.0

CCSC HOTWELL	FLOW MOD	pH	TDS		WATER		WATER		WATER		TRS
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
			0.0		0.0		0.0		0.0		0.0

	0.0	0.0	0.0	0.0	0.0
	TOTAL LBS / HR	415.3	7.9	2.9	26.6

452

TOTAL LBS / HR	415.3	7.9	2.9	26.6
----------------	-------	-----	-----	------

H₂S

45.9

DECEMBER 8 TREATMENT SYSTEM FLOW

PPM = mg/L											
Clarifier inlet											
FLOW MMQ	pH	H2S		MESH		DMS		DMDS		Total TRS PPM	
		PPM	LBM/Hr	PPM	LBM/Hr	PPM	LBSAR	PPM	LBSAR		
12	8.7	15	82.6	0.68	2.6	0.41	1.7	3.4	14.2	19	81

Clarifier Outlet		H2S				MESH				DMS		DMOS		Total TRS	
FLOW MGD	pH	PPM	LBMHR	PPM	LBSHR	PPM	LBMHR	PPM	LBSHR	PPM	LBSHR	PPM	LBSHR	PPM	LBSHR
12	9.8	104.5	0.89	2.9	0.25	1.0	1.2	5.0	28	117					

ASB inlet		H2S		MESH		DMS		DMOS		Total TRS	
FLOW MMQ	pH	PPM	LBBMR	PPM	LBBMR	PPM	LBBMR	PPM	LBBMR	PPM	LBBMR
19.5	9.8	33	212.3	0.02	5.9	0.41	2.5	1.3	8.4	36.63	229

-155.7
ASB

200.7
POLISH
2010

Polishing Pond Inlet - ASB outlet after Patches

FLOW MGD	pH	H2S		MESH		DMS		DMDS		TOBI THI	
		PPM	LBS/MR	PPM	LBS/MR	PPM	LBS/MR	PPM	LBS/MR	PPM	LBS/MR
18.5	-	8.8	56.6	0	0.0	0	0.0	0	0.0	8.8	57

Polluting Pond Outlet

Flow MOlD ^a	pH	H2S		MESH		DMS		DMDS		Total TRS	
		PPM	LB/NR	PPM	LB/NR	PPM	LB/NR	PPM	LB/NR	PPM	LB/NR
18.5	8.2	40	257.3	0	0.0	0	0.0	0	0.0	40	257

Estimated average flows used, obtained from flow / sulfur balance study
Pond Outlet flows 'normalized' to match Inlet flows for comparison purposes

DECEMBER 9											
PULP MILL	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS 7.28
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
			1.8	8.4	11	6.9	0	0.0	0.34	0.2	
POWER & RECOVERY	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS 111.6
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
			4.5	48	75.1	3.7	5.8	1.6	2.5	18	
CAUST AREA TO ASH POND	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS 1371.9
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
			1.8	>11.0	1300	723.2	1000	556.3	120	68.8	
6 PM	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS 0.4
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
			3.3	6.4	0.37	0.4	0	0.0	0	0.0	
8.2 PM	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS 0.6
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
			3.5	7.1	0.37	0.5	0.15	0.2	0	0.0	
OCC	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS 0.0
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
					0.0		0.0		0.0		
ASH POND OVERFLOW TO ASB by-pass Clarifier	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS 123.0
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
			13.1		27	123.0	0	0.0	0	0.0	
EQ POND DECANT	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS 0.0
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
					0.0		0.0		0.0		
CSSC HOTWELL	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS 0.0
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
					0.0		0.0		0.0		
KRAFT HOTWELL	FLOW MGD	pH	H2S		MESH		DMS		DMDS		TRS 0.0
			PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
					0.0		0.0		0.0		
TOTAL LBS / HR			929.1		562.3		68.5		53.9		1614.8

lbs / hr
H₂S
generation

50.1
CLARIFIER

DECEMBER 9 TREATMENT SYSTEM FLOW

PPM / mg/L

Clarifier Inlet

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
12	8.7	10	41.7	0.78	3.3	0.52	2.2	4.7	19.6	16

Clarifier Outlet

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
12	-	22	91.8	0.41	1.7	0.36	1.5	1.4	5.8	24

Ash Pond Overflow - (Includes Caustic Sewer)

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
7.5	-	27	70.4	0	0.0	0	0.0	0	0.0	27

ASB Inlet

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
18.5	9.8	23	147.9	0.55	3.5	0	0.0	1.4	0.0	24.95

ASB Outlet - before Riffler

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
18.5	7.8	6.7	43.1	0	0.0	0.2	1.3	0	0.0	6.9

Polishing Pond Inlet - ASB outlet after Riffler

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
18.5	-	7.4	47.6	0	0.0	0.17	1.1	0	0.0	7.57

Polishing Pond Outlet

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS
		PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	
18.5	8.2	41	263.7	0	0.0	0	0.0	0	0.0	41

Estimated average flows used, obtained from flow / sulfur balance study
Pond Outlet flows 'normalized' to match inlet flowrate for comparison purposes

TEST PERIOD AVG (11/30 - 12/9) TREATMENT SYSTEM FLOW

PPM = mg/L

lbs / hr
H₂S
gain/loss

136.2

CLARIFIER

Clarifier Inlet

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS	
		PPM	LB/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
12	9.0	7.1	29.8	0.9	3.7	0.4	1.5	2.6	10.8	11.0	45.8

Clarifier Outlet

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS	
		PPM	LB/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
12	-	39.8	166.1	1.3	5.4	0.3	1.3	0.5	1.9	41.9	174.6

Ash Pond Overflow - (includes Caustic Sewer)

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS	
		PPM	LB/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
7.5	-	67.4	175.8	0.6	1.6	0.0	0.1	0.0	0.0	68.0	177.4

ASB Inlet

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS	
		PPM	LB/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
18.5	10.8	36.2	232.9	1.3	8.5	0.2	1.2	0.6	3.7	38.3	246.2

ASB Outlet - before Riffler

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS	
		PPM	LB/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
18.5	8.2	6.1	39.3	0.2	1.3	0.1	0.9	0.0	0.0	6.5	41.5

-202.6

ASB

Polishing Pond Inlet - ASB outlet after Riffler

FLOW MGD	pH	H2S		MESH		DMS		DMDS		Total TRS	
		PPM	LB/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
18.5	-	4.7	30.2	0.3	1.8	0.1	0.4	0.0	0.0	5.0	32.4

Polishing Pond Outlet

Flow MGD*	pH	H2S		MESH		DMS		DMDS		Total TRS	
		PPM	LB/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR	PPM	LBS/HR
18.5	8.0	33.3	214.1	0.0	0.2	0.0	0.0	0.0	0.0	33.3	214.3

183.9

**POLISH
POND**

Estimated average flows used, obtained from flow / sulfur balance study

Pond Outlet flows 'normalized' to match inlet flowrate for comparison purposes

PINE HILL TRS STUDY - PHASE II

Wastewater Lab Test Results

Weyerhaeuser Analytical & Testing Services
 32901 Weyerhaeuser Way South
 Federal Way, WA 98003

Service Request 01-3322

Report
 Pine Hill TRS Field Study
 Units in mg/L (PPM)

Client ID	Sample		Lab ID	Hydrogen sulfide	Methyl mercaptan	Dimethyl sulfide	Dimethyl disulfide	Date Analyzed
	Date	Time		624-92-0	74-93-1	75-18-3	624-92-0	
#1 PM	11/30/01	9:45	004	0.09	<0.13	<0.17	<0.26	12/06/01
#1 PM	12/01/01	8:40	016	<0.09	<0.13	<0.17	<0.26	12/06/01
#1 PM	12/02/01	9:10	028	<0.09	<0.13	<0.17	<0.26	12/06/01
#1 PM	12/03/01	10:30	049	<0.09	<0.13	<0.17	<0.26	12/13/01
#1 PM	12/04/01	9:15	061	<0.09	<0.13	<0.17	<0.26	12/13/01
#1 PM	12/05/01	9:00	073	<0.09	<0.13	<0.17	<0.26	12/13/01
#1 PM	12/06/01	11:00	094	0.51	<0.13	<0.17	<0.26	12/18/01
#1 PM	12/07/01	10:00	106	0.56	<0.14	<0.18	<0.27	12/19/01
#1 PM	12/08/01	8:00	122	0.17	<0.13	<0.17	<0.26	12/19/01
#1 PM	12/09/01	8:00	134	0.37	<0.13	<0.17	<0.26	12/19/01
#2 PM	11/30/01	9:45	005	0.13	0.14	<0.17	0.34	12/06/01
#2 PM	12/01/01	8:40	017	<0.09	<0.13	<0.17	0.47	12/06/01
#2 PM	12/02/01	9:10	029	0.13	<0.13	<0.17	0.48	12/06/01
#2 PM	12/03/01	10:30	050	<0.09	0.14	<0.17	<0.26	12/13/01
#2 PM	12/04/01	9:15	062	<0.09	<0.13	<0.17	0.30	12/13/01
#2 PM	12/05/01	9:00	074	0.42	<0.13	<0.17	<0.26	12/13/01
#2 PM	12/06/01	11:00	095	0.16	0.18	<0.17	0.28	12/19/01
#2 PM	12/07/01	10:00	107	0.33	<0.13	<0.17	<0.26	12/19/01
#2 PM	12/08/01	8:00	123	0.37	0.15	<0.17	<0.26	12/19/01
#2 PM	12/09/01	8:00	135	0.37	0.15	<0.17	<0.26	12/19/01
APO	11/30/01	9:45	006	29	0.95	<0.17	<0.26	12/07/01
APO	12/01/01	8:40	018	83	1.5	0.23	<0.26	12/07/01
APO	12/02/01	9:10	030	80	1.2	<0.17	<0.26	12/07/01
APO	12/03/01	10:30	051	98	1.3	<0.19	<0.26	12/17/01
APO	12/04/01	9:15	063	140	<0.13	<0.17	<0.26	12/17/01
APO	12/05/01	9:00	075	100	<0.13	<0.17	<0.26	12/17/01
APO	12/06/01	11:00	096	41	0.41	<0.17	<0.26	01/02/02
APO	12/07/01	10:00	108	32	0.43	<0.17	<0.26	01/02/02
APO	12/08/01	8:00	124	44	0.35	<0.17	<0.26	12/26/01
APO	12/09/01	8:00	136	27	<0.13	<0.17	<0.26	12/26/01
ASB In	11/30/01	9:45	009	15	1.4	0.20	0.31	12/10/01
ASB In	12/01/01	8:40	021	32	2.0	<0.17	0.32	12/10/01
ASB In	12/02/01	9:10	033	33	1.8	<0.17	0.37	12/10/01
ASB In	12/03/01	10:30	054	39	2.5	0.40	<0.26	12/14/01
ASB In	12/04/01	9:15	066	43	2.7	0.40	<0.26	12/14/01
ASB In	12/05/01	9:00	078	57	<0.14	<0.18	0.34	12/17/01
ASB In	12/06/01	11:00	099	56	0.77	<0.17	<0.26	12/20/01
ASB In	12/07/01	10:00	111	31	0.55	0.41	1.8	12/20/01
ASB In	12/08/01	8:00	127	33	0.92	0.41	1.3	12/20/01
ASB In	12/09/01	8:00	139	23	0.55	<0.17	1.4	12/27/01

J - Indicates the compound was detected below the calibration range. The reported value is an estimate.

Approved: Randy Eatherton Date: 01/07/02
 Telephone: (253)924-6321

Weyerhaeuser Analytical & Testing Services
32901 Weyerhaeuser Way South
Federal Way, WA 98003

Service Request 01-3322

Preliminary Report
Pine Hill TRS Field Study
Units in mg/L (PPM)

Client ID	Sample		Lab ID	Hydrogen sulfide	Methyl mercaptan	Dimethyl sulfide	Dimethyl disulfide	Date Analyzed
	Date	Time		624-92-0	74-93-1	75-18-3	624-92-0	
ASB Out	11/30/01	9:45	010	0.81	<0.13	<0.17	<0.26	12/11/01
ASB Out	12/01/01	8:40	022	0.62	<0.13	<0.17	<0.26	12/11/01
ASB Out	12/02/01	9:10	034	0.60	0.18	0.20	<0.26	12/11/01
ASB Out	12/03/01	10:30	055	1.7	0.47	0.24	<0.26	12/14/01
ASB Out	12/04/01	9:15	067	1.6	0.47	<0.17	<0.26	12/14/01
ASB Out	12/05/01	9:00	079	10	0.33	<0.17	<0.26	12/17/01
ASB Out	12/06/01	11:00	100	9.1	<0.13	0.25	<0.26	12/20/01
ASB Out	12/07/01	10:00	112	14	0.24	0.27	<0.26	12/20/01
ASB Out	12/08/01	8:00	128	16	0.31	0.29	<0.26	12/20/01
ASB Out	12/09/01	8:00	140	6.7	<0.13	0.20	<0.26	12/27/01
Clar In	11/30/01	9:45	007	3.5	0.87	0.24	1.3	12/06/01
Clar In	12/01/01	8:40	019	4.0	0.66	0.24	3.3	12/06/01
Clar In	12/02/01	9:10	031	7.7	1.1	0.33	4.7	12/06/01
Clar In	12/03/01	10:30	052	2.6	0.88	0.31	2.8	12/13/01
Clar In	12/04/01	9:15	064	14	2.5	0.60	0.85	12/14/01
Clar In	12/05/01	9:00	076	<0.09	<0.13	<0.17	<0.26	12/14/01
Clar In	12/05/01	9:00	076	0.55	<0.13	<0.17	<0.26	12/14/01
Clar In	12/06/01	11:00	097	6.0	0.61	0.36	1.6	12/21/01
Clar In	12/07/01	10:00	109	8.1	0.73	0.61	3.3	12/21/01
Clar In	12/08/01	8:00	125	15	0.68	0.41	3.4	01/02/02
Clar In	12/09/01	8:00	137	10	0.78	0.52	4.7	12/26/01
Clar Out	11/30/01	9:45	008	15	0.93	0.23	<0.26	12/06/01
Clar Out	12/01/01	8:40	020	34	2.0	0.28	<0.26	12/07/01
Clar Out	12/01/01	8:40	020Dup	33	1.1	<0.17	<0.26	01/02/02
Clar Out	12/02/01	9:10	032	54	2.5	0.30	<0.26	12/07/01
Clar Out	12/03/01	10:30	053	49	2.2	0.38	<0.26	12/14/01
Clar Out	12/04/01	9:15	065	48	2.3	0.46	<0.26	12/14/01
Clar Out	12/05/01	9:00	077	55	0.79	<0.17	<0.26	12/14/01
Clar Out	12/06/01	11:00	098	58	0.48	0.35	0.41	12/21/01
Clar Out	12/07/01	10:00	110	37	0.64	0.42	1.6	12/21/01
Clar Out	12/08/01	8:00	126	26	0.69	0.25	1.2	12/26/01
Clar Out	12/09/01	8:00	138	22	0.41	0.36	1.4	12/27/01
Lime Kiln	11/30/01	9:45	003	1000	<1.1	<1.4	<2.1	12/05/01
Lime Kiln	12/01/01	8:40	015	207	<5.3	<6.8	<10	12/05/01
Lime Kiln	12/02/01	9:10	027	2300	<5.3	<6.8	<10	12/05/01
Lime Kiln	12/03/01	10:30	048	1500	<5.3	<6.8	<10	12/28/01
Lime Kiln	12/04/01	9:15	060	840	<5.3	<6.8	<10	12/28/01
Lime Kiln	12/05/01	9:00	072	900	<5.3	<6.8	<10	12/28/01
Lime Kiln	12/06/01	11:00	093	870	<5.3	<6.8	<10	12/28/01
Lime Kiln	12/07/01	10:00	105	70	<5.3	<6.8	<10	12/28/01
Lime Kiln	12/08/01	8:00	121	190	<5.3	<6.8	<10	12/28/01
Lime Kiln	12/09/01	8:00	133	1300	1000	120	46	12/28/01

J - Indicates the compound was detected below the calibration range. The reported value is an estimate.

Approved: Randy Eatherton Date: 01/07/02
Telephone: (253)924-6321

Weyerhaeuser Analytical & Testing Services
 32901 Weyerhaeuser Way South
 Federal Way, WA 98003

Service Request 01-3322

Preliminary Report
 Pine Hill TRS Field Study
 Units in mg/L (PPM)

Client ID	Sample		Lab ID	Hydrogen sulfide	Methyl mercaptan	Dimethyl sulfide	Dimethyl disulfide	Date Analyzed
	Date	Time		624-92-0	74-93-1	75-18-3	624-92-0	
P. Pond Out	11/30/01	9:45	012	7.8	0.19	<0.17	<0.26	12/11/01
P. Pond Out	12/01/01	8:40	024	10	0.18	<0.17	<0.26	12/11/01
P. Pond Out	12/02/01	9:10	036	12	0.18	<0.17	<0.26	12/11/01
P. Pond Out	12/03/01	10:30	057	39	<0.13	<0.17	<0.26	12/17/01
P. Pond Out	12/04/01	9:15	069	41	<0.13	<0.17	<0.26	12/17/01
P. Pond Out	12/05/01	9:00	081	49	<0.13	<0.17	<0.26	12/17/01
P. Pond Out	12/06/01	11:00	102	47	<0.13	<0.17	<0.26	12/21/01
P. Pond Out	12/07/01	10:00	114	46	<0.13	<0.17	<0.26	12/21/01
P. Pond Out	12/08/01	8:00	130	40	<0.13	<0.17	<0.26	12/26/01
P. Pond Out	12/09/01	8:00	142	41	<0.13	<0.17	<0.26	12/27/01
Power/Rec	11/30/01	9:45	002	17	6.3	0.77	4.6	12/04/01
Power/Rec	12/01/01	8:40	014	17	4.4	1.1	7.0	12/05/01
Power/Rec	12/02/01	9:10	026	15	2.5	0.88	5.2	12/05/01
Power/Rec	12/03/01	10:30	047	16	6.2	<0.85	6.3	12/27/01
Power/Rec	12/04/01	9:15	059	35	11	1.3	3.9	12/27/01
Power/Rec	12/05/01	9:00	071	2.7	<0.15	<0.19	<0.29	12/27/01
Power/Rec	12/06/01	11:00	092	24	0.95	<0.85	6.5	12/27/01
Power/Rec	12/07/01	10:00	104	38	7.8	1.9	11	12/27/01
Power/Rec	12/08/01	8:00	120	57	3.9	1.8	17	12/27/01
Power/Rec	12/09/01	8:00	132	48	3.7	1.6	18	12/27/01
PPI #1	12/03/01	11:50	037	12	0.42	<0.17	<0.26	12/12/01
PPI #1	12/06/01	2:15	082	38	0.51	0.54	<0.26	12/18/01
PPI #2	12/03/01	11:40	038	10	0.37	<0.17	<0.26	12/12/01
PPI #2	12/06/01	2:03	083	41	0.55	0.25	0.30	12/18/01
PPI #3	12/03/01	11:30	039	9.4	0.37	0.19	<0.26	12/12/01
PPI #3	12/06/01	1:50	084	37	0.51	0.32	0.45	12/18/01
PPI #4	12/03/01	11:15	040	16	0.31	<0.17	<0.26	12/12/01
PPI #4	12/06/01	1:25	085	38	<0.13	<0.17	<0.26	12/18/01
PPI #4	12/07/01	14:27	115	35	<0.13	<0.17	<0.26	12/19/01
PPI #5	12/03/01	11:05	041	12	0.31	<0.17	<0.26	12/12/01
PPI #5	12/06/01	1:12	086	45	<0.13	<0.17	<0.26	12/18/01
PPI #6	12/03/01	10:50	042	17	0.32	<0.17	<0.26	12/12/01
PPI #6	12/06/01	1:00	087	48	<0.13	<0.17	<0.26	12/18/01
PPI #7	12/03/01	10:30	043	19	0.22	<0.17	<0.26	12/12/01
PPI #7	12/06/01	12:05	088	43	<0.14	<0.18	<0.27	12/18/01
PPI #8	12/03/01	10:20	044	13	0.20	<0.17	<0.26	12/12/01
PPI #8	12/06/01	11:50	089	45	<0.13	<0.17	<0.26	12/18/01
PPI #8	12/07/01	13:45	116	41	<0.13	<0.17	<0.26	12/19/01
PPI #9	12/03/01	10:05	045	20	0.21	<0.17	<0.26	12/12/01
PPI #9	12/06/01	11:25	090	45	<0.13	<0.17	<0.26	12/18/01
PPI #9	12/07/01	13:30	117	42	<0.13	<0.17	<0.26	12/19/01

J - Indicates the compound was detected below the calibration range. The reported value is an estimate.

Approved: Randy Eatherton Date: 01/07/02
 Telephone: (253)924-6321

Weyerhaeuser Analytical & Testing Services
 32901 Weyerhaeuser Way South
 Federal Way, WA 98003

Service Request 01-3322

Preliminary Report
 Pine Hill TRS Field Study
 Units in mg/L (PPM)

Client ID	Sample		Lab ID	Hydrogen sulfide	Methyl mercaptan	Dimethyl sulfide	Dimethyl disulfide	Date Analyzed
	Date	Time		624-92-0	74-93-1	75-18-3	624-92-0	
Pulp Mill	11/30/01	9:45	001	1.9	0.18	0.19	<0.26	12/04/01
Pulp Mill	12/01/01	8:40	013	38	0.53	0.18	<0.26	12/05/01
Pulp Mill	12/02/01	9:10	025	45	0.57	0.24	<0.26	12/13/01
Pulp Mill	12/03/01	10:30	046	2.6	<0.13	<0.17	<0.26	12/13/01
Pulp Mill	12/04/01	9:15	058	4.9	0.45	<0.17	0.32	12/13/01
Pulp Mill	12/05/01	9:00	070	19	<0.13	0.30	<0.26	12/13/01
Pulp Mill	12/06/01	11:00	091	6.2	<0.13	<0.17	<0.26	12/20/01
Pulp Mill	12/07/01	10:00	103	11	<0.13	<0.17	0.30	12/20/01
Pulp Mill	12/07/01	10:00	103DUp	12	0.22	<0.17	0.36	01/02/02
Pulp Mill	12/08/01	8:00	119	31	<0.14	0.20	<0.26	12/20/01
Pulp Mill	12/09/01	8:00	131	11	<0.14	0.34	0.29	12/20/01
Riff Out	11/30/01	9:45	011	0.8	0.17	<0.17	<0.26	12/11/01
Riff Out	12/01/01	8:40	023	0.45	0.14	<0.17	<0.26	12/11/01
Riff Out	12/02/01	9:10	035	0.71	<0.13	<0.17	<0.26	12/11/01
Riff Out	12/03/01	10:30	056	1.7	0.44	<0.17	<0.26	12/14/01
Riff Out	12/04/01	9:15	068	2.7	0.61	<0.17	<0.26	12/14/01
Riff Out	12/05/01	9:00	080	8.1	0.83	<0.17	<0.26	12/17/01
Riff Out	12/06/01	11:00	101	6.3	0.28	0.22	<0.26	12/21/01
Riff Out	12/07/01	10:00	113	10	0.29	0.21	<0.26	12/21/01
Riff Out	12/08/01	8:00	129	8.8	<0.13	<0.17	<0.26	12/26/01
Riff Out	12/09/01	8:00	141	7.4	<0.13	0.17	<0.26	12/27/01
Stripper Feed Tank	12/07/01	13:00	118	3.4	<1.06	<1.36	<2.06	12/28/01
Method Blank #1				<0.09	<0.13	<0.17	<0.26	12/03/01
Method Blank #2				<0.09	<0.13	<0.17	<0.26	12/05/01
Method Blank #3				<0.09	<0.13	<0.17	<0.26	12/06/01
Method Blank #4				<0.09	<0.13	<0.17	<0.26	12/07/01
Method Blank #5				<0.09	<0.13	<0.17	<0.26	12/10/01
Method Blank #6				<0.09	<0.13	<0.17	<0.26	12/11/01
Method Blank #7				<0.09	<0.13	<0.17	<0.26	12/12/01
Method Blank #8				<0.09	<0.13	<0.17	<0.26	12/13/01
Method Blank #9				<0.09	<0.13	<0.17	<0.26	12/14/01
Method Blank #10				<0.09	<0.13	<0.17	<0.26	12/17/01
Method Blank #11				<0.09	<0.13	<0.17	<0.26	12/18/01
Method Blank #12				<0.09	<0.13	<0.17	<0.26	12/19/01
Method Blank #13				<0.09	<0.13	<0.17	<0.26	12/20/01
Method Blank #14				<0.09	<0.13	<0.17	<0.26	12/21/01
Method Blank #15				<0.09	<0.13	<0.17	<0.26	12/22/01
Method Blank #16				<0.09	<0.13	<0.17	<0.26	12/26/01
Method Blank #17				<0.09	<0.13	<0.17	<0.26	12/27/01
Method Blank #18				<0.09	<0.13	<0.17	<0.26	12/28/01
Method Blank #19								01/02/02

J - Indicates the compound was detected below the calibration range. The reported value is an estimate.

Approved: Randy Eatherton Date: 01/07/02
 Telephone: (253)924-6321

Weyerhaeuser Analytical & Testing Services
32901 Weyerhaeuser Way South
Federal Way, WA 98003

Service Request 01-3322

Preliminary Report
Pine Hill TRS Field Study
Units in % Recovery

Client ID	Sample Date	Lab Time	Hydrogen sulfide ID	Methyl mercaptan 624-92-0	Dimethyl sulfide 74-93-1	Dimethyl disulfide 75-18-3	Date Analyzed 624-92-0
Lab Control Spike #1				137%	NA	NA	NA
Lab Control Spike #2				80%	NA	NA	NA
Lab Control Spike #3				99%	NA	NA	NA
Lab Control Spike #4				78%	NA	NA	NA
Lab Control Spike #5				103%	NA	NA	NA
Lab Control Spike #6				64%	NA	NA	NA
Lab Control Spike #7				112%	NA	NA	NA
Lab Control Spike #8				105%	NA	NA	NA
Lab Control Spike #9				107%	NA	NA	NA
Lab Control Spike #10				129%	NA	NA	NA
Lab Control Spike #11				126%	NA	NA	NA
Lab Control Spike #12				120%	NA	NA	NA
Lab Control Spike #13				110%	NA	NA	NA
Lab Control Spike #14				127%	NA	NA	NA
Lab Control Spike #15				127%	NA	NA	NA
Lab Control Spike #16				100%	NA	NA	NA
Lab Control Spike #17				129%	NA	NA	NA
Lab Control Spike #18				118%	NA	NA	NA
Lab Control Spike #19				88%	NA	NA	NA

J - Indicates the compound was detected below the calibration range. The reported value is an estimate.

Approved: Randy Eatherton
Telephone: (253)924-6321

Date: 01/07/02