UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 8
1595 Wynkoop Street
Denver, CO 80202-1129
Phone 800-227-8917
http://www.epa.gov/region08

October 19, 2015

Ref: 8P-AR

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

Gene Grindle, Plant Manager
Bonanza Plant
Deseret Power
12500 East 25500 South
Vernal, UT 84078

Re: Administrative Permit Amendment to Part 71 Operating Permit, Title V Permit V-UO-000004-00.00, Deseret Power, Bonanza Power Plant

Dear Mr. Grindle:

On June 3, 2015, Deseret Power requested an Administrative Permit Amendment to its 40 CFR Part 71 Operating Permit, Title V Permit V-UO-000004-00.00, issued on December 5, 2014. Six amendments were requested. We have reviewed the request and find that the requested amendments constitute corrections to inadvertent errors in the permit and therefore can be classified as Administrative Permit Amendments under permit condition IV.H and 40 CFR 71.7(d). In brief, we have made the following corrections to the permit:

Cover pages 1, 3 and 8: Corrected the permittee name from Deseret Power Electric Cooperative to Deseret Generation & Transmission Co-operative.

Condition II.A.2.(e)(ix): Corrected the language from 40 CFR 60.49Da(i), to add provisions of §60.49Da(i)(5) which had been inadvertently omitted and which allow a span value to be used for the sulfur dioxide continuous emission monitor (SO_2 CEMS) that complies with 40 CFR Part 75, Appendix A, section 2.1.1, as an alternative to the span value specified in §60.49Da(i)(5).

Condition II.A.3.d.(ii): Corrected the language from 40 CFR 63.10031(f) to reflect the current language of the regulation, which was revised by EPA Headquarters after the Title V permit was issued by the Region in December of 2014.

Condition II.A.7.(b): Corrected the cross-references to conditions II.A.5.(b) and (c), to instead cross-reference conditions II.A.6.(b) and (c).

Page 2 of Attachment 1 (Process Description): Corrected the language about characteristics of the limestone used in the SO_2 scrubber.

Printed on Recycled Paper

Page 3 of Attachment 1 (Process Description): Corrected language about the height of the main boiler stack.

Enclosed please find the re-issued permit as amended. The permit is being re-issued as permit number V-UO-000004-00.01. Please note that this re-issuance will not change the effective date of the original permit, which was January 7, 2015, nor the expiration date of January 7, 2020. If you have any questions, please contact Mike Owens of my staff at (303) 312-6440.

Sincerely,

Carl Daly, Director
Air Program

Enclosure

cc: David Crabtree, Deseret Power (w/enclosure)
Eric Olsen, Deseret Power (w/enclosure)
Bruce Pargeets, Ute Indian Tribe