

May 26, 2005

Mr. Bob Williams  
Alternate Authorized Account Representative  
Blue Ridge Paper Products, Inc.  
P.O. Box 4000  
Canton, North Carolina 28716

Dear Mr. Williams:

This is in response to your May 11, 2005 letter requesting EPA approval of your use of the rectangular duct wall effects conditional test method (CTM-041). You have provided all of the required information to begin using the correction factor on January 1, 2005 on the power plant and associated units and stacks/ducts in the attached table, provided that you perform CTM-041 in calendar year 2004 or 2005.

Your wall effects adjusted data will be considered valid quality-assured data, retroactive to the start date and time of the rectangular duct wall effects adjustment, provided that: (1) all other Part 75 requirements are met; and (2) you do not adjust the rectangular duct cross-sectional area to account for any build-up of particulate matter or other material in the bottom of the duct when calculating stack gas volumetric flow.

We recommend that you follow the updated EDR reporting instructions dated March 1, 2005 available at the following internet address: <http://www.epa.gov/airmarkets/monitoring> and scroll to "Rectangular Duct Wall Effects" under Monitoring Guidance for All Programs, and that you run your EDR reports through the MDC software tool available at the same web site prior to submitting the EDRs to EPA. A spreadsheet to calculate rectangular duct wall effects is also available at the same web site. If you have any questions or concerns about this matter, please contact John Schakenbach of my staff at 202-343-9158 or at ([schakenbach.john@epa.gov](mailto:schakenbach.john@epa.gov)).

Sincerely,

/s/

Reynaldo Forte, Chief  
Emissions Monitoring Branch

Attachment

cc: Mani Oliva, EPA, CAMD, EMB  
Kevin Tran, EPA, CAMD, MOB  
David McNeal, EPA Region IV  
Dennis Igboko, NC Department of Environment

Attachment

<b>Plant</b>	<b>Unit/Stack ID</b>	<b>ORISPL</b>	<b>Start Date/Time</b>
BRPP	BB	050244	1/1/2005 / 0000
	PG	050244	1/1/2005 / 0000
	RC	050244	1/1/2005 / 0000