Mr. Michael W. Bridgers, P.E. Alternate Authorized Account Representative International Paper Eastover Mill 4001 McCords Ferry Road Eastover, South Carolina 29044

Dear Mr. Bridgers:

This is in response to your March 14, 2007 letter requesting EPA approval of your use of the rectangular duct wall effects conditional test method (CTM-041). You have provided all of the required information to begin using the correction factor on May 1, 2007 (start of the ozone season) on the power plant and associated unit and stack/duct in the attached table, provided that you perform CTM-041 in calendar year 2007.

Your wall effects adjusted data will be considered valid quality-assured data, retroactive to the start date and time of the rectangular duct wall effects adjustment, provided that: (1) all other Part 75 requirements are met; and (2) you do not adjust the rectangular duct cross-sectional area to account for any build-up of particulate matter or other material in the bottom of the duct when calculating stack gas volumetric flow.

We recommend that you follow the EDR reporting instructions dated November 1, 2005 available at the following internet address: http://www.epa.gov/airmarkets/emissions/other.html and click on "Rectangular Duct Wall Effects", and that you run your EDR reports through the MDC software tool available at the same web site prior to submitting the EDRs to EPA. A spreadsheet to calculate rectangular duct wall effects is also available at the same web site. If you have any questions or concerns about this matter, please contact John Schakenbach of my staff at 202-343-9158 or at (schakenbach.john@epa.gov).

Sincerely,

 $/_{\rm S}/$

Reynaldo Forte, Chief Emissions Monitoring Branch

Attachment

cc: John Schakenbach, EPA, CAMD, EMB
Mani Oliva, EPA, CAMD, EMB
Kevin Tran, EPA, CAMD, MOB
David McNeal, EPA Region IV
Roderick A. Moore, SCDHEC, Bureau of Air Quality

Attachment

Plant	Unit/Stack ID	ORISPL	Start Date/Time
I P Eastover Mill	001 / 001	52151	5/1/2007 / 0000