

APPENDIX D - VIOLATIONS BY COUNTY

CONTAMINANT		PUBLIC WATER SYSTEM				NUMBER OF MCL VIOLATIONS	NUMBER OF MONITORING VIOLATIONS
NAME	MCL (mg/L)	NUMBER	NAME	POPULATION AFFECTED			
ALPINE							
Haa5 - Haloacetic Acids (Five)	0.06	0210001	LAKE ALPINE WATER COMPANY	2650	1		
SWTR - treatment technique (41)	TT	0210001	LAKE ALPINE WATER COMPANY	2650	1		
COUNTS/TOTALS			1	2650	2	0	
AMADOR							
Total Coliform - Monitoring, Routine Minor	Absence	0300006	CAMP RITCHIE	800		1	
Total Coliform - Monitoring, Routine Major	Absence	0300011	MELODY OAKS TRAILER PARK	40		1	
Total Coliform - Monitoring, Routine Minor	Absence	0300022	CAMP WINTON	1000		1	
SWTR-unfiltered sys-monitoring (31)	MR	0300037	LAKE AMADOR RECREATION AREA	2000		2	
SWTR-filtered sys-monitoring (36)	MR	0300037	LAKE AMADOR RECREATION AREA	2000		2	
Total Coliform - Monitoring, Routine Major	Absence	0300052	COOK S STATION	1000		1	
Total Coliform - Acute MCL	Absence	0300053	RANCHO DEL ORO MHP	34	2		
Total Coliform - Monitoring, Repeat Major	Absence	0300065	BEAR RIVER SUMMER HOME TRACT	90		1	
Total Coliform - Non acute MCL	Absence	0300448	MALLO GOLD MINE PLAZA	25	1		
Total Coliform - Monitoring, Routine Major	Absence	0300518	ORO MADRE MOOSE LODGE 1761	300		1	
Lead and Copper Rule	TT	0310001	CITY OF JACKSON	5223	1		
Total Coliform - Non acute MCL	Absence	0310002	AWA, IONE	4940	1		
COUNTS/TOTALS			11	15452	5	10	

BUTTE						
Nitrate (As No3)	45	0400007	BUTTE CRK EST MUTUAL WATER CO	399		1
Total Coliform - Monitoring, Routine Major	Absence	0400013	MERRY MOUNTAIN MUTUAL	100		1
Nitrate (As No3)	45	0400018	BRUSH CREEK RANGER STATION	30		1
Total Coliform - Monitoring, Routine Major	Absence	0400018	BRUSH CREEK RANGER STATION	30		2
Nitrate (As No3)	45	0400023	GOLDEN OAKS MOBILE ESTATES	86		1
Haa5 - Haloacetic Acids (Five)	0.06	0400027	FOOTHILL MOBILE HOME PARK	180		2
Trihalomethanes (TTHM) - Total	0.08	0400027	FOOTHILL MOBILE HOME PARK	180		2
Total Coliform - Non acute MCL	Absence	0400028	BIG BEND MOBILEHOME PARK	85		2
Arsenic	0.01	0400030	GOLDEN FEATHER MHP	275		1
Nitrite (As N)	1	0400030	GOLDEN FEATHER MHP	275		1
Nitrate (As No3)	45	0400036	MOUNTAIN VIEW MOBILE ACRES MHP LLC	230		1
Nitrate (As No3)	45	0400040	ALMOND GROVE MOBILE PARK	250		1
Total Coliform - Monitoring, Routine Major	Absence	0400040	ALMOND GROVE MOBILE PARK	250		1
Public Notice Rule violation for an NPDWR violat	n/a	0400041	FOREST RANCH MOBILE PARK	25		1
Perchlorate	0.006	0400045	COHASSET MOBILE ESTATES	20		1
Arsenic	0.01	0400048	SCOTTYS TRAILER PARK	25		1
Nitrate (As No3)	45	0400048	SCOTTYS TRAILER PARK	25		1
Nitrite (As N)	1	0400048	SCOTTYS TRAILER PARK	25		1
Perchlorate	0.006	0400048	SCOTTYS TRAILER PARK	25		1
Radium 226 + Radium 228, Combined	5 pCi/L	0400048	SCOTTYS TRAILER PARK	25		1
Total Coliform - Monitoring, Routine Major	Absence	0400048	SCOTTYS TRAILER PARK	25		5
Total Coliform - Monitoring, Routine Major	Absence	0400066	DURHAM UNIFIED SCHOOL DISTRICT	1400		1
Nitrate (As No3)	45	0400067	FEATHER RIVER SCHOOL	50		1
Nitrite (As N)	1	0400068	BERRY CREEK SCHOOL	180		2
Total Coliform - Monitoring, Routine Major	Absence	0400068	BERRY CREEK SCHOOL	180		1
Nitrate (As No3)	45	0400094	OUTPOST, THE	200		1
Nitrite (As N)	1	0400094	OUTPOST, THE	200		1
Total Coliform - Monitoring, Routine Major	Absence	0400094	OUTPOST, THE	200		2
Total Coliform - Monitoring, Routine Major	Absence	0400107	FEATHER FALLS SCHOOL	50		1
Nitrate (As No3)	45	0400125	GENETIC RESOURCE CENTER	29		1
Perchlorate	0.006	0400133	LUNDBERG RICE PRODUCTS	100		1
Total Coliform - Monitoring, Routine Major	Absence	0400141	LLANO SECO RANCHO	40		1
Nitrate (As No3)	45	0400142	BOY SCOUTS OF AMER-CAMP LASSEN	150		1

BUTTE

Total Coliform - Monitoring, Routine Major	Absence	0400142	BOY SCOUTS OF AMER-CAMP LASSEN	150		1
Nitrate (As No3)	45	0400143	BUTTE MEADOWS CAMP	30		1
Nitrite (As N)	1	0400151	KEEFER CREEK ESTATES MUTUAL	95		2
Total Coliform - Monitoring, Routine Major	Absence	0400151	KEEFER CREEK ESTATES MUTUAL	95		1
Total Coliform - Monitoring, Routine Major	Absence	0400155	BIGGERS GLEN MUTUAL WATER COMP	10		1
Perchlorate	0.006	0400158	FRANCIS PROPERTY MANAGEMENT	51		1
Total Coliform - Monitoring, Routine Major	Absence	0400162	PLEASANT VALLEY BAPTIST CHURCH	500		1
Nitrate (As No3)	45	0400175	NORFIELD INDUSTRIES	62		1
Total Coliform - Monitoring, Routine Major	Absence	0400175	NORFIELD INDUSTRIES	62		2
1,1,1-Trichloroethane	0.2	0409177	G & J PROPERTIES	30		1
1,1,2,2-Tetrachloroethane	0.001	0409177	G & J PROPERTIES	30		1
1,1,2-Trichloro-1,2,2-Trifluoroethane	1.2	0409177	G & J PROPERTIES	30		1
1,1,2-Trichloroethane	0.005	0409177	G & J PROPERTIES	30		1
1,1-Dichloroethane	0.005	0409177	G & J PROPERTIES	30		1
1,1-Dichloroethylene	0.005	0409177	G & J PROPERTIES	30		1
1,2,4-Trichlorobenzene	0.005	0409177	G & J PROPERTIES	30		1
1,2-Dichlorobenzene	0.6	0409177	G & J PROPERTIES	30		1
1,2-Dichloroethane	0.0005	0409177	G & J PROPERTIES	30		1
1,2-Dichloropropane	0.005	0409177	G & J PROPERTIES	30		1
1,3-Dichloropropane	0.0005	0409177	G & J PROPERTIES	30		1
1,4-Dichlorobenzene	0.005	0409177	G & J PROPERTIES	30		1
Benzene	0.001	0409177	G & J PROPERTIES	30		1
Carbon Tetrachloride	0.0005	0409177	G & J PROPERTIES	30		1
Cis-1,2-Dichloroethylene	0.006	0409177	G & J PROPERTIES	30		1
Dichloromethane	0.005	0409177	G & J PROPERTIES	30		1
Ethylbenzene	0.3	0409177	G & J PROPERTIES	30		1
Methyl-Tert-Butyl-Ether (MTBE)	0.013	0409177	G & J PROPERTIES	30		1
Monochlorobenzene	0.07	0409177	G & J PROPERTIES	30		1
Styrene	0.1	0409177	G & J PROPERTIES	30		1
Tetrachloroethylene	0.005	0409177	G & J PROPERTIES	30		1
Toluene	0.15	0409177	G & J PROPERTIES	30		1
Trans-1,2-Dichloroethylene	0.01	0409177	G & J PROPERTIES	30		1
Trichloroethylene	0.005	0409177	G & J PROPERTIES	30		1

BUTTE

Trichlorofluoromethane	0.15	0409177	G & J PROPERTIES	30		1	
Vinyl Chloride	0.0005	0409177	G & J PROPERTIES	30		1	
Xylenes (Total)	1.75	0409177	G & J PROPERTIES	30		1	
Nitrite (As N)	1	0409178	SKYWAY HOUSE	25		1	
Total Coliform - Monitoring, Routine Major	Absence	0409179	L. C. HUNTING CLUB	60		1	
Perchlorate	0.006	0409183	SIERRA MOON	0		2	
Radium 226 + Radium 228, Combined	5 pCi/L	0409183	SIERRA MOON	0		1	
Total Coliform - Non acute MCL	Absence	0410007	PARADISE IRRIGATION DISTRICT	26299	1		
COUNTS/TOTALS				32	31066	1	86

CALAVERAS							
Nitrite (As N)	1	0500006	GLORY HOLE CENTER	1		1	
Total Coliform - Monitoring, Routine Minor	Absence	0500012	BLUNDER INN	60		1	
Total Coliform - Monitoring, Repeat Minor	Absence	0500012	BLUNDER INN	60		1	
Nitrate (As No3)	45	0500016	COTTAGE SPRINGS WATER CO.	51		1	
Total Coliform - Monitoring, Routine Major	Absence	0500016	COTTAGE SPRINGS WATER CO.	51		2	
Total Coliform - Non acute MCL	Absence	0500019	MINERAL MOUNTAIN MUTUAL WATER	125	1		
Total Coliform - Monitoring, Routine Major	Absence	0500022	CAMP MENZIES	150		1	
Total Coliform - Monitoring, Routine Major	Absence	0500023	TAMARACK CABIN OWNERS ASSN	50		1	
Total Coliform - Monitoring, Routine Major	Absence	0500024	MOUNTAIN RANCH KITCHEN, THE	228		2	
Total Coliform - Monitoring, Routine Major	Absence	0500043	STANISLAUS RIVER CAMPGROUND	100		2	
Total Coliform - Monitoring, Routine Major	Absence	0500057	CALIFORNIA CAVERNS	80		1	
Total Coliform - Monitoring, Repeat Major	Absence	0500064	CAMP MADONNA OF PEACE	70		1	
Nitrite Nitrogen (No2-N)		0500069	EL TORERO RESTAURANT	225		1	
Total Coliform - Monitoring, Routine Major	Absence	0500082	ANGELS CAMP RV/CAMPING RESORT	228		1	
Total Coliform - Monitoring, Routine Minor	Absence	0500082	ANGELS CAMP RV/CAMPING RESORT	228		1	
Nitrate (As No3)	45	0500084	MORNING STAR OUTREACH	100		1	
Total Coliform - Non acute MCL	Absence	0500085	TOYON MIDDLE SCHOOL	200	1		
Total Coliform - Monitoring, Routine Major	Absence	0500088	MOANING CAVERN	80		1	
Gross Alpha	15 pCi/L	0500091	RITE OF PASSAGE/SIERRA RIDGE	150		1	
Uranium	30 µg/L	0500091	RITE OF PASSAGE/SIERRA RIDGE	150		1	
Nitrate (As No3)	45	0500096	LEE S PIG OUT BBQ	125		1	
Total Coliform - Non acute MCL	Absence	0500098	CALAVERAS COUNTY AIRPORT	25	1		
Total Coliform - Monitoring, Routine Minor	Absence	0500098	CALAVERAS COUNTY AIRPORT	25		1	
Total Coliform - Monitoring, Routine Minor	Absence	0500103	STONE CORRAL COMMUNITY CHURCH	80		2	
Total Coliform - Monitoring, Repeat Major	Absence	0500103	STONE CORRAL COMMUNITY CHURCH	80		2	
Total Coliform - Monitoring, Repeat Minor	Absence	0510010	VALLEY SPRINGS PUD	900		1	
COUNTS/TOTALS				20	3028	3	28
COLUSA							
Arsenic	0.01	0600008	COLUSA CO. W.D. #1 - GRIMES	500	3		
Arsenic	0.01	0600013	PRINCETON WATER DISTRICT	356	4		
COUNTS/TOTALS				2	856	7	0

CONTRA COSTA

Total Coliform - Monitoring, Routine Major	Absence	0706059	GAS N SAVE	120		1
Total Coliform - Monitoring, Routine Major	Absence	0707515	CHURCH OF JESUS CHRIST	200		1
Total Coliform - Non acute MCL	Absence	0707558	HERTZ WATER SYSTEM	35	1	
Total Coliform - Acute MCL	Absence	0707564	MARIN FOOD SPECIALTIES*INACTIVE	25	1	
Total Coliform - Monitoring, Routine Major	Absence	0707588	BIG OAK MOBILE HOME PARK WATER	156		1
Total Coliform - Monitoring, Routine Major	Absence	0707595	BYRON INN	60		1
Total Coliform - Monitoring, Routine Major	Absence	0707598	CAMINO MOBILEHOME	210		1
Total Coliform - Non acute MCL	Absence	0707625	GOLDEN EAGLE REFINERY (TESORO)	600	1	
Total Coliform - Monitoring, Routine Major	Absence	0707639	OLD BORGES RANCH WATER SYS	75		1

COUNTS/TOTALS

9

1481

3

6

EL DORADO

Total Coliform - Non acute MCL	Absence	0900100	CAMP FLEMING	100	1	
Total Coliform - Non acute MCL	Absence	0900110	COYOTE JUNCTION WATER SYSTEM	50	1	
Nitrate (As No3)	45	0900118	PEART S LITTLE PLACE - RESTAUR	35		1
Total Coliform - Monitoring, Routine Major	Absence	0900118	PEART S LITTLE PLACE - RESTAUR	35		1
Total Coliform - Non acute MCL	Absence	0900204	GOLD N NUGGET CAMPGROUND	1000	1	
Total Coliform - Non acute MCL	Absence	0900210	MILLERS HILL SCHOOL	120	1	
Nitrate (As No3)	45	0900211	GOLD RUSH OUTFITTERS, LLC #02	103		1
Total Coliform - Monitoring, Routine Major	Absence	0900211	GOLD RUSH OUTFITTERS, LLC #02	103		1
Total Coliform - Non acute MCL	Absence	0900213	PIONEER PARK WATER SYSTEM	100	2	
Nitrate (As No3)	45	0900216	FAIRPLAY BISTRO WATER SYSTEM	100		1
Total Coliform - Non acute MCL	Absence	0900216	FAIRPLAY BISTRO WATER SYSTEM	100	1	
Total Coliform - Non acute MCL	Absence	0900220	GRACE FOUNDATION, THE	100	2	
Total Coliform - Monitoring, Routine Major	Absence	0900220	GRACE FOUNDATION, THE	100		1
Nitrate (As No3)	45	0900318	JOKERS ROADHOUSE	50		1
Total Coliform - Non acute MCL	Absence	0900320	DANTE S ON THE RIVER	50	1	
Total Coliform - Notification	Absence	0900408	MADRONE MONTESSORI SCHOOL	50		1
Total Coliform - Monitoring, Routine Major	Absence	0900408	MADRONE MONTESSORI SCHOOL	50		1
Total Coliform - Monitoring, Routine Major	Absence	0900417	RIVERS BEND RESORT	100		1
Total Coliform - Non acute MCL	Absence	0900419	BACCHI RANCH WATER SYSTEM	100	2	
Total Coliform - Monitoring, Routine Major	Absence	0900422	CRYSTAL CAVES MHP	100		1
Total Coliform - Monitoring, Repeat Minor	Absence	0900422	CRYSTAL CAVES MHP	100		1

EL DORADO

Total Coliform - Monitoring, Routine Major	Absence	0900523	CASCADE MUTUAL WATER COMPANY	60		1
Total Coliform - Monitoring, Routine Major	Absence	0900533	EAGLE FALLS	500		1
Total Coliform - Monitoring, Routine Major	Absence	0900536	TAHOE CHALET INN .	100		1
Total Coliform - Monitoring, Routine Major	Absence	0900539	ECONO LODGE	120		1
Total Coliform - Monitoring, Routine Major	Absence	0900551	ALDER INN	25		1
Total Coliform - Monitoring, Routine Major	Absence	0900586	A & A LAKE TAHOE INN	25		1
Total Coliform - Monitoring, Routine Major	Absence	0900623	TRAVEL INN	100		1
Nitrate (As No3)	45	0901219	CAPPS CROSSING CAMPGROUND	25		1
Nitrate (As No3)	45	0901222	CHINA FLAT CAMPGROUND	75		1
Nitrate (As No3)	45	0901239	SAND FLAT CAMPGROUND	50		1
Nitrate (As No3)	45	0901243	SILVERFORK CAMPGROUND	70		1
Total Coliform - Acute MCL	Absence	0901246	PENINSULA RECREATION AREA	350	1	
Total Coliform - Non acute MCL	Absence	0901246	PENINSULA RECREATION AREA	350	1	
Tetrachloroethylene	0.005	0910015	TAHOE KEYS WATER COMPANY	3004	4	

COUNTS/TOTALS

28

6662

18

23

FRESNO

ESWTR - turbidity >0.3 NTU (44)	TT	1000003	BEAR CREEK WATER IMPROVEMENT	100	1	
Consumer Confidence Report	n/a	1000004	BELMONT WATER CORPORATION	86		1
Nitrate (As No3)	45	1000007	IDYLWILDE TRACT ASSOCIATION	55		1
Total Coliform - Non acute MCL	Absence	1000007	IDYLWILDE TRACT ASSOCIATION	55		1
ESWTR - turbidity >0.3 NTU (44)	TT	1000010	CAMP SIERRA	180	4	
Total Coliform - Monitoring, Routine Minor	Absence	1000015	DINKEY CREEK WATER IMPROVEMENT	30		1
Total Coliform - Monitoring, Repeat Major	Absence	1000015	DINKEY CREEK WATER IMPROVEMENT	30		2
Total Coliform - Monitoring, Routine Minor	Absence	1000017	DOWVILLE IMPROVEMENT ASSN	150		1
Total Coliform - Monitoring, Repeat Major	Absence	1000017	DOWVILLE IMPROVEMENT ASSN	150		1
Trihalomethanes (TTHM) - Total	0.08	1000019	FCSA #30/EL PORVENIR	130	4	
Total Coliform - Monitoring, Routine Major	Absence	1000041	FCWWD #38/SKY HARBOUR	150		1
Gross Alpha	15 pCi/L	1000042	FCWWD #40/SHAVER SPRINGS	172	1	
Uranium	30 µg/L	1000042	FCWWD #40/SHAVER SPRINGS	172	3	
Total Coliform - Non acute MCL	Absence	1000048	HERNDON WATER COMPANY	260	2	
Arsenic	0.01	1000053	LANARE COMMUNITY SERVICES DIST	400	3	
Arsenic	0.01	1000053	LANARE COMMUNITY SERVICES DIST	400		1

FRESNO						
Consumer Confidence Report	n/a	1000053	LANARE COMMUNITY SERVICES DIST	400		1
Consumer Confidence Report	n/a	1000054	LAS DELTAS MUTUAL WATER SYSTEM	375		1
Total Coliform - Monitoring, Routine Major	Absence	1000059	MUSICK HEIGHTS MUTUAL	32		1
Total Coliform - Non acute MCL	Absence	1000060	MUSICK MEADOWS #1	70	1	
Total Coliform - Monitoring, Routine Major	Absence	1000067	RANCHERIA WATER & IMPRMNT ASSN	75		1
Total Coliform - Non acute MCL	Absence	1000072	SHAVER LAKE POINT #2	210	1	
Total Coliform - Non acute MCL	Absence	1000075	TRACT 1199 WATER SYSTEM	39	4	
Total Coliform - Monitoring, Routine Major	Absence	1000075	TRACT 1199 WATER SYSTEM	39		1
Total Coliform - Monitoring, Routine Minor	Absence	1000078	FCWWD #42/ALLUVIAL & FANCHER	255		1
Total Coliform - Monitoring, Routine Major	Absence	1000079	BAR 20 PARTNER	60		1
Total Coliform - Monitoring, Repeat Major	Absence	1000079	BAR 20 PARTNER	60		1
Consumer Confidence Report	n/a	1000079	BAR 20 PARTNER	60		1
Total Coliform - Monitoring, Routine Major	Absence	1000097	FCPG/LOST LAKE RECREATION AREA	100		1
Nitrate (As No3)	45	1000112	FAIRMONT SCHOOL	493	1	
Nitrate (As No3)	45	1000112	FAIRMONT SCHOOL	493	2	
Nitrate (As No3)	45	1000116	USFS/HUME LAKE CAMPGROUND	500		1
Nitrate (As No3)	45	1000128	CAMP TULEQUOIA WATER SYSTEM	125		1
Total Coliform - Monitoring, Routine Minor	Absence	1000128	CAMP TULEQUOIA WATER SYSTEM	125		1
Total Coliform - Monitoring, Repeat Major	Absence	1000128	CAMP TULEQUOIA WATER SYSTEM	125		1
Nitrate (As No3)	45	1000129	CAMP REDWOOD/MILLWOOD WATER	160		1
Total Coliform - Monitoring, Routine Minor	Absence	1000129	CAMP REDWOOD/MILLWOOD WATER	160		1
Nitrate (As No3)	45	1000130	CAMP SEQUOIA/GAINES WATER SYS	160		1
Nitrate (As No3)	45	1000135	USFS/DINKEY CREEK WORK CENTER	25		1
Total Coliform - Monitoring, Repeat Minor	Absence	1000135	USFS/DINKEY CREEK WORK CENTER	25		1
Total Coliform - Non acute MCL	Absence	1000136	USFS/TRIMMER RANGER STATION	56	2	
Nitrate (As No3)	45	1000157	BSA/CAMP KERN	300		1
Total Coliform - Non acute MCL	Absence	1000157	BSA/CAMP KERN	300	2	
Total Coliform - Monitoring, Routine Minor	Absence	1000161	WISH-I-AH CARE CENTER	120		1
Total Coliform - Monitoring, Repeat Major	Absence	1000161	WISH-I-AH CARE CENTER	120		1
Total Coliform - Non acute MCL	Absence	1000171	CHINA PEAK MOUNTAIN RESORT	200	1	
Total Coliform - Monitoring, Routine Major	Absence	1000172	LAKESHORE RESORT	200		1
Trihalomethanes (TTHM) - Total	0.08	1000175	CASACA VINEYARDS	25	4	
SWTR - treatment technique (41)	TT	1000175	CASACA VINEYARDS	25	1	

FRESNO

Total Coliform - Non acute MCL	Absence	1000176	J R SIMPLOT COMPANY	25	1	
Trihalomethanes (TTHM) - Total	0.08	1000177	I-5 AND PANOCHE DEVELOPMENT	85	4	
Trihalomethanes (TTHM) - Total	0.08	1000178	I-5 AND HWY 198 REST AREA	225	4	
Consumer Confidence Report	n/a	1000182	BURREL UNION ELEMENTARY SCHOOL	120		1
Total Coliform - Non acute MCL	Absence	1000184	DUNLAP K-8 SCHOOL	459	1	
Total Coliform - Monitoring, Routine Minor	Absence	1000186	HELM SCHOOL	150		1
Total Coliform - Monitoring, Routine Minor	Absence	1000189	LATON HIGH SCHOOL	260		1
Total Coliform - Non acute MCL	Absence	1000193	NAVELENCIA SCHOOL	203	1	
Nitrate (As No3)	45	1000201	SUN EMPIRE SCHOOL	780		1
Consumer Confidence Report	n/a	1000201	SUN EMPIRE SCHOOL	780		1
Consumer Confidence Report	n/a	1000204	AMERICAN UNION SCHOOL	250		1
Nitrate (As No3)	45	1000207	PERSHING HIGH SCHOOL	175	3	
Uranium	30 µg/L	1000207	PERSHING HIGH SCHOOL	175	2	
Total Coliform - Monitoring, Routine Major	Absence	1000207	PERSHING HIGH SCHOOL	175		1
Total Coliform - Non acute MCL	Absence	1000208	ROOSEVELT ELEMENTARY SCHOOL	370	2	
Trihalomethanes (TTHM) - Total	0.08	1000213	HARRIS FARMS/HORSE BARN	100	3	
ESWTR-filtered sys-monitoring (38)	MR	1000213	HARRIS FARMS/HORSE BARN	100		2
Trihalomethanes (TTHM) - Total	0.08	1000214	HARRIS RANCH	275	4	
SWTR - treatment technique (41)	TT	1000214	HARRIS RANCH	275	1	
Dibromochloropropane (Dbcp)	0.0002	1000221	WASHINGTON UNION HIGH SCHOOL	1150	3	
Total Coliform - Non acute MCL	Absence	1000230	FRESNO COUNTY SPORTSMEN'S CLUB	30	1	
Total Coliform - Monitoring, Routine Minor	Absence	1000230	FRESNO COUNTY SPORTSMEN'S CLUB	30		1
Arsenic	0.01	1000238	CAMDEN TRAILER PARK	90	2	
Consumer Confidence Report	n/a	1000244	SHADY LAKES MOBILE HOME PARK	130		1
Total Coliform - Non acute MCL	Absence	1000247	SHERWOOD FOREST MHP	100	1	
Total Coliform - Monitoring, Routine Minor	Absence	1000248	DOUBLE L MOBILE RANCH PARK	80		2
Total Coliform - Monitoring, Repeat Major	Absence	1000248	DOUBLE L MOBILE RANCH PARK	80		1
Consumer Confidence Report	n/a	1000248	DOUBLE L MOBILE RANCH PARK	80		1
Total Coliform - Monitoring, Repeat Major	Absence	1000264	SUNNYSLOPE CAMPGROUNDS	30		1
Total Coliform - Monitoring, Routine Major	Absence	1000267	KINGS CANYON MOBILE HOME PARK	200		4
Total Coliform - Non acute MCL	Absence	1000276	ORANGE CENTER SCHOOL	410	1	
Total Coliform - Monitoring, Routine Minor	Absence	1000276	ORANGE CENTER SCHOOL	410		1
Consumer Confidence Report	n/a	1000277	ELM COURT	40		1

FRESNO

Trihalomethanes (TTHM) - Total	0.08	1000290	WESTSIDE SCHOOL	398	2	
SWTR - treatment technique (41)	TT	1000290	WESTSIDE SCHOOL	398	1	
Nitrate (As No3)	45	1000298	WOODWARD BLUFFS MHP	300		1
Total Coliform - Non acute MCL	Absence	1000298	WOODWARD BLUFFS MHP	300	1	
Total Coliform - Monitoring, Routine Major	Absence	1000304	SIERRA INN	25		1
Nitrate (As No3)	45	1000308	MONO HOT SPRINGS RESORT	85		1
Total Coliform - Monitoring, Routine Major	Absence	1000308	MONO HOT SPRINGS RESORT	85		1
Total Coliform - Monitoring, Routine Minor	Absence	1000308	MONO HOT SPRINGS RESORT	85		1
Total Coliform - Monitoring, Repeat Major	Absence	1000308	MONO HOT SPRINGS RESORT	85		1
Total Coliform - Monitoring, Routine Major	Absence	1000317	JAVIER'S FRESNO WEST	50		1
Nitrate (As No3)	45	1000318	BENSON'S LAKESIDE RESORT	30		1
Total Coliform - Monitoring, Routine Major	Absence	1000318	BENSON'S LAKESIDE RESORT	30		2
Total Coliform - Monitoring, Routine Major	Absence	1000330	KINGS CANYON LODGE	30		1
Nitrate (As No3)	45	1000343	HARDING & LEGGETT- PACKING FACILITY	85		1
Nitrate (As No3)	45	1000344	CENTRAL CA HEALTH CARE SYSTEM	2000		1
Total Coliform - Monitoring, Routine Major	Absence	1000344	CENTRAL CA HEALTH CARE SYSTEM	2000		3
Total Coliform - Monitoring, Repeat Major	Absence	1000344	CENTRAL CA HEALTH CARE SYSTEM	2000		1
Consumer Confidence Report	n/a	1000344	CENTRAL CA HEALTH CARE SYSTEM	2000		1
Trihalomethanes (TTHM) - Total	0.08	1000345	PANOCHÉ WATER DISTRICT	27	3	
Total Coliform - Non acute MCL	Absence	1000345	PANOCHÉ WATER DISTRICT	27	1	
Consumer Confidence Report	n/a	1000345	PANOCHÉ WATER DISTRICT	27		1
Total Coliform - Monitoring, Routine Minor	Absence	1000352	SPRECKELS SUGAR COMPANY	230		1
Trihalomethanes (TTHM) - Total	0.08	1000359	FCSA #32/CANTUA CREEK	230	4	
Trihalomethanes (TTHM) - Total	0.08	1000360	COTTON WEST AG MANAGEMENT	50	4	
Trihalomethanes (TTHM) - Total	0.08	1000361	WESTLANDS WATER DISTRICT	48	4	
SWTR - treatment technique (41)	TT	1000361	WESTLANDS WATER DISTRICT	48	2	
Total Coliform - Non acute MCL	Absence	1000365	PONDEROSA TRAILER PARK	156	1	
Consumer Confidence Report	n/a	1000366	SUNNYSIDE CONVALESCENT HOSP	116		1
Nitrate (As No3)	45	1000367	SELMA HIGH SCHOOL	2225		1
Arsenic	0.01	1000369	ZONNEVELD DAIRY	141	3	
Total Coliform - Monitoring, Routine Minor	Absence	1000369	ZONNEVELD DAIRY	141		1
Nitrate (As No3)	45	1000377	ST NICHOLAS RANCH & RETREAT	104		1
Total Coliform - Monitoring, Routine Major	Absence	1000377	ST NICHOLAS RANCH & RETREAT	104		3

FRESNO

Total Coliform - Monitoring, Routine Minor	Absence	1000378	SUNSET WEST MOBILE HOME PARK	239		1
Consumer Confidence Report	n/a	1000378	SUNSET WEST MOBILE HOME PARK	239		1
Consumer Confidence Report	n/a	1000381	SUN-MAID GROWERS OF CALIFORNIA	750		1
Consumer Confidence Report	n/a	1000383	GUARDIAN INDUSTRIES CORP	240		1
Total Coliform - Monitoring, Routine Minor	Absence	1000405	DOYALS MOBILE HOME PARK	16		1
Consumer Confidence Report	n/a	1000405	DOYALS MOBILE HOME PARK	16		1
Total Coliform - Monitoring, Routine Major	Absence	1000406	FRESNO HMONG ALLIANCE CHURCH	55		3
Public Notice Rule violation for an NPDWR violat	n/a	1000406	FRESNO HMONG ALLIANCE CHURCH	55		1
Total Coliform - Non acute MCL	Absence	1000407	GEORGE COX WATER SYSTEM	40	1	
Consumer Confidence Report	n/a	1000407	GEORGE COX WATER SYSTEM	40		1
Total Coliform - Non acute MCL	Absence	1000410	SHORTYS PLACE	40	1	
Total Coliform - Monitoring, Routine Major	Absence	1000410	SHORTYS PLACE	40		5
Consumer Confidence Report	n/a	1000410	SHORTYS PLACE	40		1
Public Notice Rule violation for an NPDWR violat	n/a	1000410	SHORTYS PLACE	40		1
Total Coliform - Non acute MCL	Absence	1000411	O'NEILL VINTNERS & DISTILLERS	70	3	
Total Coliform - Monitoring, Routine Major	Absence	1000416	EASTON PRESBYTERIAN CHURCH	250		2
Consumer Confidence Report	n/a	1000416	EASTON PRESBYTERIAN CHURCH	250		1
Total Coliform - Monitoring, Routine Minor	Absence	1000418	GERAWAN FARMING PLANT 5 CENTERVILLE	35		1
Arsenic	0.01	1000424	CANYON FORK PROPERTIES	24	1	
Total Coliform - Monitoring, Repeat Minor	Absence	1000426	RIVERBEND MOBILE HOME & RV PARK	200		1
Total Coliform - Non acute MCL	Absence	1000445	LINDA VISTA FARMS	61	2	
Total Coliform - Monitoring, Routine Minor	Absence	1000445	LINDA VISTA FARMS	61		1
Total Coliform - Monitoring, Routine Major	Absence	1000448	CRAIG ROQUE LABOR CAMP	100		1
Total Coliform - Monitoring, Routine Major	Absence	1000453	JOHNNY QUIK STORE #149	50		2
Nitrate (As No3)	45	1000459	JOHNNY QUIK FOOD STORE #127	300	1	
Nitrate (As No3)	45	1000461	BEEF PACKERS	950	4	
Total Coliform - Monitoring, Routine Major	Absence	1000466	LDS SEQUOIA BRANCH CHURCH	75		2
Nitrate (As No3)	45	1000469	LION RAISINS INC. EMPLOYE LABOR CAMP	30	1	
Total Coliform - Monitoring, Routine Major	Absence	1000471	FCSA #39 A&B	350		1
Arsenic	0.01	1000472	PG&E HELMS SUPPORT FACILITY	36	4	
Total Coliform - Non acute MCL	Absence	1000473	BELMONT COUNTRY CLUB	150	2	
Total Coliform - Non acute MCL	Absence	1000474	BEAR MOUNTAIN LIBRARY/ACT CNTR	25	1	
Total Coliform - Non acute MCL	Absence	1000479	FRANZIA WINERY-SANGER	60	3	

FRESNO						
Dibromochloropropane (Dbcp)	0.0002	1000480	FOWLER PACKING COMPANY	450	1	
Total Coliform - Monitoring, Routine Minor	Absence	1000482	WOLF LAKES PARK	500		1
Dibromochloropropane (Dbcp)	0.0002	1000485	TESENDERLO KERLEY INC	50	2	
Total Coliform - Monitoring, Routine Major	Absence	1000485	TESENDERLO KERLEY INC	50		1
Total Coliform - Monitoring, Routine Major	Absence	1000487	VERMILION VALLEY RESORT	30		1
Trihalomethanes (TTHM) - Total	0.08	1000490	LOS GATOS TOMATO PRODUCTS	100	3	
ESWTR-filtered sys-monitoring (43)	TT	1000490	LOS GATOS TOMATO PRODUCTS	100	1	
SWTR - treatment technique (41)	TT	1000490	LOS GATOS TOMATO PRODUCTS	100	1	
Total Coliform - Monitoring, Routine Major	Absence	1000492	TABERNACLE OF PRAISE CHURCH	30		2
Total Coliform - Monitoring, Routine Minor	Absence	1000494	CALVARY MISSIONARY BAPTIST CH	50		1
Total Coliform - Monitoring, Repeat Major	Absence	1000494	CALVARY MISSIONARY BAPTIST CH	50		1
Nitrate (As No3)	45	1000495	GODS FAMILY CHURCH	586		1
Total Coliform - Non acute MCL	Absence	1000496	COPPER RIVER COUNTRY CLUB	125	1	
Total Coliform - Monitoring, Routine Major	Absence	1000496	COPPER RIVER COUNTRY CLUB	125		1
Nitrate (As No3)	45	1000500	HINDU TEMPLE OF FRESNO	30		1
Total Coliform - Non acute MCL	Absence	1000501	TOLLHOUSE MARKET	25	1	
Total Coliform - Non acute MCL	Absence	1000507	GILLETTE CITRUS COMPANY	74	2	
Total Coliform - Monitoring, Routine Major	Absence	1000511	NEW BEGINNINGS CHURCH	50		1
Public Notice Rule violation for an NPDWR violat	n/a	1000511	NEW BEGINNINGS CHURCH	50		1
Total Coliform - Non acute MCL	Absence	1000512	FRESNO LOGISTICS	150	1	
Total Coliform - Monitoring, Routine Major	Absence	1000512	FRESNO LOGISTICS	150		1
Consumer Confidence Report	n/a	1000512	FRESNO LOGISTICS	150		1
Total Coliform - Monitoring, Routine Major	Absence	1000513	KINGDOM HALL OF JEHOVAH S WITNESSES	25		2
LCR - Routine&followup monitoring	MR	1000514	KINGS RIVER PACKING	25		1
Total Coliform - Monitoring, Routine Major	Absence	1000514	KINGS RIVER PACKING	25		3
Total Coliform - Monitoring, Routine Major	Absence	1000515	MICHELSEN PACKAGING	25		1
Nitrate (As No3)	45	1000517	BLOSSOM TRAIL CAFE	25		1
Total Coliform - Monitoring, Routine Major	Absence	1000517	BLOSSOM TRAIL CAFE	25		1
Total Coliform - Monitoring, Routine Minor	Absence	1000528	BEAR MOUNTAIN PIZZA	25		1
Total Coliform - Monitoring, Repeat Minor	Absence	1000528	BEAR MOUNTAIN PIZZA	25		1
Nitrate (As No3)	45	1000530	AMERICAN AVENUE LANDFILL	29	2	
Total Coliform - Monitoring, Routine Major	Absence	1000530	AMERICAN AVENUE LANDFILL	29		1
Total Coliform - Monitoring, Repeat Minor	Absence	1000533	THREE CROWNS INDUSTRIAL PARK WATER	25		1

FRESNO

Consumer Confidence Report	n/a	1000534	CHOOIJIAN BROS PACKING CO	30		1
SWTR - treatment technique (41)	TT	1000536	CON AGRA FOODS, CULINARY BUSINESS F	25	2	
Total Coliform - Monitoring, Routine Major	Absence	1000537	JOHNNY QUIK FOOD STORE #161	25		1
Uranium	30 µg/L	1000542	USED PALLET COMPANY	60	4	
Total Coliform - Non acute MCL	Absence	1000542	USED PALLET COMPANY	60	1	
Total Coliform - Monitoring, Routine Minor	Absence	1000544	SHOP-N-QUICK #2	25		1
Total Coliform - Monitoring, Repeat Minor	Absence	1000544	SHOP-N-QUICK #2	25		1
Total Coliform - Monitoring, Routine Major	Absence	1000545	SELMA EXXON TIGER MART	25		1
Total Coliform - Monitoring, Routine Major	Absence	1000552	FRESNO SOUTH JEHOVAH WITNESSES	170		1
Total Coliform - Monitoring, Routine Major	Absence	1000553	TRINITY PRESBYTERIAN CHURCH	450		1
Total Coliform - Non acute MCL	Absence	1000560	CENTRAL CA ALMOND GROWERS ASSN	80		2
Total Coliform - Monitoring, Routine Minor	Absence	1000565	USDA AGRICULTURAL RESEARCH SERVICE	130		1
Total Coliform - Monitoring, Repeat Major	Absence	1000565	USDA AGRICULTURAL RESEARCH SERVICE	130		1
Gross Alpha	15 pCi/L	1000571	NORTHWEST WORLD HARVEST CHURCH	360		1
Nitrate (As No3)	45	1000571	NORTHWEST WORLD HARVEST CHURCH	360		1
Perchlorate	0.006	1000571	NORTHWEST WORLD HARVEST CHURCH	360		1
Total Coliform - Monitoring, Routine Major	Absence	1000571	NORTHWEST WORLD HARVEST CHURCH	360		3
Consumer Confidence Report	n/a	1000571	NORTHWEST WORLD HARVEST CHURCH	360		1
Total Coliform - Non acute MCL	Absence	1000575	POINDEXTER NUT COMPANY	50	1	
Consumer Confidence Report	n/a	1000575	POINDEXTER NUT COMPANY	50		1
Dibromochloropropane (Dbcp)	0.0002	1000576	LONE STAR DEHYDRATOR	25	2	
Total Coliform - Monitoring, Routine Major	Absence	1000576	LONE STAR DEHYDRATOR	25		1
Total Coliform - Non acute MCL	Absence	1000580	CAMPOS BROS. FARMS (WALNUT)	150	3	
Nitrate (As No3)	45	1000585	MURRIETA/HERNANDEZ FARMS	4	1	
Trihalomethanes (TTHM) - Total	0.08	1009006	PAPPAS & CO (COALINGA)	50	4	
SWTR-filtered sys-monitoring (36)	MR	1009006	PAPPAS & CO (COALINGA)	50		1
SWTR - treatment technique (41)	TT	1009006	PAPPAS & CO (COALINGA)	50	3	
Trihalomethanes (TTHM) - Total	0.08	1009023	BRITZ/COLUSA	106	4	
Trihalomethanes (TTHM) - Total	0.08	1009027	HARRIS FARMS CAMP C #501-523	300	4	
SWTR - treatment technique (41)	TT	1009027	HARRIS FARMS CAMP C #501-523	300	5	
Trihalomethanes (TTHM) - Total	0.08	1009028	HARRIS FARMS SOUTH #101-144	160	4	
Trihalomethanes (TTHM) - Total	0.08	1009034	WESTRIDGE	54	3	
Trihalomethanes (TTHM) - Total	0.08	1009035	PILIBOS BROTHERS RANCH (SIMONIAN FARMS)	25	4	

FRESNO

SWTR - treatment technique (41)	TT	1009035	PILIBOS BROTHERS RANCH (SIMONIAN FARMS)	25	2	
Trihalomethanes (TTHM) - Total	0.08	1009039	PAPPAS & COMPANY (MENDOTA)	25	4	
Trihalomethanes (TTHM) - Total	0.08	1009051	HOULDING FARMS	50	4	
SWTR-filtered sys-monitoring (36)	MR	1009051	HOULDING FARMS	50		1
SWTR - treatment technique (41)	TT	1009051	HOULDING FARMS	50	3	
Trihalomethanes (TTHM) - Total	0.08	1009078	HARRIS FEEDING COMPANY	225	4	
ESWTR-filtered sys-monitoring (38)	MR	1009078	HARRIS FEEDING COMPANY	225		2
Total Coliform - Monitoring, Routine Minor	Absence	1009120	RAU DAIRY	80		1
Consumer Confidence Report	n/a	1009120	RAU DAIRY	80		1
SWTR - treatment technique (41)	TT	1009129	PG&E BALCH CAMP	17	2	
ESWTR - turbidity >0.3 NTU (44)	TT	1009129	PG&E BALCH CAMP	17	1	
Trihalomethanes (TTHM) - Total	0.08	1009147	FARMING D	100	3	
Trihalomethanes (TTHM) - Total	0.08	1009172	VAQUERO FARMS	70	3	
Trihalomethanes (TTHM) - Total	0.08	1009179	BRITZ/FIVE POINT SYSTEM	150	2	
Trihalomethanes (TTHM) - Total	0.08	1009214	WESTSIDE HARVESTING	25	4	
DBP	n/a	1009214	WESTSIDE HARVESTING	25		1
SWTR - treatment technique (41)	TT	1009214	WESTSIDE HARVESTING	25	1	
Trihalomethanes (TTHM) - Total	0.08	1009222	TERRA LINDA FARMS	40	4	
Trihalomethanes (TTHM) - Total	0.08	1009232	PECK RANCH	42	4	
SWTR - treatment technique (41)	TT	1009232	PECK RANCH	42	1	
Trihalomethanes (TTHM) - Total	0.08	1009258	SAN ANDREAS FARMS	40	4	
SWTR - treatment technique (41)	TT	1009258	SAN ANDREAS FARMS	40	1	
Trihalomethanes (TTHM) - Total	0.08	1009281	HAMMONDS RANCH	50	4	
SWTR - treatment technique (41)	TT	1009281	HAMMONDS RANCH	50	1	
Total Coliform - Non acute MCL	Absence	1010001	BAKMAN WATER COMPANY	8751	1	
Dibromochloropropane (Dbcp)	0.0002	1010007	FRESNO, CITY OF	457511	1	
Consumer Confidence Report	n/a	1010017	FRESNO CO WATERWORKS DIST 41	2157		1
Nitrate (As No3)	45	1010026	PINEDALE COUNTY WATER DISTRICT	8495		1
Arsenic	0.01	1010028	RIVERDALE PUBLIC UTILITY DISTRICT	2416	4	
Arsenic	0.01	1010030	TRANQUILLITY IRRIGATION DIST	820	4	
Total Coliform - Monitoring, Routine Minor	Absence	1010030	TRANQUILLITY IRRIGATION DIST	820		1
Total Coliform - Monitoring, Repeat Major	Absence	1010030	TRANQUILLITY IRRIGATION DIST	820		1
Arsenic	0.01	1010039	CARUTHERS COMM SERV DIST	2103	4	

FRESNO						
Total Coliform - Non acute MCL	Absence	1010039	CARUTHERS COMM SERV DIST	2103	1	
Total Coliform - Monitoring, Routine Minor	Absence	1010039	CARUTHERS COMM SERV DIST	2103		1
Consumer Confidence Report	n/a	1010042	MALAGA COUNTY WATER DISTRICT	900		1
Trihalomethanes (TTHM) - Total	0.08	1010044	HURON, CITY OF	7306	2	
Haa5 - Haloacetic Acids (Five)	0.06	1010051	FRESNO CO WATER WORKS DIST 18	860	2	
Trihalomethanes (TTHM) - Total	0.08	1010051	FRESNO CO WATER WORKS DIST 18	860	2	
COUNTS/TOTALS				164	518472	254
HUMBOLDT						
Total Coliform - Monitoring, Routine Major	Absence	1200501	ALDERPOINT COUNTY WATER	215		1
Total Coliform - Non acute MCL	Absence	1200509	HEARTWOOD INSTITUTE	125	1	
Total Coliform - Monitoring, Routine Major	Absence	1200518	RIVERSIDE CSD	293		1
SWTR - treatment technique (41)	TT	1200544	REDCREST WATER WORKS	100	1	
Total Coliform - Non acute MCL	Absence	1200547	MILL CREEK M.W.C.	65	1	
Total Coliform - Monitoring, Repeat Minor	Absence	1200547	MILL CREEK M.W.C.	65		1
Total Coliform - Monitoring, Routine Major	Absence	1200566	ORLEANS MUTUAL WATER CO.	85		1
SWTR - treatment technique (41)	TT	1200566	ORLEANS MUTUAL WATER CO.	85	1	
Total Coliform - Non acute MCL	Absence	1200579	M.F. MITCHELL & COMPANY (NEW)	28	2	
Total Coliform - Monitoring, Routine Major	Absence	1200592	BIG LAGOON CSD	140		2
Total Coliform - Non acute MCL	Absence	1200597	RICHARDSON'S GROVE CAMPGROUND & RV PARK	750	1	
Total Coliform - Non acute MCL	Absence	1200687	RIVERBEND MOBILE HOME PARK	60	3	
Total Coliform - Monitoring, Routine Major	Absence	1200710	VIEW CREST LODGE	50		1
Total Coliform - Monitoring, Routine Major	Absence	1200728	SOUNDS OF THE SEAS W. S.	100		1
Total Coliform - Monitoring, Routine Major	Absence	1200793	MERRYMAN'S RESTAURANT	125		1
Total Coliform - Monitoring, Routine Minor	Absence	1210010	SCOTIA, TOWN OF, LLC	1000		1
Haa5 - Haloacetic Acids (Five)	0.06	1210018	TRINIDAD, CITY OF	1000	1	
Haa5 - Haloacetic Acids (Five)	0.06	1210024	WESTHAVEN C.S.D.	490	1	
SWTR - treatment technique (41)	TT	1210801	HIGH ROCK CONSERVATION CAMP	130	1	
COUNTS/TOTALS				17	4756	13
COUNTS/TOTALS				172	518472	254

IMPERIAL							
Trihalomethanes (TTHM) - Total	0.08	1300571	UC DESERT RESEARCH AND EXTENSION CENTER	25	4		
Nitrite (as N)	1	1300583	CALTRANS, SAND HILL REST STOP	26		1	
Raduim 226	--	1300629	JACKSON HIDE-A-WAY	40		1	
Nitrite (as N)	1	1300629	JACKSON HIDE-A-WAY	40		1	
Benzene	0.001	1300629	JACKSON HIDE-A-WAY	40		1	
Trihalomethanes (TTHM) - Total	0.08	1310006	IMPERIAL, CITY OF	12752	3		
Trihalomethanes (TTHM) - Total	0.08	1310008	WESTMORLAND, CITY OF	2444	3		
Trihalomethanes (TTHM) - Total	0.08	1310013	SEELEY CWD	2000	4		
SWTR - treatment technique (41)	TT	1310016	GSA, CALEXICO PORT OF ENTRY	300	1		
Total Coliform - Non acute MCL	Absence	1310700	N.A.F. EL CENTRO	526	1		
Total Coliform - Non acute MCL	Absence	1310800	CALIPATRIA STATE PRISON	4800	1		
Trihalomethanes (TTHM) - Total	0.08	1310801	CENTINELA STATE PRISON	5000	4		
COUNTS/TOTALS				10	27913	21	4
INYO							
Arsenic	0.01	1400004	CHARLES BROWN WATER COMPANY	330		2	
Total Coliform - Non acute MCL	Absence	1400005	OWENS VALLEY WATER COMPANY	300	1		
Total Coliform - Monitoring, Repeat Minor	Absence	1400005	OWENS VALLEY WATER COMPANY	300		1	
Arsenic	0.01	1400036	KEEFER CREEK ESTATES MUTUAL	180	1		
Arsenic	0.01	1400037	FOOTHILL LONE PINE MHP, LLC	180	4		
Total Coliform - Monitoring, Repeat Major	Absence	1400063	TESSENDERLO KERLEY INC	50		1	
Total Coliform - Non acute MCL	Absence	1400069	DEATH VALLEY JUNCTION	200	2		
Total Coliform - Non acute MCL	Absence	1400096	TECOPA HOT SPRINGS PARK	100	1		
Total Coliform - Non acute MCL	Absence	1400111	MEADOWCREEK MUTUAL WATER COMPANY	640	1		
Arsenic	0.01	1400155	CONTROL GORGE POWER PLANT	36	4		
Total Coliform - Non acute MCL	Absence	1400500	COMFORT INN	150	1		
Arsenic	0.01	1400526	EASTERN SIERRA COLLEGE CENTER - BISHOP	100	1		
Uranium (check)	30 µg/L	1400526	EASTERN SIERRA COLLEGE CENTER - BISHOP	100	4		
Fluoride -- Natural - Source	2	1400526	EASTERN SIERRA COLLEGE CENTER - BISHOP	100		1	
Total Coliform - Non acute MCL	Absence	1410001	CITY OF BISHOP	3735	1		
Arsenic	0.01	1410504	NPS - DEATH VALLEY, GRAPEVINE RS	4	1		
COUNTS/TOTALS				13	6005	22	5

KERN						
Consumer Confidence Report	n/a	1500050	LEHIGH SOUTHWEST CEMENT COMPANY	115		1
Uranium	30 µg/L	1500096	OLD RIVER MUTUAL WATER COMPANY	60	1	
Arsenic	0.01	1500190	EDMUNDSON ACRES WATER SYSTEM	550	1	
Total Coliform - Monitoring, Routine Minor	Absence	1500289	ATHAL MUTUAL WATER SYSTEM	150		1
Arsenic	0.01	1500290	EDGEMONT ACRES MUTUAL WATER COMPANY	400	4	
Arsenic	0.01	1500364	KRVWC - KERVALE MUTUAL WATER CO	26	4	
Total Coliform - Monitoring, Routine Major	Absence	1500373	SEVENTH STANDARD MUTUAL	66		1
Arsenic	0.01	1500378	MAHER MUTUAL WATER COMPANY	150	4	
Arsenic	0.01	1500405	AERIAL ACRES WATER SYSTEM	120	4	
Consumer Confidence Report	n/a	1500421	LONGVIEW MOBILE ESTATES, ROSAMOND	69		1
Arsenic	0.01	1500424	LANDS OF PROMISE MUTUAL WATER ASSOCIATIO	190	4	
Total Coliform - Monitoring, Routine Major	Absence	1500424	LANDS OF PROMISE MUTUAL WATER ASSOCIATIO	190		1
Arsenic	0.01	1500436	HUNGRY GULCH WATER SYSTEM	37	4	
Arsenic	0.01	1500442	DUNES APARTMENTS WATER SYSTEM	37	4	
Total Coliform - Non acute MCL	Absence	1500448	HILLVIEW ACRES MUTUAL WATER COMPANY	40	1	
Arsenic	0.01	1500449	FOURTH STREET WATER SYSTEM	25	4	
Arsenic	0.01	1500455	WILLIAM FISHER MEMORIAL WATER COMPANY	51	4	
Arsenic	0.01	1500458	R.S. MUTUAL WATER COMPANY	25	2	
Total Coliform - Non acute MCL	Absence	1500458	R.S. MUTUAL WATER COMPANY	25	2	
Total Coliform - Monitoring, Repeat Minor	Absence	1500458	R.S. MUTUAL WATER COMPANY	25		1
Arsenic	0.01	1500461	FOUNTAIN TRAILER PARK WATER	68	4	
Total Coliform - Non acute MCL	Absence	1500478	VALLEY ESTATES POA, INC.	300	1	
Arsenic	0.01	1500493	EL ADOBE POA, INC.	200	4	
Total Coliform - Non acute MCL	Absence	1500493	EL ADOBE POA, INC.	200	1	
Total Coliform - Monitoring, Routine Major	Absence	1500516	TUT BROTHERS FARM #96	100		1
Consumer Confidence Report	n/a	1500516	TUT BROTHERS FARM #96	100		1
Arsenic	0.01	1500521	BOULDER CANYON WATER ASSOCIATION	29	4	
Arsenic	0.01	1500525	LAKEVIEW RANCHOS MUTUAL WATER	120	4	
Total Coliform - Monitoring, Routine Major	Absence	1500535	MANON MANOR MUTUAL WATER COMPANY	200		1
Arsenic	0.01	1500540	PINON HILL WATER COMPANY	80	4	
Total Coliform - Non acute MCL	Absence	1500556	HART FLAT BEAR MUTUAL WATER	43	1	
Arsenic	0.01	1500571	LUCKY 18 ON ROSAMOND, LLC	73	4	
Total Coliform - Monitoring, Routine Major	Absence	1500571	LUCKY 18 ON ROSAMOND, LLC	73		1

KERN						
Arsenic	0.01	1500585	OASIS PROPERTY OWNERS ASSOCIATION	100	1	
Total Coliform - Monitoring, Routine Major	Absence	1500591	SWEET WATER CO-OP	25		2
Consumer Confidence Report	n/a	1500591	SWEET WATER CO-OP	25		1
Total Coliform - Non acute MCL	Absence	1500593	UPLANDS OF THE KERN MUTUAL WATER COMPANY	80	2	
Arsenic	0.01	1500600	J.G. BOSWELL COMPANY WATER SYSTEM	30	4	
Total Coliform - Monitoring, Routine Major	Absence	1502008	JONES AUCTION	120		1
Total Coliform - Monitoring, Routine Major	Absence	1502012	HECK CELLARS WATER SYSTEM	45		1
Total Coliform - Non acute MCL	Absence	1502034	CALIFORNIA PORTLAND CEMENT	200	1	
Total Coliform - Monitoring, Routine Minor	Absence	1502084	FRAZIER WOODS CONFERENCE CENTER	250		1
Total Coliform - Monitoring, Repeat Major	Absence	1502084	FRAZIER WOODS CONFERENCE CENTER	250		1
Total Coliform - Monitoring, Routine Major	Absence	1502093	HARVEST STEAKHOUSE	65		2
Total Coliform - Monitoring, Routine Major	Absence	1502142	KERN VALLEY GOLF COURSE	500		1
Total Coliform - Monitoring, Routine Minor	Absence	1502142	KERN VALLEY GOLF COURSE	500		1
Arsenic	0.01	1502154	LAKESIDE SCHOOL	800	4	
Total Coliform - Non acute MCL	Absence	1502181	TURNING POINT MOTHER-INFANT PROGRAM	45	1	
Total Coliform - Monitoring, Routine Major	Absence	1502217	BETHEL IN THE HILLS - PCG CAMP	320		1
Total Coliform - Monitoring, Repeat Minor	Absence	1502217	BETHEL IN THE HILLS - PCG CAMP	320		1
Arsenic	0.01	1502221	POND SCHOOL WATER SYSTEM	250	3	
Total Coliform - Non acute MCL	Absence	1502231	ROSAMOND SCHOOL WATER SYSTEM	750	1	
Arsenic	0.01	1502244	SEMI TROPIC SCHOOL WATER SYSTEM	320	4	
Total Coliform - Non acute MCL	Absence	1502244	SEMI TROPIC SCHOOL WATER SYSTEM	320	2	
Arsenic	0.01	1502383	NORD ROAD WATER ASSOCIATION	39	4	
Total Coliform - Non acute MCL	Absence	1502398	FARMER JOHN EGG RANCH #2	30	1	
Total Coliform - Monitoring, Routine Major	Absence	1502449	CYPRESS CANYON WATER SYSTEM	50		2
Consumer Confidence Report	n/a	1502449	CYPRESS CANYON WATER SYSTEM	50		1
Total Coliform - Monitoring, Repeat Minor	Absence	1502524	CAMP AREV	300		2
Total Coliform - Non acute MCL	Absence	1502545	SCHWEIKART WATER SYSTEM	37	1	
Arsenic	0.01	1502569	FIRST MUTUAL WATER SYSTEM	40	4	
Total Coliform - Non acute MCL	Absence	1502569	FIRST MUTUAL WATER SYSTEM	40	1	
Total Coliform - Non acute MCL	Absence	1502581	SUNVIEW COLD STORAGE WATER SYSTEM	130	1	
Fluoride -- Natural - Source	2	1502607	PIUTE MOUNTAIN SCHOOL WATER	200	2	
Consumer Confidence Report	n/a	1502620	POND MUTUAL WATER COMPANY	48		1
Arsenic	0.01	1502622	GOSFORD ROAD WATER COMPANY	52	4	

KERN						
Total Coliform - Monitoring, Routine Major	Absence	1502633	JOSEPHINA AND ENRIQUE WATER SYSTEM	63		1
Consumer Confidence Report	n/a	1502633	JOSEPHINA AND ENRIQUE WATER SYSTEM	63		1
Total Coliform - Non acute MCL	Absence	1502645	MEADOWS OF THE KERN MUTUAL WATER COMPAN	32	1	
Total Coliform - Non acute MCL	Absence	1502649	DIXIE WATER COMPANY	30	2	
Perchlorate	0.006	1502670	FAIRVIEW WATER COMPANY, LLC	100	1	
Total Coliform - Non acute MCL	Absence	1502685	USFS - LK ISABELLA OFFICE WATER SYSTEM	40	1	
Total Coliform - Non acute MCL	Absence	1502682	CLM - PARADISE COVE CAMPGROUND	168	1	
Total Coliform - Non acute MCL	Absence	1502686	USFS - FRENCH GULCH CAMPGROUND WS	34	1	
Total Coliform - Non acute MCL	Absence	1502689	USFS - CAMP 9	160	2	
Total Coliform - Non acute MCL	Absence	1502690	DUNE III WATER CO., LLC	100	2	
Total Coliform - Non acute MCL	Absence	1502697	GE WIND ENERGY	100	1	
Consumer Confidence Report	n/a	1502699	EAST WILSON ROAD WATER COMPANY	35		1
Arsenic	0.01	1502724	QUAIL VALLEY WATER DIST-EASTSIDE SYSTEM	60	4	
Total Coliform - Monitoring, Routine Minor	Absence	1502735	TWIN OAKS RANCH WATER SYSTEM	6		1
Total Coliform - Monitoring, Routine Major	Absence	1502745	SYCAMORE CANYON GOLF COURSE	400		2
Arsenic	0.01	1502771	KERN OIL AND REFINING COMPANY	70	4	
Total Coliform - Non acute MCL	Absence	1502820	FLYING J TRAVEL PLAZA	100	1	
Total Coliform - Monitoring, Routine Major	Absence	1503210	DAVES SPORTS BAR	60		1
Total Coliform - Monitoring, Repeat Minor	Absence	1503211	DWR-CHRISMAN PUMPING PLANT/WIND GAP	130		1
Total Coliform - Monitoring, Routine Minor	Absence	1503212	DWR - EDMONSTON PUMPING PLANT	35		1
Total Coliform - Monitoring, Repeat Minor	Absence	1503212	DWR - EDMONSTON PUMPING PLANT	35		1
Total Coliform - Monitoring, Routine Major	Absence	1503231	FOUR WINDS WATER SYSTEM	50		1
Total Coliform - Non acute MCL	Absence	1503256	KIDS KOUNTRY PRESCHOOL	70	2	
Total Coliform - Monitoring, Routine Major	Absence	1503336	GOLDEN EMPIRE CONCRETE COMPANY	44		1
Total Coliform - Monitoring, Routine Major	Absence	1503361	CAL MAT - PANAMA LANE FACILITY	42		1
Total Coliform - Non acute MCL	Absence	1503368	SOUTH FORK MIDDLE SCHOOL	180	1	
Total Coliform - Monitoring, Routine Major	Absence	1503378	WIND WOLVES PRESERVE	30		1
Arsenic	0.01	1503380	J G BOSWELL TOMATO COMPANY LLC	125	4	
Total Coliform - Monitoring, Routine Major	Absence	1503392	FOUR TWENTY 420 CLUB	150		2
Total Coliform - Non acute MCL	Absence	1503482	RIO MESA MUTUAL WATER COMPANY	25	1	
Total Coliform - Monitoring, Routine Minor	Absence	1503509	THE ANNE SIPPI CLINIC-RIVERSIDE RANCH	30		1
Total Coliform - Monitoring, Repeat Major	Absence	1503509	THE ANNE SIPPI CLINIC-RIVERSIDE RANCH	30		1
Fluoride -- Natural - Source	2	1503558	EL CAMINO PINES LUTHERAN CHURCH	70	4	

KERN							
Nitrate (As No3)	45	1503565	MURRAY FAMILY FARMS FRUIT STAND	50	1		
Total Coliform - Non acute MCL	Absence	1503576	ANTHONY VINEYARDS WATER SYSTEM	104	1		
Total Coliform - Non acute MCL	Absence	1503642	WEEKS WHOLESALE ROSE GROWER WATER SYSTEM	25	1		
Arsenic	0.01	1510001	ARVIN COMMUNITY SERVICES DIST	11847	4		
Arsenic	0.01	1510002	BORON CSD	2500	4		
Arsenic	0.01	1510005	DELANO, CITY OF	53855	4		
Arsenic	0.01	1510006	EAST NILES CSD	25500	4		
Arsenic	0.01	1510012	LAMONT PUBLIC UTILITY DIST	13296	3		
Arsenic	0.01	1510012	LAMONT PUBLIC UTILITY DIST	13296		1	
Haa5 - Haloacetic Acids (Five)	0.06	1510012	LAMONT PUBLIC UTILITY DIST	13296		1	
Trihalomethanes (TTHM) - Total	0.08	1510012	LAMONT PUBLIC UTILITY DIST	13296		1	
Arsenic	0.01	1510013	CITY OF MCFARLAND	12138		3	
Total Coliform - Non acute MCL	Absence	1510013	CITY OF MCFARLAND	12138	1		
Total Coliform - Monitoring, Routine Minor	Absence	1510013	CITY OF MCFARLAND	12138		2	
Haa5 - Haloacetic Acids (Five)	0.06	1510013	CITY OF MCFARLAND	12138		1	
Trihalomethanes (TTHM) - Total	0.08	1510013	CITY OF MCFARLAND	12138		1	
Arsenic	0.01	1510014	MOJAVE PUD	4000	4		
Total Coliform - Notification	Absence	1510014	MOJAVE PUD	4000		1	
Arsenic	0.01	1510016	RAND COMMUNITIES CWD - RANDSBURG	931	4		
Arsenic	0.01	1510017	INDIAN WELLS VALLEY W.D.	30000	4		
Trihalomethanes (TTHM) - Total	0.08	1510019	SHAFTER, CITY OF	15609	1		
Arsenic	0.01	1510024	GREENFIELD COUNTY WD	6500	1		
Arsenic	0.01	1510027	DESERT LAKE COMM SERV DIST	600	4		
Consumer Confidence Report	n/a	1510036	INYOKERN CSD	984		1	
Haa5 - Haloacetic Acids (Five)	0.06	1510046	LOST HILLS UTILITY DISTRICT	2772		1	
Trihalomethanes (TTHM) - Total	0.08	1510046	LOST HILLS UTILITY DISTRICT	2772		1	
Fluoride -- Natural - Source	2	1510051	LEBEC COUNTY WATER DISTRICT	830	3		
Total Coliform - Non acute MCL	Absence	1510051	LEBEC COUNTY WATER DISTRICT	830	2		
Arsenic	0.01	1510052	NORTH EDWARDS WD	650	4		
Arsenic	0.01	1510802	KERN VALLEY STATE PRISON	6546	4		
COUNTS/TOTALS				103	199426	198	61

KINGS							
Arsenic	0.01	1600004	FOUR SEASONS MOBILE HOME PARK	350	1		
Arsenic	0.01	1600004	FOUR SEASONS MOBILE HOME PARK	350		1	
Total Coliform - Non acute MCL	Absence	1600007	COUTURE FARMS	38	1		
Arsenic	0.01	1600010	LACEY COURTS MHP	66	1		
Arsenic	0.01	1600010	LACEY COURTS MHP	66		3	
Total Coliform - Non acute MCL	Absence	1600013	LAKESIDE ELEMENTARY SCHOOL	388	2		
Arsenic	0.01	1600014	KIT CARSON ELEM SCHOOL	510	1		
Arsenic	0.01	1600017	ISLAND UNION SCHOOL	300	2		
Total Coliform - Non acute MCL	Absence	1600022	WESTSIDE HARVESTING LLC	25	1		
Arsenic	0.01	1600050	CENTRAL VALLEY MEAT CO INC	280	2		
Arsenic	0.01	1600253	COS-HANFORD CENTER	515	1		
Total Coliform - Non acute MCL	Absence	1600253	COS-HANFORD CENTER	515	1		
Total Coliform - Non acute MCL	Absence	1600255	OVERLAND STOCKYARD	25	2		
Total Coliform - Non acute MCL	Absence	1600293	CHARDELLS	50	1		
Arsenic	0.01	1600296	CONAGRA FOOD INGREDIENTS	75	1		
Arsenic	0.01	1600504	HAMBLIN MUTUAL WATER CO	80	1		
Arsenic	0.01	1600504	HAMBLIN MUTUAL WATER CO	80		1	
Total Coliform - Non acute MCL	Absence	1600602	NICHOLS FARMS	70	1		
Total Coliform - Non acute MCL	Absence	1600603	MARKET 52	100	1		
Arsenic	0.01	1600605	BAKER COMMODITIES	47	1		
Total Coliform - Non acute MCL	Absence	1600605	BAKER COMMODITIES	47	4		
Arsenic	0.01	1610001	ARMONA COMMUNITY SERVICES DIST	3239	4		
Trihalomethanes (TTHM) - Total	0.08	1610002	AVENAL, CITY OF	16223	4		
Arsenic	0.01	1610003	HANFORD, CITY OF	53320	3		
Total Coliform - Non acute MCL	Absence	1610003	HANFORD, CITY OF	53320	1		
Arsenic	0.01	1610005	LEMOORE, CITY OF	24500	4		
Total Coliform - Monitoring, Routine Major	Absence	1610006	STRATFORD PUD	837		1	
Total Coliform - Monitoring, Repeat Minor	Absence	1610006	STRATFORD PUD	837		1	
Arsenic	0.01	1610007	HOME GARDEN CSD	1750		4	
Total Coliform - Non acute MCL	Absence	1610007	HOME GARDEN CSD	1750		3	
Total Coliform - Monitoring, Routine Minor	Absence	1610007	HOME GARDEN CSD	1750		1	
Arsenic	0.01	1610009	KETTLEMAN CITY CSD	1499	4		
Trihalomethanes (TTHM) - Total	0.08	1610700	LEMOORE NAVAL AIR STATION	10130	4		
COUNTS/TOTALS				24	114417	49	15

LAKE							
LCR - Routine&followup monitoring	MR	1700501	ADAMS SPRINGS WATER DISTRICT	200		1	
LCR - Routine&followup monitoring	MR	1700518	LOCH LOMOND MUTUAL WATER CO	679		1	
Trihalomethanes (TTHM) - Total	0.08	1700519	CRESCENT BAY IMPROVEMENT COMPANY	18		1	
Haa5 - Haloacetic Acids (Five)	0.06	1700519	CRESCENT BAY IMPROVEMENT COMPANY	18		1	
Trihalomethanes (TTHM) - Total	0.08	1700526	PINE GROVE WATER SYSTEM	304		1	
Haa5 - Haloacetic Acids (Five)	0.06	1700526	PINE GROVE WATER SYSTEM	304		1	
LCR - Routine&followup monitoring	MR	1700526	PINE GROVE WATER SYSTEM	304		1	
Consumer Confidence Report	n/a	1700536	SUNRISE SHORE MUTUAL WATER COMPANY	45		1	
ESWTR - turbidity >0.3 NTU (44)	TT	1700568	RIVIERA WEST MUTUAL WATER CO.	550	1		
Total Coliform - Non acute MCL	Absence	1700589	BLUE LAKES MOBILE HOME PARK	50	1		
Total Coliform - Monitoring, Repeat Major	Absence	1700589	BLUE LAKES MOBILE HOME PARK	50		1	
Public Notice Rule violation for an NPDWR violat	n/a	1700596	LAKEVIEW HAVEN RESORT	140		1	
Haa5 - Haloacetic Acids (Five)	0.06	1700609	LAZY S MOBILE RANCH	73	1		
Total Coliform - Non acute MCL	Absence	1700650	JELLYSTONE PARK	200	1		
Total Coliform - Monitoring, Repeat Minor	Absence	1700650	JELLYSTONE PARK	200		2	
Bromate (running average/quarterly)	0.01	1700716	GUENOC WINERY	30	2		
Bromate (running average/quarterly)	0.01	1700716	GUENOC WINERY	30		1	
SWTR-filtered sys-monitoring (36)	MR	1710004	LAKEPORT, CITY OF	5200		1	
LCR - Routine&followup monitoring	MR	1710012	COBB AREA COUNTY WATER DISTRICT	2500		1	
Trihalomethanes (TTHM) - Total	0.08	1710018	LAKE COUNTY CSA 2 - SPRING VALLEY	1018	3		
COUNTS/TOTALS				14	11007	9	15
LASSEN							
Total Coliform - Non acute MCL	Absence	1800503	SUSAN RIVER PARK WATER CO.	48	3		
Total Coliform - Non acute MCL	Absence	1800511	LAKE FOREST MUTUAL W.C.	568	2		
Total Coliform - Non acute MCL	Absence	1800521	HERLONG MOBILEHOME PARK	23	1		
Total Coliform - Monitoring, Routine Major	Absence	1800522	HONEY LAKE CAMPGROUND	17		1	
Total Coliform - Monitoring, Routine Major	Absence	1800534	SPAULDING EAGLE LAKE MWC	325		1	
Total Coliform - Non acute MCL	Absence	1800542	MNF-WILLOW CREEK CG	25	1		
Total Coliform - Non acute MCL	Absence	1800589	LNF-BOGARD REST STOP	20	1		
Total Coliform - Non acute MCL	Absence	1800601	LNF-EAGLE LAKE CAMPGROUNDS	200	1		
COUNTS/TOTALS				8	1226	9	2

LOS ANGELES							
Haa5 - Haloacetic Acids (Five)	0.06	1900523	WHITE FENCE FARMS MWC NO.3	567		1	
Trihalomethanes (TTHM) - Total	0.08	1900523	WHITE FENCE FARMS MWC NO.3	567		1	
Nitrate (As No3)	45	1910001	CITY OF ALHAMBRA	92158	1		
Total Coliform - Non acute MCL	Absence	1910002	AMARILLO MUTUAL WATER COMPANY	3134	1		
Total Coliform - Non acute MCL	Absence	1910018	BELLFLOWER MUNICIPAL WATER SYSTEM	5907	1		
Chlorine	4.0	1910053	HEMLOCK MUTUAL WATER CO.	950		4	
LCR - Initial monitoring	MR	1910053	HEMLOCK MUTUAL WATER CO.	950		1	
Total Coliform - Monitoring, Routine Minor	Absence	1910097	NORTHROP GRUMMAN CORP.	2778		1	
Haa5 - Haloacetic Acids (Five)	0.06	1910189	SAN GABRIEL VALLEY WATER CO.-MONTEBELLO	5520		1	
Trihalomethanes (TTHM) - Total	0.08	1910189	SAN GABRIEL VALLEY WATER CO.-MONTEBELLO	5520		1	
Arsenic	0.01	1910246	LAND PROJECT MUTUAL WATER CO.	1500	4		
Total Coliform - Monitoring, Routine Major	Absence	1910246	LAND PROJECT MUTUAL WATER CO.	1500		1	
Arsenic	0.01	1910249	WHITE FENCE FARMS MUTUAL WATER CO.	1760		4	
Total Coliform - Monitoring, Repeat Minor	Absence	1910254	HUNGRY VALLEY STATE VEHICULAR REC AREA	260		1	
COUNTS/TOTALS				10	26645	7	16
MADERA							
Total Coliform - Monitoring, Routine Major	Absence	2000048	YOSEMITE BIBLE CAMP	200		1	
Nitrate (As No3)	45	2000258	YOSEMITE FORKS MTN HOUSE RESTAURANT	50		1	
Total Coliform - Monitoring, Routine Major	Absence	2000258	YOSEMITE FORKS MTN HOUSE RESTAURANT	50		1	
Gross Alpha	15 pCi/L	2000293	MD#46 AHWAHNEE RESORTS	300	4		
Arsenic	0.01	2000293	MD#46 AHWAHNEE RESORTS	300	3		
Nitrate (As No3)	45	2000377	S & J RANCH - OFFICE	43		1	
Arsenic	0.01	2000502	BASS LAKE HEIGHTS MUTUAL WATER	250	12		
Nitrate (As No3)	45	2000505	LUPINE BASS LAKE(water)	1340		1	
Total Coliform - Monitoring, Routine Major	Absence	2000505	LUPINE BASS LAKE(water)	1340		2	
Gross Alpha	15 pCi/L	2000506	SIERRA LINDA MUTUAL WATER CO	180	1		
Uranium	30 µg/L	2000506	SIERRA LINDA MUTUAL WATER CO	180	2		
Arsenic	0.01	2000506	SIERRA LINDA MUTUAL WATER CO	180	4		
Total Coliform - Non acute MCL	Absence	2000507	WARNOCK FOOD PRODUCTS #2	40	1		
Total Coliform - Monitoring, Routine Major	Absence	2000507	WARNOCK FOOD PRODUCTS #2	40		1	
Gross Alpha	15 pCi/L	2000509	CASCADEL MUTUAL WATER SYSTEM	300	1		
Uranium	30 µg/L	2000509	CASCADEL MUTUAL WATER SYSTEM	300	1		

MADERA						
Arsenic	0.01	2000512	EAST ACRES MUTUAL WATER COMPANY	250	7	
Total Coliform - Monitoring, Routine Major	Absence	2000514	WAGON WHEEL SUPER MARKET	40		2
Total Coliform - Monitoring, Routine Major	Absence	2000516	ROCK CREEK CAMPGROUND(water)	90		2
Nitrate (As No3)	45	2000518	MAMMOTH POOL/FOREST SERVICE(water)	225		1
Total Coliform - Monitoring, Routine Major	Absence	2000518	MAMMOTH POOL/FOREST SERVICE(water)	225		2
Gross Alpha	15 pCi/L	2000526	PIKE RANCH MUTUAL WATER CO	75	1	
Total Coliform - Non acute MCL	Absence	2000526	PIKE RANCH MUTUAL WATER CO	75	1	
Arsenic	0.01	2000527	YOSEMITE FORKS ESTATES MUTUAL WTR	110	2	
Perchlorate	0.006	2000529	BONADELLE RANCHOS MUTUAL WATER	50		1
Nitrate (As No3)	45	2000530	CRASS MUTUAL WATER COMPANY	80		1
Total Coliform - Non acute MCL	Absence	2000533	SUGAR PINE HOMEOWNERS ASSOC	120	1	1
Total Coliform - Monitoring, Routine Major	Absence	2000533	SUGAR PINE HOMEOWNERS ASSOC	120		2
Arsenic	0.01	2000534	LEISURE ACRES MUTUAL WATER COMPANY	45	2	
Total Coliform - Monitoring, Routine Major	Absence	2000534	LEISURE ACRES MUTUAL WATER COMPANY	45		1
Total Coliform - Monitoring, Routine Major	Absence	2000535	BEASORE MEADOWS	100		1
Arsenic	0.01	2000538	CEDAR VALLEY MUTUAL WATER CO	137	4	
Arsenic	0.01	2000550	MD#06 LAKE SHORE PARK	130	9	
Gross Alpha	15 pCi/L	2000550	MD#06 LAKE SHORE PARK	130	2	
Gross Alpha	15 pCi/L	2000551	MD#07 MARINA VIEW HEIGHTS	200	1	
Arsenic	0.01	2000551	MD#07 MARINA VIEW HEIGHTS	200	3	
Nitrate (As No3)	45	2000556	PUTNEY RANCH CAMP	80		2
Total Coliform - Non acute MCL	Absence	2000556	PUTNEY RANCH CAMP	80	1	
Total Coliform - Monitoring, Routine Major	Absence	2000556	PUTNEY RANCH CAMP	80		1
Arsenic	0.01	2000561	MD#08 NORTH FORK WATER SYSTEM	264	5	
Total Coliform - Monitoring, Routine Major	Absence	2000563	EMERALD COVE CAMP	150		1
Arsenic	0.01	2000567	YOSEMITE HIGH SCHOOL	1100	3	
Nitrate (As No3)	45	2000587	YOSEMITE SOUTH KOA	350		2
Total Coliform - Monitoring, Routine Major	Absence	2000587	YOSEMITE SOUTH KOA	350		1
Nitrate (As No3)	45	2000589	MAMMOTH POOL MOBILE HOME PARK	60		4
Perchlorate	0.006	2000589	MAMMOTH POOL MOBILE HOME PARK	60		4
Total Coliform - Non acute MCL	Absence	2000589	MAMMOTH POOL MOBILE HOME PARK	60	1	
Total Coliform - Monitoring, Routine Major	Absence	2000589	MAMMOTH POOL MOBILE HOME PARK	60		1
Total Coliform - Monitoring, Routine Major	Absence	2000592	TWO TWENTY FOUR MOBILE HOME PK	30		1

MADERA						
Total Coliform - Monitoring, Routine Major	Absence	2000595	COUNTRY LIVING MHP	450		1
Total Coliform - Non acute MCL	Absence	2000597	DAIRYLAND SCHOOL	250	1	
Dibromochloropropane (Dbcp)	0.0002	2000600	HOWARD ELEMENTARY SCHOOL	673	1	
Nitrate (As No3)	45	2000605	WHISPERING PINES MHP	41	1	
Arsenic	0.01	2000612	NORTH FORK UNION SCHOOL	400	4	
Total Coliform - Monitoring, Routine Major	Absence	2000613	OAKHURST ELEMENTARY SCHOOL	329		2
Total Coliform - Monitoring, Routine Major	Absence	2000614	OAK CREEK INTERMEDIATE SCHOOL	217		2
Total Coliform - Non acute MCL	Absence	2000616	WASUMA SCHOOL	311	1	
Total Coliform - Monitoring, Routine Major	Absence	2000616	WASUMA SCHOOL	311		2
Arsenic	0.01	2000619	COLD SPRING GRANITE CO RAYMOND	10	4	
Total Coliform - Monitoring, Routine Major	Absence	2000637	DELGADO S WATER SYSTEM	35		2
Total Coliform - Monitoring, Routine Major	Absence	2000647	JOHN HOVANNISIAN WATER SYSTEM	80		3
Dibromochloropropane (Dbcp)	0.0002	2000659	CONSTELLATION WINE CO. MISSION BELL	450	1	
Nitrate (As No3)	45	2000659	CONSTELLATION WINE CO. MISSION BELL	450		2
Total Coliform - Monitoring, Routine Major	Absence	2000659	CONSTELLATION WINE CO. MISSION BELL	450		1
Total Coliform - Non acute MCL	Absence	2000660	SAINT-GOBAIN CONTAINERS	354	2	
Total Coliform - Non acute MCL	Absence	2000672	ROBERT JOHNSON FARMS	40	1	
Arsenic	0.01	2000688	ECCO	100	2	
Total Coliform - Monitoring, Routine Minor	Absence	2000695	MADERA CENTER COMMUNITY COLLEGE	2500		1
Perchlorate	0.006	2000724	SA#14 CHUK CHANSE SUBDIVISION	100		1
Total Coliform - Non acute MCL	Absence	2000727	MD#36 EASTIN ARCOLA	150	2	
Total Coliform - Non acute MCL	Absence	2000733	PG&E OAKHURST SERVICE CENTER	40	2	
Arsenic	0.01	2000737	MD#42 STILL MEADOW	100	8	
Total Coliform - Monitoring, Routine Major	Absence	2000743	OAK ROOM THE	65		2
Total Coliform - Monitoring, Routine Major	Absence	2000764	OAKHURST LODGE INC	120		3
Arsenic	0.01	2000785	VALLEY TEEN RANCH	50	4	
Total Coliform - Monitoring, Routine Major	Absence	2000785	VALLEY TEEN RANCH	50		2
Total Coliform - Non acute MCL	Absence	2000807	CALIFORNIA VIPASSANA CENTER	125	3	
Total Coliform - Non acute MCL	Absence	2000811	ED S CORNER(Water Only)	35	1	
Total Coliform - Monitoring, Routine Major	Absence	2000819	GRAAS FAMILY LTD PARTNERSHIP	41		2
Gross Alpha	15 pCi/L	2000828	SHADY OAKS MOBILE HOME PARK	40	1	
Nitrate (As No3)	45	2000829	SILVER CREEK CENTER	64		1
Total Coliform - Monitoring, Routine Major	Absence	2000847	SWEETWATER STEAKHOUSE & SALOON	600		1

MADERA							
Nitrate (As No3)	45	2000852	TACKLE BOX TOO, THE	35		1	
Total Coliform - Monitoring, Routine Major	Absence	2000855	LAMANUZZI & PANTALEO CS & DEHY	25		1	
Nitrate (As No3)	45	2000856	MAMMOTH POOL RESORT	50		1	
Total Coliform - Non acute MCL	Absence	2000857	LAGORIO FARMING COMPANY INC-BERENDA	500	1		
Total Coliform - Non acute MCL	Absence	2000865	MD#58 SIERRA HIGHLANDS	75	2		
Arsenic	0.01	2000866	AGRILAND FARMING CO INC	190	1		
Uranium	30 µg/L	2000909	ZORIA FARMS	250	1		
Total Coliform - Non acute MCL	Absence	2000909	ZORIA FARMS	250	1		
Total Coliform - Non acute MCL	Absence	2000920	SAN JOAQUIN WINE COMPANY	90	1		
Total Coliform - Monitoring, Routine Major	Absence	2000920	SAN JOAQUIN WINE COMPANY	90		1	
Nitrate (As No3)	45	2000942	CHOWCHILLA CONG OF J W S	300		2	
Nitrite (As N)	1	2000942	CHOWCHILLA CONG OF J W S	300		1	
Nitrate (As No3)	45	2000943	PARADISE SPRINGS	26		1	
Total Coliform - Monitoring, Routine Major	Absence	2000943	PARADISE SPRINGS	26		1	
Nitrate (As No3)	45	2000944	KATY S TAQUERIA	50	1		
Total Coliform - Monitoring, Routine Major	Absence	2000944	KATY S TAQUERIA	50		1	
Total Coliform - Monitoring, Routine Major	Absence	2000945	ELIU GALVAN WATER SYSTEM	21		1	
Total Coliform - Non acute MCL	Absence	2010006	MADERA CSA NO 3 PARKSDALE	1188	1		
Arsenic	0.01	2010007	HILLVIEW WC-OAKHURST/SIERRA LAKES	3006	4		
Uranium	30 µg/L	2010007	HILLVIEW WC-OAKHURST/SIERRA LAKES	3006	4		
Arsenic	0.01	2010801	VALLEY STATE PRISON FOR WOMEN	4000	4		
Arsenic	0.01	2010801	VALLEY STATE PRISON FOR WOMEN	4000		1	
COUNTS/TOTALS				74	23965	132	79
MARIN							
Trihalomethanes (TTHM) - Total	0.08	2110001	INVERNESS PUBLIC UTILITY DIST	702	2		
Haa5 - Haloacetic Acids (Five)	0.06	2110005	BOLINAS COMMUNITY PUD	1200	2		
Trihalomethanes (TTHM) - Total	0.08	2110005	BOLINAS COMMUNITY PUD	1200	1		
Nitrate (As No3)	45	2110503	NPS PRNS - CAMPGROUNDS	1200		1	
COUNTS/TOTALS				3	3102	5	1

MARIPOSA							
Total Coliform - Monitoring, Routine Major	Absence	2202048	INDIAN FLAT R V PARK AND CAMPGROUND	100	1		
Total Coliform - Monitoring, Routine Major	Absence	2202048	INDIAN FLAT R V PARK AND CAMPGROUND	100			2
Total Coliform - Monitoring, Routine Minor	Absence	2203024	THE COTTAGES AT TENAYA LODGE	300			1
Total Coliform - Non acute MCL	Absence	2204054	MCPR- WOODLAND PARK	100			1
Total Organic Carbon (TOC) (1)	Failure	2210001	MARIPOSA PUBLIC UTILITY DIST	2000	1		
Haa5 - Haloacetic Acids (Five)	0.06	2210001	MARIPOSA PUBLIC UTILITY DIST	2000	3		
Arsenic	0.01	2210900	CEDAR LODGE RESORT	32	4		
Total Coliform - Non acute MCL	Absence	2210924	YOSEMITE WEST WATER SYSTEM	300	1		
Total Coliform - Non acute MCL	Absence	2210930	NEW LIFE CHRISTIAN FELLOWSHIP	130	2		
Total Coliform - Monitoring, Routine Major	Absence	2210937	MARIPOSA COUNTY PUBLIC WORKS DEPARTMENT	135			1

COUNTS/TOTALS				8	3097	12	5
----------------------	--	--	--	----------	-------------	-----------	----------

MENDOCINO							
Total Coliform - Monitoring, Repeat Minor	Absence	2300620	SEA FOAM LODGE	56			1
Trihalomethanes (TTHM) - Total	0.08	2300663	HARWOOD WATER SYSTEM	100			1
Haa5 - Haloacetic Acids (Five)	0.06	2300663	HARWOOD WATER SYSTEM	100			1
Total Coliform - Monitoring, Repeat Major	Absence	2300718	WAGON WHEEL MOTEL	25			1
Total Coliform - Non acute MCL	Absence	2300731	CITY OF 10,000 BUDDHAS	200	1		
Total Coliform - Monitoring, Routine Major	Absence	2300837	YOKAYO WATER SYSTEM	75			2
SWTR-filtered sys-monitoring (36)	MR	2300839	CAMP MENDOCINO	260			3
Trihalomethanes (TTHM) - Total	0.08	2300847	WHALE GULCH ELEMENTARY SCHOOL	45			1
Haa5 - Haloacetic Acids (Five)	0.06	2300847	WHALE GULCH ELEMENTARY SCHOOL	45			1
SWTR-filtered sys-monitoring (36)	MR	2300858	BLACK OAK FACILITY	200			1
SWTR - treatment technique (41)	TT	2310007	NORTH GUALALA WATER COMPANY	2595	1		
Arsenic	0.01	2310011	LAYTONVILLE COUNTY WATER DISTRICT	1301	1		
Trihalomethanes (TTHM) - Total	0.08	2310012	IRISH BEACH WATER DISTRICT	106			1
Haa5 - Haloacetic Acids (Five)	0.06	2310012	IRISH BEACH WATER DISTRICT	106			1
Trihalomethanes (TTHM) - Total	0.08	2310304	CSP-RUSSIAN GULCH STATE PARK	25			1
Haa5 - Haloacetic Acids (Five)	0.06	2310304	CSP-RUSSIAN GULCH STATE PARK	25			1
Total Coliform - Monitoring, Routine Major	Absence	2310313	CSP-MENDOCINO WOODLANDS	25			1
Total Coliform - Monitoring, Routine Major	Absence	2310800	CDF-PARLIN FORK CONSERVATION CAMP	140			1
Trihalomethanes (TTHM) - Total	0.08	2310800	CDF-PARLIN FORK CONSERVATION CAMP	140			1
Haa5 - Haloacetic Acids (Five)	0.06	2310800	CDF-PARLIN FORK CONSERVATION CAMP	140			1

COUNTS/TOTALS				14	5153	3	20
----------------------	--	--	--	-----------	-------------	----------	-----------

MERCED							
Total Coliform - Monitoring, Routine Major	Absence	2400082	STEVINSON STATE PRESCHOOL	25		1	
Nitrate (As No3)	45	2400122	LONGVIEW MENNONITE SCHOOL	79	1		
Total Coliform - Monitoring, Routine Major	Absence	2400233	GONZALES FOOD FACILITY	60		1	
Total Coliform - Monitoring, Routine Minor	Absence	2410003	GUSTINE CITY	5311		1	
Total Coliform - Non acute MCL	Absence	2410008	MEADOWBROOK WC	4400	1		
Trihalomethanes (TTHM) - Total	0.08	2410018	SANTA NELLA COUNTY WATER DISTRICT	1500	2		
Total Coliform - Non acute MCL	Absence	2410301	CDPR-MCCONNELL	140	1		
Total Coliform - Monitoring, Routine Minor	Absence	2410304	CDPR FOUR RIVERS DISTRICT-SAN LUIS CREEK	458		1	
Trihalomethanes (TTHM) - Total	0.08	2410950	DWR - SAN LUIS DIVISION O&M	650	4		
COUNTS/TOTALS				9	12623	9	4
MONO							
Total Coliform - Monitoring, Routine Major	Absence	2600502	BENTON STATION	25		2	
Total Coliform - Monitoring, Routine Major	Absence	2600649	CROWLEY LAKE FISH CAMP	25		1	
Total Coliform - Monitoring, Routine Major	Absence	2600658	POKONOBE LODGE REST./STORE	100		1	
Arsenic	0.01	2610003	BRIDGEPORT PUD	300	4		
COUNTS/TOTALS				4	450	4	4

MONTEREY

Total Coliform - Monitoring, Routine Major	Absence	2700503	ASSISI MWC	126		1
Total Coliform - Non acute MCL	Absence	2700509	OAK MANOR WS	71	2	
Nitrate (As No3)	45	2700511	NORMCO WC	928		1
Total Coliform - Monitoring, Routine Major	Absence	2700511	NORMCO WC	928		1
Lead and Copper Rule	MR	2700511	NORMCO WC	928		1
Total Coliform - Non acute MCL	Absence	2700547	DESMOND RD WS #03	55		1
Arsenic	0.01	2700552	ECHO VALLEY SCHOOL WS	503	2	
Arsenic	0.01	2700552	ECHO VALLEY SCHOOL WS	503		2
Perchlorate	0.006	2700558	PENTECOSTAL CHURCH WS	25	1	
Nitrate (As No3)	45	2700558	PENTECOSTAL CHURCH WS	25		1
Nitrate (As No3)	45	2700558	PENTECOSTAL CHURCH WS	25		1
Total Coliform - Monitoring, Routine Minor	Absence	2700558	PENTECOSTAL CHURCH WS	25		3
Total Coliform - Monitoring, Repeat Major	Absence	2700558	PENTECOSTAL CHURCH WS	25		1
Total Coliform - Monitoring, Routine Major	Absence	2700575	EL CAMINO REAL WS #16	29		1
Nitrate (As No3)	45	2700577	ELKHORN SCHOOL WS	545		1
Total Coliform - Acute MCL	Absence	2700594	HIDDEN VALLEY WA	51	1	
Total Coliform - Monitoring, Routine Major	Absence	2700594	HIDDEN VALLEY WA	51		1
Total Coliform - Monitoring, Routine Minor	Absence	2700594	HIDDEN VALLEY WA	51		1
Total Coliform - Monitoring, Repeat Major	Absence	2700594	HIDDEN VALLEY WA	51		1
Total Coliform - Monitoring, Routine Minor	Absence	2700598	MOSS LANDING SCHOOL WS **CLOSED**	575		1
Total Coliform - Monitoring, Repeat Major	Absence	2700598	MOSS LANDING SCHOOL WS **CLOSED**	575		2
Total Coliform - Non acute MCL	Absence	2700606	HIDDEN VIEWS MHP WS	75	1	
Total Coliform - Non acute MCL	Absence	2700622	OUTLOOK WA	45	1	
Total Coliform - Non acute MCL	Absence	2700636	ROYAL OAKS PARK WS	25	2	
Total Coliform - Non acute MCL	Absence	2700638	MAHER RD WS #05	51	1	
Total Coliform - Monitoring, Routine Major	Absence	2700674	PARADISE LAKE MWC	180		1
Total Coliform - Non acute MCL	Absence	2700682	PARADISE RD WS #09	250	1	
Total Coliform - Non acute MCL	Absence	2700702	PRUNEDALE MWC	252	1	
Total Coliform - Monitoring, Routine Major	Absence	2700703	CALVARY CHURCH INC WS	150		1
Total Coliform - Non acute MCL	Absence	2700705	PRUNEDALE SCHOOL WS	400	1	
Total Coliform - Monitoring, Routine Major	Absence	2700706	QUEEN MOTEL WS	250		1
Total Coliform - Non acute MCL	Absence	2700713	ROLLING HILLS RANCHO WA	177	1	
Total Coliform - Monitoring, Routine Major	Absence	2700713	ROLLING HILLS RANCHO WA	177		1

MONTEREY

Total Coliform - Non acute MCL	Absence	2700731	Z RANCH MWC	62	1	
Total Coliform - Monitoring, Routine Minor	Absence	2700731	Z RANCH MWC	62		1
Total Coliform - Monitoring, Repeat Major	Absence	2700731	Z RANCH MWC	62		1
Nitrate (As No3)	45	2700738	SAN MIGUEL WS #01	100	3	
Total Coliform - Monitoring, Routine Major	Absence	2700772	STRUVE RD WS #02	166		1
Total Coliform - Monitoring, Routine Major	Absence	2700775	TIERRA VERDE MWC	48		1
Total Coliform - Monitoring, Routine Minor	Absence	2700799	VISTA DEL TORO WS	87		1
Nitrate (As No3)	45	2700838	SPRING CANYON WA	99		1
Total Coliform - Non acute MCL	Absence	2700842	BAUMANN RD WS #01	40	3	
Total Coliform - Monitoring, Repeat Major	Absence	2700850	CENTRAL COAST GROWERS WS	55		1
Total Coliform - Non acute MCL	Absence	2700853	COLOR SPOT NURSERY WS #01	200	1	
Total Coliform - Non acute MCL	Absence	2700856	ALTMAN PLANTS WS #01	45	2	
Total Coliform - Monitoring, Routine Major	Absence	2700856	ALTMAN PLANTS WS #01	45		2
Total Coliform - Monitoring, Routine Minor	Absence	2700856	ALTMAN PLANTS WS #01	45		1
Total Coliform - Monitoring, Routine Minor	Absence	2700875	PAJARO VALLEY GREENHOUSE WS	110		1
Total Coliform - Monitoring, Routine Minor	Absence	2700964	BRADLEY UNION SCHOOL WS	39		1
Total Coliform - Monitoring, Repeat Major	Absence	2700964	BRADLEY UNION SCHOOL WS	39		1
Total Coliform - Monitoring, Repeat Major	Absence	2701001	PARAISO HOT SPRINGS WS	25		1
Total Coliform - Monitoring, Routine Minor	Absence	2701009	RIPPLEWOOD RESORT WS	10		1
Total Coliform - Monitoring, Routine Major	Absence	2701034	APPLE AVE WS #02	75		4
Total Coliform - Monitoring, Repeat Major	Absence	2701034	APPLE AVE WS #02	75		1
Total Coliform - Monitoring, Repeat Major	Absence	2701057	FOLETTA RD WS #01	100		1
Total Coliform - Monitoring, Routine Major	Absence	2701063	RIVER RD WS #25	65		2
Total Coliform - Monitoring, Repeat Major	Absence	2701063	RIVER RD WS #25	65		1
Total Coliform - Monitoring, Routine Major	Absence	2701109	ASSOCIATED TAGLINE WS	70		1
Total Coliform - Monitoring, Routine Minor	Absence	2701109	ASSOCIATED TAGLINE WS	70		1
Total Coliform - Non acute MCL	Absence	2701171	CHEVRON OIL FIELD WS	31	1	
Total Coliform - Monitoring, Routine Major	Absence	2701176	SOLEDAD MISSION WS	25		1
Total Coliform - Monitoring, Routine Major	Absence	2701183	SAN ANTONIO LAKE PARK NORTH WS	999		1
Fluoride -- Natural - Source	2	2701232	OLD NATIVIDAD RD WS #01	25		1
Total Coliform - Monitoring, Routine Minor	Absence	2701241	ENCINAL RD WS #01	41		1
Total Coliform - Monitoring, Repeat Major	Absence	2701257	GARRAPATA WC INC	150		1
Chlorine	4.0	2701257	GARRAPATA WC INC	150		1

MONTEREY

Total Coliform - Non acute MCL	Absence	2701263	PARTINGTON RIDGE MWC	75	9	
SWTR-filtered sys-monitoring (36)	MR	2701273	RIVERSIDE CAMPGROUND WS	100		3
Total Coliform - Monitoring, Routine Minor	Absence	2701278	RANCHO CHAPARRAL MWC	48		1
Chlorine	4.0	2701295	ESALEN INSTITUTE WS	200		1
Total Coliform - Non acute MCL	Absence	2701355	PRINCES CAMP RESORT WS	126	1	
Total Coliform - Monitoring, Routine Major	Absence	2701364	PEDRAZZI MWC	273		1
Arsenic	0.01	2701367	TIERRA MEADOWS HOA WS	63		1
Methyl-Tert-Butyl-Ether (MTBE)	0.013	2701422	OAKRIDGE SUBDIVISION MWC	66		1
Total Coliform - Non acute MCL	Absence	2701422	OAKRIDGE SUBDIVISION MWC	66	1	
Total Coliform - Non acute MCL	Absence	2701423	ECHO VALLEY RD WS #05	48	1	
Total Coliform - Non acute MCL	Absence	2701498	HARBOR VIEW WA	75	2	
Arsenic	0.01	2701503	MESA DEL TORO MWC	90	2	
Total Coliform - Non acute MCL	Absence	2701503	MESA DEL TORO MWC	90	1	
Total Coliform - Non acute MCL	Absence	2701542	GONZALES 76 STATION WS	200	3	
Total Coliform - Monitoring, Routine Major	Absence	2701542	GONZALES 76 STATION WS	200		2
Total Coliform - Monitoring, Routine Minor	Absence	2701553	POND-DEROSA OAKS WC	216		1
Total Coliform - Monitoring, Routine Major	Absence	2701575	BUENA VISTA CENTER WS	35		1
Total Coliform - Non acute MCL	Absence	2701633	PARADISE RD WS #21	48	2	
Total Coliform - Monitoring, Routine Major	Absence	2701633	PARADISE RD WS #21	48		1
Chlorine	4.0	2701658	ARROYO CENTER WC	130		1
Total Coliform - Monitoring, Routine Major	Absence	2701658	ARROYO CENTER WC	130		1
Total Coliform - Non acute MCL	Absence	2701659	CHAMISAL WA	376	1	
Chlorine	4.0	2701683	MOSS LANDING MWC	200		1
Total Coliform - Non acute MCL	Absence	2701683	MOSS LANDING MWC	200	1	
Total Coliform - Monitoring, Routine Major	Absence	2701701	BRADLEY-LOCKWOOD RD WS	39		1
Total Coliform - Non acute MCL	Absence	2701800	TULARCITOS MWC	85	1	
Nitrate (As No3)	45	2701876	MUSHROOM FARMS WS	75		1
Total Coliform - Monitoring, Routine Major	Absence	2701876	MUSHROOM FARMS WS	75		1
Total Coliform - Monitoring, Routine Major	Absence	2701888	CACHAGUA MUTUAL WS (#4)	55		1
Total Coliform - Monitoring, Routine Major	Absence	2701912	SPRECKELS LN WS #03	25		1
Total Coliform - Non acute MCL	Absence	2701926	MORO RD WS #09	210	1	
Total Coliform - Monitoring, Routine Major	Absence	2701926	MORO RD WS #09	210		1
Total Coliform - Monitoring, Repeat Major	Absence	2701926	MORO RD WS #09	210		1

MONTEREY

Total Coliform - Monitoring, Routine Minor	Absence	2701935	MOUNT TORO RANCHOS MWA	45		1
Total Coliform - Monitoring, Repeat Major	Absence	2701946	MISIONERO VEGETABLES WS	60		1
Total Coliform - Non acute MCL	Absence	2701956	PIONEER PLACE MWS	66	2	
Total Coliform - Non acute MCL	Absence	2702030	CYPRESS COMMUNITY CHURCH WS	200	1	
Arsenic	0.01	2702050	CHURCH OF THE GOOD SHEPHERD WS	50	1	
Total Coliform - Non acute MCL	Absence	2702055	VIERRA KNOLLS MWC	66	1	
Total Coliform - Non acute MCL	Absence	2702121	ROSEHART INDUSTRIAL PARK WS	75	1	
Total Coliform - Monitoring, Routine Major	Absence	2702172	STONEPINE RESORT WS	100		1
Total Coliform - Non acute MCL	Absence	2702180	GRAVES SCHOOL WS	56	1	
Total Coliform - Monitoring, Repeat Major	Absence	2702209	BIG SUR BAZAAR WS	100		1
Total Coliform - Non acute MCL	Absence	2702229	MANZANITA PARK WS	300	2	
Total Coliform - Non acute MCL	Absence	2702254	PACIFIC VALLEY SCHOOL WS	55	1	
Total Coliform - Monitoring, Routine Major	Absence	2702254	PACIFIC VALLEY SCHOOL WS	55		1
Total Coliform - Monitoring, Repeat Major	Absence	2702254	PACIFIC VALLEY SCHOOL WS	55		1
Total Coliform - Non acute MCL	Absence	2702255	ALL SAINTS CAMPGROUND WS	25	1	
Total Coliform - Non acute MCL	Absence	2702268	NEW CAMALDOLI HERMITAGE WS	25	2	
Total Coliform - Monitoring, Routine Major	Absence	2702268	NEW CAMALDOLI HERMITAGE WS	25		1
Nitrate (As No3)	45	2702293	ROD MCLELLAN BOTANICALS WS	45		1
Arsenic	0.01	2702370	SPCA WS	50	1	
Total Coliform - Non acute MCL	Absence	2702370	SPCA WS	50	1	
Total Coliform - Monitoring, Repeat Major	Absence	2702370	SPCA WS	50		1
Total Coliform - Non acute MCL	Absence	2702405	JENSEN MHP WS	56	4	
Total Coliform - Monitoring, Routine Major	Absence	2702405	JENSEN MHP WS	56		1
Total Coliform - Monitoring, Routine Major	Absence	2702453	MARINA LANDFILL WS	55		1
Total Coliform - Monitoring, Routine Minor	Absence	2702453	MARINA LANDFILL WS	55		1
Total Coliform - Non acute MCL	Absence	2702456	MRWPCA TREATMENT PLANT WS	25	1	
Total Coliform - Monitoring, Routine Major	Absence	2702466	SAN VICENTE MWC	90		1
Total Coliform - Monitoring, Routine Minor	Absence	2702475	FREE WILL BAPTIST CHURCH WS	80		1
Nitrate (As No3)	45	2702482	COLOR SPOT NURSERY WS #02	25		1
Total Coliform - Monitoring, Routine Major	Absence	2702482	COLOR SPOT NURSERY WS #02	25		1
Total Coliform - Monitoring, Repeat Major	Absence	2702482	COLOR SPOT NURSERY WS #02	25		1
Total Coliform - Non acute MCL	Absence	2702490	CENTRAL BAY HIGH SCHOOL WS	250	1	
Total Coliform - Non acute MCL	Absence	2702503	CARMEL VALLEY TENNIS CAMP WS	27	1	

MONTEREY							
Total Coliform - Monitoring, Repeat Major	Absence	2702503	CARMEL VALLEY TENNIS CAMP WS	27		1	
Total Coliform - Non acute MCL	Absence	2702520	ARROYO SECO ESTATES MWS	70	2		
Nitrate (As No3)	45	2702521	SANTA LUCIA PRESERVE WS	300		1	
Total Coliform - Monitoring, Routine Major	Absence	2702521	SANTA LUCIA PRESERVE WS	300		1	
Total Coliform - Monitoring, Repeat Major	Absence	2702521	SANTA LUCIA PRESERVE WS	300		1	
Total Coliform - Monitoring, Routine Major	Absence	2702526	BEAR S LAIR WS	25		1	
Total Coliform - Monitoring, Routine Major	Absence	2702544	SANCTUARY BIBLE CHURCH WS	25		1	
Total Coliform - Monitoring, Routine Major	Absence	2702561	KIRK CREEK CAMPGROUNDS WS	25		1	
Total Coliform - Non acute MCL	Absence	2702572	ALBA WS	70	4		
Total Coliform - Monitoring, Routine Major	Absence	2702575	TREE BONES RESORT WS	25		1	
ESWTR-filtered sys-monitoring (43)	TT	2702595	CACHAGUA COMM CTR WS	32	10		
Total Coliform - Non acute MCL	Absence	2702601	LEWIS RD WS #20	39	1		
Total Coliform - Monitoring, Routine Major	Absence	2702616	ALTMAN PLANTS WS #02	25		2	
Total Coliform - Non acute MCL	Absence	2702621	IVERSON RD WS #03	40	2		
Total Coliform - Monitoring, Routine Minor	Absence	2702621	IVERSON RD WS #03	40		1	
Fluoride -- Natural - Source	2	2702643	CYPRESS CENTER WS	40		2	
Total Coliform - Monitoring, Routine Major	Absence	2702643	CYPRESS CENTER WS	40		1	
Total Coliform - Non acute MCL	Absence	2702704	HARRIS RD WS #10	25	3		
Total Coliform - Monitoring, Routine Minor	Absence	2710003	MONTE DEL LAGO MHC	730		1	
Total Coliform - Non acute MCL	Absence	2710011	SOLEDAD, CITY OF	16146	1		
Arsenic	0.01	2710021	CAL AM WATER COMPANY - TORO	1296	4		
Nitrate (As No3)	45	2710702	FORT HUNTER LIGGETT	5500		1	
COUNTS/TOTALS				110	36627	101	113

NAPA

Total Coliform - Monitoring, Routine Major	Absence	2800025	HAGAFEN CELLARS	25		1
Total Coliform - Monitoring, Routine Major	Absence	2800027	NICKEL & NICKEL WINERY	25		1
Total Coliform - Monitoring, Routine Major	Absence	2800032	TERRA VALENTINE	25		1
Total Coliform - Monitoring, Routine Major	Absence	2800037	KATHRYN HALL WINERY	25		1
Total Coliform - Monitoring, Routine Major	Absence	2800042	FROGS LEAP WINERY	25		1
Total Coliform - Monitoring, Routine Major	Absence	2800044	LARKMEAD VINEYARDS	25		2
Total Coliform - Monitoring, Routine Major	Absence	2800103	NAPA L ATTITUDE	25		1
Total Coliform - Monitoring, Routine Major	Absence	2800186	TURTLE ROCK	25		1
Total Coliform - Monitoring, Routine Major	Absence	2800301	LAIRD FAMILY ESTATE	25		1
Total Coliform - Monitoring, Routine Major	Absence	2800527	LINDA FALLS TERRACE MUTUAL	35		1
Total Coliform - Monitoring, Routine Major	Absence	2800530	MEYERS WATER CO.	260		1
Total Coliform - Monitoring, Routine Major	Absence	2800548	SILVERADO PINES MOBILE HOME	255		2
Total Coliform - Monitoring, Routine Major	Absence	2800555	TWOMEY CELLARS	25		1
Total Coliform - Monitoring, Routine Major	Absence	2800557	CASTLE TROVE, INC.	25		1
Total Coliform - Monitoring, Routine Major	Absence	2800564	SODA CANYON STORE	50		1
Total Coliform - Monitoring, Routine Major	Absence	2800579	NAPA-SOLANO GIRL SCOUTS	150		1
Total Coliform - Monitoring, Routine Major	Absence	2800583	WELCOME GRANGE HALL	200		1
Total Coliform - Monitoring, Routine Major	Absence	2800593	R RANCH AT THE LAKE	28		1
Total Coliform - Monitoring, Routine Major	Absence	2800602	GLASS MTN TRAILER PARK	100		1
Total Coliform - Monitoring, Routine Major	Absence	2800609	PHELPS VINEYARDS	50		1
Total Coliform - Monitoring, Repeat Major	Absence	2800635	STRACK W.D. WATER	25		1
Total Coliform - Monitoring, Routine Major	Absence	2800683	COUNTRY INN, THE	29		1
Total Coliform - Monitoring, Routine Major	Absence	2800719	MUND S MOBILE HOME PARK	25		1
Total Coliform - Monitoring, Routine Major	Absence	2800736	DOMAINE CHANDON	200		1
Total Coliform - Monitoring, Routine Major	Absence	2801011	DOMAINE CARNEROS	25		1
Total Coliform - Monitoring, Repeat Major	Absence	2801016	HESS WINERY	100		1
Total Coliform - Monitoring, Routine Major	Absence	2801020	ESPINOZA WATER SYSTEM	30		2
Bromate (running average/quarterly)	0.01	2801024	MUMM OF NAPA VALLEY	50	1	
Total Coliform - Monitoring, Routine Major	Absence	2801026	OPUS ONE WINERY	100		1
Total Coliform - Monitoring, Routine Major	Absence	2801028	CARDINALE ESTATE	100		1
Total Coliform - Monitoring, Repeat Major	Absence	2801035	ROUND HILL WINERY	100		1
Total Coliform - Monitoring, Routine Major	Absence	2801038	SILVER OAKS WINE CELLARS	100		1
Total Coliform - Monitoring, Routine Major	Absence	2801041	SILVERADO VINEYARDS	100		1

NAPA							
Total Coliform - Monitoring, Routine Major	Absence	2801047	STAG S LEAP WINE CELLARS	40		1	
Total Coliform - Monitoring, Routine Major	Absence	2801049	THE RANCH WINERY	200		2	
Total Coliform - Monitoring, Routine Major	Absence	2802715	NORMAN ALUMBAUGH CO., INC.	10		1	
Total Coliform - Monitoring, Routine Major	Absence	2803137	MUCHO DINERO AQUA CIA WATER	10		1	
Total Coliform - Monitoring, Routine Major	Absence	2803657	WOODLAND RIDGE MUTUAL WATER CO	15		2	
Trihalomethanes (TTHM) - Total	0.08	2810001	HOWELL MOUNTAIN MUTUAL WATER COMPANY	1500	4		
Trihalomethanes (TTHM) - Total	0.08	2810001	HOWELL MOUNTAIN MUTUAL WATER COMPANY	1500		1	
Haa5 - Haloacetic Acids (Five)	0.06	2810001	HOWELL MOUNTAIN MUTUAL WATER COMPANY	1500	3		
Haa5 - Haloacetic Acids (Five)	0.06	2810001	HOWELL MOUNTAIN MUTUAL WATER COMPANY	1500		1	
Total Coliform - Monitoring, Routine Major	Absence	2810007	TOWN OF YOUNTVILLE	3000		1	
COUNTS/TOTALS				40	7162	8	45
NEVADA							
Total Coliform - Monitoring, Routine Major	Absence	2900088	SHINNEYBOO CREEK CABINS WATER SYSTEM	100		1	
Total Coliform - Monitoring, Routine Major	Absence	2900089	RIDGE STOP CAFE WATER SYSTEM	75		1	
Total Coliform - Monitoring, Repeat Major	Absence	2900089	RIDGE STOP CAFE WATER SYSTEM	75		1	
Total Coliform - Monitoring, Routine Major	Absence	2900501	BRASS RAIL WATER SYSTEM	150		1	
Total Coliform - Non acute MCL	Absence	2900529	SUNSET MOBILE HOME PARK WATER SYSTEM	60	1		
Total Coliform - Non acute MCL	Absence	2900530	ROUGH & READY MHP WATER SYSTEM	200	1		
Total Coliform - Non acute MCL	Absence	2900535	PLEASANT RIDGE SCHOOL WATER SYSTEM	140	1		
Total Coliform - Acute MCL	Absence	2900548	SIERRA ESTATES MUTUAL WATER COMPANY	75	2		
Total Coliform - Non acute MCL	Absence	2900562	ANANDA VILLAGE WATER SYSTEM	400	1		
Total Coliform - Monitoring, Routine Major	Absence	2900562	ANANDA VILLAGE WATER SYSTEM	400		1	
Total Coliform - Monitoring, Routine Major	Absence	2900587	MILHOUS CHILDREN SERVICES WATER SYSTEM	50		1	
Total Coliform - Non acute MCL	Absence	2900599	NEVADA IRRIGATION DISTRICT/SCOTT S FLAT	250	1		
Total Coliform - Monitoring, Routine Major	Absence	2900618	NELSON INDUSTRIAL PARK WATER SYSTEM	32		1	
Total Coliform - Monitoring, Routine Major	Absence	2901208	DONNER TRAIL ELEMENTARY SCHOOL WATER SYS	60		1	
Total Coliform - Monitoring, Routine Major	Absence	2902363	MISSION BETHEL CHURCH WATER SYSTEM	60		1	
Total Coliform - Monitoring, Routine Major	Absence	2902391	NORTH GOLD SENIOR MOUNTAINEERS WATER SYS	50		1	
Arsenic	0.01	2910011	PLAVADA COMMUNITY ASSOCIATION	300	4		
COUNTS/TOTALS				15	2002	11	10

ORANGE						
Total Coliform - Monitoring, Routine Minor	Absence	3000585	PAGE AVENUE MUTUAL WATER COMPANY	104		1
Uranium	30 µg/L	3000662	CATALINA STREET PUMP OWNERS	150	1	
Nitrate (As No3)	45	3000663	DIAMOND PARK MUTUAL WATER CO.	200	4	
Total Coliform - Monitoring, Routine Major	Absence	3000663	DIAMOND PARK MUTUAL WATER CO.	200		2
Total Coliform - Non acute MCL	Absence	3000852	RANCHO MISSION VIEJO	40	1	
Aluminum	1	3010094	TRABUCO CANYON WATER DISTRICT	14217	1	
DBP	n/a	3010097	MIDWAY CITY MUTUAL WC	1000		1
Total Coliform - Non acute MCL	Absence	3010097	MIDWAY CITY MUTUAL WC	1000	1	
Total Coliform - Monitoring, Routine Minor	Absence	3010097	MIDWAY CITY MUTUAL WC	1000		1
Chlorine	4.0	3010097	MIDWAY CITY MUTUAL WC	1000		1
Total Coliform - Monitoring, Routine Minor	Absence	3010101	SANTA MARGARITA WATER DISTRICT	155000		1
COUNTS/TOTALS				7	170711	8
PLACER						
SWTR-unfiltered sys-monitoring (31)	MR	3110015	FULTON WATER COMPANY	500		1
SWTR - treatment technique (41)	TT	3110015	FULTON WATER COMPANY	500	1	
Total Coliform - Non acute MCL	Absence	3110019	SQUAW VALLEY MWC	500	1	
Total Coliform - Non acute MCL	Absence	3110023	NORTH TAHOE PUD - CARNELIAN WOODS	600	1	
Trihalomethanes (TTHM) - Total	0.08	3110032	LAKE FOREST UTILITY COMPANY	50		1
Total Coliform - Monitoring, Routine Minor	Absence	3110034	CHRISTIAN VALLEY PARK CSD	2000		2
Total Coliform - Non acute MCL	Absence	3110043	MADDEN CREEK WATER COMPANY	300	1	
Lead	0.015	3110049	TAHOE PARK WATER CO - SKYLAND/NIELSEN	50		1
COUNTS/TOTALS				7	4000	4

PLUMAS							
Total Coliform - Non acute MCL	Absence	3200018	SIERRA BIBLE CAMP	200	1		
Total Coliform - Non acute MCL	Absence	3200030	ELWELL LAKES LODGE	45	1		
Total Coliform - Monitoring, Routine Major	Absence	3200033	PNF LONG POINT CG	40		1	
Total Coliform - Non acute MCL	Absence	3200037	PNF BIG COVE CG	80	1		
Total Coliform - Non acute MCL	Absence	3200038	PNF COTTONWOOD CG.- FRENCHMAN ADM.	40	1		
Total Coliform - Non acute MCL	Absence	3200039	PNF CHILCOOT CG	40	2		
Total Coliform - Non acute MCL	Absence	3200046	PNF NORTH FORK/QUEEN LILY CG	40	1		
Total Coliform - Monitoring, Routine Major	Absence	3200046	PNF NORTH FORK/QUEEN LILY CG	40		1	
Total Coliform - Non acute MCL	Absence	3200048	PNF MT. HOUGH RANGER STATION	100	2		
Total Coliform - Non acute MCL	Absence	3200049	SIERRA SPRINGS RESORT	30	1		
Total Coliform - Monitoring, Routine Minor	Absence	3200049	SIERRA SPRINGS RESORT	30		1	
Total Coliform - Non acute MCL	Absence	3200054	BIG MEADOWS SUBDIVISION	38	2		
Total Coliform - Non acute MCL	Absence	3200058	CROMBERG SPRING WATER ASSOCIATION	18	8		
Total Coliform - Monitoring, Routine Major	Absence	3200071	BUCKS LAKE LODGE	40		1	
Total Coliform - Monitoring, Routine Major	Absence	3200078	FRCCSD-OLD MILL RANCH	32		1	
Total Coliform - Non acute MCL	Absence	3200105	FRCCSD-TOBIN	19	1		
Total Coliform - Non acute MCL	Absence	3200107	GRIZZLY LAKE RID-CROCKER/WELCH	215	3		
Total Coliform - Monitoring, Routine Major	Absence	3200118	LAKE COVE RESORT	120		2	
Total Coliform - Non acute MCL	Absence	3200134	BLAIRSDEN WATER USERS ASSOC.	200	2		
Total Coliform - Non acute MCL	Absence	3200135	ALMANOR COMMUNITY WELL MWC	33	2		
Total Coliform - Non acute MCL	Absence	3200150	HAMILTON BRANCH MUTUAL W.C.	250	1		
Total Coliform - Non acute MCL	Absence	3200151	LAYMAN ASSOCIATION	50	1		
Total Coliform - Monitoring, Routine Minor	Absence	3200175	LA PORTE PINES COUNTRY CLUB	25		1	
Total Coliform - Monitoring, Routine Major	Absence	3200177	PANCAKE BAY MUTUAL WATER CO.	40		1	
Total Coliform - Non acute MCL	Absence	3200187	LIGHTNING TREE CG, PLUMAS NF	0	2		
Total Coliform - Monitoring, Routine Major	Absence	3200205	TWO RIVERS SOCCER CAMP	150		1	
Total Coliform - Non acute MCL	Absence	3200507	LA PORTE WATER DISTRICT	25	2		
Total Coliform - Non acute MCL	Absence	3205007	PNF SPANISH CREEK CG	30	1		
Total Coliform - Monitoring, Routine Major	Absence	3205007	PNF SPANISH CREEK CG	30		1	
Arsenic	0.01	3210003	CITY OF PORTOLA	2500	4		
Total Coliform - Non acute MCL	Absence	3210004	QUINCY COMMUNITY S.D.	1879	1		
Total Coliform - Non acute MCL	Absence	3210008	EAST QUINCY SERVICES DISTRICT	2572	1		
Arsenic	0.01	3210011	PLUMAS EUREKA CSD	1785	4		
Total Coliform - Non acute MCL	Absence	3210300	PLUMAS-EUREKA S.P.	194	1		
COUNTS/TOTALS				31	10830	46	11

RIVERSIDE							
LCR - Routine&followup monitoring	MR	3301879	SHARONDALE MESA HOA	330		1	
LCR - Routine&followup monitoring	MR	3310002	BEAUMONT CHERRY VALLEY WD	40000		1	
Chlorine	4.0	3310007	COACHELLA, CITY OF	42591		2	
Total Coliform - Monitoring, Routine Minor	Absence	3310008	MISSION SPRINGS WD	29802		1	
Nitrate (As No3)	45	3310016	HEMET, CITY OF	20395		1	
Haa5 - Haloacetic Acids (Five)	0.06	3310017	SOUTH MESA WC	12093		1	
Trihalomethanes (TTHM) - Total	0.08	3310017	SOUTH MESA WC	12093		1	
Total Coliform - Non acute MCL	Absence	3310018	HOME GARDENS COUNTY WD	3033	1		
Nitrite (As N)	1	3310022	LAKE HEMET MWD	50001		1	
Nitrate (As No3)	45	3310025	NORCO, CITY OF	27160		1	
Total Coliform - Monitoring, Repeat Minor	Absence	3310025	NORCO, CITY OF	27160		1	
Total Coliform - Monitoring, Repeat Minor	Absence	3310029	PERRIS, CITY OF	9000		1	
Dichloromethane	0.005	3310030	PINE COVE WATER DISTRICT	1000		1	
Toluene	0.15	3310030	PINE COVE WATER DISTRICT	1000		1	
Nitrate (As No3)	45	3310047	CABAZON WATER DISTRICT	2229		1	
Nitrate (As No3)	45	3310052	LAKE HEMET-GARNER VALLEY	765		1	
Nitrate (As No3)	45	3310080	LAKE HEMET MWD-CAMP GROUND	500		1	
Chlorine	4.0	3310082	NORTH PERRIS WATER SYSTEM	3300		1	
Total Coliform - Non acute MCL	Absence	3310501	JOSHUA TREE NP - COTTONWOOD SPRINGS	240	1		
Total Coliform - Monitoring, Routine Minor	Absence	3310501	JOSHUA TREE NP - COTTONWOOD SPRINGS	240		2	
LCR - Routine&followup monitoring	MR	3310802	CHUCKAWALLA VALLEY/IRONWOOD STATE PRISON	7370		1	
COUNTS/TOTALS				17	249809	2	21

SACRAMENTO

Total Coliform - Acute MCL	Absence	3400119	EDDO S HARBOR & R V PARK	75	1	
Total Coliform - Non acute MCL	Absence	3400119	EDDO S HARBOR & R V PARK	75	1	
Arsenic	0.01	3400130	GREGG WATER CO	40	1	
Arsenic	0.01	3400138	LOCKE WATER WORKS CO [SWS]	65	4	
Arsenic	0.01	3400149	RANCHO MARINA	75	4	
Arsenic	0.01	3400164	VIEIRA S RESORT, INC	150	12	
Total Coliform - Monitoring, Routine Major	Absence	3400204	THE LIBRARY LLC	50		2
Total Coliform - Non acute MCL	Absence	3400206	BRUNO S ISLAND	100	2	
Nitrate (As No3)	45	3400208	HAWKS TRUCK STOP	100		1
Arsenic	0.01	3400248	FRANKLIN ELEMENTARY SCHOOL	246	4	
Total Coliform - Monitoring, Routine Major	Absence	3400283	VALLEY HI COUNTRY CLUB	100		2
Total Coliform - Monitoring, Repeat Minor	Absence	3400283	VALLEY HI COUNTRY CLUB	100		1
Total Coliform - Monitoring, Routine Major	Absence	3400303	DELTA BEACH RESORTS [SWS]	50		1
Arsenic	0.01	3400332	OXBOW MARINA	200	5	
Nitrate (As No3)	45	3400333	SWABBIES	30		1
Nitrate (As No3)	45	3400387	BLUE DIAMOND GROWERS	500		1
Total Coliform - Monitoring, Repeat Minor	Absence	3400359	HAMILTON STREET PARK	100		1
Arsenic	0.01	3400364	HARVEY,JEAN SCHOOL	25	1	
Total Coliform - Non acute MCL	Absence	3400380	BERT S DINER	60	2	
Total Coliform - Monitoring, Routine Major	Absence	3400380	BERT S DINER	60		1
Total Coliform - Non acute MCL	Absence	3400381	PITTS STOP RESTAURANT	60	1	
Total Coliform - Monitoring, Repeat Major	Absence	3400381	PITTS STOP RESTAURANT	60		1
Total Coliform - Monitoring, Repeat Major	Absence	3400399	KUHN WATER SYSTEM	100		2
Nitrate (As No3)	45	3400402	SHELDON ACRES DEV CENTER	100		1
Nitrite (as N)	1	3400424	ARCO AM PM	150		1
Arsenic	0.01	3400433	EDGEWATER MOBILE HOME PARK	29	3	
Total Coliform - Non acute MCL	Absence	3400444	SHERMAN LAKE MARINA	34	1	
Total Coliform - Monitoring, Routine Major	Absence	3400446	GIL S SERVICE	25		1
Total Coliform - Non acute MCL	Absence	3400451	TEICHERT PERKINS	25	1	
Total Coliform - Monitoring, Routine Major	Absence	3400454	VILLAGE BRADSHAW	100		1
Nitrate (As No3)	45	3410001	SACRAMENTO SUBURBAN WATER DISTRICT	171200		1
Arsenic	0.01	3410011	GALT, CITY OF	22982	4	
Haa5 - Haloacetic Acids (Five)	0.06	3410018	RIO LINDA/ELVERTA COMMUNITY WATER DIST	13386		2

SACRAMENTO						
Trihalomethanes (TTHM) - Total	0.08	3410018	RIO LINDA/ELVERTA COMMUNITY WATER DIST	13386		2
Consumer Confidence Report	n/a	3410018	RIO LINDA/ELVERTA COMMUNITY WATER DIST	13386		1
COUNTS/TOTALS				29	210157	47
SAN BENITO						
Trihalomethanes (TTHM) - Total	0.08	3500006	CSA NO. 31 STONEGATE WS	252	3	
Total Coliform - Non acute MCL	Absence	3500505	THOUSAND TRAILS SAN BENITO PRESERVE	1000	1	
Total Coliform - Monitoring, Routine Minor	Absence	3500505	THOUSAND TRAILS SAN BENITO PRESERVE	1000		1
Total Coliform - Monitoring, Repeat Minor	Absence	3500505	THOUSAND TRAILS SAN BENITO PRESERVE	1000		2
SWTR	TT	3500507	BITTERWATER-TULLY SCHOOL WS	55	1	
Total Coliform - Non acute MCL	Absence	3500521	SOUTHSIDE ELEMENTARY SCHOOL	284	1	
Total Coliform - Monitoring, Repeat Minor	Absence	3500521	SOUTHSIDE ELEMENTARY SCHOOL	284		1
Consumer Confidence Report	n/a	3500527	VALENZUELA WATER SYSTEM	55		1
Nitrate (As No3)	45	3500537	ST. FRANCIS RETREAT CENTER	145		1
Public Notice Rule violation for an NPDWR violat	n/a	3500547	CEDAR HOUSE RESTAURANT	500		1
Trihalomethanes (TTHM) - Total	0.08	3500552	VENTURE ESTATES MWC	60	3	
Total Coliform - Monitoring, Routine Minor	Absence	3500557	33RD DISTRICT AGRICULTURAL ASSOCIATION	8875		2
Alachlor	0.002	3500565	FAIRVIEW CHILD DEVELOPMENT CENTER	70		1
Arsenic	0.01	3500565	FAIRVIEW CHILD DEVELOPMENT CENTER	70	2	
Nitrate (As No3)	45	3500565	FAIRVIEW CHILD DEVELOPMENT CENTER	70		2
Chlorine	4.0	3500565	FAIRVIEW CHILD DEVELOPMENT CENTER	70	3	
Haa5 - Haloacetic Acids (Five)	0.06	3500565	FAIRVIEW CHILD DEVELOPMENT CENTER	70		1
Trihalomethanes (TTHM) - Total	0.08	3500565	FAIRVIEW CHILD DEVELOPMENT CENTER	70		1
Consumer Confidence Report	n/a	3500565	FAIRVIEW CHILD DEVELOPMENT CENTER	70		1
Consumer Confidence Report	n/a	3500570	B & R FARMS	25		1
Consumer Confidence Report	n/a	3500571	SAN BENITO HIGH SCHOOL	3125		1
Total Coliform - Non acute MCL	Absence	3500806	BLOSSOM HILL WINERY	60	2	
Total Coliform - Monitoring, Routine Minor	Absence	3500806	BLOSSOM HILL WINERY	60		2
Nitrate (As No3)	45	3500816	QUINTERO LABOR CAMP #2	15		1
Nitrate (As No3)	45	3500825	UNION HEIGHTS MWC	98		1
Nitrite (As N)	1	3500825	UNION HEIGHTS MWC	98		1
Total Coliform - Non acute MCL	Absence	3500900	ASHFORD HIGHLANDS MWC	85	1	
Total Coliform - Monitoring, Routine Major	Absence	3500900	ASHFORD HIGHLANDS MWC	85		1

SAN BENITO						
Total Coliform - Monitoring, Repeat Minor	Absence	3500900	ASHFORD HIGHLANDS MWC		85	1
Total Coliform - Monitoring, Routine Major	Absence	3500906	HAYDON FAMILY FARM & PARK		5000	2
Total Coliform - Monitoring, Routine Major	Absence	3500912	COMSTOCK MUTUAL WATER COMPANY		100	1
Public Notice Rule violation for an NPDWR violat	n/a	3500920	PAICINES WATER SYSTEM		50	1
SWTR	TT	3500924	EL MODENO NURSERY INC.		120	1
Total Coliform - Monitoring, Routine Major	Absence	3510300	CSP-FREMONT PEAK		250	1
Nitrate (As No3)	45	3510302	CSP HOLLISTER HILLS SVRA		2500	1
COUNTS/TOTALS				22	22724	18
SAN BERNARDINO						
Total Coliform - Non acute MCL	Absence	3600036	CALICO GHOST TOWN		10	1
Total Coliform - Non acute MCL	Absence	3600063	CAMP ANGELUS TR LAND ASSN		25	1
Total Coliform - Non acute MCL	Absence	3600139	JUBILEE MWC		855	1
Total Coliform - Monitoring, Routine Major	Absence	3600175	BARSTOW DAGGET AIRPORT		25	1
Total Coliform - Non acute MCL	Absence	3600185	OAK GLEN DOMESTIC WATER		175	1
Total Coliform - Non acute MCL	Absence	3600306	THUNDERBIRD CWD		720	1
Total Coliform - Monitoring, Routine Major	Absence	3600306	THUNDERBIRD CWD		720	1
Total Coliform - Non acute MCL	Absence	3600308	DEER PARK NUDIST RESORT/BUFF CREEK		500	1
Total Coliform - Non acute MCL	Absence	3600316	UNION PACIFIC RR/YERMO		25	1
Total Coliform - Non acute MCL	Absence	3600371	CALIZONA TRAILER PARK		10	1
Total Coliform - Non acute MCL	Absence	3600372	PALMS RIVER RESORT		200	1
Total Coliform - Monitoring, Routine Major	Absence	3600385	BROOKSIDE MOBILE HOME PARK		100	1
Total Coliform - Monitoring, Routine Major	Absence	3600388	DESERT VIEW MOBILE PARK		130	1
Total Coliform - Monitoring, Routine Major	Absence	3600391	HILL CREST MOBILE EST INC		900	1
Total Coliform - Monitoring, Routine Major	Absence	3600452	LUCERNE VALLEY PARKS & REC (CSA 29)		26	1
Total Coliform - Monitoring, Routine Major	Absence	3600453	APPLE VALLEY HORSEMAN CENTER		25	1
Arsenic	0.01	3600504	KNOLL ENTERPRISES INC		500	1
Total Coliform - Monitoring, Routine Major	Absence	3600532	CAMP SKY MEADOWS		150	1
Total Coliform - Monitoring, Routine Major	Absence	3600536	CAMP LA VERNE INC		25	1
Total Coliform - Monitoring, Routine Major	Absence	3600540	THE PALMS		25	1
Total Coliform - Monitoring, Routine Major	Absence	3600577	IRON HOG SALOON		25	1
Total Coliform - Monitoring, Routine Major	Absence	3600593	CAMP CEDAR CREST		300	1
Total Coliform - Monitoring, Routine Major	Absence	3600608	TWENTYNINE PALMS INN / 29 PALMS INN		25	1

SAN BERNARDINO

Total Coliform - Monitoring, Routine Major	Absence	3600615	ACE MOTEL	25		1
Total Coliform - Monitoring, Routine Major	Absence	3600707	SNOW SUMMIT SKI CORP	30		1
Total Coliform - Monitoring, Routine Major	Absence	3600783	BLUE SKY MEADOW SCIENCE INSTITUTE	200		1
Total Coliform - Non acute MCL	Absence	3600785	LAKE JODIE WATER SYSTEM	250	1	
Total Coliform - Non acute MCL	Absence	3601036	CALICO LAKES HOMEOWNERS	25	1	
Total Coliform - Non acute MCL	Absence	3601045	BEAR VALLEY MHP (WESTLAND MHP)	150	1	
Total Coliform - Monitoring, Routine Major	Absence	3601049	MINNEOLA MINI MART	25		1
Total Coliform - Monitoring, Routine Major	Absence	3601059	DEL TACO #201	25		1
Total Coliform - Monitoring, Routine Major	Absence	3601070	CADIZ LAND CO (#1/LABOR CAMP/COOKHS)	25		1
Total Coliform - Non acute MCL	Absence	3601097	CAL TRANS - VALLEY WELLS	2500	1	
Total Coliform - Monitoring, Routine Major	Absence	3601137	LIZZE ENTERPRISES	25		1
Total Coliform - Monitoring, Routine Major	Absence	3601147	RILEY S FARM/LLC-SYS#1	25		1
Arsenic	0.01	3610001	CITY OF ADELANTO	31765	1	
Total Coliform - Monitoring, Repeat Major	Absence	3610016	GLEN MARTIN MWC	450		1
Total Coliform - Monitoring, Routine Minor	Absence	3610021	FALLSVALE SERVICE COMPANY	1100		1
Total Coliform - Monitoring, Repeat Major	Absence	3610028	MARYGOLD MWC	3449		1
Total Coliform - Non acute MCL	Absence	3610031	MUSCOY MWC NO. 1	7500	1	
Total Coliform - Monitoring, Repeat Minor	Absence	3610037	REDLANDS CITY MUD-WATER DIV	80000		1
Total Coliform - Non acute MCL	Absence	3610043	GOLDEN STATE WATER CO - BARSTOW	25772	1	
Gross Alpha	15 pCi/L	3610051	VALLEY OF ENCHANTMENT MWC	1280	1	
Total Coliform - Monitoring, Repeat Minor	Absence	3610061	DWP - SUGARLOAF/ERWIN LAKE	3781		1
Gross Alpha	15 pCi/L	3610064	EAST VALLEY WATER DISTRICT	70000	1	
Total Coliform - Monitoring, Routine Minor	Absence	3610093	ARROWHEAD VILLAS MUTUTUAL SERV. CO.	500		1
Total Coliform - Monitoring, Repeat Minor	Absence	3610093	ARROWHEAD VILLAS MUTUTUAL SERV. CO.	500		1
Total Coliform - Non acute MCL	Absence	3610110	ARROWBEAR PARK CWD	580	1	
Total Coliform - Monitoring, Routine Major	Absence	3610110	ARROWBEAR PARK CWD	580		1
Total Coliform - Monitoring, Repeat Major	Absence	3610110	ARROWBEAR PARK CWD	580		1
Arsenic	0.01	3610112	HELENDALE COMMUNITY SERVICE DISTRICT	8646	4	
Total Coliform - Monitoring, Repeat Minor	Absence	3610703	USMC - 29 PALMS	24373		1
Arsenic	0.01	3610705	US ARMY FORT IRWIN	16000	4	
Arsenic	0.01	3610854	SEARLES VALLEY MINERALS OPERATIONS INC	2100	4	

COUNTS/TOTALS				50	285377	32	31
----------------------	--	--	--	-----------	---------------	-----------	-----------

SAN DIEGO

Total Coliform - Monitoring, Routine Major	Absence	3700003	WHISPERING WINDS CATHOLIC CONFERENCE CEN	162		2
Total Coliform - Monitoring, Routine Major	Absence	3700013	DESCANSO JUNCTION	100		1
Total Coliform - Non acute MCL	Absence	3700025	CIBBETTS FLATS CAMPGROUND	25	1	
Total Coliform - Non acute MCL	Absence	3700029	DESCANSO FIRE STATION	34	1	
Total Coliform - Monitoring, Routine Major	Absence	3700029	DESCANSO FIRE STATION	34		1
Total Coliform - Monitoring, Repeat Minor	Absence	3700029	DESCANSO FIRE STATION	34		1
Total Coliform - Monitoring, Routine Major	Absence	3700030	FRY CREEK / OBSERVATORY	200		1
Total Coliform - Monitoring, Routine Major	Absence	3700049	POTRERO GENERAL STORE	500		2
Total Coliform - Monitoring, Routine Major	Absence	3700195	SACRED ROCKS RESERVE	300		2
Total Coliform - Monitoring, Routine Major	Absence	3700782	FALLBROOK KAMP RETREAT	55		1
Total Coliform - Monitoring, Routine Major	Absence	3700858	SHADY OAKS TRAILER RANCH	25		1
Total Coliform - Monitoring, Routine Major	Absence	3700873	THOUSAND TRAILS OAKZANITA INC.	400		1
Total Coliform - Monitoring, Routine Major	Absence	3700918	RANCHO SANTA TERESA MW CO.	74		1
Nitrate (As No3)	45	3700923	LAKE MORENA OAK SHORE MW CO.	700	1	
Nitrate + Nitrite (sum as N)	10	3700923	LAKE MORENA OAK SHORE MW CO.	700	3	
Uranium (check)	30 µg/L	3700923	LAKE MORENA OAK SHORE MW CO.	700	1	
Total Coliform - Monitoring, Repeat Minor	Absence	3700923	LAKE MORENA OAK SHORE MW CO.	700		1
Uranium	30 µg/L	3700924	LAKE MORENA VIEWS MW CO.	360	1	
Total Coliform - Non acute MCL	Absence	3700930	POTRERO COUNTY PARK	100	1	
Haa5 - Haloacetic Acids (Five)	0.06	3700953	TECATE VISTA MUTUAL WATER COMPANY	200		1
Trihalomethanes (TTHM) - Total	0.08	3700953	TECATE VISTA MUTUAL WATER COMPANY	200		1
Total Coliform - Non acute MCL	Absence	3700958	LOS TULES MUTUAL WATER COMPANY	140	1	
Total Coliform - Monitoring, Repeat Major	Absence	3700958	LOS TULES MUTUAL WATER COMPANY	140		1
Total Coliform - Monitoring, Routine Major	Absence	3700959	WARNER SPRINGS RANCH OWNERS ASSOC.	85		2
Gross Alpha	15 pCi/L	3700964	HARBISON CANYON ESTATES	140	1	
Total Coliform - Monitoring, Routine Major	Absence	3700964	HARBISON CANYON ESTATES	140		1
Total Coliform - Non acute MCL	Absence	3700968	SAN PASQUAL ACADEMY	350	1	
Total Coliform - Monitoring, Routine Major	Absence	3700968	SAN PASQUAL ACADEMY	350		1
Total Coliform - Monitoring, Routine Major	Absence	3700970	YOGA CENTER RETREAT	50		2
Total Coliform - Monitoring, Routine Major	Absence	3701010	WARNER UNIFIED SCHOOL DISTRICT	250		1
Total Coliform - Monitoring, Routine Major	Absence	3701240	YOGA CENTER MOTHER S KITCHEN	100		2
Total Coliform - Monitoring, Routine Major	Absence	3701241	AL BAHR SHRINE CAMP	100		1
Total Coliform - Monitoring, Routine Major	Absence	3701299	SCHOEPE SCOUT RESERVATION AT LOST VALLEY	550		3

SAN DIEGO

Total Coliform - Monitoring, Routine Major	Absence	3701341	BUTTERFIELD OAKS MOBILE HOME PARK	120		4
Total Coliform - Monitoring, Routine Major	Absence	3701380	CAMERON CORNERS	50		2
Total Coliform - Non acute MCL	Absence	3701476	INDIAN HILLS CAMP	400	1	
Total Coliform - Non acute MCL	Absence	3701478	PHOENIX HOUSE FOUNDATION, INC.	75	1	
Total Coliform - Non acute MCL	Absence	3701594	FEATHERSTONE CANYON CHRISTIAN CAMP	300	1	
Total Coliform - Monitoring, Routine Major	Absence	3701747	NORTH PEAK MUTUAL WATER COMPANY	25		1
Total Coliform - Non acute MCL	Absence	3701780	RICHARDSON BEARDSLEY PARK, INC.	28	1	
Total Coliform - Monitoring, Routine Major	Absence	3701793	TWIN LAKES RESORT	200		2
Total Coliform - Monitoring, Routine Major	Absence	3701826	SALSA LYNDA RESTAURANT	25		1
Total Coliform - Monitoring, Routine Major	Absence	3701884	MOUNTAIN EMPIRE R.V. PARK AND CAMPGROUND	26		1
Total Coliform - Monitoring, Routine Major	Absence	3701965	MATAGUAY SCOUT RESERVATION	400		1
Total Coliform - Non acute MCL	Absence	3701982	PALOMAR CHRISTIAN CONFERENCE CENTER	350	1	
Total Coliform - Monitoring, Routine Major	Absence	3701995	WILLOWSIDE TERRACE WATER ASSOCIATION	100		1
Total Coliform - Monitoring, Routine Major	Absence	3702059	SKYLINE RANCH RV PARK & CAMPGROUND	45		1
Total Coliform - Acute MCL	Absence	3702104	MHC TT INC., DBA PIO PICO	2000	1	
Total Coliform - Non acute MCL	Absence	3702104	MHC TT INC., DBA PIO PICO	2000	1	
Total Coliform - Monitoring, Routine Major	Absence	3702253	DULZURA CAF�	50		1
Total Coliform - Non acute MCL	Absence	3702283	MOUNT LAGUNA IMPROVEMENT ASSN.	100	1	
Total Coliform - Monitoring, Routine Major	Absence	3702302	DESERT IRONWOODS RESORT INC.	25		1
Total Coliform - Monitoring, Routine Major	Absence	3702338	WESTERN HORIZONS RAMONA CANYON	250		1
Total Coliform - Non acute MCL	Absence	3702349	RANCHO L ABRI	52	2	
Total Coliform - Non acute MCL	Absence	3702354	WARNER SPRINGS ESTATES	340	1	
Total Coliform - Monitoring, Routine Major	Absence	3702420	STAGECOACH TRAILS RV RESORT	600		2
Total Coliform - Monitoring, Routine Major	Absence	3702479	RANCH FEED & SUPPLY	50		1
Total Coliform - Monitoring, Routine Major	Absence	3702494	CHEF S HAT RESTAURANT	250		1
Total Coliform - Monitoring, Routine Major	Absence	3702498	LA POSTA RESTAURANT	60		1
Total Coliform - Monitoring, Routine Major	Absence	3702703	DE ANZA SPRINGS RESORT	400		1
Total Coliform - Monitoring, Routine Major	Absence	3702757	BARRETT JUNCTION PROPERTIES, INC.	100		2
Total Coliform - Monitoring, Routine Major	Absence	3705046	MUIR INDUSTRIES, INC.	70		1
Total Coliform - Monitoring, Routine Major	Absence	3705059	SET FREE MINISTRIES	50		1
Total Coliform - Monitoring, Routine Major	Absence	3705060	WILL BILL S RETAIL CENTER	50		1
Total Coliform - Monitoring, Routine Major	Absence	3705061	CITY OF SAN DIEGO, CAMP MORENA	200		2
Total Coliform - Non acute MCL	Absence	3710006	ESCONDIDO, CITY OF	140000	1	

SAN DIEGO

LCR - Routine&followup monitoring	MR	3710041	MAJESTIC PINES COMMUNITY SD	1964		1
LCR - Initial monitoring	MR	3710049	PINE VALLEY BORDER PATROL STATION	435		1
DBP	n/a	3710049	PINE VALLEY BORDER PATROL STATION	435		1
Nitrate (As No3)	45	3710305	ANZA BORREGO SP - HORSE CAMP	50		1
Total Coliform - Monitoring, Routine Major	Absence	3710318	SAN PASQUAL BATTLEFIELD STATE PARK	25		1
Total Coliform - Non acute MCL	Absence	3710700	CAMP PENDLETON (NORTH)	11600	1	
Total Coliform - Monitoring, Repeat Minor	Absence	3710700	CAMP PENDLETON (NORTH)	11600		1
Trihalomethanes (TTHM) - Total	0.08	3710707	USN SAN CLEMENTE ISLAND	400	3	
Chlorine	4.0	3710801	MCCAIN VALLEY CC	110		1

COUNTS/TOTALS

63

166375

28

68

SAN JOAQUIN

Total Coliform - Monitoring, Routine Major	Absence	3900575	ARCHIES CAFE	36		1
Total Coliform - Non acute MCL	Absence	3900589	MOSSDALE MOBILE HOME PARK	100	1	
Total Coliform - Non acute MCL	Absence	3900616	WINDMILL COVE RESORT/MARINA LLC	50	1	
Total Coliform - Non acute MCL	Absence	3900648	TURTLE BEACH & WATER SYSTEM	70	2	
Nitrate (As No3)	45	3900649	GLENWOOD MOBILE HOME PARK	100	3	
Total Coliform - Non acute MCL	Absence	3900651	LOST ISLE RESORT	25	1	
Total Coliform - Non acute MCL	Absence	3900653	ISLANDER MARINA	150	1	
Total Coliform - Non acute MCL	Absence	3900666	KING ISLAND MARINA PWS	1000	1	
Total Coliform - Non acute MCL	Absence	3900711	SIDHU MOBILE PARK WATER SYSTEM	75	1	
Total Coliform - Monitoring, Routine Major	Absence	3900711	SIDHU MOBILE PARK WATER SYSTEM	75		5
Total Coliform - Monitoring, Repeat Major	Absence	3900712	MUSD-FRENCH CAMP SCHOOL	650		1
Total Coliform - Non acute MCL	Absence	3900732	V & P TRAILER COURT WATER SYSTEM	35	2	
Total Coliform - Non acute MCL	Absence	3900748	ESCALON USD- COLLEGEVILLE SCH	100	1	
Total Coliform - Non acute MCL	Absence	3900755	SHADY REST TRAILER COURT	120	1	
Total Coliform - Monitoring, Repeat Major	Absence	3900778	STOCKTON MOOSE LODGE	300		1
Total Coliform - Non acute MCL	Absence	3900805	MOREHEAD PARK	300	2	
Total Coliform - Non acute MCL	Absence	3900810	JR SIMPLOT CO	300	2	
Total Coliform - Non acute MCL	Absence	3900825	OWENS BROCKWAY	280	2	
Total Coliform - Non acute MCL	Absence	3900837	LODI HOMES	39	2	
Total Coliform - Monitoring, Routine Minor	Absence	3900837	LODI HOMES	39		1
Total Coliform - Monitoring, Repeat Major	Absence	3900837	LODI HOMES	39		2

SAN JOAQUIN

Total Coliform - Non acute MCL	Absence	3900848	LODI USD-TOKAY COLONY SCHOOL	166	1	
Total Coliform - Monitoring, Routine Major	Absence	3900907	BEL AIR MOBILE ESTATE	150		1
Total Coliform - Non acute MCL	Absence	3900921	CARDOZA VILLA CORP	30	1	
Total Coliform - Non acute MCL	Absence	3900983	CHERRY LANE TRAILER PARK	100	1	
Total Coliform - Non acute MCL	Absence	3901032	LODI USD-TURNER SCHOOL	200	2	
Total Coliform - Non acute MCL	Absence	3901035	LODI USD-HENDERSON SCHOOL	200	1	
Total Coliform - Non acute MCL	Absence	3901090	NORTH VALLEY SCHOOL PWS	35	3	
Nitrate (As No3)	45	3901116	NAVARRA WATER SYSTEM	725	2	
Total Coliform - Non acute MCL	Absence	3901169	MUSD-NILE GARDEN SCHOOL	804	1	
Total Coliform - Non acute MCL	Absence	3901176	PHILLIPS FARMS	3000	1	
Total Coliform - Non acute MCL	Absence	3901181	AMERON INTERNATIONAL	100	2	
Nitrate (As No3)	45	3901182	FINLEY S	25	1	
Total Coliform - Non acute MCL	Absence	3901204	DIAMOND PET FOOD	35	2	
Total Coliform - Non acute MCL	Absence	3901229	HAMMER LANE WATER SYSTEM	100	1	
Total Coliform - Non acute MCL	Absence	3901253	WATERLOO GUN & BOCCI CLUB	50	3	
Total Coliform - Monitoring, Routine Minor	Absence	3901253	WATERLOO GUN & BOCCI CLUB	50		1
Total Coliform - Monitoring, Repeat Major	Absence	3901253	WATERLOO GUN & BOCCI CLUB	50		1
Total Coliform - Non acute MCL	Absence	3901276	HANOT FOUNDATION INC	38	1	
Total Coliform - Non acute MCL	Absence	3901278	COLOR SPOT, LODI	30	4	
Total Coliform - Non acute MCL	Absence	3901280	HORIZON CHRISTIAN FELLOWSHIP	1000	1	
Total Coliform - Non acute MCL	Absence	3901306	KELLOGG GARDEN PRODUCTS	185	1	
Total Coliform - Non acute MCL	Absence	3901309	PACIFIC TRIPLE E LTD	50	1	
Total Coliform - Non acute MCL	Absence	3901310	DARRIGO S WATER SYSTEM	100	2	
Total Coliform - Monitoring, Routine Major	Absence	3901310	DARRIGO S WATER SYSTEM	100		3
Total Coliform - Non acute MCL	Absence	3901320	OLIN CHLOR ALKALI PRODUCTS WTR SYS	50	3	
Total Coliform - Non acute MCL	Absence	3901344	ESCALON LIVESTOCK MKT	100	1	
Total Coliform - Monitoring, Repeat Major	Absence	3901344	ESCALON LIVESTOCK MKT	100		1
Consumer Confidence Report	n/a	3901345	NORMAN S NURSERY	25		2
Total Coliform - Monitoring, Routine Major	Absence	3901354	PEARCE, JEFF H 39-40	30		1
Total Coliform - Non acute MCL	Absence	3901360	HOLIDAY HARBOR MARINA	100	1	
Total Coliform - Non acute MCL	Absence	3901368	OM SCOTT & SONS/HYPONEX CORP	50	5	
Total Coliform - Monitoring, Routine Minor	Absence	3901368	OM SCOTT & SONS/HYPONEX CORP	50		1
Total Coliform - Non acute MCL	Absence	3901370	JIMMYS ONE STOP	25	3	

SAN JOAQUIN

Total Coliform - Non acute MCL	Absence	3901371	LOCKEFORD SPRINGS GOLF COURSE	25	3	
Total Coliform - Non acute MCL	Absence	3901378	SAN-I-PAK INC	25	1	
Consumer Confidence Report	n/a	3901378	SAN-I-PAK INC	25		1
Total Coliform - Non acute MCL	Absence	3901387	STOCKTON BAPTIST CHURCH	25	2	
Total Coliform - Monitoring, Repeat Minor	Absence	3901391	MCHENRY AVE RECREATION AREA	25		1
Total Coliform - Non acute MCL	Absence	3901393	TURNER RD VINTNERS WEST	25	1	
Total Coliform - Non acute MCL	Absence	3901394	CALVA PRODUCTS CO INC	30	1	
Total Coliform - Monitoring, Routine Major	Absence	3901394	CALVA PRODUCTS CO INC	30		1
Consumer Confidence Report	n/a	3901394	CALVA PRODUCTS CO INC	30		1
Consumer Confidence Report	n/a	3901396	BENETO WATER SYSTEM	30		1
Total Coliform - Non acute MCL	Absence	3901397	GURU NANAK DARBAR GURDAWARA	25	1	
Total Coliform - Non acute MCL	Absence	3901406	SOUTHWINDS CHURCH OF TRACY	25	1	
Total Coliform - Monitoring, Routine Major	Absence	3901406	SOUTHWINDS CHURCH OF TRACY	25		1
Total Coliform - Non acute MCL	Absence	3901421	VIEJO LTD	163	1	
Total Coliform - Non acute MCL	Absence	3901422	ST MICHAELS WATER SYSTEM	25	1	
Total Coliform - Non acute MCL	Absence	3901437	LODI BUILDING ASSOCIATION	25	2	
Total Coliform - Monitoring, Routine Major	Absence	3901439	STONE GATE WINERY WATER SYSTEM	25		3
Total Coliform - Non acute MCL	Absence	3901442	TARDITI RENTALS WATER	25	2	
Total Coliform - Non acute MCL	Absence	3901444	GIANNECCHINI WATER SYSTEM	25	2	
Total Coliform - Non acute MCL	Absence	3901446	AMOROSA INN & GARDENS LLC	25	1	
Total Coliform - Non acute MCL	Absence	3901451	FIRST BAPTIST CHURCH OF LINDEN	25	3	
Total Coliform - Non acute MCL	Absence	3901474	HESKETT, JOE WATER SYSTEM	39	2	
Total Coliform - Non acute MCL	Absence	3901476	PG&E WATER SYSTEM	25	1	
Total Coliform - Non acute MCL	Absence	3901477	TRACY MATRL RECVRY/SLD WASTE WS	25	2	
Total Coliform - Non acute MCL	Absence	3901481	LINDEN USD-CHARTVILLE SCHOOL	40	2	
Total Coliform - Acute MCL	Absence	3901485	WESTGATE LANDING PARK WATER SYSTEM	25	2	
Total Coliform - Non acute MCL	Absence	3901485	WESTGATE LANDING PARK WATER SYSTEM	25	1	
Total Coliform - Non acute MCL	Absence	3902133	JIMMYS LIQUORS WATER SYSTEM	25	2	
Total Coliform - Monitoring, Routine Minor	Absence	3902133	JIMMYS LIQUORS WATER SYSTEM	25		1
Total Coliform - Monitoring, Repeat Major	Absence	3902133	JIMMYS LIQUORS WATER SYSTEM	25		2
Arsenic	0.01	3910005	MANTECA, CITY OF	66451	4	
Total Coliform - Monitoring, Repeat Minor	Absence	3910009	SAN JOAQUIN COUNTY - THORNTON	957		1
Arsenic	0.01	3910015	CITY OF LATHROP	12427	4	

COUNTS/TOTALS

72

91820

110

35

SAN LUIS OBISPO							
Total Coliform - Monitoring, Routine Major	Absence	4000205	TIGER WATER SUPPLY	1600		1	
Total Coliform - Monitoring, Routine Major	Absence	4000206	LAUREATE WATER COMPANY	350		1	
Total Coliform - Monitoring, Routine Major	Absence	4000217	CROSSROADS COMMUNITY CHURCH	30		1	
Total Coliform - Monitoring, Routine Major	Absence	4000219	LINKS AT VISTA DEL HOMBRE, THE	25		1	
Total Coliform - Monitoring, Routine Major	Absence	4000224	T & A PROPERTIES WATER CO	25		2	
Total Coliform - Monitoring, Routine Major	Absence	4000507	GARDEN FARMS C.W.D.	240		1	
Total Coliform - Monitoring, Routine Major	Absence	4000620	SATCOM WATER SUPPLY--CAMP ROBERTS	100		1	
Total Coliform - Monitoring, Routine Major	Absence	4000632	HIDDEN HILLS MOBILODGE	55		2	
Total Coliform - Monitoring, Routine Major	Absence	4000640	CAL SHASTA CLUB	166		1	
Total Coliform - Monitoring, Routine Major	Absence	4000665	MORRO BAY MUTUAL WATER CO	100		1	
Total Coliform - Monitoring, Routine Major	Absence	4000693	CRESTON ELEMENTARY SCHOOL	100		1	
Total Coliform - Monitoring, Routine Major	Absence	4000700	EMMANUEL HEIGHTS	25		1	
Total Coliform - Monitoring, Routine Major	Absence	4000703	SAN SIMEON CREEK RANCH	42		2	
Total Coliform - Monitoring, Routine Major	Absence	4000707	LONGBRANCH SALOON, THE	30		7	
Total Coliform - Monitoring, Routine Major	Absence	4000708	LOADING CHUTE	25		2	
Total Coliform - Monitoring, Routine Major	Absence	4000711	SAN LUIS BUSINESS PARK	100		2	
Total Coliform - Monitoring, Routine Major	Absence	4000716	AVILA VALLEY MUTUAL WATER CO	65		1	
Total Coliform - Monitoring, Routine Major	Absence	4000730	HOLDGRAFER & ASSOCIATES	30		2	
Total Coliform - Monitoring, Routine Major	Absence	4000732	CARRISA PLAINS SCHOOL	65		1	
Total Coliform - Monitoring, Routine Major	Absence	4000747	LAST STAGE WEST	25		1	
Total Coliform - Monitoring, Routine Major	Absence	4000753	SLO PARTNERS	40		3	
Total Coliform - Monitoring, Routine Major	Absence	4000757	CERRO ALTO CAMPGROUND	30		2	
Total Coliform - Monitoring, Routine Major	Absence	4000778	PARSONS WATER SUPPLY	30		1	
COUNTS/TOTALS				23	3298	0	38
SAN MATEO							
Gross Alpha	15 pCi/L	4100510	REDWOOD TERRACE MUTUAL	43		1	
Radium 228	--	4100510	REDWOOD TERRACE MUTUAL	43		3	
Carbon Tetrachloride	0.0005	4100510	REDWOOD TERRACE MUTUAL	43		2	
Toluene	0.15	4100510	REDWOOD TERRACE MUTUAL	43		2	
Benzene	0.001	4100510	REDWOOD TERRACE MUTUAL	43		2	
Benzo (A) Pyrene	0.0002	4100510	REDWOOD TERRACE MUTUAL	43		1	
Monochlorobenzene	0.07	4100510	REDWOOD TERRACE MUTUAL	43		2	

SAN MATEO

Ethylbenzene	0.3	4100510	REDWOOD TERRACE MUTUAL	43		2
Dichloromethane	0.005	4100510	REDWOOD TERRACE MUTUAL	43		2
Tetrachloroethylene	0.005	4100510	REDWOOD TERRACE MUTUAL	43		2
Trichlorofluoromethane	0.15	4100510	REDWOOD TERRACE MUTUAL	43		2
1,1-Dichloroethane	0.005	4100510	REDWOOD TERRACE MUTUAL	43		2
1,1-Dichloroethylene	0.005	4100510	REDWOOD TERRACE MUTUAL	43		2
1,1,1-Trichloroethane	0.2	4100510	REDWOOD TERRACE MUTUAL	43		2
1,1,2-Trichloroethane	0.005	4100510	REDWOOD TERRACE MUTUAL	43		2
1,1,2,2-Tetrachloroethane	0.001	4100510	REDWOOD TERRACE MUTUAL	43		2
1,2-Dichloroethane	0.0005	4100510	REDWOOD TERRACE MUTUAL	43		2
1,2-Dichlorobenzene	0.6	4100510	REDWOOD TERRACE MUTUAL	43		2
1,2-Dichloropropane	0.005	4100510	REDWOOD TERRACE MUTUAL	43		2
Trans-1,2-Dichloroethylene	0.01	4100510	REDWOOD TERRACE MUTUAL	43		2
1,2,4-Trichlorobenzene	0.005	4100510	REDWOOD TERRACE MUTUAL	43		2
1,3-Dichloropropene (total of isomers)	0.0005	4100510	REDWOOD TERRACE MUTUAL	43		2
1,4-Dichlorobenzene	0.005	4100510	REDWOOD TERRACE MUTUAL	43		2
Hexachlorocyclopentadiene	0.05	4100510	REDWOOD TERRACE MUTUAL	43		1
2,3,7,8-TCDD (Dioxin)	3 x 10 ⁻⁸	4100510	REDWOOD TERRACE MUTUAL	43		1
Dalapon	0.2	4100510	REDWOOD TERRACE MUTUAL	43		1
Bentazon	0.018	4100510	REDWOOD TERRACE MUTUAL	43		1
Dibromochloropropane	0.0002	4100510	REDWOOD TERRACE MUTUAL	43		1
Oxamyl	0.05	4100510	REDWOOD TERRACE MUTUAL	43		1
Endothall	0.1	4100510	REDWOOD TERRACE MUTUAL	43		1
Pentachlorophenol	0.001	4100510	REDWOOD TERRACE MUTUAL	43		1
Atrazine	0.001	4100510	REDWOOD TERRACE MUTUAL	43		1
2,4,5-TP (Silvex)	0.05	4100510	REDWOOD TERRACE MUTUAL	43		1
Simazine	0.004	4100510	REDWOOD TERRACE MUTUAL	43		1
Di(2-ethylhexyl)phthalate	0.004	4100510	REDWOOD TERRACE MUTUAL	43		1
Vinyl Chloride	0.0005	4100510	REDWOOD TERRACE MUTUAL	43		2
Lindane	0.0002	4100510	REDWOOD TERRACE MUTUAL	43		1
Chlordane	0.0001	4100510	REDWOOD TERRACE MUTUAL	43		1
Endrin	0.002	4100510	REDWOOD TERRACE MUTUAL	43		1
Toxaphene	0.003	4100510	REDWOOD TERRACE MUTUAL	43		1

SAN MATEO

Heptachlor	0.00001	4100510	REDWOOD TERRACE MUTUAL	43		1
Heptachlor Epoxide	0.00001	4100510	REDWOOD TERRACE MUTUAL	43		1
Methoxychlor	0.03	4100510	REDWOOD TERRACE MUTUAL	43		1
Polychlorinated Biphenyls	0.0005	4100510	REDWOOD TERRACE MUTUAL	43		1
Hexachlorobenzene	0.001	4100510	REDWOOD TERRACE MUTUAL	43		1
Picloram	0.5	4100510	REDWOOD TERRACE MUTUAL	43		1
2,4-D	0.07	4100510	REDWOOD TERRACE MUTUAL	43		1
Nitrate (as NO ₃)	45	4100510	REDWOOD TERRACE MUTUAL	43		2
cis-1,2-Dichloroethylene	0.006	4100510	REDWOOD TERRACE MUTUAL	43		2
Styrene	0.1	4100510	REDWOOD TERRACE MUTUAL	43		2
Ethylene Dibromide	0.00005	4100510	REDWOOD TERRACE MUTUAL	43		1
Alachlor	0.002	4100510	REDWOOD TERRACE MUTUAL	43		2
Diquat	0.02	4100510	REDWOOD TERRACE MUTUAL	43		1
Glyphosate	0.7	4100510	REDWOOD TERRACE MUTUAL	43		1
Dinoseb	0.007	4100510	REDWOOD TERRACE MUTUAL	43		1
Carbofuran	0.018	4100510	REDWOOD TERRACE MUTUAL	43		1
Xylenes	1.75	4100510	REDWOOD TERRACE MUTUAL	43		2
1,1,2-Trichloro-1,2,2-Trifluoroethane (freon 113)	1.2	4100510	REDWOOD TERRACE MUTUAL	43		2
Trihalomethanes (TTHM) - Total	0.08	4100510	REDWOOD TERRACE MUTUAL	43		2
Molinate	0.02	4100510	REDWOOD TERRACE MUTUAL	43		1
Thiobencarb	0.07	4100510	REDWOOD TERRACE MUTUAL	43		1
Di(2-ethylhexyl)adipate	0.4	4100510	REDWOOD TERRACE MUTUAL	43		1
Nitrite (as N)	1	4100513	PESCADERO HIGH SCHOOL	400	1	
Nitrate (as NO ₃)	45	4100513	PESCADERO HIGH SCHOOL	400	1	
SWTR - treatment technique (41)	TT	4100529	CAMP LOMA MAR	350	1	
Aluminum	1	4100605	SKYLAWN INC	36		2
Antimony	0.006	4100605	SKYLAWN INC	36		2
Arsenic	0.01	4100605	SKYLAWN INC	36		2
Barium	1	4100605	SKYLAWN INC	36		2
Beryllium	0.004	4100605	SKYLAWN INC	36		2
Cadmium	0.005	4100605	SKYLAWN INC	36		2
Chromium (total)	0.05	4100605	SKYLAWN INC	36		2
Selenium	0.05	4100605	SKYLAWN INC	36		2

SAN MATEO							
Thallium	0.002	4100605	SKYLAWN INC		36		2
Gross Alpha	15 pCi/L	4100605	SKYLAWN INC		36		4
Radium 228	--	4100605	SKYLAWN INC		36		5
Carbon Tetrachloride	0.0005	4100605	SKYLAWN INC		36		1
Toluene	0.15	4100605	SKYLAWN INC		36		1
Benzene	0.001	4100605	SKYLAWN INC		36		1
Benzo(a)pyrene	0.0002	4100605	SKYLAWN INC		36		1
Monochlorobenzene	0.07	4100605	SKYLAWN INC		36		1
Ethylbenzene	0.3	4100605	SKYLAWN INC		36		1
Hexachlorocyclopentadiene	0.05	4100605	SKYLAWN INC		36		1
Dichloromethane	0.005	4100605	SKYLAWN INC		36		1
Tetrachloroethylene	0.005	4100605	SKYLAWN INC		36		1
Trichlorofluoromethane	0.15	4100605	SKYLAWN INC		36		1
1,1-Dichloroethane	0.005	4100605	SKYLAWN INC		36		1
1,1-Dichloroethylene	0.005	4100605	SKYLAWN INC		36		1
1,1,1-Trichloroethane	0.2	4100605	SKYLAWN INC		36		1
1,1,2-Trichloroethane	0.005	4100605	SKYLAWN INC		36		1
1,1,2,2-Tetrachloroethane	0.001	4100605	SKYLAWN INC		36		1
1,2-Dichloroethane	0.0005	4100605	SKYLAWN INC		36		1
1,2-Dichlorobenzene	0.6	4100605	SKYLAWN INC		36		1
1,2-Dichloropropane	0.005	4100605	SKYLAWN INC		36		1
Trans-1,2-Dichloroethylene	0.01	4100605	SKYLAWN INC		36		1
1,2,4-Trichlorobenzene	0.005	4100605	SKYLAWN INC		36		1
1,3-Dichloropropene (total of isomers)	0.0005	4100605	SKYLAWN INC		36		1
1,4-Dichlorobenzene	0.005	4100605	SKYLAWN INC		36		1
2,3,7,8-TCDD (Dioxin)	3 x 10-8	4100605	SKYLAWN INC		36		1
Dalapon	0.2	4100605	SKYLAWN INC		36		1
Bentazon	0.018	4100605	SKYLAWN INC		36		1
Dibromochloropropane (Dbcp)	0.0002	4100605	SKYLAWN INC		36		1
Oxamyl	0.05	4100605	SKYLAWN INC		36		1
Endothall	0.1	4100605	SKYLAWN INC		36		1
Pentachlorophenol	0.001	4100605	SKYLAWN INC		36		1
Atrazine	0.001	4100605	SKYLAWN INC		36		1

SAN MATEO							
2,4,5-TP (Silvex)	0.05	4100605	SKYLAWN INC		36	1	
Simazine	0.004	4100605	SKYLAWN INC		36	1	
Di(2-ethylhexyl)phthalate	0.004	4100605	SKYLAWN INC		36	1	
Vinyl Chloride	0.0005	4100605	SKYLAWN INC		36	1	
Trichloroethylene	0.005	4100605	SKYLAWN INC		36	1	
Lindane	0.0002	4100605	SKYLAWN INC		36	1	
Chlordane	0.0001	4100605	SKYLAWN INC		36	1	
Endrin	0.002	4100605	SKYLAWN INC		36	1	
Toxaphene	0.003	4100605	SKYLAWN INC		36	1	
Heptachlor	0.00001	4100605	SKYLAWN INC		36	1	
Heptachlor Epoxide	0.00001	4100605	SKYLAWN INC		36	1	
Methoxychlor	0.03	4100605	SKYLAWN INC		36	1	
Polychlorinated Biphenyls	0.0005	4100605	SKYLAWN INC		36	1	
Hexachlorobenzene	0.001	4100605	SKYLAWN INC		36	1	
Picloram	0.5	4100605	SKYLAWN INC		36	1	
2,4-D	0.07	4100605	SKYLAWN INC		36	1	
Mercury	0.002	4100605	SKYLAWN INC		36	2	
cis-1,2-Dichloroethylene	0.006	4100605	SKYLAWN INC		36	1	
Styrene	0.1	4100605	SKYLAWN INC		36	1	
Ethylene Dibromide	0.00005	4100605	SKYLAWN INC		36	1	
Alachlor	0.002	4100605	SKYLAWN INC		36	1	
Diquat	0.02	4100605	SKYLAWN INC		36	1	
Glyphosate	0.7	4100605	SKYLAWN INC		36	1	
Dinoseb	0.007	4100605	SKYLAWN INC		36	1	
Carbofuran	0.018	4100605	SKYLAWN INC		36	1	
Xylenes	1.75	4100605	SKYLAWN INC		36	1	
1,1,2-Trichloro-1,2,2-Trifluoroethane	1.2	4100605	SKYLAWN INC		36	1	
Trihalomethanes (TTHM) - Total	0.08	4100605	SKYLAWN INC		36	1	
Molinate	0.02	4100605	SKYLAWN INC		36	1	
Thiobencarb	0.07	4100605	SKYLAWN INC		36	1	
Di(2-ethylhexyl)adipate	0.4	4100605	SKYLAWN INC		36	1	
COUNTS/TOTALS				4	829	3	181

SANTA BARBARA							
Total Coliform - Non acute MCL	Absence	4200725	GAVIOTA OIL HEATING FACILITY	50	1		
Nitrate (As No3)	45	4200886	MOSBY WINERY	200		1	
Total Coliform - Non acute MCL	Absence	4200933	MELVILLE WIINERY	25	1		
Total Coliform - Non acute MCL	Absence	4200942	FOLEY ESTATES VINEYARD & WINERY	25	1		
Nitrate (As No3)	45	4200943	TEIXEIRA FARMS - FRONTIER COOLING	100		1	
Total Coliform - Non acute MCL	Absence	4200947	BETTER COOLING PRODUCE	35	1		
SWTR - treatment technique (41)	TT	4210006	LOMPOC-CITY WATER UTILITY DIV	38311	1		
Arsenic	0.01	4210009	CUYAMA COMMUNITY SERVICES DISTRICT	820	1		
Total Coliform - Non acute MCL	Absence	4210009	CUYAMA COMMUNITY SERVICES DISTRICT	820	1		
Haa5 - Haloacetic Acids (Five)	0.06	4210013	SOLVANG WATER DEPARTMENT	5383		1	
Trihalomethanes (TTHM) - Total	0.08	4210013	SOLVANG WATER DEPARTMENT	5383		1	
SWTR - treatment technique (41)	TT	4210700	VANDENBERG AIR FORCE BASE	12817	1		
COUNTS/TOTALS				10	57766	8	4
SANTA CLARA							
Total Coliform - Monitoring, Routine Major	Absence	4300605	GILROY USD-RUCKER SCHOOL	688		1	
Total Coliform - Monitoring, Routine Major	Absence	4300748	THE JUNCTION WATER SYSTEM	50		1	
Total Coliform - Non acute MCL	Absence	4300833	SANTA CLARA VALLEY MEDICAL CENTER	7000	1		
Nitrate (As No3)	45	4300941	MONTEREY MUSHROOMS	351	1		
Total Coliform-routine monitoring Major	Absence	4300943	FARMERS LABOR EXCHANGE	150		3	
Total Coliform - Non acute MCL	Absence	4300988	GEORGE CHIALA FARMS, INC.	150	4		
Total Coliform - Non acute MCL	Absence	4300992	GOLDEN HEIGHTS MUTUAL WATER COMPANY	66	1		
COUNTS/TOTALS				7	8455	7	5

SANTA CRUZ							
Total Coliform - Monitoring, Routine Major	Absence	4400505	DAVID BRUCE WINERY		25	1	
Total Coliform - Monitoring, Repeat Major	Absence	4400517	LAKEVIEW APARTMENTS		33	1	
Total Coliform - Monitoring, Repeat Major	Absence	4400543	R A FARMS		44	1	
Total Coliform - Monitoring, Repeat Major	Absence	4400581	OLYMPIA MUTUAL WATER COMPANY		155	1	
Total Coliform - Non acute MCL	Absence	4400624	RANCHO CORRALITOS		60	1	
Total Coliform - Non acute MCL	Absence	4400634	APTOS HILLS MUTUAL WATER CO		38	1	
Total Coliform - Monitoring, Routine Major	Absence	4400659	POTBELLY BEACH CLUB		50	1	
Total Coliform - Non acute MCL	Absence	4400660	RANCHO SAN ANDREAS		200	1	
Total Coliform - Monitoring, Routine Major	Absence	4400660	RANCHO SAN ANDREAS		200	1	
Total Coliform - Monitoring, Routine Major	Absence	4400662	SANTA CRUZ MOUNTAIN PURE WC		25	1	
Total Coliform - Monitoring, Routine Major	Absence	4400704	BOULDER CREEK SCOUT RESERV.		100	1	
Total Coliform - Monitoring, Repeat Major	Absence	4400707	CAMP LINDBLAD		60	1	
Total Coliform - Monitoring, Routine Major	Absence	4400709	KOINONIA CONFERENCE GROUNDS		150	2	
Total Coliform - Monitoring, Routine Major	Absence	4400711	CAMP CHESEBROUGH		150	2	
Total Coliform - Non acute MCL	Absence	4400764	MOUNT MADONNA CENTER		75	1	
Total Coliform - Monitoring, Routine Major	Absence	4400806	AVIZA TECHNOLOGY		650	1	
Total Coliform - Non acute MCL	Absence	4400825	ROARING CAMP RAILROAD INC		250	2	
Total Coliform - Monitoring, Repeat Major	Absence	4400825	ROARING CAMP RAILROAD INC		250	1	
Total Coliform - Non acute MCL	Absence	4410013	SCOTTS VALLEY WATER DISTRICT		11301	1	
Arsenic	0.01	4410016	FOREST LAKES MWC		1145	2	
Nitrate (As No3)	45	4410016	FOREST LAKES MWC		1145	1	
Total Coliform - Non acute MCL	Absence	4410017	SOQUEL CREEK WATER DISTRICT		50000	1	
Nitrate (As No3)	45	4410018	CENTRAL WATER DISTRICT		2700	1	
Nitrate (As No3)	45	4410800	BEN LOMOND CAMP		130	1	
COUNTS/TOTALS				21	67341	10	18
SHASTA							
Haa5 - Haloacetic Acids (Five)	0.06	4500006	SHASTA CO CSA # 2 SUGARLOAF		160	1	
Total Coliform - Monitoring, Routine Major	Absence	4500011	ANDREINI BUSINESS PARK WATER SYSTEM		130	1	
Total Coliform - Monitoring, Routine Major	Absence	4500037	WHEELABRATOR SHASTA ENERGY		52	1	
Total Coliform - Non acute MCL	Absence	4500041	ANDERSON UNION HIGH SCHOOL		1250	1	
Total Coliform - Monitoring, Repeat Major	Absence	4500053	ANTLERS RESORT & MARINA		109	1	
Total Coliform - Monitoring, Repeat Major	Absence	4500058	BURNEY FALLS TRAILER PARK		50	1	

SHASTA

Total Coliform - Non acute MCL	Absence	4500062	LONE TREE MOBILE HOME PARK	92	1		
Total Coliform - Monitoring, Routine Major	Absence	4500066	CLEAR CREEK MOBILE PARK	110		1	
Total Coliform - Monitoring, Routine Major	Absence	4500072	HAT CREEK RESORT & RV PARK	170		1	
Total Coliform - Monitoring, Routine Major	Absence	4500085	MILL CREEK ECO RESORT	70		1	
Total Coliform - Monitoring, Repeat Minor	Absence	4500093	RED HILL MOBILEHOME PARK	50		1	
Total Coliform - Monitoring, Routine Major	Absence	4500097	SALT CREEK RESORT LLC	50		1	
Total Coliform - Monitoring, Repeat Major	Absence	4500097	SALT CREEK RESORT LLC	50		1	
Total Coliform - Monitoring, Repeat Minor	Absence	4500097	SALT CREEK RESORT LLC	50		1	
Total Coliform - Monitoring, Routine Major	Absence	4500099	SHASTA LAKE RV RESORT	140		1	
Total Coliform - Monitoring, Routine Major	Absence	4500101	BIG HORSE RESORT & RV	215		1	
Total Coliform - Monitoring, Routine Major	Absence	4500102	BEAR MOUNTAIN RV RESORT	300		1	
Total Coliform - Monitoring, Routine Major	Absence	4500110	SILVERTHORN RESORT	175		6	
Total Coliform - Monitoring, Routine Major	Absence	4500155	SHINGLE SHACK	65		1	
Total Coliform - Monitoring, Routine Major	Absence	4500160	PACHECO ELEMENTARY SCHOOL	600		1	
Total Coliform - Monitoring, Routine Major	Absence	4500161	PRARIE ELEMENTARY SCHOOL	365		1	
Arsenic	0.01	4500187	TRINITY MEADOWS INC	60	1		
Antimony	0.006	4500187	TRINITY MEADOWS INC	60	1		
Total Coliform - Monitoring, Repeat Major	Absence	4500187	TRINITY MEADOWS INC	60		1	
Total Coliform - Monitoring, Repeat Minor	Absence	4500192	SHASTA LAKE MOTEL	30		1	
Total Coliform - Non acute MCL	Absence	4500254	ANDERSON PARK VILLAGE	110	1		
Total Coliform - Monitoring, Repeat Major	Absence	4500274	AIRPORT INDUSTRIAL PARK	90		1	
Total Coliform - Monitoring, Routine Major	Absence	4500291	JULIAN CHRISTIAN HIGH SCHOOL	250		1	
Total Coliform - Monitoring, Routine Major	Absence	4500302	ANDERSON MOOSE LODGE # 509	75		1	
Total Coliform - Monitoring, Routine Major	Absence	4500303	TUCKER OAKS EAST WATER DISTRICT	105		2	
Total Coliform - Monitoring, Repeat Major	Absence	4500306	RIVERVIEW INN	50		2	
Total Coliform - Monitoring, Repeat Major	Absence	4500328	GARY GARD WATER SYSTEM	50		1	
Total Coliform - Monitoring, Routine Major	Absence	4500333	AIRPORT PLANET WATER	35		1	
Arsenic	0.01	4510005	CITY OF REDDING	85703	1		
COUNTS/TOTALS				30	90711	7	34

SIERRA						
Total Coliform - Acute MCL	Absence	4600017	R.R. LEWIS SMALL WC	324	1	
Total Coliform - Non acute MCL	Absence	4600017	R.R. LEWIS SMALL WC	324	1	
Arsenic	0.01	4600019	SIERRA CO. W.W.D #1 CALPINE	225	4	
COUNTS/TOTALS				2	549	6 0
SISKIYOU						
SWTR-filtered sys-monitoring (36)	MR	4700517	SAWYERS BAR COUNTY WATER DISTRICT	100		1
Total Coliform-routine monitoring Major	Absence	4700585	JUNCTION ELEMENTARY SCHOOL	40		1
Total Coliform-routine monitoring Major	Absence	4700586	SEIAD SCHOOL	50		1
Total Coliform-routine monitoring Major	Absence	4700847	QUARTZ VALLEY SCHOOL	60		1
Nitrate (as No3)	45	4700851	GOOSENEST DISTRICT OFFICE	50	1	
Nitrate (as No3)	45	4700851	GOOSENEST DISTRICT OFFICE	50	1	
Total Coliform - Non acute MCL	Absence	4710001	CITY OF DORRIS	887	1	
Trihalomethanes (TTHM) - Total	0.08	4710007	CITY OF MONTAGUE	1495	2	
COUNTS/TOTALS				7	2682	5 4
SOLANO						
Total Coliform - Non acute MCL	Absence	4800773	PUNJABI DHABA	430	1	
COUNTS/TOTALS				1	430	1 0
SONOMA						
Total Coliform - Acute MCL	Absence	4900513	MADRONE MUTUAL WATER COMPANY	95	1	
Total Coliform - Non acute MCL	Absence	4900513	MADRONE MUTUAL WATER COMPANY	95	1	
Total Coliform - Monitoring, Routine Major	Absence	4900533	SONOMA SPRINGS WATER COMPANY (PUC)	55		1
SWTR - treatment technique (41)	TT	4900549	SONOMA COUNTY CSA 41-FREESTONE	60	1	
LCR - Routine&followup monitoring	MR	4900551	MELITA HEIGHTS MUTUAL WATER COMPANY	60		1
LCR - Routine&followup monitoring	MR	4900552	MICHELE MUTUAL WATER COMPANY	170		1
Nitrate (As No3)	45	4900568	VALLEY FORD WATER ASSOCIATION	40	2	
Arsenic	0.01	4900575	LOCH HAVEN MUTUAL WATER COMPANY	50	4	
Total Coliform - Acute MCL	Absence	4900575	LOCH HAVEN MUTUAL WATER COMPANY	50	1	
Total Coliform - Non acute MCL	Absence	4900575	LOCH HAVEN MUTUAL WATER COMPANY	50	1	
Nitrate (As No3)	45	4900577	RIO LINDO ADVENTIST ACADEMY	200		1
Total Coliform - Monitoring, Routine Major	Absence	4900580	SONOMA MOUNTAIN COUNTY WATER DISTRICT	130		1
Arsenic	0.01	4900643	MOUNT WESKE ESTATES MUTUAL WATER COMPAN	62	4	

SONOMA						
Nitrate (As No3)	45	4900675	ROSELAND MOBILE HOME PARK	100		1
Arsenic	0.01	4900676	SEQUOIA GARDENS MOBILE HOME PARK	300	4	
Haa5 - Haloacetic Acids (Five)	0.06	4900679	FORT ROSS SCHOOL DISTRICT	100	2	
Trihalomethanes (TTHM) - Total	0.08	4900679	FORT ROSS SCHOOL DISTRICT	100	2	
LCR - Routine&followup monitoring	MR	4900700	NONESUCH FARM SCHOOL	46		1
LCR - Routine&followup monitoring	MR	4900702	PACIFIC CHRISTIAN ACADEMY	84		1
Total Coliform - Monitoring, Routine Major	Absence	4900722	URJ CAMP NEWMAN	600		1
Arsenic	0.01	4900723	SHAMROCK MOBILE HOME PARK	188	4	
Total Coliform - Non acute MCL	Absence	4900737	KOA - PETALUMA	25	1	
Total Coliform - Non acute MCL	Absence	4900788	EL CRYSTAL MOBILE HOME PARK	130	1	
Nitrate (As No3)	45	4900791	WESTERN MOBILE HOME PARK	225		1
Total Coliform - Monitoring, Routine Major	Absence	4900791	WESTERN MOBILE HOME PARK	225		1
LCR - Routine&followup monitoring	MR	4900793	VINEHILL VISTA MUTUAL WATER COMPANY	87		1
LCR - Routine&followup monitoring	MR	4900799	EL PORTAL MOBILE ESTATES	200		1
Arsenic	0.01	4900815	DAYS INN	300	4	
Arsenic	0.01	4900815	DAYS INN	300		1
Total Coliform - Non acute MCL	Absence	4900822	MOUNT TAYLOR MOBILE HOME PARK	60	2	
Total Coliform - Monitoring, Repeat Minor	Absence	4900832	LEISURE MOBILE HOME PARK	410		1
Arsenic	0.01	4900845	RANCHO DE SONOMA	130	4	
Total Coliform - Acute MCL	Absence	4900846	ROLLING OAKS ROAD ASSOCIATION	55	2	
SWTR - treatment technique (41)	TT	4900850	BODEGA WATER COMPANY	150	1	
Arsenic	0.01	4900855	WEST FIELD COMMUNITY	75	2	
Total Coliform - Monitoring, Routine Major	Absence	4900893	WEST WATER COMPANY (PUC)	50		1
LCR - Routine&followup monitoring	MR	4900893	WEST WATER COMPANY (PUC)	50		1
Arsenic	0.01	4900897	RODNEY STRONG VINEYARDS	100	4	
Arsenic	0.01	4900904	J VINEYARDS & WINERY	40	4	
Total Coliform - Monitoring, Routine Major	Absence	4900924	FREMONT DINER	50		2
Total Coliform - Non acute MCL	Absence	4900998	DE LOACH WINERY	30	1	
Total Coliform - Acute MCL	Absence	4901024	DRY CREEK STORE	50	1	
Total Coliform - Monitoring, Repeat Minor	Absence	4901024	DRY CREEK STORE	50		1
Total Coliform - Monitoring, Routine Major	Absence	4901062	KINNYBROOK MUTUAL WATER COMPANY	48		1
Total Coliform - Non acute MCL	Absence	4901069	SONOMA VALLEY MOOSE LODGE #2048	80	1	
Total Coliform - Monitoring, Routine Major	Absence	4901069	SONOMA VALLEY MOOSE LODGE #2048	80		1

SONOMA						
Total Coliform - Acute MCL	Absence	4901077	SONOMA MOUNTAIN ZEN CENTER	25	2	
Total Coliform - Monitoring, Routine Major	Absence	4901129	VIANSA WINERY	200		3
LCR - Routine&followup monitoring	MR	4901129	VIANSA WINERY	200		1
LCR - Routine&followup monitoring	MR	4901130	GRAVENSTEIN BUSINESS PARK	50		1
Total Coliform - Monitoring, Routine Major	Absence	4901135	HOOT OWL CREEK/ALEX. VALLEY VINEYARDS JV	26		1
Arsenic	0.01	4901136	WILSON ELEMENTARY SCHOOL	200	3	
Nitrate (As No3)	45	4901154	GILARDI WATER SYSTEM	50		1
Total Coliform - Monitoring, Routine Major	Absence	4901162	QUIVIRA VINEYARDS	60		1
Total Coliform - Non acute MCL	Absence	4901164	GURDJIEFF FOUNDATION	90	1	
Total Coliform - Monitoring, Routine Major	Absence	4901165	JEHOVAH S WITNESSES HALL	650		1
Total Coliform - Monitoring, Routine Major	Absence	4901193	SCHELLVILLE GRILL	50		2
Arsenic	0.01	4901195	MOORLAND AVENUE APARTMENTS	64	4	
Arsenic	0.01	4901195	MOORLAND AVENUE APARTMENTS	64		1
Arsenic	0.01	4901218	GROSKOPF WAREHOUSE & LOGISTICS	60	4	
Arsenic	0.01	4901218	GROSKOPF WAREHOUSE & LOGISTICS	60		1
Arsenic	0.01	4901225	SONOMA INTERNATIONAL	45	4	
Arsenic	0.01	4901236	VINO FARMS, INC. - PRESTON RANCH	60	3	
Arsenic	0.01	4901247	CARNEROS WAREHOUSING	50	3	
Total Coliform - Acute MCL	Absence	4901247	CARNEROS WAREHOUSING	50	1	
Total Coliform - Non acute MCL	Absence	4901247	CARNEROS WAREHOUSING	50	1	
Total Coliform - Non acute MCL	Absence	4901251	SAFARI WEST	60	1	
Total Coliform - Non acute MCL	Absence	4901252	E & J GALLO WINERY-SONOMA	120	1	
LCR - Routine&followup monitoring	MR	4901262	RAVENSWOOD (QUARRY) WINERY	25		1
Total Coliform - Monitoring, Repeat Major	Absence	4901265	SONOMA STATE U.-FAIRFIELD OSBORN PRES	26		1
LCR - Routine&followup monitoring	MR	4901267	TRUE TO LIFE	35		1
Arsenic	0.01	4901269	UNITED RENTALS	30		1
Total Coliform - Monitoring, Routine Major	Absence	4901272	WILDWOOD RETREAT	75		1
Nitrate (As No3)	45	4901283	FRITZ WINERY AND VINEYARD	26		1
Arsenic	0.01	4901294	WINE COUNTRY IND PARK-BLDGS A&B	30	1	
Nitrate (As No3)	45	4901300	WINDY HILL WINERY	26		1
Total Coliform - Monitoring, Repeat Major	Absence	4901300	WINDY HILL WINERY	26		2
Total Coliform - Non acute MCL	Absence	4901305	TRUETT & HURST WINERY	30	1	
Total Coliform - Monitoring, Routine Major	Absence	4901307	WASHOE CREEK GOLF COURSE	40		1

SONOMA							
Total Coliform - Acute MCL	Absence	4901313	SEBASTOPOL VINEYARDS	26	1		
Total Coliform - Monitoring, Routine Major	Absence	4901316	RUED VINEYARDS	26		1	
Arsenic	0.01	4901323	FULTON PROCESSORS, INC.	100	4		
Arsenic	0.01	4901323	FULTON PROCESSORS, INC.	100		1	
Total Coliform - Non acute MCL	Absence	4901337	ALEXANDER VALLEY RV PARK & CAMPGROUND	230	1		
Total Coliform - Acute MCL	Absence	4901342	PADMASAMBHAVA PEACE INSTITUTE	262	1		
Total Coliform - Acute MCL	Absence	4901346	DELORES LANE WATER SYSTEM	50	1		
Total Coliform - Non acute MCL	Absence	4901346	DELORES LANE WATER SYSTEM	50	1		
Total Coliform - Acute MCL	Absence	4901351	MUELLER WINERY	50	1		
Total Coliform - Acute MCL	Absence	4901356	GARY FARRELL WINERY	50	1		
Total Coliform - Monitoring, Routine Major	Absence	4901357	RIVERS EDGE KAYAK & CANOE TRIPS	50		2	
Haa5 - Haloacetic Acids (Five)	0.06	4910002	CLOVERDALE, CITY OF	8200		2	
Trihalomethanes (TTHM) - Total	0.08	4910002	CLOVERDALE, CITY OF	8200		2	
Arsenic	0.01	4910011	SEBASTOPOL, CITY OF	7750	4		
COUNTS/TOTALS				75	23632	100	53
STANISLAUS							
Total Coliform - Non acute MCL	Absence	5000019	RIVERDALE PARK TRACT COMMUNITY SERVICES	300	1		
Arsenic	0.01	5000033	COBLES CORNER	50	3		
Arsenic	0.01	5000051	MOBILE PLAZA PARK	125	1		
Arsenic	0.01	5000077	CERES WEST MHP	161	3		
Arsenic	0.01	5000080	COUNTRY WESTERN MOBILE HOME PARK	120	3		
Total Coliform - Acute MCL	Absence	5000082	4N MOBILEHOME PARK	165	1		
Arsenic	0.01	5000085	GREEN RUN MOBILE ESTATES	100	3		
Arsenic	0.01	5000086	COUNTRYSIDE MOBILEHOME ESTATES - ADULT P	60	3		
Total Coliform - Non acute MCL	Absence	5000099	DEL RIO EAST HOA WATER SYSTEM	110	1		
Total Coliform - Non acute MCL	Absence	5000132	VALLEY HOME SCHOOL TEXAS	26	1		
Total Coliform - Non acute MCL	Absence	5000134	DEPARTMENT OF TRANSPORTATION	8900	1		
Nitrate (As No3)	45	5000136	LOG CABIN WATER SYSTEM	26	1		
Total Coliform - Non acute MCL	Absence	5000138	EL RINCON & YOSEMITE HACIENDA MARKET	25	1		
Arsenic	0.01	5000195	SWANSON FARMS	25	2		
Total Coliform - Non acute MCL	Absence	5000202	JOE S TRAVEL PLAZA (EH)	26	1		
Arsenic	0.01	5000218	COUNTRY VILLA APTS	30	3		
Total Coliform - Monitoring, Routine Major	Absence	5000238	SUN DRY PRODUCTS-WATER	26		1	

STANISLAUS

Total Coliform - Non acute MCL	Absence	5000263	OASIS INVESTMENTS	75	1		
Arsenic	0.01	5000273	GRATTON SCHOOL	110	3		
Total Coliform - Non acute MCL	Absence	5000297	BUEHNER HOUSES	25	1		
Total Coliform - Non acute MCL	Absence	5000313	BUEHNER WATER SYSTEM	150	1		
Arsenic	0.01	5000335	BRETHREN HERITAGE SCHOOL, INC	25	1		
Arsenic	0.01	5000389	MONTEREY PARK TRACT COMMUNITY SERVICE DI	186	3		
Total Coliform - Non acute MCL	Absence	5000391	SUPERIOR DISTRIBUTION CENTER	45	1		
Total Coliform - Non acute MCL	Absence	5000401	KNIGHTS FERRY RECREATION AREA	26	1		
Arsenic	0.01	5000465	DUARTE NURSERY INC WATER SYSTEM	75	5		
Total Coliform - Non acute MCL	Absence	5000470	HUGHSON NUT COMPANY WATER SYSTEM	120	1		
Arsenic	0.01	5000484	UNITED PALLET WATER SYSTEM	45	3		
Arsenic	0.01	5000499	RATTO BROS	100	1		
Total Coliform - Non acute MCL	Absence	5000507	GURUDWARA GURU NANAK SAHIB	109	1		
Total Coliform - Non acute MCL	Absence	5000517	KIERNAN/MCHENRY WATER COMPANY, INC	25	1		
Total Coliform - Non acute MCL	Absence	5000530	FRAZIER NUT FARMS, INC.	40	1		
Total Coliform - Non acute MCL	Absence	5000552	KIERNAN BUSINESS CENTER	120	1		
Arsenic	0.01	5000553	FOSTER FARMS-WEST MAIN FEEDMILL	25	3		
Total Coliform - Non acute MCL	Absence	5000554	HUGHSON NUT #2	25	1		
Arsenic	0.01	5000555	PIRANHA PRODUCE	26	2		
Total Coliform - Non acute MCL	Absence	5000571	WATERFORD SPORTSMEN S CLUB	25	2		
Total Coliform - Non acute MCL	Absence	5000579	FOSTER FARMS #5	26	1		
Total Coliform - Non acute MCL	Absence	5000581	PIONEER EQUINE HOSPITAL WATER SYSTEM	25	1		
Arsenic	0.01	5010008	HUGHSON, CITY OF	6082	4		
Arsenic	0.01	5010009	KEYES COMMUNITY SERVICES DIST.	4575	4		
Haa5 - Haloacetic Acids (Five)	0.06	5010013	CITY OF NEWMAN-WATER DEPARTMENT	10586		1	
Trihalomethanes (TTHM) - Total	0.08	5010013	CITY OF NEWMAN-WATER DEPARTMENT	10586		1	
Total Coliform - Non acute MCL	Absence	5010014	OAKDALE, CITY OF	19250	1		
Total Coliform - Non acute MCL	Absence	5010019	TURLOCK, CITY OF	64215	1		
Total Coliform - Non acute MCL	Absence	5010028	CERES, CITY OF	40943	1		
Trihalomethanes (TTHM) - Total	0.08	5010039	WESTERN HILLS WATER DISTRICT/DIABLO GRAN	3000	3		
Consumer Confidence Report	n/a	5010039	WESTERN HILLS WATER DISTRICT/DIABLO GRAN	3000		1	
Total Organic Carbon (TOC)	Failure	5010039	WESTERN HILLS WATER DISTRICT/DIABLO GRAN	3000		1	
COUNTS/TOTALS				46	160354	79	5

SUTTER							
Arsenic	0.01	5100107	SUTTER CO. WWD#1 (ROBBINS)	336	4		
Arsenic	0.01	5100109	WILDWOOD MUTUAL WATER COMPANY	255	4		
Total Coliform - Monitoring, Routine Major	Absence	5100118	LOVEY'S LANDING	350		1	
Total Coliform - Monitoring, Routine Major	Absence	5100120	ROLL-A-HOME MOBILE H.P.	150		4	
Total Coliform - Monitoring, Routine Major	Absence	5100125	QUALITY INN AND SUITES	25		2	
Arsenic	0.01	5100140	MARCUM ILLINOIS ELEMENTARY SCHOOL	200	4		
Total Coliform - Non acute MCL	Absence	5100141	MERIDIAN ELEMENTARY SCHOOL	93	1		
Total Coliform - Monitoring, Routine Major	Absence	5100142	NUESTRO SCHOOL	120		1	
Arsenic	0.01	5100145	WINSHIP ELEMENTARY SCHOOL	50	4		
Arsenic	0.01	5100145	WINSHIP ELEMENTARY SCHOOL	50		1	
Arsenic	0.01	5100149	BARRY ELEMENTARY SCHOOL	560	4		
Arsenic	0.01	5100149	BARRY ELEMENTARY SCHOOL	560		1	
Arsenic	0.01	5100153	HOLT OF CALIFORNIA	100	4		
Arsenic	0.01	5100158	SUNSET MOULDING CO.	65	3		
Arsenic	0.01	5100180	GRACE BAPTIST CHURCH	200	4		
Arsenic	0.01	5101001	FIRST UNITED METHODIST CHURCH	65	4		
Arsenic	0.01	5101001	FIRST UNITED METHODIST CHURCH	65		1	
Total Coliform - Monitoring, Routine Major	Absence	5102016	PASQUINI'S (MICHELI) WS	150		1	
Total Coliform - Monitoring, Routine Minor	Absence	5102025	BLUE ANGEL APARTMENTS W.S.	15		1	
Total Coliform - Monitoring, Routine Major	Absence	5103325	SOUTH RIDGE GOLF COURSE	25		2	
Total Coliform - Monitoring, Routine Minor	Absence	5105007	RIVER RANCH CAMP W.S.	25		1	
Arsenic	0.01	5105008	VALLEY FARM TRANSPORT	25	4		
Total Coliform - Monitoring, Routine Major	Absence	5105009	SIKH TEMPLE GURDWARA	250		1	
Arsenic	0.01	5110003	YUBA CITY GROUNDWATER-REGION 2-3	10200	2		
COUNTS/TOTALS				21	13259	42	17

TEHAMA							
Trihalomethanes (TTHM) - Total	0.08	5200008	BREESE SUBDIVISION 2	90		1	
Nitrate (As No3)	45	5200010	WOODSON BRIDGE R.V. PARK	25		1	
Nitrate (As No3)	45	5200618	LAKE CALIFORNIA POA R.V. PARK	200		1	
Nitrate (As No3)	45	5201127	CROSS PETROLEUM	25		1	
Nitrate (As No3)	45	5201140	ANTOINETTE MUTUAL WATER CO	30		1	
Total Coliform - Monitoring, Routine Major	Absence	5201140	ANTOINETTE MUTUAL WATER CO	30		1	
Nitrate (As No3)	45	5205008	MEYER MOTELS DIAMOND PROPERTY	25		1	
Arsenic	0.01	5210003	LOS MOLINOS COMM. SERVICES DIST.	1500	4		
COUNTS/TOTALS				7	1895	4	7
TRINITY							
Arsenic	0.01	5301002	LEWISTON VALLEY WATER CO., INC.	150	4		
Total Coliform - Non acute MCL	Absence	5301014	BRIDGE CAMP	190	1		
Total Coliform - Non acute MCL	Absence	5301113	CLARK SYSTEM	450	1		
Total Coliform - Non acute MCL	Absence	5304502	SALYER HEIGHTS W.S., INC	82	1		
SWTR - treatment technique (41)	TT	5305402	BAR 717 RANCH	180	1		
COUNTS/TOTALS				5	1052	8	0

TULARE

Total Coliform - Monitoring, Routine Major	Absence	5400504	A & A MHP	200		1
Consumer Confidence Report	n/a	5400504	A & A MHP	200		1
Nitrate (As No3)	45	5400506	NORTH KAWEAH MUTUAL WATER CO	75		1
Consumer Confidence Report	n/a	5400506	NORTH KAWEAH MUTUAL WATER CO	75		1
Nitrate (As No3)	45	5400507	VISALIA - FRESNO SOUTH KOA	150	1	
Nitrate (As No3)	45	5400523	EL MONTE VILLAGE M H P	100	4	
Total Coliform - Non acute MCL	Absence	5400526	ENNS PACKING CO	50	1	
Total Coliform - Acute MCL	Absence	5400527	SHILOH WATER CO.	75	1	
Total Coliform - Non acute MCL	Absence	5400529	SHADY GROVE M H P	137	1	
Total Coliform - Non acute MCL	Absence	5400536	KINGS RIVER ESTATES	100	2	
Nitrate (As No3)	45	5400537	LINDYS LANDING	500		1
Nitrate (As No3)	45	5400541	PARAMOUNT CITRUS	100	1	
Nitrate (As No3)	45	5400542	DUCOR CSD	850	1	
Total Coliform - Non acute MCL	Absence	5400544	ALLENSWORTH C S D	400	1	
Nitrate (As No3)	45	5400548	KINGS INN MOTEL	130	1	
Total Coliform - Non acute MCL	Absence	5400548	KINGS INN MOTEL	130	1	
Total Coliform - Monitoring, Repeat Major	Absence	5400550	SEVILLE WATER CO	400		1
Nitrate (As No3)	45	5400552	STONEY CREEK - RESTAURANT/STORE	42		1
Nitrate (As No3)	45	5400555	CITRUS SOUTH TULE SCHOOL	50	1	
Total Coliform - Non acute MCL	Absence	5400555	CITRUS SOUTH TULE SCHOOL	50	3	
Nitrate (As No3)	45	5400558	SAUCELITO ELEM SCHOOL	75	2	
Nitrate (As No3)	45	5400558	SAUCELITO ELEM SCHOOL	75		1
Total Coliform - Non acute MCL	Absence	5400558	SAUCELITO ELEM SCHOOL	75	1	
Total Coliform - Monitoring, Repeat Major	Absence	5400558	SAUCELITO ELEM SCHOOL	75		1
Total Coliform - Non acute MCL	Absence	5400567	TOOLEVILLE WATER COMPANY	300	3	
Consumer Confidence Report	n/a	5400567	TOOLEVILLE WATER COMPANY	300		1
Total Coliform - Monitoring, Routine Major	Absence	5400581	SPEAR CREEK CABIN OWNERS ASSOC	52		1
Total Coliform - Acute MCL	Absence	5400602	EAGLE S NEST RESORT	200	1	
Total Coliform - Monitoring, Routine Major	Absence	5400602	EAGLE S NEST RESORT	200		1
Total Coliform - Non acute MCL	Absence	5400604	MOUNTAIN VIEW DUPLEXES	108	1	
Total Coliform - Monitoring, Routine Major	Absence	5400611	PORTERVILLE TRAILER PARK	80		2
Nitrate (As No3)	45	5400616	LEMON COVE WATER CO	200	1	
Total Coliform - Non acute MCL	Absence	5400623	WESTERN - HOLIDAY LODGE	100	1	

TULARE

Nitrate (As No3)	45	5400628	LEMON COVE-SEQUOIA CAMP	100	1	
Arsenic	0.01	5400629	SEQUOIA RV RANCH	22	1	
Arsenic	0.01	5400629	SEQUOIA RV RANCH	22	1	
Total Coliform - Non acute MCL	Absence	5400629	SEQUOIA RV RANCH	22	2	
Consumer Confidence Report	n/a	5400636	OROSI HIGH SCHOOL	900		1
Consumer Confidence Report	n/a	5400641	TEVISTON C S D	450		1
Nitrate (As No3)	45	5400651	BEVERLY GRAND MUTUAL WATER	108	1	
Total Coliform - Non acute MCL	Absence	5400655	CENTRAL MUTUAL WATER CO	115	1	
Nitrate (As No3)	45	5400660	LAKE SUCCESS MOBILE LODGE	20	3	
Nitrate (As No3)	45	5400660	LAKE SUCCESS MOBILE LODGE	20		1
Total Coliform - Monitoring, Repeat Minor	Absence	5400660	LAKE SUCCESS MOBILE LODGE	20		1
Nitrate (As No3)	45	5400663	FAIRWAYS TRACT MUTUAL	250		1
Uranium	30 µg/L	5400665	DEL ORO RIVER ISLAND SERV TERR #1	810	1	
Nitrate (As No3)	45	5400670	TRIPLE R MUTUAL WATER CO	400	2	
Total Coliform - Non acute MCL	Absence	5400670	TRIPLE R MUTUAL WATER CO	400	2	
Total Coliform - Non acute MCL	Absence	5400679	MOTEL 99	60	1	
Nitrate (As No3)	45	5400687	ORANGE BLOSSOM JUNCTION	100		1
Total Coliform - Monitoring, Routine Major	Absence	5400687	ORANGE BLOSSOM JUNCTION	100		2
Total Coliform - Acute MCL	Absence	5400704	THREE RIVERS SCHOOL	300	2	
Total Coliform - Non acute MCL	Absence	5400704	THREE RIVERS SCHOOL	300	3	
Total Coliform - Non acute MCL	Absence	5400710	BADGER HILL ESTATES	300	1	
Nitrate (As No3)	45	5400711	SIERRA VIEW JR ACADEMY	160	2	
Nitrate (As No3)	45	5400711	SIERRA VIEW JR ACADEMY	160		1
Consumer Confidence Report	n/a	5400711	SIERRA VIEW JR ACADEMY	160		1
Arsenic	0.01	5400713	OAK VALLEY SCHOOL	300	4	
Total Coliform - Non acute MCL	Absence	5400713	OAK VALLEY SCHOOL	300	1	
Nitrate (As No3)	45	5400735	RODRIGUEZ LABOR CAMP	110	1	
Consumer Confidence Report	n/a	5400735	RODRIGUEZ LABOR CAMP	110		1
Nitrate (As No3)	45	5400737	ST ANTHONY S RETREAT	130		1
SWTR-filtered sys-monitoring (36)	MR	5400737	ST ANTHONY S RETREAT	130		1
SWTR - treatment technique (41)	TT	5400737	ST ANTHONY S RETREAT	130	4	
Total Coliform - Non acute MCL	Absence	5400742	ELK BAYOU PARK	25	2	
SWTR - treatment technique (41)	TT	5400749	GATEWAY RESTAURANT	150	1	

TULARE						
Arsenic	0.01	5400754	SO KAWEAH MUTUAL WATER CO	300	5	
Arsenic	0.01	5400754	SO KAWEAH MUTUAL WATER CO	300	2	
Nitrate (As No3)	45	5400762	GIUMARRA VINEYARDS 3 & 4	125		1
Total Coliform - Non acute MCL	Absence	5400762	GIUMARRA VINEYARDS 3 & 4	125	1	
Nitrate (As No3)	45	5400763	GIUMARRA VINEYARDS 5 & 6	150		1
Total Coliform - Non acute MCL	Absence	5400792	WOODVILLE FARM LABOR CENTER	725	1	
Nitrate (As No3)	45	5400795	WAUKENA ELEMENTARY SCHOOL	230	1	
Uranium	30 µg/L	5400795	WAUKENA ELEMENTARY SCHOOL	230	2	
Uranium	30 µg/L	5400795	WAUKENA ELEMENTARY SCHOOL	230		2
Total Coliform - Acute MCL	Absence	5400795	WAUKENA ELEMENTARY SCHOOL	230	1	
Nitrate (As No3)	45	5400805	SOULTS MUTUAL WATER CO	100	1	
Nitrate (As No3)	45	5400810	AKAL TRAVEL PLAZA	200	1	
Total Coliform - Non acute MCL	Absence	5400824	SULTANA C S D	650	1	
Nitrate (As No3)	45	5400838	THREE RIVERS VILLAGE	25		1
Total Coliform - Non acute MCL	Absence	5400868	CLM-FAIRVIEW CAMPGROUND	125	2	
Nitrate (As No3)	45	5400890	CLM-FIR&COVE GROUP CAMPGROUNDS	75		1
Nitrate (As No3)	45	5400894	CAMP SAN JOAQUIN	80		1
Nitrate (As No3)	45	5400895	PYTHIAN YOUTH CAMP	75		1
Total Coliform - Non acute MCL	Absence	5400917	SHOP N GO	25	1	
Nitrate (As No3)	45	5400918	OPEN COUNTRY SWAP MEET	300	3	
Nitrate (As No3)	45	5400918	OPEN COUNTRY SWAP MEET	300		1
Nitrate (As No3)	45	5400919	BUENA VISTA SCHOOL	130	1	
Nitrate (As No3)	45	5400920	TIPTON ELEMENTARY SCHOOL	480		1
Total Coliform - Acute MCL	Absence	5400924	SIERRA LAKES CHRISTIAN CAMP	62	2	
Total Coliform - Non acute MCL	Absence	5400957	WEST GOSHEN MUTUAL WATER CO	200	1	
Consumer Confidence Report	n/a	5400957	WEST GOSHEN MUTUAL WATER CO	200		1
Total Coliform - Monitoring, Routine Major	Absence	5400961	QUAKER MEADOW CAMP	200		1
Carbon Tetrachloride	0.0005	5400963	WOODEN SHOE VISALIA LLC	90		2
Nitrate (As No3)	45	5400966	WESTLAKE VILLAGE M H P	350	1	
Total Coliform - Monitoring, Routine Major	Absence	5400975	THE SEAFOOD CAFE	50		1
Total Coliform - Monitoring, Routine Major	Absence	5400984	SUCCESS MARKET	25		3
Nitrate (As No3)	45	5400987	FOUNTAIN SPRINGS EL TAPATIO	25	1	
Total Coliform - Monitoring, Routine Major	Absence	5400987	FOUNTAIN SPRINGS EL TAPATIO	25		1

TULARE

Nitrate (As No3)	45	5400994	HOPE ELEMENTARY SCHOOL	100		1
Nitrate (As No3)	45	5401003	EAST OROSI CSD	700	2	
Total Coliform - Non acute MCL	Absence	5401003	EAST OROSI CSD	700	6	
Total Coliform - Monitoring, Repeat Major	Absence	5401003	EAST OROSI CSD	700		1
Consumer Confidence Report	n/a	5401003	EAST OROSI CSD	700		1
Nitrate (As No3)	45	5401004	STYROTEK	36	4	
Nitrate (As No3)	45	5401006	UC DAVIS-SCHOOL OF VET. MED.	80	1	
Consumer Confidence Report	n/a	5401026	DEER MEADOW MUTUAL	75		1
Total Coliform - Non acute MCL	Absence	5401038	AKIN WATER CO	50	1	
Consumer Confidence Report	n/a	5401038	AKIN WATER CO	50		1
Total Coliform - Monitoring, Routine Major	Absence	5401041	CHUCK S HIDDEN LAKES	30		1
Nitrate (As No3)	45	5401048	KINGS RIVER GOLF COURSE	500		1
Total Coliform - Monitoring, Routine Major	Absence	5401049	CAMP WILDERNESS	40		1
Nitrate (As No3)	45	5401053	CHARLIE S	150	3	
Nitrate (As No3)	45	5401053	CHARLIE S	150		1
Total Coliform - Acute MCL	Absence	5401053	CHARLIE S	150	1	
Nitrate (As No3)	45	5401063	THARP REAL PROPERTIES	35	1	
Nitrate (As No3)	45	5401071	SILVER CITY WATER CO	128		1
Total Coliform - Non acute MCL	Absence	5401079	LIVESTOCK SALES YARD	60	1	
Nitrate (As No3)	45	5401080	LAKE EXPRESS MARKET	25	2	
Nitrate (As No3)	45	5401080	LAKE EXPRESS MARKET	25		1
Total Coliform - Non acute MCL	Absence	5401080	LAKE EXPRESS MARKET	25	1	
Total Coliform - Non acute MCL	Absence	5401082	VENTURA COASTAL CORP	35	1	
Nitrate (As No3)	45	5401084	SISTERS MOUNTAIN HOUSE	25		1
Nitrate (As No3)	45	5401099	SIERRA CHRISTIAN CAMP	150		1
Nitrate (As No3)	45	5402008	HOT SPRINGS SCHOOL	42		1
Nitrate (As No3)	45	5402013	SUN PACIFIC SHIPPERS LP - EXETER	200	1	
Consumer Confidence Report	n/a	5402013	SUN PACIFIC SHIPPERS LP - EXETER	200		1
Nitrate (As No3)	45	5402024	KINGS RIVER MARKET	25	1	
Nitrate (As No3)	45	5402025	LAKESIDE MINNIT MART	25	1	
Nitrate (As No3)	45	5402025	LAKESIDE MINNIT MART	25		1
Nitrate (As No3)	45	5402030	WAUKENA MARKET	140	4	
Total Coliform - Monitoring, Routine Major	Absence	5402036	R-RANCH IN THE SEQUOIAS	500		1

TULARE

Total Coliform - Non acute MCL	Absence	5402041	PENNY WISE MOTEL	25	1	
Nitrate (As No3)	45	5402043	MONSON MARKET	25	1	
Nitrate (As No3)	45	5402046	GNI WATERMAN LLC	225	1	
Total Coliform - Non acute MCL	Absence	5402046	GNI WATERMAN LLC	225	1	
Nitrate (As No3)	45	5402047	GLEANINGS FOR THE HUNGRY	31	4	
Total Coliform - Non acute MCL	Absence	5402047	GLEANINGS FOR THE HUNGRY	31	1	
Nitrate (As No3)	45	5402056	PEOPLES GROCERY	25	1	
Nitrate (As No3)	45	5403007	E M THARP INC	65	1	
Total Coliform - Non acute MCL	Absence	5403007	E M THARP INC	65	1	
Carbon Tetrachloride	0.0005	5403009	SUPER STOP	95		1
Nitrate (As No3)	45	5403010	GOLDEN STATE CITRUS PACKERS	75	1	
Nitrate (As No3)	45	5403013	PRINCE MART	25	1	
Nitrate (As No3)	45	5403030	FOOTHILL FRUIT CO	50		1
Consumer Confidence Report	n/a	5403031	SUN PACIFIC-TULARE	250		1
Total Coliform - Non acute MCL	Absence	5403032	MONROVIA NURSERY - NURSERY	400	1	
Nitrate (As No3)	45	5403045	IMMANUEL SCHOOL	35	1	
Nitrate (As No3)	45	5403046	TRI COUNTY CITRUS	80	1	
Total Coliform - Non acute MCL	Absence	5403048	J D HEISKELL & CO	33	1	
Nitrate (As No3)	45	5403053	NS MINI MART	140		1
Total Coliform - Non acute MCL	Absence	5403053	NS MINI MART	140	2	
Total Coliform - Monitoring, Routine Major	Absence	5403053	NS MINI MART	140		1
Arsenic	0.01	5403054	CLOUGHERTY PACKING - FARM DIVISION	87	3	
Arsenic	0.01	5403054	CLOUGHERTY PACKING - FARM DIVISION	87		1
Arsenic	0.01	5403054	CLOUGHERTY PACKING - FARM DIVISION	87		2
Total Coliform - Acute MCL	Absence	5403054	CLOUGHERTY PACKING - FARM DIVISION	87	1	
Total Coliform - Non acute MCL	Absence	5403054	CLOUGHERTY PACKING - FARM DIVISION	87	3	
Total Coliform - Monitoring, Repeat Major	Absence	5403054	CLOUGHERTY PACKING - FARM DIVISION	87		1
Total Coliform - Monitoring, Repeat Minor	Absence	5403054	CLOUGHERTY PACKING - FARM DIVISION	87		1
Total Coliform - Acute MCL	Absence	5403061	RIVERVIEW RESTAURANT	50	1	
SWTR - treatment technique (41)	TT	5403061	RIVERVIEW RESTAURANT	50	1	
Total Coliform - Non acute MCL	Absence	5403062	COMFORT INN & SUITES	125	1	
Nitrate (As No3)	45	5403071	THREE RIVERS CHEVRON	50		1
Nitrate (As No3)	45	5403072	ROGERS CAMP HOMEOWNERS ASSN	25		1

TULARE

Total Coliform - Monitoring, Routine Major	Absence	5403074	KRAFT FOODS - TULARE SO	130		1
Nitrate (As No3)	45	5403076	CENTRAL CAL TRISTEZA ERAD	25	1	
Nitrate (As No3)	45	5403080	FRUIT PATCH INC	125		1
Total Coliform - Non acute MCL	Absence	5403081	PETERS FRUIT FARMS, INC	125	1	
Nitrate (As No3)	45	5403103	TRACT 327 MUTUAL WATER CO	24		1
Uranium	30 µg/L	5403103	TRACT 327 MUTUAL WATER CO	24		4
Total Coliform - Non acute MCL	Absence	5403103	TRACT 327 MUTUAL WATER CO	24	2	
Total Coliform - Monitoring, Routine Minor	Absence	5403103	TRACT 327 MUTUAL WATER CO	24		1
Total Coliform - Monitoring, Repeat Major	Absence	5403103	TRACT 327 MUTUAL WATER CO	24		1
Total Coliform - Monitoring, Repeat Minor	Absence	5403103	TRACT 327 MUTUAL WATER CO	24		1
Consumer Confidence Report	n/a	5403103	TRACT 327 MUTUAL WATER CO	24		1
Consumer Confidence Report	n/a	5403106	LO BUE BROS - EARLIBEST	99		1
Nitrate (As No3)	45	5403110	SIERRA MUTUAL WATER CO	39	1	
Total Coliform - Non acute MCL	Absence	5403114	TRAVER FEEDMILL PWS	40	2	
Total Coliform - Monitoring, Routine Major	Absence	5403116	KERN RIVER GOLDEN TROUT RESORT	104		1
Total Coliform - Monitoring, Routine Major	Absence	5403119	SUNKIST GROWERS	75		2
Consumer Confidence Report	n/a	5403119	SUNKIST GROWERS	75		1
Nitrate (As No3)	45	5403121	INTERNATIONAL PAPER - TRI WALL	50		1
Total Coliform - Monitoring, Routine Major	Absence	5403125	VICTORIAN GARDENS	200		1
Total Coliform - Non acute MCL	Absence	5403127	MONROVIA VENICE HILLS NURSERY	30	1	
Total Coliform - Monitoring, Routine Major	Absence	5403128	MOZZARELLA FRESCA	150		2
Total Coliform - Acute MCL	Absence	5403129	TRACT 403 MUTUAL WATER CO	30	1	
Total Coliform - Non acute MCL	Absence	5403130	ELEANOR ROOSEVELT COMM LEARNING CTR	100	1	
Total Coliform - Non acute MCL	Absence	5403131	SUNNY ACRES WATER SYSTEM	80	2	
Total Coliform - Non acute MCL	Absence	5403132	CALGREN RENEWABLE FUELS	70	3	
Dibromochloropropane (Dbcp)	0.0002	5410001	CUTLER PUD	6200	2	
Haa5 - Haloacetic Acids (Five)	0.06	5410002	DINUBA, CITY OF	21237		1
Trihalomethanes (TTHM) - Total	0.08	5410002	DINUBA, CITY OF	21237		1
Total Coliform - Non acute MCL	Absence	5410004	FARMERSVILLE, CITY OF	10672	1	
Haa5 - Haloacetic Acids (Five)	0.06	5410007	LSID - TONYVILLE	400	3	
Trihalomethanes (TTHM) - Total	0.08	5410007	LSID - TONYVILLE	400	4	
Arsenic	0.01	5410009	PIXLEY PUBLIC UTIL DIST	2793	4	
Total Coliform - Monitoring, Routine Minor	Absence	5410011	SPRINGVILLE PUD	1500		1

TULARE							
Total Coliform - Monitoring, Repeat Major	Absence	5410014	TIPTON COMMUNITY SERVICES DIST	1992		1	
Total Coliform - Non acute MCL	Absence	5410017	LONDON COMMUNITY SERV DIST	1638	1		
LCR - Routine&followup monitoring	MR	5410019	IVANHOE PUBLIC UTILITY DIST	4474		1	
ESWTR - turbidity >0.3 NTU (44)	TT	5410022	CAMP NELSON WATER COMPANY	150	4		
Arsenic	0.01	5410024	RICHGROVE COMMUNITY SERVICES DISTRICT	3330		1	
Total Coliform - Monitoring, Routine Minor	Absence	5410024	RICHGROVE COMMUNITY SERVICES DISTRICT	3330		1	
Arsenic	0.01	5410033	PRATT MUTUAL WATER CO	1500	1		
Uranium	30 µg/L	5410034	PINE FLAT WATER COMPANY	200	1		
Haa5 - Haloacetic Acids (Five)	0.06	5410037	LSID-PAGE MOORE SYSTEM	550	3		
Trihalomethanes (TTHM) - Total	0.08	5410037	LSID-PAGE MOORE SYSTEM	550	4		
Nitrate (As No3)	45	5410039	PLAINVIEW MUTUAL WATER COMPANY	800		1	
Arsenic	0.01	5410050	ALPAUGH JOINT POWERS AUTHORITY	910	2		
Arsenic	0.01	5410050	ALPAUGH JOINT POWERS AUTHORITY	910		2	
Nitrate (As No3)	45	5410050	ALPAUGH JOINT POWERS AUTHORITY	910		1	
Total Coliform - Monitoring, Repeat Minor	Absence	5410050	ALPAUGH JOINT POWERS AUTHORITY	910		1	
Haa5 - Haloacetic Acids (Five)	0.06	5410503	NPS-WOLVERTON	5	4		
Trihalomethanes (TTHM) - Total	0.08	5410503	NPS-WOLVERTON	5	4		
Haa5 - Haloacetic Acids (Five)	0.06	5410801	PORTERVILLE DEVELOPMENTAL CENTER	2567		1	
Trihalomethanes (TTHM) - Total	0.08	5410801	PORTERVILLE DEVELOPMENTAL CENTER	2567		1	
COUNTS/TOTALS				149	81562	208	109

TUOLUMNE							
Haa5 - Haloacetic Acids (Five)	0.06	5510007	DEL ORO WATER COMPANY - STRAWBERRY DIV.	330	1		
Trihalomethanes (TTHM) - Total	0.08	5510008	LAKE DON PEDRO C S D	3240	1		
Total Coliform - Monitoring, Routine Major	Absence	5510500	YOSEMITE NPS-TUOLUMNE MEADOWS	2500		1	
Lead and Copper Rule	MR	5510503	YOSEMITE NPS-HODGDON MEADOW	51		2	
Public Notice Rule violation for an NPDWR violat	n/a	5510503	YOSEMITE NPS-HODGDON MEADOW	51		2	
Total Organic Carbon (TOC)	Failure	5510851	DEPT. OF CORRECTIONS	4050	2		
COUNTS/TOTALS				5	10171	4	5
VENTURA							
Total Coliform - Monitoring, Routine Major	Absence	5601117	SENIOR CANYON MUTUAL WATER CO	450		1	
Consumer Confidence Report	n/a	5601119	SIETE ROBLES MUTUAL WATER CO	300		1	
Nitrate (As No3)	45	5601122	TICO MUTUAL WATER CO	95	1		
Total Coliform - Monitoring, Routine Major	Absence	5601122	TICO MUTUAL WATER CO	95		2	
Total Coliform - Monitoring, Repeat Minor	Absence	5601122	TICO MUTUAL WATER CO	95		1	
Total Coliform - Monitoring, Routine Minor	Absence	5601141	SOUTH MOUNTAIN MUTUAL WATER CO	45		1	
Total Coliform - Monitoring, Repeat Major	Absence	5601141	SOUTH MOUNTAIN MUTUAL WATER CO	45		1	
Consumer Confidence Report	n/a	5601141	SOUTH MOUNTAIN MUTUAL WATER CO	45		1	
Total Coliform - Non acute MCL	Absence	5601405	SANTA CLARA SCHOOL	39	1		
Total Coliform - Non acute MCL	Absence	5601716	USFS - WHEELER GORGE CAMPGROUND	500	1		
Consumer Confidence Report	n/a	5602101	ESTERINA PROPERTIES	80		1	
Total Coliform - Non acute MCL	Absence	5602103	CYPRESS MUTUAL WATER CO INC	332	1		
Consumer Confidence Report	n/a	5602107	EVERGREEN TRAILER PARK	100		1	
Total Coliform - Monitoring, Routine Major	Absence	5602109	GLENVIEW MOBILE PARK	100		2	
Consumer Confidence Report	n/a	5602109	GLENVIEW MOBILE PARK	100		1	
Consumer Confidence Report	n/a	5602110	NAVALAIR MOBILE HOME PARK	160		1	
Consumer Confidence Report	n/a	5602115	SAVIERS ROAD MUTUAL WATER CO	455		1	
Total Coliform - Monitoring, Routine Major	Absence	5602117	STRICKLAND ACRES	252		3	
Consumer Confidence Report	n/a	5602512	BOUQUET MULTIMEDIA	100		1	
Total Coliform - Non acute MCL	Absence	5602513	PYRAMID FLOWERS	30	1		
Total Coliform - Monitoring, Repeat Minor	Absence	5602513	PYRAMID FLOWERS	30		1	
Consumer Confidence Report	n/a	5603101	CONEJO MOBILE HOME PARK	120		1	
Consumer Confidence Report	n/a	5603116	SUNRISE RANCH	45		1	
Total Coliform - Non acute MCL	Absence	5603117	SANTA CLARA RESOURCES	200	1		
Antimony	0.006	5603118	VENTURA FARMS	45	2		

VENTURA							
Arsenic	0.01	5603118	VENTURA FARMS	45	4		
Consumer Confidence Report	n/a	5603118	VENTURA FARMS	45		1	
Consumer Confidence Report	n/a	5610001	DEMPSEY ROAD MUTUAL WATER CO	1520		1	
Consumer Confidence Report	n/a	5610002	FILLMORE WATER DEPT	15222		1	
SWTR - treatment technique (41)	TT	5610005	MEINERS OAKS CWD	4000	1		
Total Coliform - Monitoring, Repeat Minor	Absence	5610009	PORT HUENEME WATER DEPT	22000		1	
Total Coliform - Non acute MCL	Absence	5610010	RIO PLAZA WATER CO INC	2000	1		
COUNTS/TOTALS				24	48190	14	26
YOLO							
Total Coliform - Non acute MCL	Absence	5700537	CAMPBELL SOUP SUPPLY CO LLC - WATER	25	1		
Total Coliform - Non acute MCL	Absence	5700553	MUMMA (THOMAS) WELL	45	1		
Total Coliform - Non acute MCL	Absence	5700558	DUNNIGAN VALERO	100	2		
Total Coliform - Non acute MCL	Absence	5700565	ROSE VALLEY GROUP INC	25	1		
Total Coliform - Non acute MCL	Absence	5700571	MADISON SERVICE DIST	876	1		
Total Coliform - Non acute MCL	Absence	5700580	GREEN ACRE SCHOOL CHILD CARE	35	2		
Total Coliform - Non acute MCL	Absence	5700642	PLAINFIELD STATION	60	1		
Total Coliform - Non acute MCL	Absence	5700649	WESTUCKY WATER ASSOC	33	1		
Total Coliform - Non acute MCL	Absence	5700652	YOLO FLIERS CLUB	410	1		
Total Coliform - Non acute MCL	Absence	5700707	ROLLING ACRES WAT MUTUAL	33	1		
Total Coliform - Non acute MCL	Absence	5700745	WOODLAND MOTORS	45	2		
Total Coliform - Non acute MCL	Absence	5700752	CHEVRON STATIONS #1777 - FOOD/WATER	71	1		
Total Coliform - Non acute MCL	Absence	5700813	SOUTHPORT DELI-MART	40	1		
Nitrate (As No3)	45	5700827	PIONEER HI-BRED INTERNATIONAL	87	1		
Total Coliform - Non acute MCL	Absence	5700827	PIONEER HI-BRED INTERNATIONAL	87	3		
Arsenic	0.01	5710011	WILD WINGS GOLF COMMUNITY	1187	3		
COUNTS/TOTALS				15	3072	23	0