

# BLUE SKY ENVIRONMENTAL LLC

August 12, 2014

Bonnie Braganza  
Federal Minor NSR Permit Coordinator (PDR)  
U.S. Environmental Protection Agency  
Region 6  
1445 Ross Avenue; Ste 1200  
Dallas, Texas 75202-2733

Re: Amendment to Federal Minor New Source Review (NSR) Application for Indian Country Sandia Resort and Casino, Albuquerque, New Mexico

Dear Ms. Braganza:

On behalf of the Pueblo of Sandia, a sovereign tribal nation located in Bernalillo and Sandoval Counties, New Mexico, attached please find an amendment to the Federal Minor Source Review (NSR) application under EPA's Federal Minor NSR Program in Indian Country that was submitted to you on August 30, 2012. This amendment is in regards to two new 4,000 kW generators with certified Tier 2 emergency engines that will be installed later this year. Since these generators will be used for emergency use only, you recommended that a registration be submitted. This application is in regards to the sources at the Sandia Resort and Casino located at 30 Rainbow Road NE, Albuquerque, New Mexico. The facility is currently working on the upgrades to the three older generators (or subset) so that the engines meet the non-emergency requirements of the RICE NESHAP. Until the engines are upgraded, the generators are used for emergency and testing/maintenance use only.

The Pueblo of Sandia appreciates your review of the application and future issuance of this synthetic minor permit.

If you have any questions or require additional information, please do not hesitate to contact me at 617-834-8408 or at [don@blueskyenviro.com](mailto:don@blueskyenviro.com).

Sincerely,  
Blue Sky Environmental LLC



Don C. DiCristofaro, CCM  
President  
Attachments

cc: Joseph M. Rodriguez, Sandia Resort and Casino Facility Superintendent

## Narrative Description

On July 13, 2009 the Sandia Resort and Casino (the “Casino”), an instrumentality of a federally recognized Indian tribe submitted a notification regarding three electrical generators at the Casino located at 30 Rainbow Road NE in Albuquerque, New Mexico at the Pueblo of Sandia Indian land. The notification was submitted pursuant to the EPA Memorandum entitled *Potential to Emit (PTE) Transition Policy for Part 71 Implementation in Indian Country* from John S. Seitz, Director, Office of Air Quality Planning and Standards, and Eric V. Schaeffer, Director, Office of Regulatory Enforcement, dated March 7, 1999 (“EPA Transition Memo”). As per the EPA Transition Memo, the EPA treated a source as non-major for the purposes of the Federal Operating Permits Program (Part 71) if its actual emissions are and remain below 50 percent of the PTE thresholds for major source status, for every consecutive 12-month period (beginning with the 12 months immediately preceding March, 1999) and it maintains adequate records to demonstrate that its actual emissions are kept below these levels. On July 1, 2011, the EPA promulgated the final rule for New Source Review (“NSR”) in Indian Country. The final rule became effective on August 30, 2011. The EPA Transition Memo specifies that the PTE transition policy terminates when EPA adopts and implements a mechanism that can be used to limit PTE or EPA explicitly provides such a mechanism. Since this new minor NSR program for Indian Country adopts and implements a mechanism that can be used to limit PTE the PTE transition policy has been terminated by EPA. For sources, such as the Casino, that are currently operating under the EPA Transition Memo, synthetic minor permit applications are required by EPA by September 4, 2012. The synthetic minor permit application was submitted to EPA by the tribe on August 30, 2012.

Since the 2012 filing with EPA, the facility plans to install two Caterpillar 4,000 kW generators, Engine Model C175-20 (Model Year 2014, Tier 2 Certified, Emergency Use Only), later this year. Thus, the facility will operate the following emission sources:

- Two Caterpillar 4,000 kW Generators with 5,646 hp engines Model C175-20, Tier 2 Certified, Emergency Use Only (To be installed in late 2014)
- Two Detroit Diesel Model DDC 16V-4000 rated diesel stand-by generators, 2935 hp each
- One Detroit Diesel Model MTV 1000 rated diesel stand-by generator, 1,676 hp
- Thirteen 2.07 mmBtu/hr natural gas fired boilers
- Four 0.99 mmBtu/hr natural gas fired boilers

The three Detroit Diesel generators are existing units and are currently used solely for emergency power during periods when electrical power from the local utilities is not available, testing/maintenance, and for non-emergency demand response (“DR”) once the engines are upgraded. The two new generators to be installed in late 2014 will have Tier 2 certified emergency only engines so the generators will be used for emergency use and

testing/maintenance only. The generators are driven by diesel-fueled reciprocating internal combustion engines (“RICE”) which are sources of emissions of regulated air pollutants and hazardous air pollutants (“HAPs”). The HAP emissions of the engines are insignificant as defined by 40 CFR 71.5(11)(ii)(B)<sup>1</sup>.

Once the engines for the three older generators (or a subset) have been upgraded to meet the non-emergency requirements of the RICE NESHAP as per 40 CFR 63 Subpart ZZZZ, the Casino plans to reenter the three generators (or a subset) back into a non-emergency demand response (“DR”) program that could be called a maximum of 100 hours per year. The generators continue to operate for emergencies when electrical power is not available from the local utility and for testing/maintenance. All electrical generation is used onsite; electrical power is not sent to the grid. The generators are owned and operated by the Casino; however, participation in the DR program is managed by EnerNOC, Inc.

Bernalillo County, New Mexico falls is currently designated as an unclassified/attainment area with a major source threshold for oxides of nitrogen (“NO<sub>x</sub>”) of 100 tons per year (“tpy”).

Attached (see Attachment 1) is a facility emissions analysis that includes all fuel burning sources onsite including the two new generators that are being installed in late 2014. Both criteria pollutant and greenhouse gas emissions are provided. In addition the proposed worst-case rates are included. The emissions from the generators are derived from the attached (see Attachment 3) Exhaust Emission Data Sheets as provided by the engine manufacturer for generators #1 and 2 (and the two new generators #4 and 5) and from EPA AP-42 for generator #3. In addition to the five generators, there are seventeen natural gas-fired boilers. No emission controls are used. The allowable emissions are based on 500 hours per year for all generators and a conservative 8,760 hours per year of operation for the natural gas fired units. Using this assumption the worst-case annual NO<sub>x</sub> emissions from the facility are 87.4 tpy, well below the 100 tpy major source threshold. Since the engines do not operate at 100% load, fuel usage from the five engines will be tracked to ensure that the 12-month rolling average does not exceed 457,812 gallons (see Attachment 1, Operating and Firing Rates for details). Also, shown in the attached emissions analysis, the potential HAP emissions are insignificant as per 40 CFR 71.5(11)(ii)(B) since the PTE is less than 1,000 lbs/year. The Casino will keep records onsite to demonstrate that emissions are below these thresholds. These records will include hours of operation for each generator and total fuel usage.

## Criteria Pollutant Emissions Estimates

The criteria pollutant emissions estimates (allowable and PTE) along with the source of the emission factors are presented in Attachment 1. Greenhouse gas emission estimates are also

---

<sup>1</sup> Potential to emit of any HAP from any single emission unit shall not exceed 1,000 lb per year or the de minimis level established under section 112(g) of the Act, whichever is less.


provided in Attachment 1. The emission factors used for the engines and other fuel burning equipment are included. The engine specification data sheets for the two new Caterpillar engines are presented in Attachment 2.

## Operating and Firing Rates

The proposed operating and firing rates are provided in Attachment 1.

## Process Flow Diagrams

The Process Flow Diagrams for the facility's fuel burning equipment is as follows:



The five generators use ultra low sulfur diesel fuel only (sulfur content 0.0015% or less). The three older generators have their own 500 gallon storage fuel tank. The three older generators were installed prior to June 12, 2006. Thus, the three older generators operate under the EPA RICE NESHAP (40 CFR 63 Subpart ZZZZ). The engines associated with the two newest generators are Tier 2 emergency certified with a manufacture year of 2014; thus, they operate under the EPA New Source Performance Standards (40 CFR 60 Subpart IIII) as emergency engines. The boilers use natural gas only.

## Forms

Since the two newest generators will be used for emergency only, a Registration for Existing Sources (Form REG) is included in Attachment 3.

## **Attachment 1**

### **Facility Emissions: Proposed Allowable, Potential, and GHG; Operating and Firing Rates**

---

Facility Emissions Analysis - Allowable

Sandia Resort and Casino  
20 Rainbow Road NE  
Albuquerque, NM 87113-2154

Source	Model	Size (hp)	Size (MW)	Fuel	Fuel Use (GJ/h or scfm)	Heat Input (GJ/h or scfm)	Emissions (t/hr)	CO	SO2	PM2.5	PM10	VOC	Pb	Proposed Alternative Emissions (tpy)	CO	SO2	PM	H2SO4	Pb	Fluorides	Hg	TRS	
Generator #1	DOD (194,000)	2035	219.0 Diesel	17.06	44.65	2.50	2.50	5.60	0.03	2.50	2.50	0.00	0.00	13.75	4.81E-03	0.65	0.65	0.57	0	0	0	0	
Generator #2	DOD (194,000)	2035	219.0 Diesel	17.06	44.65	2.50	2.50	5.60	0.03	2.50	2.50	0.00	0.00	13.75	4.81E-03	0.65	0.65	0.57	0	0	0	0	
Generator #3	DOD (194,000)	2035	219.0 Diesel	17.06	44.65	2.50	2.50	5.60	0.03	2.50	2.50	0.00	0.00	13.75	4.81E-03	0.65	0.65	0.57	0	0	0	0	
Generator #4	DOD (194,000)	2035	219.0 Diesel	17.06	44.65	2.50	2.50	5.60	0.03	2.50	2.50	0.00	0.00	13.75	4.81E-03	0.65	0.65	0.57	0	0	0	0	
Generator #5	DOD (194,000)	2035	219.0 Diesel	17.06	44.65	2.50	2.50	5.60	0.03	2.50	2.50	0.00	0.00	13.75	4.81E-03	0.65	0.65	0.57	0	0	0	0	
Generator #6	DOD (194,000)	2035	219.0 Diesel	17.06	44.65	2.50	2.50	5.60	0.03	2.50	2.50	0.00	0.00	13.75	4.81E-03	0.65	0.65	0.57	0	0	0	0	
Generator #7	DOD (194,000)	2035	219.0 Diesel	17.06	44.65	2.50	2.50	5.60	0.03	2.50	2.50	0.00	0.00	13.75	4.81E-03	0.65	0.65	0.57	0	0	0	0	
Generator #8	DOD (194,000)	2035	219.0 Diesel	17.06	44.65	2.50	2.50	5.60	0.03	2.50	2.50	0.00	0.00	13.75	4.81E-03	0.65	0.65	0.57	0	0	0	0	
Generator #9	DOD (194,000)	2035	219.0 Diesel	17.06	44.65	2.50	2.50	5.60	0.03	2.50	2.50	0.00	0.00	13.75	4.81E-03	0.65	0.65	0.57	0	0	0	0	
Generator #10	DOD (194,000)	2035	219.0 Diesel	17.06	44.65	2.50	2.50	5.60	0.03	2.50	2.50	0.00	0.00	13.75	4.81E-03	0.65	0.65	0.57	0	0	0	0	
Generator #11	DOD (194,000)	2035	219.0 Diesel	17.06	44.65	2.50	2.50	5.60	0.03	2.50	2.50	0.00	0.00	13.75	4.81E-03	0.65	0.65	0.57	0	0	0	0	
Generator #12	DOD (194,000)	2035	219.0 Diesel	17.06	44.65	2.50	2.50	5.60	0.03	2.50	2.50	0.00	0.00	13.75	4.81E-03	0.65	0.65	0.57	0	0	0	0	
Generator #13	DOD (194,000)	2035	219.0 Diesel	17.06	44.65	2.50	2.50	5.60	0.03	2.50	2.50	0.00	0.00	13.75	4.81E-03	0.65	0.65	0.57	0	0	0	0	
Generator #14	DOD (194,000)	2035	219.0 Diesel	17.06	44.65	2.50	2.50	5.60	0.03	2.50	2.50	0.00	0.00	13.75	4.81E-03	0.65	0.65	0.57	0	0	0	0	
Generator #15	DOD (194,000)	2035	219.0 Diesel	17.06	44.65	2.50	2.50	5.60	0.03	2.50	2.50	0.00	0.00	13.75	4.81E-03	0.65	0.65	0.57	0	0	0	0	
Boiler #1		54545	40000 Diesel	271.0	0.06	0.60	0.60	0.60	0.00	0.78	0.78	0.00	0.00	2.00	1.4E-02	0.50	0.50	0.17	0.17	0.00	0	0	
Boiler #2		2029.4	31.0 Diesel	31.0	0.06	0.17	0.17	0.17	0.00	1.2E-02	1.5E-02	1.01E-04	0.00	0.50	2.00	1.4E-02	0.17	0.17	0.07	0.07	0.00	0	0
Boiler #3		2029.4	31.0 Diesel	31.0	0.06	0.17	0.17	0.17	0.00	1.2E-02	1.5E-02	1.01E-04	0.00	0.50	2.00	1.4E-02	0.17	0.17	0.07	0.07	0.00	0	0
Boiler #4		2029.4	31.0 Diesel	31.0	0.06	0.17	0.17	0.17	0.00	1.2E-02	1.5E-02	1.01E-04	0.00	0.50	2.00	1.4E-02	0.17	0.17	0.07	0.07	0.00	0	0
Boiler #5		2029.4	31.0 Diesel	31.0	0.06	0.17	0.17	0.17	0.00	1.2E-02	1.5E-02	1.01E-04	0.00	0.50	2.00	1.4E-02	0.17	0.17	0.07	0.07	0.00	0	0
Boiler #6		2029.4	31.0 Diesel	31.0	0.06	0.17	0.17	0.17	0.00	1.2E-02	1.5E-02	1.01E-04	0.00	0.50	2.00	1.4E-02	0.17	0.17	0.07	0.07	0.00	0	0
Boiler #7		2029.4	31.0 Diesel	31.0	0.06	0.17	0.17	0.17	0.00	1.2E-02	1.5E-02	1.01E-04	0.00	0.50	2.00	1.4E-02	0.17	0.17	0.07	0.07	0.00	0	0
Boiler #8		2029.4	31.0 Diesel	31.0	0.06	0.17	0.17	0.17	0.00	1.2E-02	1.5E-02	1.01E-04	0.00	0.50	2.00	1.4E-02	0.17	0.17	0.07	0.07	0.00	0	0
Boiler #9		2029.4	31.0 Diesel	31.0	0.06	0.17	0.17	0.17	0.00	1.2E-02	1.5E-02	1.01E-04	0.00	0.50	2.00	1.4E-02	0.17	0.17	0.07	0.07	0.00	0	0
Boiler #10		2029.4	31.0 Diesel	31.0	0.06	0.17	0.17	0.17	0.00	1.2E-02	1.5E-02	1.01E-04	0.00	0.50	2.00	1.4E-02	0.17	0.17	0.07	0.07	0.00	0	0
Boiler #11		2029.4	31.0 Diesel	31.0	0.06	0.17	0.17	0.17	0.00	1.2E-02	1.5E-02	1.01E-04	0.00	0.50	2.00	1.4E-02	0.17	0.17	0.07	0.07	0.00	0	0
Boiler #12		2029.4	31.0 Diesel	31.0	0.06	0.17	0.17	0.17	0.00	1.2E-02	1.5E-02	1.01E-04	0.00	0.50	2.00	1.4E-02	0.17	0.17	0.07	0.07	0.00	0	0
Boiler #13		2029.4	31.0 Diesel	31.0	0.06	0.17	0.17	0.17	0.00	1.2E-02	1.5E-02	1.01E-04	0.00	0.50	2.00	1.4E-02	0.17	0.17	0.07	0.07	0.00	0	0
Boiler #14		2029.4	31.0 Diesel	31.0	0.06	0.17	0.17	0.17	0.00	1.2E-02	1.5E-02	1.01E-04	0.00	0.50	2.00	1.4E-02	0.17	0.17	0.07	0.07	0.00	0	0
Boiler #15		2029.4	31.0 Diesel	31.0	0.06	0.17	0.17	0.17	0.00	1.2E-02	1.5E-02	1.01E-04	0.00	0.50	2.00	1.4E-02	0.17	0.17	0.07	0.07	0.00	0	0
Boiler #16		2029.4	31.0 Diesel	31.0	0.06	0.17	0.17	0.17	0.00	1.2E-02	1.5E-02	1.01E-04	0.00	0.50	2.00	1.4E-02	0.17	0.17	0.07	0.07	0.00	0	0
Boiler #17		2029.4	31.0 Diesel	31.0	0.06	0.17	0.17	0.17	0.00	1.2E-02	1.5E-02	1.01E-04	0.00	0.50	2.00	1.4E-02	0.17	0.17	0.07	0.07	0.00	0	0
TOTAL																							

Notes:  
Fuel Use for Generators #1 and #2 (4 land 8 gas engines) & city wheel.  
Engine rating conservatively assumes 100% load.

Fuel Use for Generator #3 estimated as 0.007 kW. Estimated Fuel Input = gal/hr \* 135,000 Btu/gal

Emissions factors:

Emergency Generators

Generator #1-2  
Source: Municipal  
District Diesel 10/31/2000  
g/hr-Nr

NOx 6.9  
VOC 0.7  
CO 6.5  
PM2.5 0.4  
PM10 0.4  
SOx 0.0

Use AP-42

SOx 0  
Pb 0  
H2SO4 0  
Hg 0  
TSS 0

Burner #3

Source: EPA AP-42 Fifth Edition, October, 1990  
Dust > 600  $\mu$ m  
Btu-hr  
65.52  
0.78  
0.88  
0.09

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007

0.0007



Facility Emissions: Analysis - Greenhouse Gas Emissions

**Sandia Resort and Casino**  
**30 Rainbow Road NE**  
**Albuquerque, NM 87113-2156**

Source	Vake	Model	Size (kW)	Fuel	Fuel Use (gph or scfh)	Heat Input (mmBtu/hr)	Hours CO2	CH4	N2O	HFCs (metric tons)	PFCs	SF6	CO2e
Generator #1	Detroit Diesel	DDC 16V-4000	2935	2190 Diesel	133.2	17.98	500	679.75	0.03	0.01	0.00	0.00	682.04
Generator #2	Detroit Diesel	DDC 16V-4000	2935	2190 Diesel	133.2	17.98	500	679.75	0.03	0.01	0.00	0.00	682.04
Generator #3	Detroit Diesel	MTV 1000	1250	1676 Diesel	134.1	18.10	500	684.24	0.03	0.01	0.00	0.00	686.55
Generator #4 (NEW)	Caterpillar	C175-20	5646	4000 Diesel	274.6	37.07	500	1401.35	0.06	0.01	0.00	0.00	1406.07
Generator #5 (NEW)	Caterpillar	C175-20	5646	4000 Diesel	274.6	37.07	500	1401.35	0.06	0.01	0.00	0.00	1406.07
Boiler #1	Boiler #2			Natural Gas	2029.4	2.07	8760	968.96	0.02	0.00	0.00	0.00	969.91
	Boiler #3			Natural Gas	2029.4	2.07	8760	968.96	0.02	0.00	0.00	0.00	969.91
	Boiler #4			Natural Gas	2029.4	2.07	8760	968.96	0.02	0.00	0.00	0.00	969.91
	Boiler #5			Natural Gas	2029.4	2.07	8760	968.96	0.02	0.00	0.00	0.00	969.91
	Boiler #6			Natural Gas	2029.4	2.07	8760	968.96	0.02	0.00	0.00	0.00	969.91
	Boiler #7			Natural Gas	2029.4	2.07	8760	968.96	0.02	0.00	0.00	0.00	969.91
	Boiler #8			Natural Gas	2029.4	2.07	8760	968.96	0.02	0.00	0.00	0.00	969.91
	Boiler #9			Natural Gas	2029.4	2.07	8760	968.96	0.02	0.00	0.00	0.00	969.91
	Boiler #10			Natural Gas	2029.4	2.07	8760	968.96	0.02	0.00	0.00	0.00	969.91
	Boiler #11			Natural Gas	2029.4	2.07	8760	968.96	0.02	0.00	0.00	0.00	969.91
	Boiler #12			Natural Gas	2029.4	2.07	8760	968.96	0.02	0.00	0.00	0.00	969.91
	Boiler #13			Natural Gas	2029.4	2.07	8760	968.96	0.02	0.00	0.00	0.00	969.91
	Boiler #14			Natural Gas	970.6	0.99	8760	463.42	0.01	0.00	0.00	0.00	463.87
	Boiler #15			Natural Gas	970.6	0.99	8760	463.42	0.01	0.00	0.00	0.00	463.87
	Boiler #16			Natural Gas	970.6	0.99	8760	463.42	0.01	0.00	0.00	0.00	463.87
	Boiler #17			Natural Gas	970.6	0.99	8760	463.42	0.01	0.00	0.00	0.00	463.87
TOTAL										0.47	0.00	0.00	19327.12

### Operating and Firing Rates

**Sandia Resort and Casino**  
**30 Rainbow Road NE**  
**Albuquerque, NM 87113-2156**

Source	Make	Model	Size (kW)	Size (bhp)	Type	Fuel %S	Fuel Use (gph or scf)	Heat Input (mmBtu/hr)	Proposed Operating Schedule Daily (Hrs)	Operating Rates (Hours) Daily	Annual	Hourly	Max Firing Rates (gals or scf) Daily	Annual
Generator #1	Detroit Diesel	DDC 16V-4000	2935	2190 Diesel	0.0015	133.2	17.98	24	168	52	3,196.8	3,196.8	66,600.0	66,600.0
Generator #2	Detroit Diesel	DDC 16V-4000	2935	2190 Diesel	0.0015	133.2	17.98	24	168	52	3,196.8	3,196.8	66,600.0	66,600.0
Generator #3	Detroit Diesel	MTV 1000	1676	1250 Diesel	0.0015	100.0	13.50	24	168	52	100.0	2,400.6	50,118.6	50,118.6
Generator #4 (NEW)	Caterpillar	C175-20	5646	4000 Diesel	0.0015	274.6	37.07	24	168	52	1	24	500	137,300.0
Generator #5 (NEW)	Caterpillar	C175-20	5646	4000 Diesel	0.0015	274.6	37.07	24	168	52	1	24	500	137,300.0
Boiler #1		Natural Gas	2029.4	2.1		2.1	24	168	52	1	24	8760	2,029.4	48,705.9
Boiler #2		Natural Gas	2029.4	2.1		2.1	24	168	52	1	24	8760	2,029.4	48,705.9
Boiler #3		Natural Gas	2029.4	2.1		2.1	24	168	52	1	24	8760	2,029.4	48,705.9
Boiler #4		Natural Gas	2029.4	2.1		2.1	24	168	52	1	24	8760	2,029.4	48,705.9
Boiler #5		Natural Gas	2029.4	2.1		2.1	24	168	52	1	24	8760	2,029.4	48,705.9
Boiler #6		Natural Gas	2029.4	2.1		2.1	24	168	52	1	24	8760	2,029.4	48,705.9
Boiler #7		Natural Gas	2029.4	2.1		2.1	24	168	52	1	24	8760	2,029.4	48,705.9
Boiler #8		Natural Gas	2029.4	2.1		2.1	24	168	52	1	24	8760	2,029.4	48,705.9
Boiler #9		Natural Gas	2029.4	2.1		2.1	24	168	52	1	24	8760	2,029.4	48,705.9
Boiler #10		Natural Gas	2029.4	2.1		2.1	24	168	52	1	24	8760	2,029.4	48,705.9
Boiler #11		Natural Gas	2029.4	2.1		2.1	24	168	52	1	24	8760	2,029.4	48,705.9
Boiler #12		Natural Gas	2029.4	2.1		2.1	24	168	52	1	24	8760	2,029.4	48,705.9
Boiler #13		Natural Gas	2029.4	2.1		2.1	24	168	52	1	24	8760	2,029.4	48,705.9
Boiler #14		Natural Gas	970.6	1.0		1.0	24	168	52	1	24	8760	970.6	23,294.1
Boiler #15		Natural Gas	970.6	1.0		1.0	24	168	52	1	24	8760	970.6	23,294.1
Boiler #16		Natural Gas	970.6	1.0		1.0	24	168	52	1	24	8760	970.6	23,294.1
Boiler #17		Natural Gas	970.6	1.0		1.0	24	168	52	1	24	8760	970.6	23,294.1
Total Diesel (gals)													457,811.8	
Total Natural Gas (scf)													265,118,823.5	

**Attachment 2**

**Equipment Specification Sheets**

## DIESEL GENERATOR SET




Image shown may not reflect actual package

### STANDBY 4000 ekW 5000 kVA 60 Hz 1800 rpm 12470 Volts

Caterpillar is leading the power generation market place with Power Solutions engineered to deliver unmatched flexibility, expandability, reliability, and cost-effectiveness.

#### FUEL/EMISSIONS STRATEGY

- EPA Certified for Stationary Emergency Applications (EPA Tier 2 emissions level)

#### DESIGN CRITERIA

- The generator set accepts 100% rated load in one step per NFPA 110 and meets ISO 8528-5 transient response.

#### FULL RANGE OF ATTACHMENTS

- Wide range of bolt-on system expansion attachments, factory designed and tested
- Flexible packaging options for easy and cost effective installation

#### SINGLE-SOURCE SUPPLIER

- Fully prototype tested with certified torsional vibration analysis available

#### WORLDWIDE PRODUCT SUPPORT

- Cat® dealers provide extensive post sale support including maintenance and repair agreements
- Cat dealers have over 1600 dealer branch stores operating in 200 countries.
- The Cat® S•O•S™ program effectively detects internal engine component condition, even the presence of unwanted fluids and combustion by products.

#### CAT C175-20 DIESEL ENGINE

- Reliable, rugged, durable design
- Four-stroke diesel engine combines consistent performance and excellent fuel economy with minimum weight

#### CAT SR5 GENERATOR

- Designed to match performance and output characteristics of Cat diesel engines
- Single point access to accessory connections

#### CAT EMCP 4 CONTROL PANELS

- Simple user friendly interface and navigation
- Scalable system to meet a wide range of customer needs
- Integrated Control System and Communications Gateway

## **FACTORY INSTALLED STANDARD & OPTIONAL EQUIPMENT**

<b>System</b>	<b>Standard</b>	<b>Optional</b>
Air Inlet	<ul style="list-style-type: none"> <li>• Air cleaner, 4 x single element canister with service indicator(s)</li> <li>• <u>Plug group</u> for air inlet shut-off</li> </ul>	<input type="checkbox"/> Air cleaner, 4 x dual element with service indicator(s) <input type="checkbox"/> <u>Air inlet adapters</u>
Cooling	<ul style="list-style-type: none"> <li>• SCAC cooling</li> <li>• Jacket water and AC inlet/outlet flanges</li> </ul>	<input type="checkbox"/> Remote horizontal SCAC radiator <input type="checkbox"/> Remote fuel cooler <input type="checkbox"/> Low coolant level sensor (for remote radiators)
Exhaust	<ul style="list-style-type: none"> <li>• Dry exhaust manifold</li> <li>• Bolted flange (ANSI 8" &amp; DIN 200) with bellow for each turbo (qty 4)</li> </ul>	<input type="checkbox"/> Engine Exhaust Temperature Module <input type="checkbox"/> Mufflers (15 dBA, 25 dBA, or 40 dBA) <input type="checkbox"/> Dual 20" or single 24" vertical exhaust collector <input type="checkbox"/> Weld flanges: ANSI 20" and ANSI 24"
Crankcase Systems	<ul style="list-style-type: none"> <li>• Open crankcase ventilation</li> </ul>	<input type="checkbox"/> Crankcase explosion relief valve
Fuel	<ul style="list-style-type: none"> <li>• Primary fuel filter with water separator</li> <li>• Secondary fuel filters (engine mounted)</li> </ul>	
Generator SR5	<ul style="list-style-type: none"> <li>• 3 phase brushless, salient pole</li> <li>• Space heater kit</li> <li>• IEC platinum stator RTD's</li> <li>• Cat digital voltage regulator (CDVR)</li> </ul>	<input type="checkbox"/> Oversize generators <input type="checkbox"/> Power connection arrangement
Governor	<ul style="list-style-type: none"> <li>• ADEM™ A4</li> </ul>	<input type="checkbox"/> Redundant shutdown
Control Panels	<ul style="list-style-type: none"> <li>• EMCP 4.2 Genset Controller</li> </ul>	<input type="checkbox"/> Local & remote annunciator modules <input type="checkbox"/> Discrete I/O module <input type="checkbox"/> Generator temperature monitoring & protection <input type="checkbox"/> Remote monitoring <input type="checkbox"/> Load share module
Lube	<ul style="list-style-type: none"> <li>• Lubricating oil</li> <li>• Oil filter, filler and dipstick</li> <li>• Oil drain line with valves</li> <li>• Fumes disposal</li> <li>• Gear type lube oil pump</li> <li>• Integral lube oil cooler</li> <li>• Electric prelube pumps</li> </ul>	
Mounting	<ul style="list-style-type: none"> <li>• Rails-engine / generator</li> <li>• Rubber anti-vibration mounts (shipped loose)</li> </ul>	<input type="checkbox"/> Spring type linear vibration isolators <input type="checkbox"/> IBC vibration isolators
Starting / Charging	<ul style="list-style-type: none"> <li>• Dual 24 volt electric starting motors</li> <li>• Batteries with rack and cables</li> <li>• Battery disconnect switch</li> </ul>	<input type="checkbox"/> Oversized battery set <input type="checkbox"/> 75 amp charging alternator <input type="checkbox"/> Battery chargers (20,35 or 50 Amp) <input type="checkbox"/> Jacket water heater <input type="checkbox"/> Redundant Electric Starter
General	<ul style="list-style-type: none"> <li>• RH service (Except LH Service Oil Filter)</li> <li>• Paint - Caterpillar Yellow with high gloss black rails</li> <li>• SAE standard rotation</li> <li>• Flywheel and flywheel housing - SAE No. 00</li> </ul>	<input type="checkbox"/> Barring group- manual or air powered <input type="checkbox"/> Factory test reports

## SPECIFICATIONS

### CAT GENERATOR

Frame .....	3055
Excitation .....	PM
Pitch.....	0.6667
Number of poles.....	4
Number of bearings .....	2
Number of Leads.....	6
Insulation .....	Class F
IP rating .....	Drip proof IP23
Over speed capability - % of rated.....	125%
Wave form deviation.....	3 %
Voltage regulator.....	3 phase sensing with selectable V/Hz regulation
Telephone Influence Factor .....	Less than 50
Harmonic Distortion .....	Less than 5%

### CAT DIESEL ENGINE

C175-20 SCAC, V-20, 4 stroke, water-cooled diesel	
Bore .....	175.00 mm (6.89 in)
Stroke .....	220.00 mm (8.66in)
Displacement .....	105.8 L (6456.31 in <sup>3</sup> )
Compression ratio.....	15.3:1
Aspiration.....	TA
Fuel system.....	Common Rail
Governor Type.....	ADEM™ A4

### CAT EMCP 4 CONTROL PANELS

EMCP 4 controls including:

- Run / Auto / Stop Control
  - Speed Adjust
  - Voltage Adjust
  - Engine Cycle Crank
  - Emergency stop pushbutton
- EMCP 4.2 controller features:
- 24-volt DC operation
  - Environmental sealed front face
  - Text alarm/event descriptions
  - True RMS AC metering, 3-phase, ±1% accuracy.

Digital indication for:

- RPM
- DC volts
- Operating hours
- Oil pressure (psi, kPa or bar)
- Coolant temperature
- Volts (L-L & L-N), frequency (Hz)
- Amps (per phase & average)
- Power Factor (per phase & average)
- kW (per phase, average & percent)
- kVA (per phase, average & percent)
- kVAr (per phase, average & percent)
- kW-hr (total)
- kVAr-hr (total)

Warning/shutdown with common LED indication of shutdowns for:

- Low oil pressure
- High coolant temperature
- Overspeed
- Emergency stop
- Failure to start (overcrank)
- Low coolant temperature
- Low coolant level

Programmable protective relaying functions:

- Generator phase sequence
- Over/Under voltage (27/59)
- Over/Under Frequency (81 o/u)
- Reverse Power (kW) (32)
- Reverse Reactive Power (kVAr) (32RV)
- Overcurrent (50/51)

Communications

- Customer data link (Modbus RTU)
- Accessory module data link
- Serial annunciator module data link
- 6 programmable digital inputs
- 6 programmable relay outputs (Form A)
- 2 programmable relay outputs (Form C)
- 2 programmable digital outputs

**STANDBY 4000 ekW 5000 kVA**  
60 Hz 1800 rpm 12470 Volts



**Technical Data**

<b>Open Generator Set - 1800 rpm/60 Hz/12 470 Volts</b>		<b>DM8854</b>
<b>Stationary Emergency (EPA Tier 2)</b>		
<b>Generator Set Package Performance</b>		
Genset Power rating @ 0.8 pf	5000 kVA	
Genset Power Rating without fan	4000 ekW	
<b>Fuel Consumption</b>		
100% Load with fan	1039.3 L/hr	274.6 Gal/hr
75% Load with fan	770.6 L/hr	203.6 Gal/hr
50% Load with fan	615.0 L/hr	162.5 Gal/hr
<b>Inlet Air</b>		
Combustion air inlet flow rate	339.1 m <sup>3</sup> /min	11975 cfm
<b>Exhaust System</b>		
Exhaust stack gas temperature (engine out)	473.9 °C	885 °F
Exhaust gas flow rate	871.4 m <sup>3</sup> /min	30771 cfm
Exhaust system backpressure (maximum allowable)	6.7 kPa	26.9 in water
<b>Heat Rejection</b>		
Heat rejection to coolant (total)	2148 kW	122133 Btu/min
Heat rejection to exhaust (total)	3928 kW	223338 Btu/min
Heat rejection to aftercooler	447 kW	25437 Btu/min
Heat rejection to atmosphere from engine	304 kW	17303 Btu/min
Heat rejection to atmosphere from generator	197 kW	11213 Btu/min
<b>Alternator</b>		
Motor starting capability @30% voltage dip	10728 skVA	
Frame	3055	
Temperature Rise	130 °C	234 °F
<b>Lube System</b>		
Sump refill with filter	675 L	178.3 gal
<b>Emissions (Nominal)<sup>2</sup></b>		
NOx g/hp-hr	5.07 g/hp-hr	
CO g/hp-hr	0.52 g/hp-hr	
HC g/hp-hr	0.17 g/hp-hr	
PM g/hp-hr	0.04 g/hp-hr	

Note: This generator set is not offered with an engine driven radiator. Addition of an engine driven fan will reduce the output below the nameplate rating.

<sup>1</sup> Some packages may have oversized generators with a different temperature rise and motor starting characteristics. Generator temperature rise is based on a 40 degree C ambient per NEMA MG1-32.

<sup>2</sup> Emissions data measurement procedures are consistent with those described in EPA CFR 40 Part 89, Subpart D & E and ISO8178-1 for measuring HC, CO, PM, NOx.

Data shown is based on steady state operating conditions of 77°F, 28.42 in HG and number 2 diesel fuel with 35° API and LHV of 18,360 btu/lb. The nominal emissions data shown is subject to instrumentation, measurement, facility and engine to engine variations. Emissions data is based on 100% load and thus cannot be used to compare to EPA regulations which use values based on a weighted cycle. Emissions values are tailpipe out with aftertreatment installed. Values shown as zero may be greater than zero but were below the detection level of the equipment used at the time of measurement.

## **RATING DEFINITIONS AND CONDITIONS**

**Meets or Exceeds International Specifications:**  
AS1359, CSA, IEC60034-1, ISO3046, ISO8528, NEMA  
MG 1-22, NEMA MG 1-33, UL508A, 72/23/EEC,  
98/37/EC, 2004/108/EC

**Standby** - Output available with varying load for the duration of the interruption of the normal source power. Average power output is 70% of the standby power rating. Typical operation is 200 hours per year, with maximum expected usage of 500 hours per year. Standby power in accordance with ISO8528. Fuel stop power in accordance with ISO3046. Standby ambient shown indicate ambient temperature at 100% load which results in a coolant top tank temperature just below the shutdown temperature.

Ratings are based on SAE J1349 standard conditions. These ratings also apply at ISO3046 standard conditions

**Fuel Rates** are based on fuel oil of 35° API [16° C (60° F)] gravity having an LHV of 42 780 kJ/kg (18,390 Btu/lb) when used at 29° C (85° F) and weighing 838.9 g/liter (7.001 lbs/U.S. gal.). Additional ratings may be available for specific customer requirements, contact your Caterpillar representative for details. For information regarding Low Sulfur fuel and Biodiesel capability, please consult your Cat dealer.

**STANDBY 4000 ekW 5000 kVA**  
60 Hz 1800 rpm 12470 Volts



**DIMENSIONS**

Package Dimensions		
Length	6719 mm	267.5 in
Width	2377 mm	93.6 in
Height	2556 mm	100.6 in

NOTE: For reference only - do not use for installation design. Please contact your local dealer for exact weight and dimensions.

[www.Cat-ElectricPower.com](http://www.Cat-ElectricPower.com)

©2012 Caterpillar  
All rights reserved.

Sourced: U.S. Sourced

EPD00066-C (03/2012)

Materials and specifications are subject to change without notice. The International System of Units (SI) is used in this publication.

CAT, CATERPILLAR, their respective logos, "Caterpillar Yellow," the "Power Edge" trade dress as well as corporate and product identity used herein, are trademarks of Caterpillar and may not be used without permission.

# PERFORMANCE DATA[DM8854]

January 27, 2014

Performance Number: DM8854

Change Level: 01

SALES MODEL:	C175-20
ENGINE POWER (BHP):	5,647
GEN POWER W/O FAN (EKW):	4,000.0
COMPRESSION RATIO:	15.3
APPLICATION:	GENERATOR SET
RATING LEVEL:	STANDBY
SUB APPLICATION:	STANDARD
PUMP QUANTITY:	2
FUEL TYPE:	DIESEL
MANIFOLD TYPE:	DRY
GOVERNOR TYPE:	ADEM4
ELECTRONICS TYPE:	ADEM4
CAMSHAFT TYPE:	STANDARD
IGNITION TYPE:	CI
INJECTOR TYPE:	CR
FUEL INJECTOR:	3492522
REF EXH STACK DIAMETER (IN):	14

COMBUSTION:	DI
ENGINE SPEED (RPM):	1,800
HERTZ:	60
ASPIRATION:	TA
AFTERCOOLER TYPE:	SCAC
AFTERCOOLER CIRCUIT TYPE:	JW+OC+1AC, 2AC
AFTERCOOLER TEMP (F):	115
JACKET WATER TEMP (F):	210.2
TURBO CONFIGURATION:	PARALLEL
TURBO QUANTITY:	4
TURBOCHARGER MODEL:	GTB6772BLN-4BT-1.56
CERTIFICATION YEAR:	2012
CRANKCASE BLOWBY RATE (FT3/HR):	2,683.6
FUEL RATE (RATED RPM) NO LOAD (GAL/HR):	17.7
PISTON SPD @ RATED ENG SPD (FT/MIN):	2,598.4

## General Performance Data

GENSET POWER WITHOUT FAN	PERCENT LOAD	ENGINE POWER	BRAKE MEAN EFF PRES (BMEP)	BRAKE SPEC FUEL CONSUMPTN (BSFC)	VOL FUEL CONSUMPTN (VFC)	INLET MFLD PRES	INLET MFLD TEMP	EXH MFLD TEMP	EXH MFLD PRES	ENGINE OUTLET TEMP
EKW	%	BHP	PSI	LB/BHP-HR	GAL/HR	IN-HG	DEG F	DEG F	IN-HG	DEG F
4,000.0	100	5,646	385	0.340	274.8	91.5	121.4	1,223.6	63.8	885.0
3,600.0	90	5,110	348	0.333	243.0	79.2	122.1	1,172.3	53.8	884.4
3,200.0	80	4,559	311	0.331	215.6	69.6	122.7	1,132.9	45.9	849.4
3,000.0	75	4,280	292	0.333	203.6	65.8	122.9	1,117.9	42.9	844.1
2,800.0	70	3,995	272	0.341	194.4	64.0	123.1	1,110.4	41.3	842.1
2,400.0	60	3,424	233	0.365	178.6	61.7	123.2	1,102.4	39.4	841.5
2,000.0	50	2,853	194	0.399	162.5	58.5	123.3	1,095.1	37.3	842.0
1,600.0	40	2,283	156	0.426	139.0	47.2	123.3	1,071.5	30.2	836.8
1,200.0	30	1,712	117	0.456	111.5	34.8	123.3	1,039.1	22.9	829.0
1,000.0	25	1,427	97	0.473	96.3	28.2	123.3	1,019.7	19.2	824.1
800.0	20	1,141	78	0.493	80.3	21.7	123.4	940.7	15.6	758.5
400.0	10	571	39	0.580	45.7	8.4	123.6	716.1	8.2	562.7

GENSET POWER WITHOUT FAN	PERCENT LOAD	ENGINE POWER	COMPRESSOR OUTLET PRES	COMPRESSOR OUTLET TEMP	WET INLET AIR VOL FLOW RATE	ENGINE OUTLET WET EXH GAS VOL FLOW RATE	WET INLET AIR MASS FLOW RATE	WET EXH GAS MASS FLOW RATE	WET EXH VOL FLOW RATE (32 DEG F AND 28.98 IN HG)	DRY EXH VOL FLOW RATE (32 DEG F AND 29.98 IN HG)
EKW	%	BHP	IN-HG	DEG F	CFM	CFM	LB/HR	LB/HR	FT3/MIN	FT3/MIN
4,000.0	100	5,646	95	447.1	11,975.3	30,771.1	52,034.6	53,956.7	11,251.4	10,278.3
3,600.0	90	5,110	82	405.5	10,853.2	27,287.2	46,799.9	48,502.0	10,132.7	9,286.2
3,200.0	80	4,559	72	372.6	9,961.1	24,548.2	42,658.8	44,169.6	9,220.3	8,447.0
3,000.0	75	4,280	69	359.6	9,608.2	23,480.4	41,031.6	42,458.6	8,854.9	8,122.0
2,800.0	70	3,995	66	353.5	9,439.0	22,951.2	40,249.6	41,612.8	8,688.7	7,964.3
2,400.0	60	3,424	63	345.1	9,203.6	22,274.4	39,199.7	40,452.1	8,417.1	7,761.2
2,000.0	50	2,853	60	333.0	8,868.0	21,447.8	37,760.4	38,900.1	8,101.3	7,497.2
1,600.0	40	2,283	48	297.9	7,784.8	19,064.6	32,954.5	33,935.5	7,229.8	6,697.6
1,200.0	30	1,712	36	251.2	6,554.1	15,890.0	27,612.6	28,398.1	6,062.6	5,629.5
1,000.0	25	1,427	29	223.6	5,887.1	14,011.6	24,757.3	25,431.4	5,386.4	4,994.3
800.0	20	1,141	23	194.3	5,224.4	11,999.1	21,926.5	22,488.6	4,843.0	4,524.3
400.0	10	571	9	128.4	3,836.2	7,454.5	16,050.1	16,369.9	3,585.0	3,383.5

## Heat Rejection Data

PUMP POWER IS INCLUDED IN HEAT REJECTION BALANCE, BUT IS NOT SHOWN.

GENSET POWER WITHOUT FAN	PERCENT LOAD	ENGINE POWER	REJECTION TO JACKET WATER	REJECTION TO ATMOSPHERE	REJECTION TO EXH	EXHAUST RECOVERY TO 350F	FROM OIL COOLER	FROM 2ND STAGE AFTERCOOLER	WORK ENERGY	LOW HEAT VALUE ENERGY	HIGH HEAT VALUE ENERGY
EKW	%	BHP	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN
4,000.0	100	5,646	122,108	11,729	223,338	122,328	31,385	25,448	239,449	589,255	627,705
3,600.0	90	5,110	105,801	11,183	195,882	105,524	27,777	20,837	218,690	521,512	555,541
3,200.0	80	4,559	92,287	10,730	174,043	93,097	24,642	17,271	193,350	462,656	492,845
3,000.0	75	4,280	86,927	10,567	165,401	88,452	23,269	15,911	181,497	436,882	465,389
2,800.0	70	3,995	83,874	10,484	160,691	86,245	22,225	15,198	169,397	417,263	444,490
2,400.0	60	3,424	79,011	10,399	154,285	83,569	20,415	14,398	145,197	383,286	408,296
2,000.0	50	2,853	74,364	10,337	147,176	80,308	18,579	13,719	120,998	348,811	371,571
1,600.0	40	2,283	63,610	10,183	130,230	69,204	15,886	11,387	96,798	298,267	317,729
1,200.0	30	1,712	51,695	9,864	108,727	56,882	12,746	8,755	72,599	239,296	254,910
1,000.0	25	1,427	45,332	9,667	92,548	50,376	11,010	7,459	60,499	206,708	220,198
800.0	20	1,141	38,998	9,193	76,271	38,117	9,183	6,338	48,399	172,408	183,658
400.0	10	571	25,829	7,893	38,363	14,179	5,219	4,238	24,199	97,980	104,373

# PERFORMANCE DATA[DM8854]

January 27, 2014

## Sound Data

### EXHAUST: Sound Power (1/3 Octave Frequencies)

GENSET POWER WITHOUT FAN	PERCENT LOAD	ENGINE POWER	OVERALL SOUND	100 HZ	125 HZ	160 HZ	200 HZ	250 HZ	316 HZ	400 HZ	600 HZ	630 HZ	800 HZ
EKW	%	BHP	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)
4,000.0	100	5,646	130.3	98.3	103.0	109.5	113.8	113.3	112.2	115.0	114.7	117.0	117.2
3,600.0	90	5,110	129.0	98.3	102.1	113.5	112.6	112.7	111.7	114.2	113.8	116.1	116.0
3,200.0	80	4,559	128.0	93.5	100.1	116.3	112.5	110.7	112.9	114.5	112.7	115.8	115.2
3,000.0	75	4,280	127.3	91.9	99.3	118.4	113.6	108.9	112.1	114.0	112.4	115.5	115.2
2,800.0	70	3,995	126.8	90.5	98.8	116.2	114.4	108.0	112.1	113.7	112.2	115.2	115.0
2,400.0	60	3,424	126.2	88.7	98.6	114.9	114.6	107.4	112.3	113.1	111.7	114.8	114.6
2,000.0	50	2,853	125.9	90.5	99.2	113.0	112.6	105.9	110.5	111.5	111.4	114.6	114.9
1,800.0	40	2,283	124.9	88.9	99.9	113.1	110.5	107.9	111.5	111.8	111.2	114.4	114.0
1,200.0	30	1,712	123.7	88.7	99.7	113.0	109.7	106.8	111.6	111.7	111.6	113.8	111.6
1,000.0	25	1,427	123.0	88.5	99.0	112.8	109.6	105.7	110.7	111.3	111.6	113.0	109.8
800.0	20	1,141	121.4	87.1	97.9	110.7	109.2	104.8	107.6	109.6	111.2	111.0	107.7
400.0	10	571	118.4	84.4	95.9	107.6	106.4	104.1	107.9	106.6	107.8	107.4	104.2

### EXHAUST: Sound Power (1/3 Octave Frequencies)

GENSET POWER WITHOUT FAN	PERCENT LOAD	ENGINE POWER	1000 HZ	1250 HZ	1600 HZ	2000 HZ	2500 HZ	3150 HZ	4000 HZ	5000 HZ	6300 HZ	8000 HZ	10000 HZ
EKW	%	BHP	dB(A)										
4,000.0	100	5,646	119.0	120.3	124.4	121.0	120.4	117.1	114.5	110.8	107.9	106.4	117.6
3,600.0	90	5,110	117.9	119.3	122.6	119.8	118.7	114.9	112.6	109.1	106.3	105.9	114.5
3,200.0	80	4,559	116.2	118.4	120.4	119.0	117.6	113.4	111.3	107.5	104.9	107.8	108.5
3,000.0	75	4,280	115.5	117.7	118.5	117.9	116.8	112.8	110.3	106.7	104.5	110.8	105.3
2,800.0	70	3,995	114.8	117.1	117.3	117.1	116.1	112.3	109.6	106.0	104.1	111.8	102.9
2,400.0	60	3,424	113.9	116.5	116.4	116.3	115.5	111.9	109.2	105.3	103.5	111.9	100.8
2,000.0	50	2,853	114.1	116.8	116.8	116.6	115.7	111.8	109.6	105.7	103.8	110.4	101.5
1,800.0	40	2,283	112.7	115.6	114.9	115.5	114.5	110.6	107.6	103.9	103.0	105.3	98.9
1,200.0	30	1,712	111.5	114.1	112.8	114.1	112.7	109.1	106.1	102.3	102.4	100.6	96.9
1,000.0	25	1,427	110.9	113.1	111.7	113.4	111.6	108.1	105.1	101.9	102.2	98.6	95.6
800.0	20	1,141	110.1	110.9	110.1	111.6	109.3	108.1	103.2	101.9	98.9	97.0	93.4
400.0	10	571	109.3	107.2	107.0	107.1	104.9	103.2	100.8	98.6	94.1	93.7	89.5

## PERFORMANCE DATA[DM8854]

January 27, 2014

### Sound Data (Continued)

#### MECHANICAL: Sound Power (1/3 Octave Frequencies)

GENSET POWER WITHOUT FAN	PERCENT LOAD	ENGINE POWER	OVERALL SOUND	100 HZ	125 HZ	160 HZ	200 HZ	250 HZ	315 HZ	400 HZ	500 HZ	630 HZ	800 HZ
EKW	%	BHP	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)	dB(A)
4,000.0	100	5,646	127.0	81.1	95.8	100.1	103.1	107.6	111.8	112.9	112.1	112.9	
3,600.0	90	5,110	126.3	80.6	95.1	99.4	102.8	106.8	111.1	112.2	111.4	112.8	
3,200.0	80	4,559	125.4	81.3	94.5	99.5	103.0	107.0	110.8	111.9	111.1	112.7	
3,000.0	75	4,280	124.9	81.8	94.1	99.7	103.3	107.0	110.4	111.7	111.2	112.6	
2,800.0	70	3,995	124.5	82.4	93.4	99.5	103.1	107.1	110.0	111.4	111.2	112.4	
2,400.0	60	3,424	124.2	83.0	92.5	98.8	103.3	107.3	109.5	110.7	111.3	111.9	
2,000.0	50	2,853	124.2	83.1	92.6	99.1	100.8	105.7	108.8	109.9	110.8	111.3	111.7
1,600.0	40	2,283	123.5	83.2	91.0	99.0	100.0	105.9	107.0	109.1	110.8	111.1	112.2
1,200.0	30	1,712	122.8	81.8	89.5	98.8	99.6	105.1	106.7	109.5	110.9	111.1	112.2
1,000.0	25	1,427	122.5	81.0	88.9	98.7	99.4	104.4	106.5	109.8	111.1	111.1	112.0
800.0	20	1,141	122.3	81.1	88.8	97.8	99.0	103.4	106.6	109.6	112.1	111.5	111.7
400.0	10	571	121.7	80.7	89.1	96.4	98.3	99.7	105.8	108.5	109.9	110.5	110.6

#### MECHANICAL: Sound Power (1/3 Octave Frequencies)

GENSET POWER WITHOUT FAN	PERCENT LOAD	ENGINE POWER	1000 HZ	1250 HZ	1600 HZ	2000 HZ	2500 HZ	3150 HZ	4000 HZ	5000 HZ	6300 HZ	8000 HZ	10000 HZ
EKW	%	BHP	dB(A)										
4,000.0	100	5,646	115.4	114.8	115.2	115.3	115.3	114.7	114.7	113.8	113.8	112.5	121.3
3,600.0	90	5,110	114.7	114.3	114.6	114.7	114.6	113.3	113.2	112.5	112.7	112.3	120.7
3,200.0	80	4,559	115.5	114.1	113.9	114.1	114.1	112.8	111.9	111.8	112.0	113.8	117.1
3,000.0	75	4,280	115.6	113.7	113.5	112.9	113.6	112.5	111.4	111.1	111.6	115.3	112.9
2,800.0	70	3,995	115.4	113.5	113.2	112.4	113.2	112.4	111.0	110.7	111.3	115.7	110.7
2,400.0	60	3,424	114.8	113.3	112.7	111.8	112.8	112.4	110.9	110.3	110.9	115.7	109.8
2,000.0	50	2,853	115.0	113.3	112.8	111.5	112.8	112.1	111.1	110.4	111.2	115.4	110.3
1,600.0	40	2,283	114.5	113.2	112.1	111.0	112.2	111.3	110.0	109.3	110.4	113.0	108.3
1,200.0	30	1,712	114.1	112.8	111.4	110.3	111.3	110.2	109.3	108.2	109.8	109.1	106.3
1,000.0	25	1,427	114.0	112.6	111.2	110.1	110.8	109.6	108.8	107.7	109.7	106.9	105.3
800.0	20	1,141	114.2	112.5	111.4	110.2	110.4	109.2	107.7	107.3	106.7	105.1	103.2
400.0	10	571	114.9	112.6	111.4	109.8	110.0	109.5	106.5	105.1	102.2	102.1	99.1

**Emissions Data****RATED SPEED POTENTIAL SITE VARIATION: 1800 RPM**

GENSET POWER WITHOUT FAN	EKW	4,000.0	3,000.0	2,000.0	1,000.0	400.0
PERCENT LOAD	%	100	75	50	25	10
ENGINE POWER	BHP	5,646	4,280	2,853	1,427	571
TOTAL NOX (AS NO2)	G/HR	37.883	30.781	9.984	4.384	2,820
TOTAL CO	G/HR	3,618	4,085	9,251	2,355	3,016
TOTAL HC	G/HR	354	318	610	824	698
PART MATTER	G/HR	310.9	246.1	180.7	155.3	179.0
TOTAL NOX (AS NO2)	(CORR 5% O2)	MG/NM3	3,184.5	3,438.7	1,401.7	1,116.9
TOTAL CO	(CORR 5% O2)	MG/NM3	269.1	434.3	1,216.8	565.4
TOTAL HC	(CORR 5% O2)	MG/NM3	23.1	28.9	69.7	170.9
PART MATTER	(CORR 5% O2)	MG/NM3	20.7	22.3	20.8	32.8
TOTAL NOX (AS NO2)	(CORR 5% O2)	PPM	1,551	1,675	683	544
TOTAL CO	(CORR 5% O2)	PPM	215	347	973	452
TOTAL HC	(CORR 5% O2)	PPM	43	54	130	319
TOTAL NOX (AS NO2)		G/HP-HR	6.81	7.25	3.51	3.08
TOTAL CO		G/HP-HR	0.65	0.96	3.25	1.65
TOTAL HC		G/HP-HR	0.06	0.07	0.21	0.58
PART MATTER		G/HP-HR	0.06	0.06	0.06	0.11
TOTAL NOX (AS NO2)		LB/HR	83.52	67.86	22.01	9.67
TOTAL CO		LB/HR	7.98	9.01	20.40	5.19
TOTAL HC		LB/HR	0.78	0.70	1.35	1.82
PART MATTER		LB/HR	0.69	0.54	0.40	0.34

**RATED SPEED NOMINAL DATA: 1800 RPM**

GENSET POWER WITHOUT FAN	EKW	4,000.0	3,000.0	2,000.0	1,000.0	400.0
PERCENT LOAD	%	100	75	50	25	10
ENGINE POWER	BHP	5,646	4,280	2,853	1,427	571
TOTAL NOX (AS NO2)	G/HR	31.569	25.851	8,320	3,654	2,350
TOTAL CO	G/HR	2,010	2,269	5,140	1,308	1,675
TOTAL HC	G/HR	268	239	459	619	525
TOTAL CO2	KG/HR	2,976	2,183	1,732	958	464
PART MATTER	G/HR	222.1	175.8	129.1	111.0	127.8
TOTAL NOX (AS NO2)	(CORR 5% O2)	MG/NM3	2,653.8	2,885.5	1,168.1	930.8
TOTAL CO	(CORR 5% O2)	MG/NM3	149.5	241.3	878.0	314.1
TOTAL HC	(CORR 5% O2)	MG/NM3	17.4	21.7	52.4	128.5
PART MATTER	(CORR 5% O2)	MG/NM3	14.8	15.9	14.9	23.4
TOTAL NOX (AS NO2)	(CORR 5% O2)	PPM	1,293	1,396	569	453
TOTAL CO	(CORR 5% O2)	PPM	120	193	541	251
TOTAL HC	(CORR 5% O2)	PPM	32	41	98	240
TOTAL NOX (AS NO2)		G/HP-HR	5.67	6.04	2.93	2.57
TOTAL CO		G/HP-HR	0.36	0.53	1.81	0.92
TOTAL HC		G/HP-HR	0.05	0.06	0.16	0.43
PART MATTER		G/HP-HR	0.04	0.04	0.05	0.08
TOTAL NOX (AS NO2)		LB/HR	69.60	56.55	18.34	8.05
TOTAL CO		LB/HR	4.43	5.00	11.33	2.88
TOTAL HC		LB/HR	0.59	0.53	1.01	1.37
TOTAL CO2		LB/HR	6,561	4,813	3,818	2,112
PART MATTER		LB/HR	0.49	0.39	0.28	0.24
OXYGEN IN EXH	%	10.0	10.7	12.0	13.0	15.2
DRY SMOKE OPACITY	%	1.5	1.5	0.6	0.5	2.3
BOSCH SMOKE NUMBER			0.53	0.51	0.25	0.18

**Regulatory Information**

<b>EPA EMERGENCY STATIONARY</b>				
GASEOUS EMISSIONS DATA MEASUREMENTS ARE CONSISTENT WITH THOSE DESCRIBED IN EPA 40 CFR PART 60 SUBPART IIII AND ISO 8178 FOR MEASURING HC, CO, PM, AND NOX. GASEOUS EMISSIONS LIMIT VALUES ARE WEIGHTED CYCLE AVERAGES AND ARE IN COMPLIANCE WITH THE NON-ROAD REGULATIONS.				
<b>Locality</b> U.S. (INCL CALIF)	<b>Agency</b> EPA	<b>Regulation</b> STATIONARY	<b>Tier/Stage</b> EMERGENCY STATIONARY	<b>Max Limits - G/BKW - HR</b> CO: 3.5 NOx + HC 6.4 PM 0.20

**Altitude Derate Data****ALTITUDE CORRECTED POWER CAPABILITY (BHP)**

AMBIENT OPERATING TEMP (F)	30	40	50	60	70	80	90	100	110	120	130	140	NORMAL
ALTITUDE (FT)													
0	5,647	5,647	5,647	5,647	5,647	5,647	5,647	5,647	5,647	5,647	5,647	5,647	5,647
1,000	5,647	5,647	5,647	5,647	5,647	5,647	5,647	5,647	5,617	5,420	5,140	5,647	
2,000	5,647	5,647	5,647	5,647	5,647	5,647	5,647	5,647	5,517	5,232	4,923	5,647	
3,000	5,647	5,647	5,647	5,647	5,647	5,647	5,647	5,632	5,806	5,379	5,056	4,730	5,647
4,000	5,628	5,628	5,628	5,628	5,628	5,628	5,625	5,571	5,488	5,264	4,977	4,689	5,628
5,000	5,503	5,503	5,503	5,503	5,503	5,503	5,479	5,414	5,346	5,151	4,900	4,649	5,503
6,000	5,360	5,360	5,360	5,360	5,360	5,336	5,275	5,214	5,031	4,796	4,560	5,360	
7,000	5,215	5,215	5,215	5,215	5,215	5,193	5,138	5,082	4,910	4,688	4,466	5,215	
8,000	5,070	5,070	5,070	5,070	5,070	5,050	5,000	4,950	4,789	4,581	4,372	5,070	
9,000	4,934	4,934	4,934	4,934	4,934	4,916	4,871	4,827	4,674	4,476	4,271	4,934	
10,000	4,805	4,805	4,805	4,805	4,805	4,789	4,749	4,709	4,564	4,372	4,168	4,805	
11,000	4,675	4,675	4,675	4,675	4,675	4,661	4,627	4,592	4,453	4,269	4,061	4,675	
12,000	4,546	4,546	4,546	4,546	4,546	4,534	4,504	4,474	4,342	4,166	3,956	4,546	
13,000	4,427	4,427	4,427	4,427	4,427	4,417	4,391	4,365	4,232	4,053	3,846	4,427	
14,000	4,311	4,311	4,311	4,311	4,311	4,311	4,302	4,280	4,257	4,122	3,939	3,736	4,311
15,000	4,194	4,194	4,194	4,194	4,194	4,194	4,187	4,168	4,149	4,012	3,825	3,626	4,194

**Cross Reference**

		<b>Engine Arrangement</b>			
<b>Arrangement Number</b>	<b>Effective Serial Number</b>	<b>Engineering Model</b>	<b>Engineering Model Version</b>		
3442955	BXR00001	GS269	-	-	-

<b>Test Spec</b>	<b>Setting</b>	<b>Effective Serial Number</b>	<b>Test Specification Data</b>			
			<b>Engine Arrangement</b>	<b>Governor Type</b>	<b>Default Low Idle Speed</b>	<b>Default High Idle Speed</b>
OK7814	LL6181	BXR00001	3442955	ADEM4	-	-

**Performance Parameter Reference****Parameters Reference:DM9600-05****PERFORMANCE DEFINITIONS****PERFORMANCE DEFINITIONS DM9800****APPLICATION:**

Engine performance tolerance values below are representative of a typical production engine tested in a calibrated dynamometer test cell at SAE J1995 standard reference conditions. Caterpillar maintains ISO9001:2000 certified quality management systems for engine test facilities to assure accurate calibration of test equipment. Engine test data is corrected in accordance with SAE J1995. Additional reference material SAE J1228, J1349, ISO 8665, 3046-1:2002E, 3046-3 1989, 1585, 2534, 2288, and 9249 may apply in part or are similar to SAE J1995. Special engine rating request (SERR) test data shall be noted.

**PERFORMANCE PARAMETER TOLERANCE FACTORS**

Power	+/- 3%
Torque	+/- 3%
Exhaust stack temperature	+/- 8%
Inlet airflow	+/- 5%
Intake manifold pressure-gage	+/- 10%
Exhaust flow	+/- 6%
Specific fuel consumption	+/- 3%
Fuel rate	+/- 5%
Heat rejection	+/- 5%
Heat rejection exhaust only	+/- 10%

Torque is included for truck and industrial applications, do not use for Gen Set or steady state applications.

On C7 - C18 engines, at speeds of 1100 RPM and under these values are provided for reference only, and may not meet the tolerance listed.

These values do not apply to C280/3600. For these models, see the tolerances listed below.

**C280/3600 HEAT REJECTION TOLERANCE FACTORS**

Heat rejection	+/- 10%
Heat rejection to Atmosphere	+/- 50%
Heat rejection to Lube Oil	+/- 20%
Heat rejection to Aftercooler	+/- 5%

**TEST CELL TRANSDUCER TOLERANCE FACTORS**

Torque	+/- 0.5%
Speed	+/- 0.2%
Fuel flow	+/- 1.0%
Temperature	+/- 2 0 C degrees
Intake manifold pressure	+/- 0.1 kPa

OBSERVED ENGINE PERFORMANCE IS CORRECTED TO SAE J1995 REFERENCE AIR AND FUEL CONDITIONS.

**REFERENCE ATMOSPHERIC INLET AIR**

FOR 3500 ENGINES AND SMALLER  
SAE J1228 reference atmospheric pressure is 100 KPA (29.61 in hg)  
and standard temperature is 25 (77) at 60% relative humidity.

**FOR 3600 ENGINES**

Engine rating obtained and presented in accordance with ISO 3046/1 and SAE J1995 JAN90 standard reference conditions of 25, 100 KPA 30% relative humidity and 150M altitude at the stated aftercooler water temperature.

**MEASUREMENT LOCATION FOR INLET AIR TEMPERATURE**

Location for air temperature measurement air cleaner inlet at stabilized operating conditions.

## PERFORMANCE DATA[DM8854]

January 27, 2014

### REFERENCE EXHAUST STACK DIAMETER

The Reference Exhaust Stack Diameter published with this dataset is only used for the calculation of Smoke Opacity values displayed in this dataset. This value does not necessarily represent the actual stack diameter of the engine due to the variety of exhaust stack adapter options available. Consult the price list, engine order or general dimension drawings for the actual stack diameter size ordered or options available.

### REFERENCE FUEL

#### DIESEL

Reference fuel is #2 distillate diesel with a 35API gravity. A lower heating value is 42,780 KJ/KG (18,390 BTU/LB) when used at 29 (84.2), where the density is 838.9 G/Liter (7.001 Lbs/Gal).

#### GAS

Reference natural gas fuel has a lower heating value of 33.74 KJ/L (905 BTU/CU FT). Low BTU ratings are based on 18.64 KJ/L (500 BTU/CU FT) lower heating value gas. Propane ratings are based on 87.56 KJ/L (2350 BTU/CU FT) lower heating value gas.

### ENGINE POWER (NET) IS THE CORRECTED FLYWHEEL POWER (GROSS) LESS EXTERNAL AUXILIARY LOAD

Engine corrected gross output includes the power required to drive standard equipment: lube oil, scavenge lube oil, fuel transfer, common rail fuel, separate circuit aftercooler and jacket water pumps. Engine net power available for the external (flywheel) load is calculated by subtracting the sum of auxiliary load from the corrected gross flywheel output power. Typical auxiliary loads are radiator cooling fans, hydraulic pumps, air compressors and battery charging alternators.

### ALTITUDE CAPABILITY

Altitude capability is the maximum altitude above sea level at standard temperature and standard pressure at which the engine could develop full rated output power on the current performance data set. Standard temperature values versus altitude could be seen on TM2001.

Engines with ADEM MEUI and HEUI fuel systems operating at conditions above the defined altitude capability derate for atmospheric pressure and temperature conditions outside the values defined, see TM2001. Mechanical governor controlled unit injector engines require a setting change for operation at conditions above the altitude defined on the engine performance sheet. See your Caterpillar technical representative for non standard ratings.

### REGULATIONS AND PRODUCT COMPLIANCE

TMI Emissions information is presented at 'nominal' and 'Potential Site Variation' values for standard ratings. No tolerances are applied to the emissions data. These values are subject to change at any time. The controlling federal and local emission requirements need to be verified by your Caterpillar technical representative. Log on to the <a href="https://pdgtcat.com/cda/layout" target="blank">Technology and Solutions Divisions (T&SD) web page (<https://pdgtcat.com/cda/layout>)</a> for information including federal regulation applicability and time lines for implementation. Information for labeling and tagging requirements is also provided.

### NOTES

Regulation watch covers regulations in effect and future regulation changes for world, federal, state and local. This page includes items on the watch list where a regulation change or product change might be pending and may need attention of the engine product group. For additional emissions information log on to the TMI web page.

Additional product information for specific market application is available.

Customer's may have special emission site requirements that need to be verified by the Caterpillar Product Group engineer.

### HEAT REJECTION DEFINITIONS

Diesel Circuit Type and HHV Balance : DM9500

### EMISSIONS DEFINITIONS:

Emissions : DM1176

## **PERFORMANCE DATA[DM8854]**

January 27, 2014

SOUND DEFINITIONS:  
Sound Power : DM8702

Sound Pressure : TM7080

RATING DEFINITIONS  
Agriculture : TM6008

Fire Pump : TM6009

Generator Set : TM6035

Generator (Gas) : TM6041

Industrial Diesel : TM6010

Industrial (Gas) : TM6040

Irrigation : TM5749

Locomotive : TM6037

Marine Auxiliary : TM6038

Marine Prop (Except 3600) : TM5747

Marine Prop (3600 only) : TM5748

MSHA : TM6042

Oil Field (Petroleum) : TM8011

Off-Highway Truck : TM6039

On-Highway Truck : TM6038

Date Released : 11/23/11




**Caterpillar Inc.**  
P.O. Box 600  
Mossdale, Illinois 61552

January 28, 2014

To Whom It May Concern:

Caterpillar Inc. confirms that engine families ECPXL78.1NZS and ECPXL106.NZS are certified in accordance with EPA procedures that allow ratings with multiple power categories to be combined into one power category for certification. In this case, two power categories,  $560 < \text{kW} \leq 2237$  and  $\text{kW} > 2237$ , were combined into power category  $560 < \text{kW} \leq 2237$ . The 3500 and C175 engine ratings on the following tables are certified in ECPXL78.1NZS and ECPXL106.NZS engine families using the one power category.

Sincerely,

  
*Gregory D. Hoenert*  
*/ SEM*

Gregory D. Hoenert  
Manager, Global Emissions Certification  
Large Power Systems Division (MOS 11)  
Caterpillar Inc.

Telephone: (309) 578-4868  
[Hoenert\\_Gregory\\_D@Cat.com](mailto:Hoenert_Gregory_D@Cat.com)

<b>EPA Engine Family Name</b>	<b>Model Year</b>	<b>Engine Model</b>	<b>Rated Power (kW)</b>	<b>Rated Speed (RPM)</b>
ECPXL78.1NZS	2014	3516C	2710	1800
ECPXL78.1NZS	2014	3516C	2441	1800
ECPXL78.1NZS	2014	3516C	2475	1800
ECPXL78.1NZS	2014	3516C	2240	1800
ECPXL78.1NZS	2014	3516C	1940	1800
ECPXL78.1NZS	2014	3516C	2190	1800
ECPXL78.1NZS	2014	3516C	2010	1800
ECPXL78.1NZS	2014	3516C	1820	1800
ECPXL78.1NZS	2014	3512C	1645	1800
ECPXL78.1NZS	2014	3512C	1500	1800
ECPXL78.1NZS	2014	3512C	1360	1800
ECPXL78.1NZS	2014	3512C	1415	1800
ECPXL78.1NZS	2014	3512C	1864	1900
ECPXL78.1NZS	2014	3512C	1101	1200
ECPXL78.1NZS	2014	3508C	671	1200
ECPXL78.1NZS	2014	3512C	932	1200
ECPXL78.1NZS	2014	3516C	2710	1800
ECPXL78.1NZS	2014	3512C	1864	1900

<b>EPA Engine Family Name</b>	<b>Model Year</b>	<b>Engine Model</b>	<b>Rated Power (kW)</b>	<b>Rated Speed (RPM)</b>
ECPXL106.NZS	2014	C175-16	3298	1800
ECPXL106.NZS	2014	C175-16	3008	1800
ECPXL106.NZS	2014	C175-16	2772	1800
ECPXL106.NZS	2014	C175-16	3263	1800
ECPXL106.NZS	2014	C175-16	2974	1800
ECPXL106.NZS	2014	C175-16	2737	1800
ECPXL106.NZS	2014	C175-20	4295	1800
ECPXL106.NZS	2014	C175-20	3527	1800
ECPXL106.NZS	2014	C175-16	3298	1800
ECPXL106.NZS	2014	C175-20	4295	1800



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
2014 MODEL YEAR  
CERTIFICATE OF CONFORMITY  
WITH THE CLEAN AIR ACT OF 1990

OFFICE OF TRANSPORTATION  
AND AIR QUALITY  
ANN ARBOR, MICHIGAN 48105

Certificate Issued To: Caterpillar Inc.  
(U.S. Manufacturer or Importer)  
Certificate Number: ECPXL106.NZS-011

Certificate Issued To:	Caterpillar Inc. (U.S. Manufacturer or Importer)	Effective Date: <u>09/30/2013</u>	Expiration Date: <u>12/31/2014</u>	Issue Date: <u>09/30/2013</u>	Revision Date: <u>N/A</u>
------------------------	---	--------------------------------------	---------------------------------------	----------------------------------	------------------------------

Model Year: 2014  
Manufacturer Type: Original Engine Manufacturer  
Engine Family: ECPXL 06.NZS

Model Year: 2014	Mobile/Stationary Indicator: Stationary Emissions Power Category: 560< kW <=2237
Manufacturer Type: Original Engine Manufacturer	Fuel Type: Diesel
Engine Family: ECPXL 06.NZS	After Treatment Devices: No After Treatment Devices Installed
	Non-after Treatment Devices: Electronic Control, Engine Design Modification

Pursuant to Section 111 and Section 213 of the Clean Air Act (42 U.S.C. sections 7411 and 7547) and 40 CFR Part 60, and subject to the terms and conditions prescribed in those provisions, this certificate of conformity is hereby issued with respect to the test engines which have been found to conform to applicable requirements and which represent the following engines, by engine family, more fully described in the documentation required by 40 CFR Part 60 and produced in the stated model year.

This certificate of conformity covers only those new compression-ignition engines which conform in all material respects to the design specifications that applied to those engines described in the documentation required by 40 CFR Part 60 and which are produced during the model year stated on this certificate of the said manufacturer, as defined in 40 CFR Part 60.

It is a term of this certificate that the manufacturer shall consent to all inspections described in 40 CFR 1068 and authorized in a warrant or court order. Failure to comply with the requirements of such a warrant or court order may lead to revocation or suspension of this certificate for reasons specified in 40 CFR Part 60. It is also a term of this certificate that this certificate may be revoked or suspended or rendered void *ab initio* for other reasons specified in 40 CFR Part 60.

This certificate does not cover engines sold, offered for sale, or introduced, or delivered for introduction, into commerce in the U.S. prior to the effective date of the certificate.



**Attachment 3**  
**Form REG**

---



United States Environmental Protection Agency  
Program  
Address  
Phone  
Fax  
Web address

Reviewing Authority  
Program  
Address  
Phone  
Fax  
Web address

## FEDERAL MINOR NEW SOURCE REVIEW PROGRAM IN INDIAN COUNTRY

### Registration for Existing Sources (FORM REG)

Please submit information to:

**Federal Minor NSR Permit Coordinator**  
**U.S. EPA, Region 6 PDR**  
**1445 Ross Ave.**  
**Dallas, TX 75202**

#### A. GENERAL SOURCE INFORMATION

1. Company Name  Sandia Resort & Casino	2. Source Name  Sandia Resort & Casino		
3. Type of Operation  Casino	4. Portable Source? Yes <input checked="" type="checkbox"/> No 5. Temporary Source? Yes <input checked="" type="checkbox"/> No		
6. NAICS Code  71320	7. SIC Code  7993		
8. Physical Address (home base for portable sources)  30 Rainbow Road NE; Albuquerque, NM 87113-2156			
9. Reservation*  Pueblo of Sandia	10. County*  Bernadillo	11a. Latitude*  35°12'23.32.32"N	11b. Longitude*  106° 33'59.04"W
12a. Quarter-Quarter Section* 6 and 7	12b. Section* 1	12c. Township* 11 North	12d. Range* 3 East

\* Provide all locations of operation for portable sources

## B. CONTACT INFORMATION

<b>1. Owner Name</b> Pueblo of Sandia; Joseph M. Rodriguez as Representative		Title Superintendent of Facilities
Mailing Address 30 Rainbow Road NE; Albuquerque, NM 87113-2156		
Email Address jmrodriguez@sandiacasino.com		
Telephone Number 505-796-7750	Facsimile Number 505-796-7617	
<b>2. Operator Name</b> (if different from owner) Paul Bitner		Title Electrical Supervisor
Mailing Address 30 Rainbow Road NE; Albuquerque, NM 87113-2156		
Email Address PBitner@sandiacasino.com		
Telephone Number 505-771-5086	Facsimile Number 505-771-5086	
<b>3. Source Contact</b> Same as Owner Contact		Title
Mailing Address		
Email Address		
Telephone Number	Facsimile Number	
<b>4. Compliance Contact</b> Frank Chaves		Title Pueblo of Sandia Environment Director
Mailing Address 30 Rainbow Road NE; Albuquerque, NM 87113-2156		
Email Address fchaves@sandiapueblo.nsn.us		
Telephone Number 505-771-5086	Facsimile Number 505-771-5086	

## C. ATTACHMENTS

**Include all of the following information as attachments to this form**

- Narrative description of the operations
- Identification and description of all emission units and air pollution generating activities (with the exception of the exempt emissions units and activities listed in §49.153(c))
- Identification and description of any existing air pollution control equipment and compliance monitoring devices or activities
- Type and amount of each fuel used
- Type raw materials used  
Production Rates
- Operating Schedules
- Any existing limitations on source operations affecting emissions or any work practice standards, where applicable, for all regulated NSR pollutants at your source.
- Total allowable (potential to emit if there are no legally and practically enforceable restrictions) emissions from the air pollution source for the following air pollutants: particulate matter, PM<sub>10</sub>, PM<sub>2.5</sub>, sulfur oxides (SO<sub>x</sub>), nitrogen oxides (NO<sub>x</sub>), carbon monoxide (CO), volatile organic compound (VOC), lead (Pb) and lead compounds, fluorides (gaseous and particulate), sulfuric acid mist (H<sub>2</sub>SO<sub>4</sub>), hydrogen sulfide (H<sub>2</sub>S), total reduced sulfur (TRS) and reduced sulfur compounds, including all calculations for the estimates.
- Estimates of the total actual emissions from the air pollution source for the following air pollutants: particulate matter, PM<sub>10</sub>, PM<sub>2.5</sub>, sulfur oxides (SO<sub>x</sub>), nitrogen oxides (NO<sub>x</sub>), carbon monoxide (CO), volatile organic compound (VOC), lead (Pb) and lead compounds, ammonia (NH<sub>3</sub>), fluorides (gaseous and particulate), sulfuric acid mist (H<sub>2</sub>SO<sub>4</sub>), hydrogen sulfide (H<sub>2</sub>S), total reduced sulfur (TRS) and reduced sulfur compounds, including all calculations for the estimates.
- Other – Manufacturer Spec Sheets

[Disclaimers] The public reporting and recordkeeping burden for this collection of information is estimated to average 6 hours per response. Send comments on the Agency's need for this information, the accuracy of the provided burden estimates, and any suggested methods for minimizing respondent burden, including through the use of automated collection techniques to the Director, Collection Strategies Division, U.S. Environmental Protection Agency (2822T), 1200 Pennsylvania Ave., NW, Washington, D.C. 20460. Include the OMB control number in any correspondence. Do not send the completed form to this address.

## D. TABLE OF ESTIMATED EMISSIONS

The following estimates of the total emissions in tons/year for all pollutants contained in your worksheet stated above should be provided.

(EMISSIONS BELOW ARE FROM ALL SOURCES INCLUDING THE TWO NEW GENERATORS)

Pollutant	Total Actual Emissions (tpy)	Total Allowable or Potential Emissions (TPY)
PM		<b>3.08</b>
PM <sub>10</sub>		<b>3.08</b>
PM <sub>2.5</sub>		<b>3.08</b>
SO <sub>x</sub>		<b>0.13</b>
NO <sub>x</sub>		<b>87.40</b>
CO		<b>44.93</b>
VOC		<b>4.55</b>
Pb		<b>6.63E-5</b>
NH <sub>3</sub>		<b>0</b>
Fluorides		<b>0</b>

H <sub>2</sub> SO <sub>4</sub>	<b>0</b>
H <sub>2</sub> S	<b>0</b>
TRS	<b>0</b>
RSC	<b>0</b>

Emissions calculations must include fugitive emissions if the source is one the following listed sources, pursuant to CAA Section 302(j):

- (a) Coal cleaning plants (with thermal dryers);
- (b) Kraft pulp mills;
- (c) Portland cement plants;
- (d) Primary zinc smelters;
- (e) Iron and steel mills;
- (f) Primary aluminum ore reduction plants;
- (g) Primary copper smelters;
- (h) Municipal incinerators capable of charging more than 250 tons of refuse per day;
- (i) Hydrofluoric, sulfuric, or nitric acid plants;
- (j) Petroleum refineries;
- (k) Lime plants;
- (l) Phosphate rock processing plants;
- (m) Coke oven batteries;
- (n) Sulfur recovery plants;
- (o) Carbon black plants (furnace process);
- (p) Primary lead smelters;
- (q) Fuel conversion plants;
- (r) Sintering plants;
- (s) Secondary metal production plants;
- (t) Chemical process plants
- (u) Fossil-fuel boilers (or combination thereof) totaling more than 250 million British thermal units per hour heat input;
- (v) Petroleum storage and transfer units with a total storage capacity exceeding 300,000 barrels;
- (w) Taconite ore processing plants;
- (x) Glass fiber processing plants;
- (y) Charcoal production plants;
- (z) Fossil fuel-fired steam electric plants of more than 250 million British thermal units per hour heat input, and
- (aa) Any other stationary source category which, as of August 7, 1980, is being regulated under section 111 or 112 of the Act.