



REGION 6
1445 ROSS AVENUE
DALLAS, TEXAS 75202-2733

NPDES Permit No TX0003310

AUTHORIZATION TO DISCHARGE UNDER THE NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM

In compliance with the provisions of the Clean Water Act, as amended, (33 U.S.C. 1251 et. seq; the "Act"),

DCP Midstream Services Wilcox Gas Plant
404 Private Road 1045
Hallettsville, TX 77964

is authorized to discharge from a facility located at 404 Private Road 1045, Hallettsville, Lavaca County, Texas,

to receiving waters named Hays Branch Creek, thence to Ragsdale Creek, thence to the Navidad River above Lake Texana, water body Segment No. 1605 of the Lavaca River Basin, from

Outfall 001: Latitude 29° 20' 15"N; Longitude 96° 40' 15"W

in accordance with this cover page and the effluent limitations, monitoring requirements, and other conditions set forth in Part I, Part II and Part III hereof.

This permit shall become effective on

This permit and the authorization to discharge shall expire at midnight,

Issued on

Prepared by

William K. Honker, P.E.
Director
Water Division (6WQ)

Maria E. Okpala
Environmental Engineer
Permitting Section (6WQ-PP)

This page is intentionally left blank

PART I – REQUIREMENTS FOR NPDES PERMITS

SECTION A. LIMITATIONS AND MONITORING REQUIREMENTS

1. Outfall 001 - 0.03 MGD

During the period beginning on the effective date of the permit and lasting until the expiration date, the permittee is authorized to discharge non-contact cooling water, reverse osmosis reject water, water condensate, and stormwater runoff from outfall number 001 to Hays Branch Creek, thence to Ragsdale Creek, thence to the Navidad River above Lake Texana, water body Segment No. 1605 of the Lavaca River Basin. Such discharges shall be limited and monitored by the permittee as specified below:

EFFLUENT CHARACTERISTICS		DISCHARGE LIMITATIONS		MONITORING REQUIREMENTS	
		Standard Units			
POLLUTANT	STORET CODE	MINIMUM	MAXIMUM	MEASUREMENT FREQUENCY	SAMPLE TYPE
pH	00400	6.5	9.0	Once/Month *1	Grab

EFFLUENT CHARACTERISTICS		DISCHARGE LIMITATIONS				MONITORING REQUIREMENTS	
		lbs/day, unless noted		mg/l, unless noted			
POLLUTANT	STORET CODE	DAILY AVG	DAILY MAX	DAILY AVG	DAILY MAX	MEASUREMENT FREQUENCY	SAMPLE TYPE
Flow	50050	Report, MGD	Report, MGD	N/A	N/A	Continuous *1	Record

Footnotes:

*1 When discharging.

SAMPLING LOCATION(S) AND OTHER REQUIREMENTS

Samples taken in compliance with the monitoring requirements specified above shall be taken at the discharge from the final treatment unit prior to the receiving stream from the following approximate location:

Outfall 001: Latitude 29° 20' 15"N; Longitude 96° 40' 15"W

FLOATING SOLIDS, VISIBLE FOAM AND/OR OILS

There shall be no discharge of floating solids or visible foam in other than trace amounts. The effluent shall contain no visible film of oil, globules of oil, grease or solids in or on the surface or coat the banks or bottoms of the watercourse.

SECTION B. SCHEDULE OF COMPLIANCE

NONE

SECTION C. MONITORING AND REPORTING (MINOR DISCHARGERS)

1. Monitoring results must be reported to EPA on either the electronic or paper Discharge Monitoring Report (DMR) approved formats. Monitoring results can be submitted electronically in lieu of the paper DMR Form. All DMRs shall be electronically reported effective December 21, 2016, per 40 CFR 127.16. To submit electronically, access the NetDMR website at www.epa.gov/netdmr and contact the R6NetDMR@epa.gov in-box for further instructions. Until you are approved for Net DMR, you must report on the Discharge Monitoring Report (DMR) Form EPA No. 3320-1 in accordance with the "General Instructions" provided on the form. No additional copies are needed if reporting electronically, however when submitting paper form EPA No. 3320-1, the permittee shall submit the original DMR signed and certified as required by Part III.D.11 and all other reports required by Part III.D. to the EPA and other agencies as required. (See Part III.D.IV of the permit.)

Discharge Monitoring Report Form(s) shall be submitted quarterly. Each quarterly submittal shall include separate forms for each month of the reporting period.

ELECTRONIC REPORTING RULE

The EPA published the electronic reporting rule in the federal register (80 FR 64063) on October 22, 2015. The rule became effective on December 21, 2015. One year after the effective date of the final rule, NPDES regulated entities that are required to submit DMRs (including majors and non-majors, individually permitted facilities and facilities covered by general permits) must do so electronically. EPA and authorized NPDES programs will begin electronically receiving these DMRs from all DMR filers and start sharing these data with each other.

2. Reporting periods shall end on the last day of the months March, June, September, and December.

3. The first Discharge Monitoring Report(s) shall represent facility operations from the effective date of the permit through the last day of the current reporting period.

4. Thereafter, the permittee is required to submit regular quarterly reports as described above and shall submit those reports postmarked no later than the 28th day of the month following each reporting period.

5. NO DISCHARGE REPORTING - If there is no discharge from any outfall during the sampling month, place an "X" in the NO DISCHARGE box located in the upper right corner of the Discharge Monitoring Report.

6. If any daily maximum or monthly average value exceeds the effluent limitations specified in Part I. A, the permittee shall report the excursion in accordance with the requirements of Part III. D.

7. Any daily maximum or monthly average value reported in the required Discharge Monitoring Report which is in excess of the effluent limitation specified in Part I. A shall constitute evidence of violation of such effluent limitation and of this permit.

8. All reports shall be sent both to EPA and the Texas Railroad Commission at the addresses shown in Part III of the permit.

PART II - OTHER REQUIREMENTS

A. MINIMUM QUANTIFICATION LEVEL (MQL)

See list of MQL's at Appendix A of Part II below. For pollutants listed on Appendix A of Part II with MQL's, analyses must be performed to the listed MQL. If any individual analytical test result is less than the MQL listed, a value of zero (0) may be used for that pollutant result for the Discharge Monitoring Report (DMR) calculations and reporting requirements.

In addition, any additional pollutant sampling for purposes of this permit, including renewal applications or any other reporting, shall be tested to the MQL shown on the attached Appendix A of Part II. Results of analyses that are less than the listed MQL may be reported as "non detect" (ND).

B. 24-HOUR ORAL REPORTING: DAILY MAXIMUM LIMITATION VIOLATIONS

Under the provisions of Part III.D.7.b.(3) of this permit, violations of daily maximum limitations for the following pollutants shall be reported orally to EPA Region 6, Compliance and Assurance Division, Water Enforcement Branch (6EN-W), Dallas, Texas, at (214) 665-6595, and concurrently to Railroad Commission of Texas, at (512) 463-6804, within 24 hours from the time the permittee becomes aware of the violation followed by a written report in five days.

NONE

C. 40 CFR PART 136 ANALYTICAL REQUIREMENTS

Unless otherwise specified in this permit, monitoring shall be conducted according to the analytical, apparatus and materials, sample collection, preservation, handling, etc., procedures listed at 40 CFR Part 136 in effect on the effective date of this permit. Appendices A, B, and C to 40 CFR Part 136 are specifically referenced as part of this requirement. Amendments to 40 CFR Part 136 promulgated after the effective date of this permit shall supersede these requirements as applicable.

Sufficiently Sensitive Analytical Methods (SSM)

The permittee must use sufficiently sensitive EPA-approved analytical methods (SSM) (under 40 CFR part 136 or required under 40 CFR chapter I, subchapters N or O) when quantifying the presence of pollutants in a discharge for analyses of pollutants or pollutant parameters under the permit. In case the approved methods are not sufficiently sensitive to the limits, the most SSM with the lowest method detection limit (MDL) must be used as defined under 40 CFR 122.44(i)(1)(iv)(A). If no analytical laboratory is able to perform a test satisfying the SSM in the region, the most SSM with the lowest MDL must be used after adequate demonstrations by the permittee and EPA approval.

D. REOPENER

The permit may be reopened and modified during the life of the permit if relevant portions of the Texas Commission on Environmental Quality (TCEQ) Water Quality Standards for Interstate and Intrastate Streams are revised or remanded. In addition, the permit may be reopened and modified during the life of the permit if relevant procedures implementing the Water Quality Standards are either revised or promulgated by the TCEQ. Should the State adopt a State water quality standard, this permit may be reopened to establish effluent limitations for the parameter(s) to be consistent with that approved State standard in accordance with 40CFR122.44 (d). Modification of the permit is subject to the provisions of 40CFR124.5.

If a new or revised TMDL is determined for the receiving stream, the permit may be reopened, and new limitations based on the TMDL may be incorporated into the permit. Additionally, in accordance with 40 CFR Part 122.62 (a) (2), the permit may be reopened and modified if new information is received that was not available at the time of permit issuance that would have justified the application of different permit conditions at the time of permit issuance. Permit modifications shall reflect the results of any of these actions and shall follow regulations listed at 40 CFR Part 124.5.

E. STORM WATER POLLUTION PREVENTION

Stormwater continues to be a component of the discharge through Outfall 001. This section applies to all stormwater discharges from the facility, either through permitted outfalls or through outfalls which are not listed in the permit. The language below has been included in this permit to control stormwater through discharges in individual permits:

1. The permittee shall continue to implement and within six (6) months of the effective date of the final permit revise as necessary, a Storm Water Pollution Prevention Plan (SWP3). The terms and conditions of the SWP3 shall be an enforceable Part of the permit.
2. A visual inspection of the facility shall be conducted and a report made annually as described in Paragraph E.2.d and E.2.e below. The annual report shall be retained onsite and available upon request.

The following "limits" shall apply:

a. The permittee shall continue to identify potential sources of pollution which may reasonably be expected to affect the quality of storm water discharges from the facility; continue to implement practices which will be used to reduce pollutants in storm water discharges from the facility; and assure compliance with the terms and conditions of this permit.

b. The permittee must document where potential spills and leaks could occur that could contribute pollutants to stormwater discharges, and the corresponding outfall(s). The permittee must document all significant spills and leaks of oil or toxic or hazardous pollutants that actually occurred at exposed areas, or that drained to a stormwater conveyance, in the 3 years prior to the date you prepare or amend your SWPPP.

Note: Significant spills and leaks include, but are not limited to, releases of oil or hazardous substances in excess of quantities that are reportable under CWA Section 311 (see 40 CFR 110.6 and 40 CFR 117.21) or Section 102 of the Comprehensive Environmental Response, Compensation and Liability Act (CERCLA), 42 USC §9602. This permit does not relieve you of the reporting requirements of 40 CFR 110, 40 CFR 117, and 40 CFR 302 relating to spills or other releases of oils or hazardous substances.

c. Where experience indicates a reasonable potential for equipment failure (e.g. a tank overflow or leakage), natural condition of (e.g. precipitation), or other circumstances which result in significant amounts of pollutants reaching surface waters, the SWP3 shall include a prediction of the direction, rate of flow and total quantity of pollutants which could be discharged from the facility as a result of each condition or circumstance.

d. The permittee shall maintain for a period of three years a record summarizing the results of the inspection and a certification that the facility is in compliance with the SWP3 and the permit, and identifying any incidents of noncompliance. The summary report should contain, at a minimum, the date and time of inspection, name of inspectors(s), conditions found, and changes to be made to the SWP3.

e. The summary report and the following certification shall be signed and attached to the SWP3 and provided to the local Municipal Separate Storm Sewer System (MS4) operator, Environmental Protection Agency and the Railroad Commission of Texas upon request.

“I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.”

Signatory requirements for the certification may be found in Part III, Section D.11 of this permit.

f. The permittee shall make available to the Agency, the Railroad Commission of Texas, and/or the USFWS, upon request, a copy of the SWP3 and any supporting documentation.

3. The following shall be included in the SWP3, if applicable.

- a. The permittee shall utilize all reasonable methods to minimize any adverse impact on the drainage system including but not limited to:
 - i. maintaining adequate road and driveway surfaces;
 - ii. removing debris and accumulated solids from the drainage system;
 - and
 - iii. cleaning up immediately any spill by sweeping, absorbent pads, or other appropriate methods.

b. All spilled product and other spilled wastes shall be immediately cleaned up and disposed of according to all applicable regulations, Spill Prevention and Control (SPC) plans or

Spill Prevention Control and Countermeasures (SPCC) plans. Use of detergents, emulsifiers, or dispersants to clean up spilled product is prohibited except where necessary to comply with State or Federal safety regulations (i.e., requirement for non-slippery work surface). In all such cases, initial cleanup shall be done by physical removal and chemical usage shall be minimized.

c. All equipment, parts, dumpsters, trash bins, petroleum products, chemical solvents, detergents, or other materials exposed to stormwater shall be maintained in a manner which prevents contamination of stormwater by pollutants.

d. All waste fuel, lubricants, coolants, solvents, or other fluids used in repair or maintenance of vehicles or equipments shall be recycled or contained for proper disposal. Spills of these materials are to be cleaned up by dry means whenever possible.

e. Stormwater Pollution Prevention Plan must be consistent with the requirements of the current Oil Pollution Prevention regulations.

f. Prior to discharge of uncontaminated stormwater from a secondary containment area, the permittee will conduct a visual inspection of the containment area for a visible sheen, an odor associated within the tanked products, and/or a stain pattern within the contained area that is indicative of a spill or leak into that area. No dewatering of the area is allowed under the condition of this permit, if evidence exists of a spill or leak, unless the discharge will not exceed 50 mg/l TOC, 15 mg/l Oil and Grease, or having a pH less than 6.0 or greater than 9.0 standard units.

g. The permittee shall assure compliance with all applicable regulations promulgated under 40 CFR Part 257. Management practices required under regulations found in this Part shall be referenced in the SWP3.

h. The permittee shall amend the SWP3 whenever there is a change in the facility or change in the operation of the facility which materially increases the potential for the ancillary activities to result in a discharge of significant amounts of pollutants.

i. If the SWP3 proves to be ineffective in achieving the general objectives preventing the release of significant amounts of pollutants to water of the state, then the specific objectives and requirements of the SWP3 shall be subject to modification to incorporate revised SWP3 requirements.

4. The facility shall maintain SWP3 describing how the above limits will be met.

APPENDIX A of PART II

The following Minimum Quantification Levels (MQL's) are to be used for reporting pollutant data for NPDES permit applications and/or compliance reporting.

POLLUTANTS	MQL µg/l	POLLUTANTS	MQL µg/l
METALS, RADIOACTIVITY, CYANIDE and CHLORINE			
Aluminum	2.5	Molybdenum	10
Antimony	60	Nickel	0.5
Arsenic	0.5	Selenium	5
Barium	100	Silver	0.5
Beryllium	0.5	Thallium	0.5
Boron	100	Uranium	0.1
Cadmium	1	Vanadium	50
Chromium	10	Zinc	20
Cobalt	50	Cyanide	10
Copper	0.5	Cyanide, weak acid dissociable	10
Lead	0.5	Total Residual Chlorine	33
Mercury *1	0.0005 0.005		
DIOXIN			
2,3,7,8-TCDD	0.00001		
VOLATILE COMPOUNDS			
Acrolein	50	1,3-Dichloropropylene	10
Acrylonitrile	20	Ethylbenzene	10
Benzene	10	Methyl Bromide	50
Bromoform	10	Methylene Chloride	20
Carbon Tetrachloride	2	1,1,2,2-Tetrachloroethane	10
Chlorobenzene	10	Tetrachloroethylene	10
Clorodibromomethane	10	Toluene	10
Chloroform	50	1,2-trans-Dichloroethylene	10
Dichlorobromomethane	10	1,1,2-Trichloroethane	10
1,2-Dichloroethane	10	Trichloroethylene	10
1,1-Dichloroethylene	10	Vinyl Chloride	10
1,2-Dichloropropane	10		
ACID COMPOUNDS			
2-Chlorophenol	10	2,4-Dinitrophenol	50
2,4-Dichlorophenol	10	Pentachlorophenol	5
2,4-Dimethylphenol	10	Phenol	10
4,6-Dinitro-o-Cresol	50	2,4,6-Trichlorophenol	10

POLLUTANTS	MLL µg/l	POLLUTANTS	MLL µg/l
BASE/NEUTRAL			
Acenaphthene	10	Dimethyl Phthalate	10
Anthracene	10	Di-n-Butyl Phthalate	10
Benidine	50	2,4-Dinitrotoluene	10
Benzo(a)anthracene	5	1,2-Diphenylhydrazine	20
Benzo(a)pyrene	5	Fluoranthene	10
3,4-Benzofluoranthene	10	Fluorene	10
Benzo(k)fluoranthene	5	Hexachlorobenzene	5
Bis(2-chloroethyl)Ether	10	Hexachlorobutadiene	10
Bis(2-chloroisopropyl)Ether	10	Hexachlorocyclopentadiene	10
Bis(2-ethylhexyl)Phthalate	10	Hexachloroethane	20
Butyl Benzyl Phthalate	10	Indeno(1,2,3-cd)Pyrene	5
2-Chloronaphthalene	10	Isophorone	10
Chrysene	5	Nitrobenzene	10
Dibenzo(a,h)anthracene	5	n-Nitrosodimethylamine	50
1,2-Dichlorobenzene	10	n-Nitrosodi-n-Propylamine	20
1,3-Dichlorobenzene	10	n-Nitrosodiphenylamine	20
1,4-Dichlorobenzene	10	Pyrene	10
3,3'-Dichlorobenzidine	5	1,2,4-Trichlorobenzene	10
Diethyl Phthalate	10		
PESTICIDES AND PCBS			
Aldrin	0.01	Beta-Endosulfan	0.02
Alpha-BHC	0.05	Endosulfan sulfate	0.02
Beta-BHC	0.05	Endrin	0.02
Gamma-BHC	0.05	Endrin Aldehyde	0.1
Chlordane	0.2	Heptachlor	0.01
4,4'-DDT and derivatives	0.02	Heptachlor Epoxide	0.01
Dieldrin	0.02	PCBs	0.2
Alpha-Endosulfan	0.01	Toxaphene	0.3

(MLL's Revised November 1, 2007)

Footnotes:

*1 Default MQL for Mercury is 0.005 unless Part I of your permit requires the more sensitive Method 1631 (Oxidation / Purge and Trap / Cold vapor Atomic Fluorescence Spectrometry), then the MQL shall be 0.0005

