

## Example Boiler Emission Credits

- A hypothetical facility manufactures wigits, operates 1 large heavy liquid fuel boiler rated at 300 MMBtu/hr and 85% efficient (Boiler # 1), and 1 medium size 60 MMBtu/hr boiler burning other gases and generating 50,000 lb/hr steam and 75% efficient (Boiler # 2)
- Boilers are used to provide steam and hot water for manufacturing process
- A major HAP source, the plant operates 24 hr/day, 365 days/yr (8,760 Hrs/Yr)

**Baseline Energy Input (EI)** for Boiler 1 = (300 MMBtu/hr) (8,760hr/yr) (.85)  
= 2.23 E+6 MMBtu/yr

(Based on yearly operation of 8,760 hours & running at 85% of rated design capacity)

**Baseline Energy Input (EI)** for Boiler 2 = (60 MMBtu/hr) (8760hr/yr) (.75)  
= 3.94 E+5 MMBtu/yr

(Based on yearly operation of 8,760 hours & running at 75% of rated design capacity)

A hypothetical **energy assessment** identifies several cost-effective energy conservation measures and facility implements the following measures:

- Boiler #1: Add insulation to steam system piping (Section 3.3 of DoE Guidance)
- Boiler #1: Replace burners with a flame retention burner (15% savings estimated)
- Boiler #2: Reduce boiler blowdown (Section 3.1 of DoE Guidance)

**Energy Input Savings (EIS)** for each measure implemented:

1. (Insulation) **EIS** = (.02klb/hr) (100ft/20ft) (8760hr/yr) (1003.342Btu/klb)  
= **879 MMBtu/yr**

Based on replacing 100 ft. of 3-inch diameter pipe, carrying steam at 165 psi, with fiberglass insulation of 1.5 inch thickness. See estimates in ConED Steam Use Efficiency and Demand Reduction (at [http://www.coned.com/steam/kc\\_sdrt.asp](http://www.coned.com/steam/kc_sdrt.asp))

2. (Burners) **EIS** = (EI)(.15) = **335,070 MMBtu/yr**

Based on 15% savings in actual energy purchases for installation of a flame retention burner. See estimates in:

[http://www.energysavers.gov/your\\_home/space\\_heating\\_cooling/index.cfm/mytopic=125](http://www.energysavers.gov/your_home/space_heating_cooling/index.cfm/mytopic=125)

3. (Blowdown) **EIS = 3,931** MMBtu/yr

Based on blowdown reduction from 6-8% assuming continuous operation at 150 psig, 60°F make-up water temperature, and 80% boiler efficiency.

Initial feedwater: 50,000 lb/hr / (1 - 0.08) = 54,348 lb/hr

Final feedwater: 50,000 lb/hr / (1 - 0.06) = 53,191 lb/hr

**Makeup water savings** = 54,348 – 53,191 = 1,156 lb/hr

Enthalpy of boiler water at 150 psig (165 psia) = 338.5 Btu/lb

Enthalpy of makeup water at 60°F = 28 Btu /lb

(calculations of thermodynamic properties of saturated steam can be found at

[http://www.peacesoftware.de/einigewerte/wasser\\_dampf\\_e.html](http://www.peacesoftware.de/einigewerte/wasser_dampf_e.html)

and using enthalpy conversion factor of kJ/kg = 0.4299 Btu/lb)

**Thermal energy savings** = 338.5 – 28 = 310.5 Btu/lb

**Annual energy savings** = (1,156 lb/hr x 8,760 hr/yr x 310.5 Btu/lb) / (0.80 x 10<sup>6</sup> Btu/MMBtu) = **3,931 MMBtu/yr**

**Credit for Boiler 1** = [(#1 EIS) + (#2 EIS) ] / {EI for Boiler 1}  
 = [ (879 MMBtu/yr) + (335,070 MMBtu/yr) ]/ 2.23 E+6 MMBtu/yr = 0.15

**Credit for Boiler 2** = 3,931 MMBtu/yr / 3.94 E+5 MMBtu/yr = 0.01

**Adjusted emission levels** = (stack test measurement) x (1 – credit) = see table below

**Compliance** is met if **adjusted emissions** (lb/MMBtu of steam output) are less than **emission limits** from **Table 2** of the final rule (lb/MMBtu of steam output), per table below.

<b>Pollutant</b>	<b>Boiler 1 Emission Limits</b>	<b>Boiler 1 Measured Emissions</b>	<b>Boiler 1 Adjusted Emissions</b>	<b>Boiler 2 Emission Limit</b>	<b>Boiler 2 Measured Emissions</b>	<b>Boiler 2 Adjusted Emissions</b>
<b>PM</b>	<b>0.075</b>	0.0080*	<b>0.0068</b>	<b>0.012</b>	0.020*	<b>0.020</b>
<b>HCl</b>	<b>0.0015</b>	0.00025*	<b>0.00021</b>	<b>0.0029</b>	0.0010*	<b>0.00099</b>
<b>Hg</b>	<b>3.3e-5</b>	9.0e-7*	<b>7.7e-7</b>	<b>1.4e-5</b>	7.8e-6*	<b>7.7e-6</b>

\*Measured (hypothetical) emissions from compliance test