

PERMIT NO. 4911-077-0001-V-04-0

ISSUANCE DATE: JAN 10 2017



GEORGIA

DEPARTMENT OF NATURAL RESOURCES

ENVIRONMENTAL PROTECTION DIVISION

Air Quality - Part 70 Operating Permit

Facility Name: Yates Steam-Electric Generating Plant
Facility Address: 708 Dyer Road
Newnan, Georgia 30263, Coweta County
Mailing Address: 241 Ralph McGill Blvd., N.E., Bin 10221
Atlanta, Georgia 30308
Parent/Holding Company: Southern Company/Georgia Power
Facility AIRS Number: 04-13-077-00001

In accordance with the provisions of the Georgia Air Quality Act, O.C.G.A. Section 12-9-1, et seq and the Georgia Rules for Air Quality Control, Chapter 391-3-1, adopted pursuant to and in effect under the Act, the Permittee described above is issued a Part 70 Permit for:

The operation of an electric utility plant including two steam electric generating units.

This Permit is conditioned upon compliance with all provisions of The Georgia Air Quality Act, O.C.G.A. Section 12-9-1, et seq, the Rules, Chapter 391-3-1, adopted and in effect under that Act, or any other condition of this Permit. Unless modified or revoked, this Permit expires five years after the issuance date indicated above.

This Permit may be subject to revocation, suspension, modification or amendment by the Director for cause including evidence of noncompliance with any of the above, for any misrepresentation made in Title V Application TV-23087 signed on January 26, 2015, any other applications upon which this Permit is based, supporting data entered therein or attached thereto, or any subsequent submittal of supporting data, or for any alterations affecting the emissions from this source.

This Permit is further subject to and conditioned upon the terms, conditions, limitations, standards, or schedules contained in or specified on the attached 47 pages.



Richard E. Dunn, Director
Environmental Protection Division

Table of Contents

PART 1.0	FACILITY DESCRIPTION	1
1.1	Site Determination	1
1.2	Previous and/or Other Names	1
1.3	Overall Facility Process Description.....	1
PART 2.0	REQUIREMENTS PERTAINING TO THE ENTIRE FACILITY	2
2.1	Facility Wide Emission Caps and Operating Limits.....	2
2.2	Facility Wide Federal Rule Standards.....	2
2.3	Facility Wide SIP Rule Standards.....	2
2.4	Facility Wide Standards Not Covered by a Federal or SIP Rule and Not Instituted as an Emission Cap or Operating Limit	2
PART 3.0	REQUIREMENTS FOR EMISSION UNITS	3
3.1	Emission Units	3
3.2	Equipment Emission Caps and Operating Limits	3
3.3	Equipment Federal Rule Standards.....	4
3.4	Equipment SIP Rule Standards	5
3.5	Equipment Standards Not Covered by a Federal or SIP Rule and Not Instituted as an Emission Cap or Operating Limit	6
PART 4.0	REQUIREMENTS FOR TESTING.....	7
4.1	General Testing Requirements	7
4.2	Specific Testing Requirements	8
PART 5.0	REQUIREMENTS FOR MONITORING (Related to Data Collection)	9
5.1	General Monitoring Requirements.....	9
5.2	Specific Monitoring Requirements	9
PART 6.0	RECORD KEEPING AND REPORTING REQUIREMENTS	13
6.1	General Record Keeping and Reporting Requirements	13
6.2	Specific Record Keeping and Reporting Requirements.....	16
PART 7.0	OTHER SPECIFIC REQUIREMENTS.....	21
7.1	Operational Flexibility	21
7.2	Off-Permit Changes	21
7.3	Alternative Requirements.....	22
7.4	Insignificant Activities	22
7.5	Temporary Sources	22
7.6	Short-term Activities.....	22
7.7	Compliance Schedule/Progress Reports	22
7.8	Emissions Trading.....	22
7.9	Acid Rain Requirements	23
7.10	Prevention of Accidental Releases (Section 112(r) of the 1990 CAAA).....	26
7.11	Stratospheric Ozone Protection Requirements (Title VI of the CAAA of 1990)	27
7.12	Revocation of Existing Permits and Amendments.....	28
7.13	Pollution Prevention.....	28
7.14	Specific Conditions	28
7.15	Cross State Air Pollution Rule (CSAPR) Allowance Trading Program Requirements.....	29
PART 8.0	GENERAL PROVISIONS	30
8.1	Terms and References	30
8.2	EPA Authorities	30
8.3	Duty to Comply.....	30

Title V Permit

8.4 Fee Assessment and Payment31

8.5 Permit Renewal and Expiration31

8.6 Transfer of Ownership or Operation31

8.7 Property Rights.....31

8.8 Submissions.....32

8.9 Duty to Provide Information32

8.10 Modifications33

8.11 Permit Revision, Revocation, Reopening and Termination.....33

8.12 Severability34

8.13 Excess Emissions Due to an Emergency34

8.14 Compliance Requirements35

8.15 Circumvention.....38

8.16 Permit Shield38

8.17 Operational Practices38

8.18 Visible Emissions.....39

8.19 Fuel-burning Equipment39

8.20 Sulfur Dioxide.....39

8.21 Particulate Emissions40

8.22 Fugitive Dust.....40

8.23 Solvent Metal Cleaning.....41

8.24 Incinerators.....42

8.25 Volatile Organic Liquid Handling and Storage42

8.26 Use of Any Credible Evidence or Information43

8.27 Internal Combustion Engines.....43

8.28 Boilers and Process Heaters46

Attachments47

A. List of Standard Abbreviations and List of Permit Specific Abbreviations

B. Insignificant Activities Checklist, Insignificant Activities Based on Emission Levels and Generic Emission Groups

C. List of References

PART 1.0 FACILITY DESCRIPTION**1.1 Site Determination**

In the past, Plant Yates contracted with an ash processing facility located on site to process and sell some of the coal ash produced from the electric generating process at Plant Yates. Even though the ash processing facility and Plant Yates were located on contiguous property, they were deemed to be separate sources for purposes of Title V permitting due to the fact that there was no common control between Georgia Power Company and the ash processing facility. Therefore, the Title V permit for Plant Yates covers only those operations controlled solely by Georgia Power. The ash processing facility, which was itself a minor source under 40 CFR Part 70, operated under its minor source SIP permit. With the removal of coal burning capability from Plant Yates, the ash processing facility will no longer be in operation.

1.2 Previous and/or Other Names

This facility is commonly known and referred to as Plant Yates. No other names were identified.

1.3 Overall Facility Process Description

Plant Yates burns fossil fuel to generate electricity. This facility includes two steam electric generating units that exclusively burns natural gas. Units 6 and Unit 7 exhaust through the 805 ft stack.

PART 2.0 REQUIREMENTS PERTAINING TO THE ENTIRE FACILITY

2.1 Facility Wide Emission Caps and Operating Limits

None applicable.

2.2 Facility Wide Federal Rule Standards

None applicable.

2.3 Facility Wide SIP Rule Standards

None applicable.

2.4 Facility Wide Standards Not Covered by a Federal or SIP Rule and Not Instituted as an Emission Cap or Operating Limit

None applicable.

PART 3.0 REQUIREMENTS FOR EMISSION UNITS

Note: Except where an applicable requirement specifically states otherwise, the averaging times of any of the Emissions Limitations or Standards included in this permit are tied to or based on the run time(s) specified for the applicable reference test method(s) or procedures required for demonstrating compliance.

3.1 Emission Units

Emission Units		Specific Limitations/Requirements		Air Pollution Control Devices	
ID No.	Description	Applicable Requirements/Standards	Corresponding Permit Conditions	ID No.	Description
SG06	Steam Generator Unit 6 (3,559 MMBtu/hr) (Natural Gas Fired)	391-3-1-.02(2)(b), (d), (g), (yy), (jjj), (sss), Acid Rain, 40 CFR 96	3.2.1, 3.2.2, 3.2.3, 3.4.1, 3.4.2, 3.4.3, 3.4.5, 3.4.6, 4.1.3, 5.2.1, 5.2.2, 5.2.3, 5.2.6, 6.1.7, 6.2.1, 6.2.3, 6.2.4, 6.2.10, 6.2.10, 6.2.12, 7.9.7	OC06	Oxidation catalyst
SG07	Steam Generator Unit 7 (3,559 MMBtu/hr) (Natural Gas Fired)	391-3-1-.02(2)(b), (d), (g), (yy), (jjj), (sss), Acid Rain, 40 CFR 96	3.2.1, 3.2.2, 3.2.3, 3.4.1, 3.4.2, 3.4.4, 3.4.5, 3.4.6, 4.1.3, 5.2.1, 5.2.2, 5.2.3, 5.2.6, 6.1.7, 6.2.1, 6.2.3, 6.2.4, 6.2.10, 6.2.12, 7.9.7	OC07	Oxidation catalyst
WBH1	Water Bath Heater Unit 1 (9 MMBtu/hr) (Natural Gas Fired)	391-3-1-.02(2)(d), (g), (rrr), 40 CFR 63 Subpart DDDDD	3.2.3, 3.3.1, 3.3.2, 3.4.7, 3.4.8, 3.4.9, 4.1.3, 5.2.4, 5.2.5, 5.2.7, 6.1.7, 6.2.11, 6.2.13, 6.2.14, 6.2.15	None	N/A

* Generally applicable requirements contained in this permit may also apply to emission units listed above.

3.2 Equipment Emission Caps and Operating Limits

3.2.1 The Permittee shall not fire any fuel other than natural gas in the steam generating units (emission unit IDs SG06, and SG07).
[391-3-1-.03(2)(c) and Avoidance of 40 CFR 51.1202, 391-3-1-.03(2)(g) subsumed,
391-3-1-.03(2)(sss) subsumed]

NOx Emission Limit For the 7-Plant Plan

3.2.2 The Permittee shall not discharge, or cause the discharge, into the atmosphere NOx emissions, including emissions occurring during startup and shutdown, from the combined operations of all affected units (emission unit IDs SG01, SG02, SG03, SG04 at Plant Bowen (AFS No. 015-00011); SG01, SG02, SG03, SG04 at Plant Branch (AFS No. 237-00008); SG01, SG02, SG03, SG04 at Plant Hammond (AFS No. 115-00003); SGM1, SGM2 at Plant McDonough (AFS No. 067-00003); SG01, SG02, SG03, SG04 at Plant Scherer (AFS No. 207-00008); SG01, SG02 at Plant Wansley (AFS No. 149-00001); and SG06, SG07 at Plant Yates (AFS No. 077-00001)) in excess of 32,335.8 tons during the ozone season. For purposes of this permit, the ozone season shall be defined as May 1 through September 30.
[391-3-1-.03(8)(c)1 and 391-3-1-.03(8)(c)15]

3.2.3 The Permittee shall not discharge into the atmosphere VOC emissions in excess of 121.5 tons per 12 consecutive months from the steam generating units (Emission Unit ID: SG06 and SG07) and the water bath heater (Emission Unit ID: WBH1), combined.
[NAA-NSR Avoidance; 40 CFR 52.21, 391-3-1-.03(c)13(ii)]

3.3 Equipment Federal Rule Standards**40 CFR 63 Subpart DDDDD**

3.3.1 The Permittee shall comply with all applicable provisions of the "National Emission Standards for Hazardous Air Pollutants" as found in 40 CFR Subpart A *General Provisions*, and 40 CFR 63 Subpart DDDDD, *National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers and Process Heaters*. The affected source includes Water Bath Heater WBH1, and is defined in 40 CFR 63.7490. In the event of any discrepancy between the terms of this Permit and 40 CFR 63 Subpart DDDDD, the terms of 40 CFR 63 Subpart DDDDD shall control.
[40 CFR 63 Subparts A and DDDDD]

3.3.2 The Permittee shall comply with the applicable work practice standards specified below in Table 3.3.2 for Water Bath Heater WBH1:
 [40 CFR 63.7500(a)(1), 63.7505(a), Table 3 to 40 CFR 63 Subpart DDDDD]

Table 3.3.2: Work Practice Standards for Water Bath Heater WBH1

If your unit is...	You must meet the following...
1. A new or existing boiler or process heater without a continuous oxygen trim system and with heat input capacity of less than 10 million Btu per hour in the unit designed to burn heavy liquid or unit designed to burn solid fuel subcategories; or a new or existing boiler or process heater with heat input capacity of less than 10 million Btu per hour, but greater than 5 million Btu per hour, in any of the following subcategories: unit designed to burn gas 1; unit designed to burn gas 2 (other); or unit designed to burn light liquid	Conduct a tune-up of the boiler or process heater biennially as specified in Condition 5.2.7.

3.4 Equipment SIP Rule Standards

3.4.1 The Permittee shall not discharge or cause the discharge into the atmosphere from the steam generating units with emission unit IDs SG06 and SG07 any gases which contain particulate matter in excess of 0.24 lb/MMBtu heat input.
 [391-3-1-.02(2)(d)1(iii)]

3.4.2 The Permittee shall not discharge or cause the discharge into the atmosphere from any steam generating units (emission unit IDs SG06 and SG07), or steam generating source comprised of such emission units, any gases which exhibit opacity equal to or greater than 40 percent.
 [391-3-1-.02(2)(b)]

NOx Emission Limits per Georgia Rule (jjj)

3.4.3 Except as indicated in Condition Nos. 3.4.5 and 3.4.6, the Permittee shall not discharge, or cause the discharge, into the atmosphere from SG06 at Plant Yates (AFS No. 077-00001), NOx emissions in excess of 0.26 lb/MMBtu heat input on a 30-day rolling averaging period. This shall apply during the period May 1 through September 30 of each year.
 [391-3-1-.02(2)(yy), 391-3-1-.02(2)(jjj)]

3.4.4 Except as indicated in Condition Nos. 3.4.5 and 3.4.6, the Permittee shall not discharge, or cause the discharge, into the atmosphere from SG07 at Plant Yates (AFS No. 077-00001), NOx emissions in excess of 0.26 lb/MMBtu heat input on a 30-day rolling averaging period. This shall apply during the period May 1 through September 30 of each year.
 [391-3-1-.02(2)(yy), 391-3-1-.02(2)(jjj)]

- 3.4.5 If the Permittee does not comply with Condition Nos. 3.4.3 or 3.4.4, the Permittee shall demonstrate that NOx emissions, averaged over all affected units (emission unit IDs SG01, SG02, SG03, SG04 at Plant Bowen (AFS No. 015-00011); SG01, SG02, SG03, SG04 at Plant Hammond (AFS No. 115-00003); SGM1, SGM2 at Plant McDonough (AFS No. 067-00003); SG01, SG02 at Plant Wansley (AFS No. 149-00001); and SG06, SG07 at Plant Yates (AFS No. 077-00001)), do not exceed 0.13 lb/MMBtu heat input on a 30-day rolling averaging period. This shall apply during the period May 1 through September 30 of each year.
[391-3-1-.02(2)(jjj)3(ii) and 391-3-1-.02(2)(yy)]
- 3.4.6 If the Permittee does not comply with Condition Nos. 3.4.3 or 3.4.4, the Permittee shall demonstrate that NOx emissions, averaged over all affected units (emission unit IDs SG01, SG02, SG03 and SG04 at Plant Bowen (AFS No. 015-00011); SG01, SG02, SG03, SG04 at Plant Branch (AFS No. 237-0008); SG01, SG02, SG03, SG04 at Plant Hammond (AFS No. 115-00003); SGM1, SGM2 at Plant McDonough (AFS No. 067-00003); SG01, SG02, SG03, SG04 at Plant Scherer (AFS No. 207-00008); SG01, SG02 at Plant Wansley (AFS No. 149-00001); and SG06, SG07 at Plant Yates (AFS No. 077-00001)), do not exceed 0.18 lb/MMBtu heat input on a 30-day rolling averaging period. This shall apply during the period May 1 through September 30 of each year.
[391-3-1-.02(2)(jjj)5(ii) and 391-3-1-.02(2)(yy)]
- 3.4.7 The Permittee shall not discharge or cause the discharge into the atmosphere from the water bath heater (Emission Unit ID: WBH1) any gases which exhibit opacity equal to or greater than 20 percent except for one six-minute period per hour of not more than 27 percent opacity.
[391-3-1-.02(2)(d)3, 391-3-1-.02(2)(b)(subsumed)]
- 3.4.8 The Permittee shall not discharge or cause the discharge into the atmosphere from the water bath heater (Emission Unit ID WBH1) any gases which contain particulate matter in excess of 0.5 lb/MMBtu heat input.
[391-3-1-.02(2)(d)2(i)]
- 3.4.9 The Permittee shall not fire any fuel other than natural gas in the water bath heater (Emission Unit ID: WBH1).
[391-3-1-.02(2)(g)2, 391-3-1-.02(2)(rrr)]
- 3.5 Equipment Standards Not Covered by a Federal or SIP Rule and Not Instituted as an Emission Cap or Operating Limit**

None Applicable.

PART 4.0 REQUIREMENTS FOR TESTING**4.1 General Testing Requirements**

- 4.1.1 The Permittee shall cause to be conducted a performance test at any specified emission unit when so directed by the Environmental Protection Division ("Division"). The test results shall be submitted to the Division within 60 days of the completion of the testing. Any tests shall be performed and conducted using methods and procedures that have been previously specified or approved by the Division.
[391-3-1-.02(6)(b)1(i)]
- 4.1.2 The Permittee shall provide the Division thirty (30) days (or sixty (60) days for tests required by 40 CFR Part 63) prior written notice of the date of any performance test(s) to afford the Division the opportunity to witness and/or audit the test, and shall provide with the notification a test plan in accordance with Division guidelines.
[391-3-1-.02(3)(a) and 40 CFR 63.7(b)(1)]
- 4.1.3 Performance and compliance tests shall be conducted and data reduced in accordance with applicable procedures and methods specified in the Division's Procedures for Testing and Monitoring Sources of Air Pollutants. The methods for the determination of compliance with emission limits listed under Sections 3.2, 3.3, 3.4 and 3.5 are as follows:
- a. Method 1 for the determination of sample point locations,
 - b. Method 2 for the determination of stack gas flow rate,
 - c. Method 3 or 3A for the determination of stack gas molecular weight,
 - d. Method 3A or 3B for the determination of the emissions rate correction factor for excess air,
 - e. Method 4 for the determination of stack gas moisture,
 - f. Method 5 or Method 17 as applicable for the determination of particulate matter concentration,
 - g. Method 6 or 6C for the determination of sulfur dioxide concentration,
 - h. Method 9 and the procedures contained in Section 1.3 of the above reference document for the visual determination of opacity,
 - i. Method 19 when applicable, to convert particulate matter, carbon monoxide, sulfur dioxide, and nitrogen oxides concentrations (i.e. grains/dscf for PM, ppm for gaseous pollutants), as determined using other methods specified in this section, to emission rates (i.e. lb/MMBtu),

- j. The procedures contained in Section 2.116.2 of the above-referenced document shall be used for the determination of nitrogen oxides concentration from the steam generating units with emission units ID Nos. SG06 and SG07 for purposes of verifying compliance with Georgia Rule 391-3-1-.02(2)(jjj),
- k. Method 7E for the determination of nitrogen oxides concentration for purposes other than verifying compliance with Georgia Rule 391-3-1-.02(2)(jjj),
- m. Method 25A for the determination of volatile organic compounds,

Minor changes in methodology may be specified or approved by the Director or his designee when necessitated by process variables, changes in facility design, or improvement or corrections that, in his opinion, render those methods or procedures, or portions thereof, more reliable.

[391-3-1-.02(3)(a)]

- 4.1.4 The Permittee shall submit performance test results to the US EPA's Central Data Exchange (CDX) using the Compliance and Emissions Data Reporting Interface (CEDRI) in accordance with any applicable NSPS or NESHAP standards (40 CFR 60 or 40 CFR 63) that contain Electronic Data Reporting Requirements. This Condition is only applicable if required by an applicable standard and for the pollutant(s) subject to said standard.
[391-3-1-.02(8)(a) and 391-3-1-.02(9)(a)]

State Only Enforceable

- 4.1.5 The Permittee shall provide, with the notification required under Condition 4.1.2, a test plan in accordance with Division guidelines.
[391-3-1-.02(3)(a)]

4.2 Specific Testing Requirements

None applicable.

PART 5.0 REQUIREMENTS FOR MONITORING (Related to Data Collection)**5.1 General Monitoring Requirements**

5.1.1 Any continuous monitoring system required by the Division and installed by the Permittee shall be in continuous operation and data recorded during all periods of operation of the affected facility except for continuous monitoring system breakdowns and repairs. Monitoring system response, relating only to calibration checks and zero and span adjustments, shall be measured and recorded during such periods. Maintenance or repair shall be conducted in the most expedient manner to minimize the period during which the system is out of service.

[391-3-1-.02(6)(b)1]

5.2 Specific Monitoring Requirements

5.2.1 The Permittee shall install, calibrate, maintain, and operate a system to continuously monitor and record the indicated pollutants on the following equipment. Each system shall meet the applicable performance specification(s) of the Division's monitoring requirements.

[391-3-1-.02(6)(b)1 and 40 CFR 70.6(a)(3)(i)]

a. A continuous emissions monitoring system (CEMS) for the measurement of nitrogen oxides concentration (ppm) and diluent concentrations (either Oxygen or Carbon Dioxide, percent), on each steam generating source (Emission Units SG06 and SG07). The output of the CEMS shall be expressed in terms of pounds per million British thermal units (lb/MMBtu).

5.2.2 The Permittee shall install, calibrate, maintain, and operate a system to continuously monitor the oxidation catalyst inlet temperature on steam generating units with emission unit IDs SG06 and SG07. Data shall be recorded continuously.

[391-3-1-.02(6)(b)1, 40 CFR 70.6(a)(3)(i), NAA/NSR Avoidance, PSD Avoidance for VOC]

5.2.3 The Permittee shall install, calibrate, maintain, and operate a system to continuously monitor the quantity of natural gas, in cubic feet on steam generating units with emission unit IDs SG06 and SG07. Data shall be recorded continuously.

[391-3-1-.02(6)(b)1, 40 CFR 70.6(a)(3)(i), NAA/NSR Avoidance, PSD Avoidance for VOC]

5.2.4 The Permittee shall install, calibrate, maintain, and operate a system to continuously monitor the quantity of natural gas, in cubic feet on the water bath heater (Emission Unit ID: WBH1). Data shall be recorded continuously.

[391-3-1-.02(6)(b)1, 40 CFR 70.6(a)(3)(i), NAA/NSR Avoidance, PSD Avoidance for VOC]

Title V Permit

- 5.2.5 The Permittee shall perform an annual tune-up on water bath heater WBH1 using the following procedures:
[391-3-1-.02(2)(rrr)]
- a. The tune-up shall be performed no earlier than February 1 and no later than May 1 of each calendar year. Should an affected unit become operational during the ozone season for the first time, a tune-up shall be performed within the first 120 hours of operation of the unit.
 - b. The annual tune-up shall be performed using the manufacturer's recommended settings for reduced Nitrogen Oxides (NOx) emissions, or using a NOx analyzer, so that NOx emissions are minimized in a manner consistent with good combustion practices and safe fuel-burning equipment operation.
 - c. If the Permittee elects to use a NOx analyzer, measurements of NOx and oxygen shall be conducted using the procedures of ASTM D 6522, Determination of Nitrogen Oxides, Carbon Monoxide, and Oxygen Emissions from Natural Gas-Fired Engines, Boilers and Process Heaters Using Portable Analyzers. The duration of each measurement shall be for a minimum of 30 minutes. In lieu of using the procedures of ASTM D 6522, measurements of Nitrogen Oxides and Oxygen can be made using the procedures of Methods 7E and 3A, respectively, or CTM030, listed in Condition 4.1.3.
 - d. During the tune-up, fuel-burning unit operating parameters shall be adjusted until NOx emissions are minimized in a manner consistent with good combustion practices and safe fuel-burning equipment operation. A minimum of three test runs is required to show that NOx emissions are minimized.
 - e. The Permittee shall maintain records of all tune-ups that are required to be performed by this condition. These records shall include the date and time the tune-up was performed, the burner settings which were determined to minimize NOx emissions, and an explanation regarding how those settings were determined. This information shall be kept as part of the tune-up, maintenance and adjustment records. All records required by this subparagraph shall be retained available for inspection or submittal either in written or electronic form.
 - f. Following the tune-up, during the ozone season each year, the Permittee shall operate each affected unit using the settings determined during the annual tune-up. If no parameters can be monitored to indicate the performance of a specific unit, the Permittee shall certify that no adjustments have been made to the unit by the Permittee and/or third party since the measurements as specified in Paragraph b. of this condition were conducted. This certification shall be made in writing, no later than October 15 of each year, and shall be maintained with the records required by Paragraph e. of this condition.

Title V Permit

- g. As an alternative to complying with the requirements in paragraphs a. through f., the Permittee may submit documentation no later than April 30 of each year confirming that an affected unit will not be operated during the ozone season. As a minimum, the documentation shall include the identification of the facility, the permit number, and the specific affected units that will not be operated.
- h. As an alternative to complying with the requirements in paragraphs a. through g., the Permittee may elect to comply with the requirements of Georgia Rule 391-3-1-.02(2)(yy).

5.2.6 The Permittee shall test the effectiveness of each oxidation catalyst (Air Pollution Control Device IDs: OC06 and OC07) every 16,000 operating hours. Testing protocol for the tests should be submitted to the Division no less than 30 days prior to the test and results should be provided to the Division no later than 60 days after the conclusion of the test. [391-3-1-.02(6)(b)1, 40 CFR 70.6(a)(3)(i), NAA/NSR Avoidance, PSD Avoidance for VOC]

5.2.7 The Permittee shall conduct a tune-up of the Water Bath Heater 1 (Emission Unit ID WBH1) every 2 years to demonstrate compliance with the following paragraphs (a)-(g) below. Each biennial tune-up must be conducted no more than 25 months after the previous tune-up. For a new or reconstructed affected source (as defined in §63.7490), the first biennial tune-up must be not later than 25 months after the initial startup of the new or reconstructed affected source. [40 CFR 63.7500(c) and 40 CFR 63.7540(a)(10), (a)(12), and (a)(13), 63.7515(d)]

- a. As applicable, inspect the burner, and clean or replace any components of the burner as necessary. The Permittee may delay the burner inspection until the next scheduled unit shutdown. At units where entry into a piece of process equipment or into a storage vessel is required to complete the tune-up inspections, inspections are required only during planned entries into the storage vessel or process equipment.
- b. Inspect the flame pattern, as applicable, and adjust the burner as necessary to optimize the flame pattern. The adjustment should be consistent with the manufacturer's specifications, if available.
- c. Inspect the system controlling the air-to-fuel ratio, as applicable, and ensure that it is correctly calibrated and functioning properly. The inspection may be delayed until the next scheduled unit shutdown.
- d. Optimize total emissions of CO. This optimization should be consistent with the manufacturer's specifications, if available, and with any nitrogen oxide requirement to which the unit is subject.
- e. Measure the concentrations in the effluent stream of CO in parts per million, by volume, and oxygen in volume percent, before and after the adjustments are made (measurements may be either on a dry or wet basis, as long as it is the same basis before and after the adjustments are made). Measurements may be taken using a portable CO analyzer.

Title V Permit

- f. Maintain on-site and submit, if requested by the Division, a report containing the following:
- i. The concentrations of CO in the effluent stream in parts per million, by volume, and oxygen in volume percent, measured at high fire or typical operating load, before and after the tune-up of the boiler or process heater.
 - ii. A description of any corrective actions taken as a part of the tune-up of the boiler or process heater.
 - iii. The type and amount of fuel used over the 12 months prior to the tune-up of the boiler or process heater, but only if the unit was physically and legally capable of using more than one type of fuel during that period. Units sharing a fuel meter may estimate the fuel used by each unit.
- g. If the unit is not operating on the required date for a tune-up, the tune-up must be conducted within 30 calendar days of startup.

PART 6.0 RECORD KEEPING AND REPORTING REQUIREMENTS**6.1 General Record Keeping and Reporting Requirements**

6.1.1 Unless otherwise specified, all records required to be maintained by this Permit shall be recorded in a permanent form suitable for inspection and submission to the Division and to the EPA. The records shall be retained for at least five (5) years following the date of entry.

[391-3-1-.02(6)(b)1(i) and 40 CFR 70.6(a)(3)]

6.1.2 In addition to any other reporting requirements of this Permit, the Permittee shall report to the Division in writing, within seven (7) days, any deviations from applicable requirements associated with any malfunction or breakdown of process, fuel burning, or emissions control equipment for a period of four hours or more which results in excessive emissions.

The Permittee shall submit a written report that shall contain the probable cause of the deviation(s), duration of the deviation(s), and any corrective actions or preventive measures taken.

[391-3-1-.02(6)(b)1(iv), 391-3-1-.03(10)(d)1(i) and 40 CFR 70.6(a)(3)(iii)(B)]

6.1.3 The Permittee shall submit written reports of any failure to meet an applicable emission limitation or standard contained in this permit and/or any failure to comply with or complete a work practice standard or requirement contained in this permit which are not otherwise reported in accordance with Conditions 6.1.4 or 6.1.2. Such failures shall be determined through observation, data from any monitoring protocol, or by any other monitoring which is required by this permit. **The reports shall cover each semiannual period ending June 30 and December 31 of each year, shall be postmarked by August 29 and February 28, respectively following each reporting period,** and shall contain the probable cause of the failure(s), duration of the failure(s), and any corrective actions or preventive measures taken.

[391-3-1-.03(10)(d)1.(i) and 40 CFR 70.6(a)(3)(iii)(B)]

6.1.4 The Permittee shall submit a written report containing any excess emissions, exceedances, and/or excursions as described in this permit and any monitor malfunctions for each quarterly period ending March 31, June 30, September 30, and December 31 of each year. **All reports shall be postmarked by May 30, August 29, November 29, and February 28, respectively following each reporting period.** In the event that there have not been any excess emissions, exceedances, excursions or malfunctions during a reporting period, the report should so state. Otherwise, the contents of each report shall be as specified by the Division's Procedures for Testing and Monitoring Sources of Air Pollutants and shall contain the following:

[391-3-1-.02(6)(b)1 and 40 CFR 70.6(a)(3)(iii)(A)]

a. A summary report of excess emissions, exceedances and excursions, and monitor downtime, in accordance with Section 1.5(c) and (d) of the above referenced document, including any failure to follow required work practice procedures.

b. Total process operating time during each reporting period.

Title V Permit

- c. The magnitude of all excess emissions, exceedances and excursions computed in accordance with the applicable definitions as determined by the Director, and any conversion factors used, and the date and time of the commencement and completion of each time period of occurrence.
- d. Specific identification of each period of such excess emissions, exceedances, and excursions that occur during startups, shutdowns, or malfunctions of the affected facility. Include the nature and cause of any malfunction (if known), the corrective action taken or preventive measures adopted.
- e. The date and time identifying each period during which any required monitoring system or device was inoperative (including periods of malfunction) except for zero and span checks, and the nature of the repairs, adjustments, or replacement. When the monitoring system or device has not been inoperative, repaired, or adjusted, such information shall be stated in the report.
- f. Certification by a Responsible Official that, based on information and belief formed after reasonable inquiry, the statements and information in the report are true, accurate, and complete.

6.1.5 Where applicable, the Permittee shall keep the following records:
[391-3-1-.03(10)(d)1(i) and 40 CFR 70.6(a)(3)(ii)(A)]

- a. The date, place, and time of sampling or measurement;
- b. The date(s) analyses were performed;
- c. The company or entity that performed the analyses;
- d. The analytical techniques or methods used;
- e. The results of such analyses; and
- f. The operating conditions as existing at the time of sampling or measurement.

6.1.6 The Permittee shall maintain files of all required measurements, including continuous monitoring systems, monitoring devices, and performance testing measurements; all continuous monitoring system or monitoring device calibration checks; and adjustments and maintenance performed on these systems or devices. These files shall be kept in a permanent form suitable for inspection and shall be maintained for a period of at least five (5) years following the date of such measurements, reports, maintenance and records.
[391-3-1-.03(10)(d)1(i) and 40 CFR 70.6 (a)(3)(ii)(B)]

- 6.1.7 For the purpose of reporting excess emissions, exceedances or excursions in the report required in Condition 6.1.4, the following excess emissions, exceedances, and excursions shall be reported:
[391-3-1-.02(6)(b)1 and 40 CFR 70.6(a)(3)(i)]
- a. Excess emissions: (means for the purpose of this Condition and Condition 6.1.4, any condition that is detected by monitoring or record keeping which is specifically defined, or stated to be, excess emissions by an applicable requirement)
 - i. Excess emissions of nitrogen oxides as described in Condition 6.2.6.
 - b. Exceedances: (means for the purpose of this Condition and Condition 6.1.4, any condition that is detected by monitoring or record keeping that provides data in terms of an emission limitation or standard and that indicates that emissions (or opacity) do not meet the applicable emission limitation or standard consistent with the averaging period specified for averaging the results of the monitoring)
 - i. An ozone season (defined as May 1 through September 30) total NO_x emission rate which exceeds 32,335.8 tons from the applicable equipment specified in Condition 3.2.2.
 - ii. Any time fuel other than natural gas is fired in any steam generating unit (emission unit IDs SG06 and SG07).
 - iii. Any period where VOC emissions are in excess of 121.5 tons per 12-month consecutive months from steam generating units (Emission Unit ID: SG06 and SG07) and the water bath heater (Emission Unit ID: WBH1), combined.
 - iv. Any time fuel other than natural gas is fired in the water bath heater (Emission Unit ID: WBH1).
 - c. Excursions: (means for the purpose of this Condition and Condition 6.1.4, any departure from an indicator range or value established for monitoring consistent with any averaging period specified for averaging the results of the monitoring)
 - i. Any three-hour block average during which the catalyst inlet temperature on Unit 6 (Emission unit ID SG06) or Unit 7 (Emission Unit ID: SG07) is less than 400°F, except during startup, shutdown, or malfunction. A three-hour block average shall be defined for the purpose of this permit as any one of the eight consecutive three-hour time periods between 12:00 midnight and the following midnight.
 - ii. Any failure to conduct the tune-up required by Condition 5.2.5b, or any operation of any fuel-burning equipment with Emission Unit ID WBH1 during the ozone season (May 1 - September 30), reported to not be operated in accordance with Condition 5.2.5g.

- d. In addition to the excess emissions, exceedances and excursions specified above, the following should also be included with the report required in Condition 6.1.4:
- i. Any failure to comply with the work practice standards for 40 CFR 63 Subpart DDDDD required by Condition 5.2.7.

6.1.8 The Permittee shall provide the Division with a statement, in such form as the Director may prescribe, showing the actual emissions of nitrogen oxides and volatile organic compounds from the entire facility. These statements shall be submitted every year by the date specified in 391-3-1-.02(6)(a)4 and shall show the actual emissions of the previous calendar year.

[391-3-1-.02(6)(b)1(i)]

6.2 Specific Record Keeping and Reporting Requirements

6.2.1 State Only Enforceable Condition.

The Permittee shall retain monthly records of all fuel burned in the steam generating units (emission unit IDs SG06 and SG07). The records shall be available for inspection or submittal to the Division, upon request, and contain the following:

[391-3-1-.02(6)(b)1(i)]

- a. Quantity (cubic feet) of natural gas burned.

6.2.2 For each shipment of fuel oil received, the Permittee shall obtain from the supplier of the fuel oil, a statement certifying that the oil complies with the specifications of fuel oil contained in ASTM D 396, ASTM D 975 and ASTM D 6751. As an alternative to the procedure described above, the Permittee may, for each shipment of fuel oil received, obtain a sample for analysis of the sulfur content. The procedures of ASTM D 4057 shall be used to acquire the sample. Sulfur content shall be determined using the procedures of Test Method ASTM D 129, ASTM D 1552, or by some other test method approved by the US EPA and acceptable to the Division.

[391-3-1-.02(6)(b)1 and 40 CFR 70.6(a)(3)(i)]

Record Keeping Requirements for the Ozone Season NOx Emission Caps

6.2.3 The Permittee shall use the data obtained from the NOx CEMS to compute the monthly mass emission rate, in tons per calendar month, of NOx from the following coal-fired steam generating units on a combined basis: emission unit IDs SG01, SG02, SG03, and SG04 at Plant Bowen (AFS No. 015-00011); emission unit IDs SG01, SG02, SG03, and SG04 at Plant Branch (AFS No. 237-00008); emission unit IDs SG01, SG02, SG03, and SG04 at Plant Hammond (AFS No. 115-00003); emission unit IDs SGM1 and SGM2 at Plant McDonough (AFS No. 067-00003); emission unit IDs SG01, SG02, SG03, SG04 at Plant Scherer (AFS No. 207-00008); emission unit IDs SG01 and SG02 at Plant Wansley (AFS No. 149-00001); emission unit IDs SG06 and SG07 at Plant Yates (AFS No. 077-00001). This emission rate must include emissions from startup, shutdown, and malfunction. This condition only applies during the ozone season (May 1 to September 30).
[391-3-1-.02(6)(b)1 and 40 CFR 70.6(a)(3)(i)]

6.2.4 The Permittee shall use the records required by Condition 6.2.3 to determine the ozone season total emission rate, in tons, of NOx from the following coal-fired steam generating units on a combined basis: emission unit IDs SG01, SG02, SG03, and SG04 at Plant Bowen (AFS No. 015-00011); emission unit IDs SG01, SG02, SG03, and SG04 at Plant Branch (AFS No. 237-00008); emission unit IDs SG01, SG02, SG03, and SG04 at Plant Hammond (AFS No. 115-00003); emission unit IDs SGM1 and SGM2 at Plant McDonough (AFS No. 067-00003); emission unit IDs SG01, SG02, SG03, SG04 at Plant Scherer (AFS No. 207-00008); emission unit IDs SG01 and SG02 at Plant Wansley (AFS No. 149-00001); emission unit IDs SG06 and SG07 at Plant Yates (AFS No. 077-00001). This emission rate must include emissions from startup, shutdown, and malfunction.
[391-3-1-.02(6)(b)1 and 40 CFR 70.6(a)(3)(i)]

Record Keeping for the Verification of Georgia Rule (jjj) NOx Emission Limits

6.2.5 The Permittee shall determine compliance with the NOx emissions limitations in Condition Nos. 3.4.3 through 3.4.6 using emissions data acquired by the NOx CEMS. The 30-day rolling average shall be determined as follows:
[391-3-1-.02(6)(b)1(i) and 40 CFR 70.6(a)(3)(i)]

- a. The first 30-day averaging period shall begin on the first operating day of the ozone season.
- b. The 30-day average shall be the average of all valid hours of NOx emissions data for any 30 successive operating days during the period of the ozone season.
- c. The last 30-day averaging period shall end on the last operating day of the ozone season.
- d. After the first 30-day average, a new 30-day rolling average shall be calculated after each operating day.

- e. For the purpose of this Permit, an operating day is a 24 hour period between 12:00 midnight and the following midnight during which any fuel is combusted at any time. It is not necessary for the fuel to be combusted continuously for the entire 24-hour period.

Reporting Requirements

- 6.2.6 The Permittee shall determine compliance with the limitation using the procedures of Section 2.116.2 of the Division's **Procedures for Testing and Monitoring Sources of Air Pollutants**. The Permittee shall maintain the records specified in Section 2.116.4 of the aforementioned procedures document and use these records to prepare a quarterly report. Reportable emissions are any calculated 30-day rolling average NOx emissions rate which exceeds the limit established in Condition Nos. 3.4.3 through 3.4.4, whichever is applicable. Excess emissions are those that exceed an area-wide average limit in Condition No. 3.4.5 or Condition No. 3.4.6 as well as the source's respective Alternative Emission Limitation as specified in Condition Nos. 3.4.3 through 3.4.4, whichever is applicable.
[391-3-1-.02(6)(b)1 and 40 CFR 70.6(a)(3)(i)]
- 6.2.7 The Permittee shall submit written reports to the Division of reportable emissions under Condition 6.2.6 (excess emissions would be reported per Condition 6.1.7) for each calendar quarter ending June 30 (April excluded) and September 30. **All reports shall be postmarked by August 29 and November 29, respectively following each reporting period.** In the event that there have not been any reportable emissions during a reporting period, the report should state as such. The Permittee shall determine compliance with the limitation using the procedures of Section 2.116.2 of the Division's Procedures for Testing and Monitoring Sources of Air Pollutants. The Permittee shall maintain the records specified in Section 2.116.4 of the aforementioned procedures document and use these records to prepare a quarterly report. Reportable emissions are any calculated 30-day rolling average NOx emissions rate which exceeds the limit established in Condition Nos. 3.4.3 through 3.4.4, whichever is applicable. Excess emissions are those that exceed an area-wide average limit in Condition No. 3.4.5 or Condition No. 3.4.6 as well as the source's respective Alternative Emission Limitation as specified in Condition Nos. 3.4.3 through 3.4.4, whichever is applicable.
[391-3-1-.02(6)(b)1 and 40 CFR 70.6(a)(3)(i)]
- 6.2.8 The Permittee may submit, via electronic media, any report required by Part 6.0 of this permit provided such format has been approved by the Division.
[391-3-1-.02(6)(b)]
- 6.2.9 The Permittee shall submit results of each RATA required under Section 2.125.3(j) of the Division's **Procedures of Monitoring and Testing of Air Pollutants** within 60 days of the completion of RATA.
[391-3-1-.02(6)(b)]

Title V Permit

- 6.2.10 The Permittee shall calculate VOC emissions on a monthly basis for steam generating units SG06 and SG07, based upon the quantity of fuel burned (Required by Condition 6.2.1) and the emission rate recorded by the initial performance test. These records shall be available for inspection or submittal to the Division upon request.
[391-3-1-.02(6)(b)1, NAA/NSR Avoidance and 40 CFR 70.6(a)(3)(i)]
- 6.2.11 The Permittee shall calculate VOC emissions on a monthly basis for water heater bath WBH1, based upon the quantity of fuel burned (Required by Condition 6.2.1) and a Division-approved emission rate. These records shall be available for inspection or submittal to the Division upon request.
[391-3-1-.02(6)(b)1, NAA/NSR Avoidance and 40 CFR 70.6(a)(3)(i)]
- 6.2.12 The Permittee shall use the monthly VOC records required by Condition 6.2.10 to calculate the twelve consecutive month total emission rate for each emission unit. A twelve consecutive month total shall be the total for a month in the reporting period plus the totals for the previous eleven consecutive months. These records shall be available for inspection or submittal to the Division upon request.
[391-3-1-.02(6)(b)1, NAA/NSR Avoidance and 40 CFR 70.6(a)(3)(i)]
- 6.2.13 The Permittee shall maintain records of all tune-ups, maintenance, and adjustments made to the water heater (Emission Unit ID WBH1). All documents and calculations used to determine reduced NOx boiler settings should be kept as part of the tune-up, maintenance, and adjustments records. These records shall include burner settings that affect NOx emissions and how the settings were determined.
[391-3-1-.02(6)(b)1]
- 6.2.14 Every 2 years, beginning January 31, 2017, the Permittee shall prepare and submit to the Division by January 31, a compliance report covering the 2-year period, January 1-December 31, since the previous reporting period, containing the information specified below for WBH1. The first reporting period shall cover from February 26, 2015 to December 31, 2016 and shall be submitted by January 31, 2017.
[40 CFR 63.7550(b) and (c)(1)]
- a. Company and Facility name and address.
 - b. Process unit information
 - c. Date of report and beginning and end dates of the reporting period.
 - d. The date of the most recent tune-up for each unit, including the date of the most recent burner inspection if delayed from the 2-year schedule.
 - e. A statement by a responsible official with official's name, title, and signature, certifying the truth, accuracy, and completeness of the content of the report.

Title V Permit

- 6.2.15 The Permittee shall maintain the following records for Water Bath Heater 1 (WBH1):
[40 CFR 63.7555(a)]
- a. A copy of each notification and report that the Permittee submitted to comply with 40 CFR 63 Subpart DDDDD, including all documentation supporting any Initial Notification or 2-year compliance report that was submitted.
 - b. The tune-up reports required by 5.2.7.
- 6.2.16 The Permittee must maintain the records required in Condition 6.2.15 in a form suitable and readily available for expeditious review. The facility must keep each record for 5 years following the date of each recorded action. The facility must keep each record on-site or be accessible from a central location by computer or other means that instantly provide access at the site for at least 2 years after the date of each recorded action. The facility may keep the record off site for the remaining 3 years.
[40 CFR 63.7560]

PART 7.0 OTHER SPECIFIC REQUIREMENTS**7.1 Operational Flexibility**

7.1.1 The Permittee may make Section 502(b)(10) changes as defined in 40 CFR 70.2 without requiring a Permit revision, if the changes are not modifications under any provisions of Title I of the Federal Act and the changes do not exceed the emissions allowable under the Permit (whether expressed therein as a rate of emissions or in terms of total emissions). For each such change, the Permittee shall provide the Division and the EPA with written notification as required below in advance of the proposed changes and shall obtain any Permits required under Rules 391-3-1-.03(1) and (2). The Permittee and the Division shall attach each such notice to their copy of this Permit.
[391-3-1-.03(10)(b)5 and 40 CFR 70.4(b)(12)(i)]

- a. For each such change, the Permittee's written notification and application for a construction Permit shall be submitted well in advance of any critical date (typically at least 3 months in advance of any commencement of construction, Permit issuance date, etc.) involved in the change, but no less than seven (7) days in advance of such change and shall include a brief description of the change within the Permitted facility, the date on which the change is proposed to occur, any change in emissions, and any Permit term or condition that is no longer applicable as a result of the change.
- b. The Permit shield described in Condition 8.16.1 shall not apply to any change made pursuant to this condition.

7.2 Off-Permit Changes

7.2.1 The Permittee may make changes that are not addressed or prohibited by this Permit, other than those described in Condition 7.2.2 below, without a Permit revision, provided the following requirements are met:
[391-3-1-.03(10)(b)6 and 40 CFR 70.4(b)(14)]

- a. Each such change shall meet all applicable requirements and shall not violate any existing Permit term or condition.
- b. The Permittee must provide contemporaneous written notice to the Division and to the EPA of each such change, except for changes that qualify as insignificant under Rule 391-3-1-.03(10)(g). Such written notice shall describe each such change, including the date, any change in emissions, pollutants emitted, and any applicable requirement that would apply as a result of the change.
- c. The change shall not qualify for the Permit shield in Condition 8.16.1.
- d. The Permittee shall keep a record describing changes made at the source that result in emissions of a regulated air pollutant subject to an applicable requirement, but not otherwise regulated under the Permit, and the emissions resulting from those changes.

7.2.2 The Permittee shall not make, without a Permit revision, any changes that are not addressed or prohibited by this Permit, if such changes are subject to any requirements under Title IV of the Federal Act or are modifications under any provision of Title I of the Federal Act.
[Rule 391-3-1-.03(10)(b)7 and 40 CFR 70.4(b)(15)]

7.3 Alternative Requirements

[White Paper #2]

Not Applicable.

7.4 Insignificant Activities

(see Attachment B for the list of Insignificant Activities in existence at the facility at the time of permit issuance)

7.5 Temporary Sources

[391-3-1-.03(10)(d)5 and 40 CFR 70.6(e)]

Not Applicable.

7.6 Short-term Activities

(see Form D5 "Short Term Activities" of the Permit application and White Paper #1)

7.6.1 The Permittee shall maintain records of the duration and frequency of the following Short-term Activities:

[391-3-1-.02(2)(a)1]

- a. Sand blasting for maintenance purposes.
- b. Asbestos removal in accordance with Georgia Rule 391-3-1-.02(9)(b)7.

7.7 Compliance Schedule/Progress Reports

[391-3-1-.03(10)(d)3 and 40 CFR 70.6(c)(4)]

Not Applicable.

7.8 Emissions Trading

[391-3-1-.03(10)(d)1(ii) and 40 CFR 70.6(a)(10)]

Not Applicable.

7.9 Acid Rain Requirements

Facility ORIS code: 728

Effective: January 1, 2015 through December 31, 2019

- 7.9.1 Emissions which exceed any allowances that the Permittee lawfully holds under Title IV of the 1990 CAAA, or the regulations promulgated thereunder, are expressly prohibited.
[40 CFR 70.6(a)(4)]
- 7.9.2 Permit revisions are not required for increases in emissions that are authorized by SO₂ allowances acquired pursuant to the State's Acid Rain Program, provided that such increases do not require a permit revision under any other applicable requirement.
[40 CFR 70.6(a)(4)(i)]
- 7.9.3 This Permit does not place limits on the number of SO₂ allowances the Permittee may hold. However, the Permittee may not use allowances as a defense to noncompliance with any other applicable requirement.
[40 CFR 70.6(a)(4)(ii)]
- 7.9.4 Any SO₂ allowances held by the Permittee shall be accounted for according to the procedures established in regulations promulgated under Title IV of the 1990 CAAA.
[40 CFR 70.6(a)(4)(iii)]
- 7.9.5 Each affected unit, with the exceptions specified in 40 CFR 72.9(g)(6), operated in accordance with the Acid Rain portion of this Permit shall be deemed to be operating in compliance with the Acid Rain Program.
[40 CFR 70.6(f)(3)(iii)]
- 7.9.6 Where an applicable requirement is more stringent than an applicable requirement of regulations promulgated under Title IV of the 1990 CAAA, both provisions shall be incorporated into the Permit and shall be enforceable.
[40 CFR 70.6(a)(1)(ii)]

Title V Permit

7.9.7 The Permittee shall comply with all applicable provisions of 40 CFR 70.6(a)(4): Emissions which exceed any allowances that the Permittee lawfully holds under Title IV of the 1990 CAAA, or the regulations promulgated thereunder, are expressly prohibited for the operation of the Steam Generating Units 6-7 (Emission Unit IDs SG06-SG07).
 [40 CFR 70.6(a)(4), 40 CFR 73 (SO₂), and 40 CFR 76 (NO_x)]

SO₂ Allocations and NO_x Requirements for Each Affected Unit

			2015	2016	2017	2018	2019
EMISSION UNIT ID	EPA ID	SO ₂ Allowances	10696	10696	10696	10696	10696
SG06	Y6BR	NO _x Limit	The standard annual average NO _x limit for a Phase I tangentially fired boiler is 0.45 lb/mmBtu. In lieu of this limit, the Permittee may comply with 40 CFR Part 76 by complying with an approved Phase II NO _x averaging plan as described below.				

Pursuant to 40 CFR 76.11, Georgia EPD approves the 2016 NO_x emissions averaging plan for this unit, effective for one calendar year. Under each plan, this unit's NO_x emissions shall not exceed the annual average alternative contemporaneous emission limitation of **0.33 lb/MMBtu**. In addition, this unit shall not have an annual heat input less than **1,370,683 MMBtu**.

Under the plan, the actual Btu-weighted annual average NO_x emission rate for the units in the plan shall be less than or equal to the Btu-weighted annual average NO_x emission rate for the same units had they each been operated, during the same period of time, in compliance with the applicable emission limitations under 40 CFR 76.5, 76.6, or 76.7, except that for any early election units, the applicable emission limitations shall be under 40 CFR 76.7. If the designated representative demonstrates that the requirement of the prior sentence (as set forth in 40 CFR 76.11(d)(1)(ii)(A)) is met for a year under the plan, then this unit shall be deemed to be in compliance for that year with its alternative contemporaneous annual emission limitation and annual heat input limit.

In accordance with 40 CFR 72.40(b)(2), approval of the averaging plan shall be final only when the Mississippi Department of Environmental Quality, the Alabama Department of Environmental Management, the Florida Department of Environmental Protection, and the Jefferson County Department of Health (Alabama) have also approved this averaging plan.

In addition to the described NO_x compliance plan, this unit shall comply with all other applicable requirements of 40 CFR part 76, including the duty to reapply for a NO_x compliance plan and requirements covering excess emissions.

Title V Permit

			2015	2016	2017	2018	2019
EMISSION UNIT ID	EPA ID	SO ₂ Allowances	10521	10521	10521	10521	10521
SG07	Y7BR	NO _x Limit	The standard annual average NO _x limit for a Phase I tangentially fired boiler is 0.45 lb/mmBtu. In lieu of this limit, the Permittee may comply with 40 CFR Part 76 by complying with an approved Phase II NO _x averaging plan as described below.				

Pursuant to 40 CFR 76.11, Georgia EPD approves the 2016 NO_x emissions averaging plan for this unit, effective for one calendar year. Under each plan, this unit's NO_x emissions shall not exceed the annual average alternative contemporaneous emission limitation of **0.30 lb/MMBtu**. In addition, this unit shall not have an annual heat input less than **363,304 Btu**.

Under the plan, the actual Btu-weighted annual average NO_x emission rate for the units in the plan shall be less than or equal to the Btu-weighted annual average NO_x emission rate for the same units had they each been operated, during the same period of time, in compliance with the applicable emission limitations under 40 CFR 76.5, 76.6, or 76.7, except that for any early election units, the applicable emission limitations shall be under 40 CFR 76.7. If the designated representative demonstrates that the requirement of the prior sentence (as set forth in 40 CFR 76.11(d)(1)(ii)(A)) is met for a year under the plan, then this unit shall be deemed to be in compliance for that year with its alternative contemporaneous annual emission limitation and annual heat input limit.

In accordance with 40 CFR 72.40(b)(2), approval of the averaging plan shall be final only when the Mississippi Department of Environmental Quality, the Alabama Department of Environmental Management, the Florida Department of Environmental Protection, and the Jefferson County Department of Health (Alabama) have also approved this averaging plan.

In addition to the described NO_x compliance plan, this unit shall comply with all other applicable requirements of 40 CFR part 76, including the duty to reapply for a NO_x compliance plan and requirements covering excess emissions.

Note: The number of allowances allocated to Phase II affected units by U.S. EPA may change as a result of revisions to 40 CFR Part 73. In addition, the number of allowances actually held by an affected source in a unit account may differ from the number allocated by U.S. EPA. Neither of the aforementioned conditions necessitate a revision to the unit SO₂ allowance allocations identified in this permit (See CFR 72.84).

Title V Permit

- 7.9.8 Permit Application: The Phase II Acid Rain permit application submitted for this source, as corrected by the State of Georgia, is attached as part of this Permit. The owners and operators of the source must comply with the standard requirements and special provisions set forth in the application.
[40 CFR 72.50(a)(1)]

7.10 Prevention of Accidental Releases (Section 112(r) of the 1990 CAAA) [391-3-1-.02(10)]

- 7.10.1 When and if the requirements of 40 CFR Part 68 become applicable, the Permittee shall comply with all applicable requirements of 40 CFR Part 68, including the following.
- a. The Permittee shall submit a Risk Management Plan (RMP) as provided in 40 CFR 68.150 through 68.185. The RMP shall include a registration that reflects all covered processes.
 - b. For processes eligible for Program 1, as provided in 40 CFR 68.10, the Permittee shall comply with 7.10.1.a. and the following additional requirements:
 - i. Analyze the worst-case release scenario for the process(es), as provided in 40 CFR 68.25; document that the nearest public receptor is beyond the distance to a toxic or flammable endpoint defined in 40 CFR 68.22(a); and submit in the RMP the worst-case release scenario as provided in 40 CFR 68.165.
 - ii. Complete the five-year accident history for the process as provided in 40 CFR 68.42 and submit in the RMP as provided in 40 CFR 68.168
 - iii. Ensure that response actions have been coordinated with local emergency planning and response agencies
 - iv. Include a certification in the RMP as specified in 40 CFR 68.12(b)(4)
 - c. For processes subject to Program 2, as provided in 40 CFR 68.10, the Permittee shall comply with 7.10.1.a., 7.10.1.b. and the following additional requirements:
 - i. Develop and implement a management system as provided in 40 CFR 68.15
 - ii. Conduct a hazard assessment as provided in 40 CFR 68.20 through 68.42
 - iii. Implement the Program 2 prevention steps provided in 40 CFR 68.48 through 68.60 or implement the Program 3 prevention steps provided in 40 CFR 68.65 through 68.87
 - iv. Develop and implement an emergency response program as provided in 40 CFR 68.90 through 68.95
 - v. Submit as part of the RMP the data on prevention program elements for Program 2 processes as provided in 40 CFR 68.170
 - d. For processes subject to Program 3, as provided in 40 CFR 68.10, the Permittee shall comply with 7.10.1.a., 7.10.1.b. and the following additional requirements:
 - i. Develop and implement a management system as provided in 40 CFR 68.15
 - ii. Conduct a hazard assessment as provided in 40 CFR 68.20 through 68.42

Title V Permit

- iii. Implement the prevention requirements of 40 CFR 68.65 through 68.87
 - iv. Develop and implement an emergency response program as provided in 40 CFR 68.90 through 68.95
 - v. Submit as part of the RMP the data on prevention program elements for Program 3 as provided in 40 CFR 68.175
- e. All reports and notification required by 40 CFR Part 68 must be submitted electronically using RMP*eSubmit (information for establishing an account can be found at www.epa.gov/rmp/rmpesubmit). Electronic Signature Agreements should be mailed to:

MAIL

Risk Management Program (RMP) Reporting Center
P.O. Box 10162
Fairfax, VA 22038

COURIER & FEDEX

Risk Management Program (RMP) Reporting Center
CGI Federal
12601 Fair Lakes Circle
Fairfax, VA 22033

Compliance with all requirements of this condition, including the registration and submission of the RMP, shall be included as part of the compliance certification submitted in accordance with Condition 8.14.1.

7.11 Stratospheric Ozone Protection Requirements (Title VI of the CAAA of 1990)

- 7.11.1 If the Permittee performs any of the activities described below or as otherwise defined in 40 CFR Part 82, the Permittee shall comply with the standards for recycling and emissions reduction pursuant to 40 CFR Part 82, Subpart F, except as provided for motor vehicle air conditioners (MVACs) in Subpart B:
- a. Persons opening appliances for maintenance, service, repair, or disposal must comply with the required practices pursuant to 40 CFR 82.156.
 - b. Equipment used during the maintenance, service, repair, or disposal of appliance must comply with the standards for recycling and recovery equipment pursuant to 40 CFR 82.158.
 - c. Persons performing maintenance, service, repair, or disposal of appliances must be certified by an approved technician certification program pursuant to 40 CFR 82.161.

- d. Persons disposing of small appliances, MVACs, and MVAC-like appliances must comply with record keeping requirements pursuant to 40 CFR 82.166.
[Note: "MVAC-like appliance" is defined in 40 CFR 82.152.]
- e. Persons owning commercial or industrial process refrigeration equipment must comply with the leak repair requirements pursuant to 40 CFR 82.156.
- f. Owners/operators of appliances normally containing 50 or more pounds of refrigerant must keep records of refrigerant purchased and added to such appliances pursuant to 40 CFR 82.166.

7.11.2 If the Permittee performs a service on motor (fleet) vehicles and if this service involves an ozone-depleting substance (refrigerant) in the MVAC, the Permittee is subject to all the applicable requirements as specified in 40 CFR Part 82, Subpart B, Servicing of Motor Vehicle Air Conditioners.

The term "motor vehicle" as used in Subpart B does not include a vehicle in which final assembly of the vehicle has not been completed. The term "MVAC" as used in Subpart B does not include air-tight sealed refrigeration systems used for refrigerated cargo, or air conditioning systems on passenger buses using HCFC-22 refrigerant.

7.12 Revocation of Existing Permits and Amendments

The following Air Quality Permits, Amendments, and 502(b)10 are subsumed by this permit and are hereby revoked:

Air Quality Permit and Amendment Number(s)	Dates of Original Permit or Amendment Issuance
4911-077-0001-V-03-0	December 27, 2010
4911-077-0001-V-03-1	November 21, 2011
4911-077-0001-V-03-2	March 2, 2012
4911-077-0001-V-03-3	March 1, 2013
4911-077-0001-V-03-5	August 29, 2014
4911-077-0001-V-03-6	November 26, 2014
4911-077-0001-V-03-7	April 20, 2014

7.13 Pollution Prevention

None applicable.

7.14 Specific Conditions

None applicable.

7.15 Cross State Air Pollution Rule (CSAPR) Allowance Trading Program Requirements
 [40 CFR 97]

7.15.1 CSAPR Units and Applicable CSAPR Programs.

Unit ID#	NOx Annual	SO2	NOx Ozone Season
SG06	X	X	X
SG07	X	X	X

7.15.2 Annual NOx, SO₂ and Ozone Season NOx emissions requirements.

The owners and operators and the CSAPR designated representative of each CSAPR Annual NOx source, CSAPR SO₂ source and CSAPR Ozone Season NOx source and each CSAPR Annual NOx unit, CSAPR SO₂ unit, and CSAPR Ozone Season NOx unit at the source shall comply with the applicable requirements of the Annual NOx, SO₂, and Ozone Season NOx Allowance Trading Programs as set forth in 40 CFR Part 97.

7.15.3 Monitoring, reporting, and recordkeeping requirements.

The owners and operators and the CSAPR designated representative of each CSAPR Annual NOx source, CSAPR SO₂ source and CSAPR Ozone Season NOx source and each CSAPR Annual NOx unit, CSAPR SO₂ unit, and CSAPR Ozone Season NOx unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR 97.430-97.435 (Annual NOx), 40 CFR 97.530-97.535 (Ozone Season NOx) and 40 CFR 97.730-97.735 (Annual SO₂).

PART 8.0 GENERAL PROVISIONS**8.1 Terms and References**

- 8.1.1 Terms not otherwise defined in the Permit shall have the meaning assigned to such terms in the referenced regulation.
- 8.1.2 Where more than one condition in this Permit applies to an emission unit and/or the entire facility, each condition shall apply and the most stringent condition shall take precedence.
[391-3-1-.02(2)(a)2]

8.2 EPA Authorities

- 8.2.1 Except as identified as "State-only enforceable" requirements in this Permit, all terms and conditions contained herein shall be enforceable by the EPA and citizens under the Clean Air Act, as amended, 42 U.S.C. 7401, et seq.
[40 CFR 70.6(b)(1)]
- 8.2.2 Nothing in this Permit shall alter or affect the authority of the EPA to obtain information pursuant to 42 U.S.C. 7414, "Inspections, Monitoring, and Entry."
[40 CFR 70.6(f)(3)(iv)]
- 8.2.3 Nothing in this Permit shall alter or affect the authority of the EPA to impose emergency orders pursuant to 42 U.S.C. 7603, "Emergency Powers."
[40 CFR 70.6(f)(3)(i)]

8.3 Duty to Comply

- 8.3.1 The Permittee shall comply with all conditions of this operating Permit. Any Permit noncompliance constitutes a violation of the Federal Clean Air Act and the Georgia Air Quality Act and/or State rules and is grounds for enforcement action; for Permit termination, revocation and reissuance, or modification; or for denial of a Permit renewal application. Any noncompliance with a Permit condition specifically designated as enforceable only by the State constitutes a violation of the Georgia Air Quality Act and/or State rules only and is grounds for enforcement action; for Permit termination, revocation and reissuance, or modification; or for denial of a Permit renewal application.
[391-3-1-.03(10)(d)1(i) and 40 CFR 70.6(a)(6)(i)]
- 8.3.2 The Permittee shall not use as a defense in an enforcement action the contention that it would have been necessary to halt or reduce the Permitted activity in order to maintain compliance with the conditions of this Permit.
[391-3-1-.03(10)(d)1(i) and 40 CFR 70.6(a)(6)(ii)]
- 8.3.3 Nothing in this Permit shall alter or affect the liability of the Permittee for any violation of applicable requirements prior to or at the time of Permit issuance.
[391-3-1-.03(10)(d)1(i) and 40 CFR 70.6(f)(3)(ii)]

- 8.3.4 Issuance of this Permit does not relieve the Permittee from the responsibility of obtaining any other permits, licenses, or approvals required by the Director or any other federal, state, or local agency.
[391-3-1-.03(10)(e)1(iv) and 40 CFR 70.7(a)(6)]

8.4 Fee Assessment and Payment

- 8.4.1 The Permittee shall calculate and pay an annual Permit fee to the Division. The amount of fee shall be determined each year in accordance with the "Procedures for Calculating Air Permit Fees."
[391-3-1-.03(9)]

8.5 Permit Renewal and Expiration

- 8.5.1 This Permit shall remain in effect for five (5) years from the issuance date. The Permit shall become null and void after the expiration date unless a timely and complete renewal application has been submitted to the Division at least six (6) months, but no more than eighteen (18) months prior to the expiration date of the Permit.
[391-3-1-.03(10)(d)1(i), (e)2, and (e)3(ii) and 40 CFR 70.5(a)(1)(iii)]
- 8.5.2 Permits being renewed are subject to the same procedural requirements, including those for public participation and affected State and EPA review, that apply to initial Permit issuance.
[391-3-1-.03(10)(e)3(i)]
- 8.5.3 Notwithstanding the provisions in 8.5.1 above, if the Division has received a timely and complete application for renewal, deemed it administratively complete, and failed to reissue the Permit for reasons other than cause, authorization to operate shall continue beyond the expiration date to the point of Permit modification, reissuance, or revocation.
[391-3-1-.03(10)(e)3(iii)]

8.6 Transfer of Ownership or Operation

- 8.6.1 This Permit is not transferable by the Permittee. Future owners and operators shall obtain a new Permit from the Director. The new Permit may be processed as an administrative amendment if no other change in this Permit is necessary, and provided that a written agreement containing a specific date for transfer of Permit responsibility coverage and liability between the current and new Permittee has been submitted to the Division at least thirty (30) days in advance of the transfer.
[391-3-1-.03(4)]

8.7 Property Rights

- 8.7.1 This Permit shall not convey property rights of any sort, or any exclusive privileges.
[391-3-1-.03(10)(d)1(i) and 40 CFR 70.6(a)(6)(iv)]

8.8 Submissions

8.8.1 Reports, test data, monitoring data, notifications, annual certifications, and requests for revision and renewal shall be submitted to:

**Georgia Department of Natural Resources
Environmental Protection Division
Air Protection Branch
Atlanta Tradeport, Suite 120
4244 International Parkway
Atlanta, Georgia 30354-3908**

8.8.2 Any records, compliance certifications, and monitoring data required by the provisions in this Permit to be submitted to the EPA shall be sent to:

**Air and EPCRA Enforcement Branch – U. S. EPA Region 4
Sam Nunn Atlanta Federal Center
61 Forsyth Street, SW
Atlanta, Georgia 30303-3104**

8.8.3 Any application form, report, or compliance certification submitted pursuant to this Permit shall contain a certification by a responsible official of its truth, accuracy, and completeness. This certification shall state that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.
[391-3-1-.03(10)(c)2, 40 CFR 70.5(d) and 40 CFR 70.6(c)(1)]

8.8.4 Unless otherwise specified, all submissions under this permit shall be submitted to the Division only.

8.9 Duty to Provide Information

8.9.1 The Permittee, upon becoming aware that any relevant facts were omitted or incorrect information was submitted in the Permit application, shall promptly submit such supplementary facts or corrected information to the Division.
[391-3-1-.03(10)(c)5]

8.9.2 The Permittee shall furnish to the Division, in writing, information that the Division may request to determine whether cause exists for modifying, revoking and reissuing, or terminating the Permit, or to determine compliance with the Permit. Upon request, the Permittee shall also furnish to the Division copies of records that the Permittee is required to keep by this Permit or, for information claimed to be confidential, the Permittee may furnish such records directly to the EPA, if necessary, along with a claim of confidentiality.
[391-3-1-.03(10)(d)1(i) and 40 CFR 70.6(a)(6)(v)]

8.10 Modifications

- 8.10.1 Prior to any source commencing a modification as defined in 391-3-1-.01(pp) that may result in air pollution and not exempted by 391-3-1-.03(6), the Permittee shall submit a Permit application to the Division. The application shall be submitted sufficiently in advance of any critical date involved to allow adequate time for review, discussion, or revision of plans, if necessary. Such application shall include, but not be limited to, information describing the precise nature of the change, modifications to any emission control system, production capacity of the plant before and after the change, and the anticipated completion date of the change. The application shall be in the form of a Georgia air quality Permit application to construct or modify (otherwise known as a SIP application) and shall be submitted on forms supplied by the Division, unless otherwise notified by the Division.
[391-3-1-.03(1) through (8)]

8.11 Permit Revision, Revocation, Reopening and Termination

- 8.11.1 This Permit may be revised, revoked, reopened and reissued, or terminated for cause by the Director. The Permit will be reopened for cause and revised accordingly under the following circumstances:
[391-3-1-.03(10)(d)1(i)]
- a. If additional applicable requirements become applicable to the source and the remaining Permit term is three (3) or more years. In this case, the reopening shall be completed no later than eighteen (18) months after promulgation of the applicable requirement. A reopening shall not be required if the effective date of the requirement is later than the date on which the Permit is due to expire, unless the original permit or any of its terms and conditions has been extended under Condition 8.5.3;
[391-3-1-.03(10)(e)6(i)(I)]
 - b. If any additional applicable requirements of the Acid Rain Program become applicable to the source;
[391-3-1-.03(10)(e)6(i)(II)] (Acid Rain sources only)
 - c. The Director determines that the Permit contains a material mistake or inaccurate statements were made in establishing the emissions standards or other terms or conditions of the Permit; or
[391-3-1-.03(10)(e)6(i)(III) and 40 CFR 70.7(f)(1)(iii)]
 - d. The Director determines that the Permit must be revised or revoked to assure compliance with the applicable requirements.
[391-3-1-.03(10)(e)6(i)(IV) and 40 CFR 70.7(f)(1)(iv)]

- 8.11.2 Proceedings to reopen and reissue a Permit shall follow the same procedures as applicable to initial Permit issuance and shall affect only those parts of the Permit for which cause to reopen exists. Reopenings shall be made as expeditiously as practicable.
[391-3-1-.03(10)(e)6(ii)]
- 8.11.3 Reopenings shall not be initiated before a notice of intent to reopen is provided to the source by the Director at least thirty (30) days in advance of the date the Permit is to be reopened, except that the Director may provide a shorter time period in the case of an emergency.
[391-3-1-.03(10)(e)6(iii)]
- 8.11.4 All Permit conditions remain in effect until such time as the Director takes final action. The filing of a request by the Permittee for any Permit revision, revocation, reissuance, or termination, or of a notification of planned changes or anticipated noncompliance, shall not stay any Permit condition.
[391-3-1-.03(10)(d)1(i) and 40 CFR 70.6(a)(6)(iii)]
- 8.11.5 A Permit revision shall not be required for changes that are explicitly authorized by the conditions of this Permit.
- 8.11.6 A Permit revision shall not be required for changes that are part of an approved economic incentive, marketable Permit, emission trading, or other similar program or process for change which is specifically provided for in this Permit.
[391-3-1-.03(10)(d)1(i) and 40 CFR 70.6(a)(8)]

8.12 Severability

- 8.12.1 Any condition or portion of this Permit which is challenged, becomes suspended or is ruled invalid as a result of any legal or other action shall not invalidate any other portion or condition of this Permit.
[391-3-1-.03(10)(d)1(i) and 40 CFR 70.6(a)(5)]

8.13 Excess Emissions Due to an Emergency

- 8.13.1 An "emergency" means any situation arising from sudden and reasonably unforeseeable events beyond the control of the source, including acts of God, which situation requires immediate corrective action to restore normal operation, and that causes the source to exceed a technology-based emission limitation under the Permit, due to unavoidable increases in emissions attributable to the emergency. An emergency shall not include noncompliance to the extent caused by improperly designed equipment, lack of preventative maintenance, careless or improper operation, or operator error.
[391-3-1-.03(10)(d)7 and 40 CFR 70.6(g)(1)]

8.13.2 An emergency shall constitute an affirmative defense to an action brought for noncompliance with the technology-based emission limitations if the Permittee demonstrates, through properly signed contemporaneous operating logs or other relevant evidence, that:

[391-3-1-.03(10)(d)7 and 40 CFR 70.6(g)(2) and (3)]

- a. An emergency occurred and the Permittee can identify the cause(s) of the emergency;
- b. The Permitted facility was at the time of the emergency being properly operated;
- c. During the period of the emergency, the Permittee took all reasonable steps to minimize levels of emissions that exceeded the emissions standards, or other requirements in the Permit; and
- d. The Permittee promptly notified the Division and submitted written notice of the emergency to the Division within two (2) working days of the time when emission limitations were exceeded due to the emergency. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

8.13.3 In an enforcement proceeding, the Permittee seeking to establish the occurrence of an emergency shall have the burden of proof.

[391-3-1-.03(10)(d)7 and 40 CFR 70.6(g)(4)]

8.13.4 The emergency conditions listed above are in addition to any emergency or upset provisions contained in any applicable requirement.

[391-3-1-.03(10)(d)7 and 40 CFR 70.6(g)(5)]

8.14 Compliance Requirements

8.14.1 Compliance Certification

The Permittee shall provide written certification to the Division and to the EPA, at least annually, of compliance with the conditions of this Permit. The annual written certification shall be postmarked no later than **February 28** of each year and shall be submitted to the Division and to the EPA. The certification shall include, but not be limited to, the following elements:

[391-3-1-.03(10)(d)3 and 40 CFR 70.6(c)(5)]

- a. The identification of each term or condition of the Permit that is the basis of the certification;

Title V Permit

- b. The status of compliance with the terms and conditions of the permit for the period covered by the certification, including whether compliance during the period was continuous or intermittent, based on the method or means designated in paragraph c below. The certification shall identify each deviation and take it into account in the compliance certification. The certification shall also identify as possible exceptions to compliance any periods during which compliance is required and in which an excursion or exceedance as defined under 40 CFR Part 64 occurred;
- c. The identification of the method(s) or other means used by the owner or operator for determining the compliance status with each term and condition during the certification period;
- d. Any other information that must be included to comply with section 113(c)(2) of the Act, which prohibits knowingly making a false certification or omitting material information; and
- e. Any additional requirements specified by the Division.

8.14.2 Inspection and Entry

- a. Upon presentation of credentials and other documents as may be required by law, the Permittee shall allow authorized representatives of the Division to perform the following:
[391-3-1-.03(10)(d)3 and 40 CFR 70.6(c)(2)]
 - i. Enter upon the Permittee's premises where a Part 70 source is located or an emissions-related activity is conducted, or where records must be kept under the conditions of this Permit;
 - ii. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this Permit;
 - iii. Inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this Permit; and
 - iv. Sample or monitor any substances or parameters at any location during operating hours for the purpose of assuring Permit compliance or compliance with applicable requirements as authorized by the Georgia Air Quality Act.
- b. No person shall obstruct, hamper, or interfere with any such authorized representative while in the process of carrying out his official duties. Refusal of entry or access may constitute grounds for Permit revocation and assessment of civil penalties.
[391-3-1-.07 and 40 CFR 70.11(a)(3)(i)]

8.14.3 Schedule of Compliance

- a. For applicable requirements with which the Permittee is in compliance, the Permittee shall continue to comply with those requirements.
[391-3-1-.03(10)(c)2 and 40 CFR 70.5(c)(8)(iii)(A)]
- b. For applicable requirements that become effective during the Permit term, the Permittee shall meet such requirements on a timely basis unless a more detailed schedule is expressly required by the applicable requirement.
[391-3-1-.03(10)(c)2 and 40 CFR 70.5(c)(8)(iii)(B)]
- c. Any schedule of compliance for applicable requirements with which the source is not in compliance at the time of Permit issuance shall be supplemental to, and shall not sanction noncompliance with, the applicable requirements on which it is based.
[391-3-1-.03(10)(c)2 and 40 CFR 70.5(c)(8)(iii)(C)]

8.14.4 Excess Emissions

- a. Excess emissions resulting from startup, shutdown, or malfunction of any source which occur though ordinary diligence is employed shall be allowed provided that:
[391-3-1-.02(2)(a)7(i)]
 - i. The best operational practices to minimize emissions are adhered to;
 - ii. All associated air pollution control equipment is operated in a manner consistent with good air pollution control practice for minimizing emissions; and
 - iii. The duration of excess emissions is minimized.
- b. Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown or malfunction are prohibited and are violations of Chapter 391-3-1 of the Georgia Rules for Air Quality Control.
[391-3-1-.02(2)(a)7(ii)]
- c. The provisions of this condition and Georgia Rule 391-3-1-.02(2)(a)7 shall apply only to those sources which are not subject to any requirement under Georgia Rule 391-3-1-.02(8) – New Source Performance Standards or any requirement of 40 CFR, Part 60, as amended concerning New Source Performance Standards.
[391-3-1-.02(2)(a)7(iii)]

8.15 Circumvention

State Only Enforceable Condition.

- 8.15.1 The Permittee shall not build, erect, install, or use any article, machine, equipment or process the use of which conceals an emission which would otherwise constitute a violation of an applicable emission standard. Such concealment includes, but is not limited to, the use of gaseous diluents to achieve compliance with an opacity standard or with a standard which is based on the concentration of the pollutants in the gases discharged into the atmosphere.
[391-3-1-.03(2)(c)]

8.16 Permit Shield

- 8.16.1 Compliance with the terms of this Permit shall be deemed compliance with all applicable requirements as of the date of Permit issuance provided that all applicable requirements are included and specifically identified in the Permit.
[391-3-1-.03(10)(d)6]
- 8.16.2 Any Permit condition identified as "State only enforceable" does not have a Permit shield.

8.17 Operational Practices

- 8.17.1 At all times, including periods of startup, shutdown, and malfunction, the Permittee shall maintain and operate the source, including associated air pollution control equipment, in a manner consistent with good air pollution control practice for minimizing emissions. Determination of whether acceptable operating and maintenance procedures are being used will be based on any information available to the Division that may include, but is not limited to, monitoring results, observations of the opacity or other characteristics of emissions, review of operating and maintenance procedures or records, and inspection or surveillance of the source.
[391-3-1-.02(2)(a)10]

State Only Enforceable Condition.

- 8.17.2 No person owning, leasing, or controlling, the operation of any air contaminant sources shall willfully, negligently or through failure to provide necessary equipment or facilities or to take necessary precautions, cause, permit, or allow the emission from said air contamination source or sources, of such quantities of air contaminants as will cause, or tend to cause, by themselves, or in conjunction with other air contaminants, a condition of air pollution in quantities or characteristics or of a duration which is injurious or which unreasonably interferes with the enjoyment of life or use of property in such area of the State as is affected thereby. Complying with Georgia's Rules for Air Quality Control Chapter 391-3-1 and Conditions in this Permit, shall in no way exempt a person from this provision.
[391-3-1-.02(2)(a)1]

8.18 Visible Emissions

- 8.18.1 Except as may be provided in other provisions of this Permit, the Permittee shall not cause, let, suffer, permit or allow emissions from any air contaminant source the opacity of which is equal to or greater than forty (40) percent.
[391-3-1-.02(2)(b)1]

8.19 Fuel-burning Equipment

- 8.19.1 The Permittee shall not cause, let, suffer, permit, or allow the emission of fly ash and/or other particulate matter from any fuel-burning equipment with rated heat input capacity of less than 10 million Btu per hour, in operation or under construction on or before January 1, 1972 in amounts equal to or exceeding 0.7 pounds per million BTU heat input.
[391-3-1-.02(2)(d)]
- 8.19.2 The Permittee shall not cause, let, suffer, permit, or allow the emission of fly ash and/or other particulate matter from any fuel-burning equipment with rated heat input capacity of less than 10 million Btu per hour, constructed after January 1, 1972 in amounts equal to or exceeding 0.5 pounds per million BTU heat input.
[391-3-1-.02(2)(d)]
- 8.19.3 The Permittee shall not cause, let, suffer, permit, or allow the emission from any fuel-burning equipment constructed or extensively modified after January 1, 1972, visible emissions the opacity of which is equal to or greater than twenty (20) percent except for one six minute period per hour of not more than twenty-seven (27) percent opacity.
[391-3-1-.02(2)(d)]

8.20 Sulfur Dioxide

- 8.20.1 Except as may be specified in other provisions of this Permit, the Permittee shall not burn fuel containing more than 2.5 percent sulfur, by weight, in any fuel burning source that has a heat input capacity below 100 million Btu's per hour.
[391-3-1-.02(2)(g)]

8.21 Particulate Emissions

8.21.1 Except as may be specified in other provisions of this Permit, the Permittee shall not cause, let, permit, suffer, or allow the rate of emission from any source, particulate matter in total quantities equal to or exceeding the allowable rates shown below. Equipment in operation, or under construction contract, on or before July 2, 1968, shall be considered existing equipment. All other equipment put in operation or extensively altered after said date is to be considered new equipment.

[391-3-1-.02(2)(e)]

- a. The following equations shall be used to calculate the allowable rates of emission from new equipment:

$E = 4.1P^{0.67}$; for process input weight rate up to and including 30 tons per hour.

$E = 55P^{0.11} - 40$; for process input weight rate above 30 tons per hour.

- b. The following equation shall be used to calculate the allowable rates of emission from existing equipment:

$$E = 4.1P^{0.67}$$

In the above equations, E = emission rate in pounds per hour, and
P = process input weight rate in tons per hour.

8.22 Fugitive Dust

[391-3-1-.02(2)(n)]

8.22.1 Except as may be specified in other provisions of this Permit, the Permittee shall take all reasonable precautions to prevent dust from any operation, process, handling, transportation or storage facility from becoming airborne. Reasonable precautions that could be taken to prevent dust from becoming airborne include, but are not limited to, the following:

- a. Use, where possible, of water or chemicals for control of dust in the demolition of existing buildings or structures, construction operations, the grading of roads or the clearing of land;
- b. Application of asphalt, water, or suitable chemicals on dirt roads, materials, stockpiles, and other surfaces that can give rise to airborne dusts;
- c. Installation and use of hoods, fans, and fabric filters to enclose and vent the handling of dusty materials. Adequate containment methods can be employed during sandblasting or other similar operations;
- d. Covering, at all times when in motion, open bodied trucks transporting materials likely to give rise to airborne dusts; and
- e. The prompt removal of earth or other material from paved streets onto which earth or other material has been deposited.

8.22.2 The opacity from any fugitive dust source shall not equal or exceed 20 percent.

8.23 Solvent Metal Cleaning

8.23.1 Except as may be specified in other provisions of this Permit, the Permittee shall not cause, suffer, allow, or permit the operation of a cold cleaner degreaser subject to the requirements of Georgia Rule 391-3-1-.02(2)(ff) "Solvent Metal Cleaning" unless the following requirements for control of emissions of the volatile organic compounds are satisfied:
[391-3-1-.02(2)(ff)1]

- a. The degreaser shall be equipped with a cover to prevent escape of VOC during periods of non-use,
- b. The degreaser shall be equipped with a device to drain cleaned parts before removal from the unit,
- c. If the solvent volatility is 0.60 psi or greater measured at 100 °F, or if the solvent is heated above 120 °F, then one of the following control devices must be used:
 - i. The degreaser shall be equipped with a freeboard that gives a freeboard ratio of 0.7 or greater, or
 - ii. The degreaser shall be equipped with a water cover (solvent must be insoluble in and heavier than water), or
 - iii. The degreaser shall be equipped with a system of equivalent control, including but not limited to, a refrigerated chiller or carbon adsorption system.
- d. Any solvent spray utilized by the degreaser must be in the form of a solid, fluid stream (not a fine, atomized or shower type spray) and at a pressure which will not cause excessive splashing, and
- e. All waste solvent from the degreaser shall be stored in covered containers and shall not be disposed of by such a method as to allow excessive evaporation into the atmosphere.

8.24 Incinerators

- 8.24.1 Except as specified in the section dealing with conical burners, no person shall cause, let, suffer, permit, or allow the emissions of fly ash and/or other particulate matter from any incinerator subject to the requirements of Georgia Rule 391-3-1-.02(2)(c) "Incinerators", in amounts equal to or exceeding the following:
[391-3-1-.02(2)(c)1-4]
- a. Units with charging rates of 500 pounds per hour or less of combustible waste, including water, shall not emit fly ash and/or particulate matter in quantities exceeding 1.0 pound per hour.
 - b. Units with charging rates in excess of 500 pounds per hour of combustible waste, including water, shall not emit fly ash and/or particulate matter in excess of 0.20 pounds per 100 pounds of charge.
- 8.24.2 No person shall cause, let, suffer, permit, or allow from any incinerator subject to the requirements of Georgia Rule 391-3-1-.02(2)(c) "Incinerators", visible emissions the opacity of which is equal to or greater than twenty (20) percent except for one six minute period per hour of not more than twenty-seven (27) percent opacity.
- 8.24.3 No person shall cause or allow particles to be emitted from an incinerator subject to the requirements of Georgia Rule 391-3-1-.02(2)(c) "Incinerators" which are individually large enough to be visible to the unaided eye.
- 8.24.4 No person shall operate an existing incinerator subject to the requirements of Georgia Rule 391-3-1-.02(2)(c) "Incinerators" unless:
- a. It is a multiple chamber incinerator;
 - b. It is equipped with an auxiliary burner in the primary chamber for the purpose of creating a pre-ignition temperature of 800°F; and
 - c. It has a secondary burner to control smoke and/or odors and maintain a temperature of at least 1500°F in the secondary chamber.

8.25 Volatile Organic Liquid Handling and Storage

- 8.25.1 The Permittee shall ensure that each storage tank subject to the requirements of Georgia Rule 391-3-1-.02(2)(vv) "Volatile Organic Liquid Handling and Storage" is equipped with submerged fill pipes. For the purposes of this condition and the permit, a submerged fill pipe is defined as any fill pipe with a discharge opening which is within six inches of the tank bottom.
[391-3-1-.02(2)(vv)(1)]

8.26 Use of Any Credible Evidence or Information

- 8.26.1 Notwithstanding any other provisions of any applicable rule or regulation or requirement of this permit, for the purpose of submission of compliance certifications or establishing whether or not a person has violated or is in violation of any emissions limitation or standard, nothing in this permit or any Emission Limitation or Standard to which it pertains, shall preclude the use, including the exclusive use, of any credible evidence or information, relevant to whether a source would have been in compliance with applicable requirements if the appropriate performance or compliance test or procedure had been performed.
[391-3-1-.02(3)(a)]

8.27 Internal Combustion Engines

- 8.27.1 For diesel-fired internal combustion engine(s) manufactured after April 1, 2006 or modified/reconstructed after July 11, 2005, the Permittee shall comply with all applicable provisions of New Source Performance Standards (NSPS) as found in 40 CFR 60 Subpart A - "General Provisions" and 40 CFR 60 Subpart III - "Standard of Performance for Stationary Compression Ignition Internal Combustion Engines." Such requirements include but are not limited to:
[40 CFR 60.4200, 391-3-1-.02(8)(b)77]

- a. Equip all emergency generator engines with non-resettable hour meters in accordance with Subpart III.
- b. Purchase only diesel fuel with a maximum sulfur content of 15 ppm unless otherwise specified by the Division in accordance with Subpart III.
- c. Conduct engine maintenance prescribed by the engine manufacturer in accordance with Subpart III.
- d. Limit maintenance checks and readiness testing operation of each engine to 100 hours per year in accordance with 40 CFR 60.4211(f)(2). 50 hours of the 100 total hours allowed for maintenance checks and readiness testing operation per year may be used for non-emergency operation as allowed by 40 CFR 60.4211(f)(3).
- e. Maintain any records in accordance with Subpart III
- f. Maintain a list of engines subject to 40 CFR 60 Subpart III, including the date of manufacture.[391-3-1-.02(6)(b)]

- 8.27.2 The Permittee shall comply with all applicable provisions of New Source Performance Standards (NSPS) as found in 40 CFR 60 Subpart A - "General Provisions" and 40 CFR 60 Subpart JJJJ - "Standard of Performance for Stationary Spark Ignition Internal Combustion Engines," for spark ignition internal combustion engines(s) (gasoline, natural gas, liquefied petroleum gas or propane-fired) manufactured after July 1, 2007 or modified/reconstructed after June 12, 2006.
[40 CFR 60.4230, 391-3-1-.02(8)(b)79]

Title V Permit

- 8.27.3 The Permittee shall comply with all applicable provisions of National Emission Standards for Hazardous Air Pollutants (NESHAP) as found in 40 CFR 63 Subpart A - "General Provisions" and 40 CFR 63 Subpart ZZZZ - "National Emission Standard for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines."

For diesel-fired emergency engines defined as "existing" in 40 CFR 63 Subpart ZZZZ (constructed prior to June 12, 2006 for area sources of HAP, constructed prior to June 12, 2006 for ≤ 500 hp engines at major sources, and constructed prior to December 19, 2002 for >500 hp engines at major sources of HAP), such requirements (if applicable) include but are not limited to:

[40 CFR 63.6580, 391-3-1-.02(9)(b)118]

- a. Equip all emergency engines with non-resettable hour meters in accordance with Subpart ZZZZ.
- b. Purchase only diesel fuel with a maximum sulfur content of 15 ppm unless otherwise specified by the Division in accordance with Subpart ZZZZ.
- c. For engines less than or equal to 500 HP, conduct the following in accordance with Subpart ZZZZ.
 - i. Change oil and filter every 500 hours of operation or annually, whichever comes first
 - ii. Inspect air cleaner every 1000 hours of operation or annually, whichever comes first and replace as necessary
 - iii. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first and replace as necessary.
- d. Limit maintenance checks and readiness testing operation of each engine to 100 hours per year in accordance with 40 CFR 63.6640(f)(2). 50 hours of the 100 total hours allowed for maintenance checks and readiness testing operation per year may be used for non-emergency operation as allowed by 40 CFR 63.6640(f)(3).
- e. Maintain any records in accordance with Subpart ZZZZ
- f. Maintain a list of engines subject to 40 CFR 63 Subpart ZZZZ, including the date of manufacture. [391-3-1-.02(6)(b)]

- 8.27.4 For stationary gas turbines, stationary gas engines used to generate electricity whose nameplate capacity is greater than or equal to 100 kilowatt (KWe) and is less than or equal to 25 megawatts (MWe), the Permittee shall not discharge, cause the discharge, into the atmosphere Nitrogen Oxides (NOx) from the following engines during each ozone season (May 1 through September 30):
- a. For stationary engines in operation before April 1, 2000: 160 ppm @ 15% O₂, dry basis;
 - b. For stationary engines installed or modified on or after April 1, 2000: 80 ppm @ 15% O₂, dry basis;
 - c. For stationary gas turbines in operation on or after January 1, 1999 and before October 1999: 42 ppm @ 15% O₂, dry basis;
 - d. For stationary gas turbines installed or modified on or after October 1, 1999: 30 ppm @ 15% O₂, dry basis
 - e. Emergency standby stationary gas turbines and stationary engines are not subject to the emission limitations in a through d. Non-emergency operation is allowed for these engines as prescribed in 40 CFR 60 Subpart IIII, 40 CFR 60 Subpart JJJJ, and 40 CFR 63 Subpart ZZZZ.
 - f. The requirements shall apply to all applicable sources located in the counties of Banks, Barrow, Bartow, Butts, Carroll, Chattooga, Cherokee, Clarke, Clayton, Cobb, Coweta, Dawson, DeKalb, Douglas, Fayette, Floyd, Forsyth, Fulton, Gordon, Gwinnett, Hall, Haralson, Heard, Henry, Jackson, Jasper, Jones, Lamar, Lumpkin, Madison, Meriwether, Monroe, Morgan, Newton, Oconee, Paulding, Pickens, Pike, Polk, Putnam, Rockdale, Spalding, Troup, Upson, and Walton.

8.28 Boilers and Process Heaters

- 8.28.1 If the facility/site is an area source of Hazardous Air Pollutants, the Permittee shall comply with all applicable provisions of National Emission Standards for Hazardous Air Pollutants (NESHAP) 40 CFR Part 63 Subpart A - "General Provisions" and 40 CFR 63 Subpart JJJJJ - "National Emission Standards for Hazardous Air Pollutants for Area Sources: Industrial, Commercial, and Institutional Boilers."
[40 CFR 63.11193]
- 8.28.2 If the facility/site is a major source of Hazardous Air Pollutants, the Permittee shall comply with all applicable provisions of National Emission Standards for Hazardous Air Pollutants (NESHAP) 40 CFR Part 63 Subpart A - "General Provisions" and 40 CFR 63 Subpart DDDDD - "National Emission Standards for Hazardous Air Pollutants for Major Sources: Industrial, Commercial, and Institutional Boilers and Process Heaters."
[40 CFR 63.7480]

Attachments

- A. List of Standard Abbreviations and List of Permit Specific Abbreviations
- B. Insignificant Activities Checklist, Insignificant Activities Based on Emission Levels and Generic Emission Groups
- C. List of References
- D. U.S. EPA Acid Rain Program Phase II Permit Application

Title V Permit

ATTACHMENT B

NOTE: Attachment B contains information regarding insignificant emission units/activities and groups of generic emission units/activities in existence at the facility at the time of Permit issuance. Future modifications or additions of insignificant emission units/activities and equipment that are part of generic emissions groups may not necessarily cause this attachment to be updated.

INSIGNIFICANT ACTIVITIES CHECKLIST

Category	Description of Insignificant Activity/Unit	Quantity
Mobile Sources	1. Cleaning and sweeping of streets and paved surfaces	X
Combustion Equipment	1. Fire fighting and similar safety equipment used to train fire fighters or other emergency personnel.	X
	2. Small incinerators that are not subject to any standard, limitation or other requirement under Section 111 or 112 (excluding 112(r)) of the Federal Act and are not considered a "designated facility" as specified in 40 CFR 60.32e of the Federal emissions guidelines for Hospital/Medical/Infectious Waste Incinerators, that are operating as follows:	
	i) Less than 8 million BTU/hr heat input, firing types 0, 1, 2, and/or 3 waste	0
	ii) Less than 8 million BTU/hr heat input with no more than 10% pathological (type 4) waste by weight combined with types 0, 1, 2, and/or 3 waste.	0
	iii) Less than 4 million BTU/hr heat input firing type 4 waste. (Refer to 391-3-1-.03(10)(g)2.(ii) for descriptions of waste types)	0
	3. Open burning in compliance with Georgia Rule 391-3-1-.02 (5).	X
	4. Stationary engines burning:	
	i) Natural gas, LPG, gasoline, dual fuel, or diesel fuel which are used exclusively as emergency generators shall not exceed 500 hours per year or 200 hours per year if subject to Georgia Rule 391-3-1-.02(2)(mmm).7	4
ii) Natural gas, LPG, and/or diesel fueled generators used for emergency, peaking, and/or standby power generation, where the combined peaking and standby power generation do not exceed 200 hours per year.	0	
iii) Natural gas, LPG, and/or diesel fuel used for other purposes, provided that the output of each engine does not exceed 400 horsepower and that no individual engine operates for more than 2,000 hours per year.	2	
iv) Gasoline used for other purposes, provided that the output of each engine does not exceed 100 horsepower and that no individual engine operates for more than 500 hours per year.	0	
Trade Operations	1. Brazing, soldering, and welding equipment, and cutting torches related to manufacturing and construction activities whose emissions of hazardous air pollutants (HAPs) fall below 1,000 pounds per year.	X
Maintenance, Cleaning, and Housekeeping	1. Blast-cleaning equipment using a suspension of abrasive in water and any exhaust system (or collector) serving them exclusively.	1
	2. Portable blast-cleaning equipment.	0
	3. Non-Perchloroethylene Dry-cleaning equipment with a capacity of 100 pounds per hour or less of clothes.	0
	4. Cold cleaners having an air/vapor interface of not more than 10 square feet and that do not use a halogenated solvent.	4
	5. Non-routine clean out of tanks and equipment for the purposes of worker entry in preparation for maintenance or decommissioning.	X
	6. Devices used exclusively for cleaning metal parts or surfaces by burning off residual amounts of paint, varnish, or other foreign material, provided that such devices are equipped with afterburners.	0
	7. Cleaning operations: Alkaline phosphate cleaners and associated cleaners and burners.	0

Title V Permit

Yates Steam-Electric Generating Plant

Permit No.: 4911-077-0001-V-04-0

INSIGNIFICANT ACTIVITIES CHECKLIST

Category	Description of Insignificant Activity/Unit	Quantity
Laboratories and Testing	1. Laboratory fume hoods and vents associated with bench-scale laboratory equipment used for physical or chemical analysis.	5
	2. Research and development facilities, quality control testing facilities and/or small pilot projects, where combined daily emissions from all operations are not individually major or are support facilities not making significant contributions to the product of a collocated major manufacturing facility.	1
Pollution Control	1. Sanitary waste water collection and treatment systems, except incineration equipment or equipment subject to any standard, limitation or other requirement under Section 111 or 112 (excluding 112(r)) of the Federal Act.	2
	2. On site soil or groundwater decontamination units that are not subject to any standard, limitation or other requirement under Section 111 or 112 (excluding 112(r)) of the Federal Act.	0
	3. Bioremediation operations units that are not subject to any standard, limitation or other requirement under Section 111 or 112 (excluding 112(r)) of the Federal Act.	0
	4. Landfills that are not subject to any standard, limitation or other requirement under Section 111 or 112 (excluding 112(r)) of the Federal Act.	2
Industrial Operations	1. Concrete block and brick plants, concrete products plants, and ready mix concrete plants producing less than 125,000 tons per year.	0
	2. Any of the following processes or process equipment which are electrically heated or which fire natural gas, LPG or distillate fuel oil at a maximum total heat input rate of not more than 5 million BTU's per hour:	
	i) Furnaces for heat treating glass or metals, the use of which do not involve molten materials or oil-coated parts.	0
	ii) Porcelain enameling furnaces or porcelain enameling drying ovens.	0
	iii) Kilns for firing ceramic ware.	0
	iv) Crucible furnaces, pot furnaces, or induction melting and holding furnaces with a capacity of 1,000 pounds or less each, in which sweating or distilling is not conducted and in which fluxing is not conducted utilizing free chlorine, chloride or fluoride derivatives, or ammonium compounds.	0
	v) Bakery ovens and confection cookers.	0
	vi) Feed mill ovens.	0
	vii) Surface coating drying ovens	0
	3. Carving, cutting, routing, turning, drilling, machining, sawing, surface grinding, sanding, planing, buffing, shot blasting, shot peening, or polishing; ceramics, glass, leather, metals, plastics, rubber, concrete, paper stock or wood, also including roll grinding and ground wood pulping; stone sharpening, provided that:	X
	i) Activity is performed indoors; &	
	ii) No significant fugitive particulate emissions enter the environment; &	
	iii) No visible emissions enter the outdoor atmosphere.	
4. Photographic process equipment by which an image is reproduced upon material sensitized to radiant energy (e.g., blueprint activity, photographic developing and microfiche).	0	
5. Grain, food, or mineral extrusion processes	0	
6. Equipment used exclusively for sintering of glass or metals, but not including equipment used for sintering metal-bearing ores, metal scale, clay, fly ash, or metal compounds.	0	
7. Equipment for the mining and screening of uncrushed native sand and gravel.	0	
8. Ozonization process or process equipment.	0	
9. Electrostatic powder coating booths with an appropriately designed and operated particulate control system.	0	
10. Activities involving the application of hot melt adhesives where VOC emissions are less than 5 tons per year and HAP emissions are less than 1,000 pounds per year.	0	
11. Equipment used exclusively for the mixing and blending water-based adhesives and coatings at ambient temperatures.	0	
12. Equipment used for compression, molding and injection of plastics where VOC emissions are less than 5 tons per year and HAP emissions are less than 1,000 pounds per year.	0	
13. Ultraviolet curing processes where VOC emissions are less than 5 tons per year and HAP emissions are less than 1,000 pounds per year.	0	

Title V Permit

Yates Steam-Electric Generating Plant

Permit No.: 4911-077-0001-V-04-0

INSIGNIFICANT ACTIVITIES CHECKLIST

Category	Description of Insignificant Activity/Unit	Quantity
Storage Tanks and Equipment	1. All petroleum liquid storage tanks storing a liquid with a true vapor pressure of equal to or less than 0.50 psia as stored.	4
	2. All petroleum liquid storage tanks with a capacity of less than 40,000 gallons storing a liquid with a true vapor pressure of equal to or less than 2.0 psia as stored that are not subject to any standard, limitation or other requirement under Section 111 or 112 (excluding 112(r)) of the Federal Act.	6
	3. All petroleum liquid storage tanks with a capacity of less than 10,000 gallons storing a petroleum liquid.	35
	4. All pressurized vessels designed to operate in excess of 30 psig storing petroleum fuels that are not subject to any standard, limitation or other requirement under Section 111 or 112 (excluding 112(r)) of the Federal Act.	3
	5. Gasoline storage and handling equipment at loading facilities handling less than 20,000 gallons per day or at vehicle dispensing facilities that are not subject to any standard, limitation or other requirement under Section 111 or 112 (excluding 112(r)) of the Federal Act.	1
	6. Portable drums, barrels, and totes provided that the volume of each container does not exceed 550 gallons.	99
	7. All chemical storage tanks used to store a chemical with a true vapor pressure of less than or equal to 10 millimeters of mercury (0.19 psia).	4

INSIGNIFICANT ACTIVITIES BASED ON EMISSION LEVELS

Description of Emission Units / Activities	Quantity
N/A	N/A

Title V Permit

ATTACHMENT B (continued)

GENERIC EMISSION GROUPS

Emission units/activities appearing in the following table are subject only to one or more of Georgia Rules 391-3-1-.02 (2) (b), (e) &/or (n). Potential emissions of particulate matter, from these sources based on TSP, are less than 25 tons per year per process line or unit in each group. Any emissions unit subject to a NESHAP, NSPS, or any specific Air Quality Permit Condition(s) are not included in this table.

Description of Emissions Units / Activities	Number of Units (if appropriate)	Applicable Rules		
		Opacity Rule (b)	PM from Mfg Process Rule (e)	Fugitive Dust Rule (n)
N/A	N/A	N/A	N/A	N/A

The following table includes groups of fuel burning equipment subject only to Georgia Rules 391-3-1-.02 (2) (b) & (d). Any emissions unit subject to a NESHAP, NSPS, or any specific Air Quality Permit Condition(s) are not included in this table.

Description of Fuel Burning Equipment	Number of Units
Fuel burning equipment with a rated heat input capacity of less than 10 million BTU/hr burning only natural gas and/or LPG.	0
Fuel burning equipment with a rated heat input capacity of less than 5 million BTU/hr, burning only distillate fuel oil, natural gas and/or LPG.	0
Any fuel burning equipment with a rated heat input capacity of 1 million BTU/hr or less.	0

ATTACHMENT C

LIST OF REFERENCES

1. The Georgia Rules for Air Quality Control Chapter 391-3-1. All Rules cited herein which begin with 391-3-1 are State Air Quality Rules.
2. Title 40 of the Code of Federal Regulations; specifically 40 CFR Parts 50, 51, 52, 60, 61, 63, 64, 68, 70, 72, 73, 75, 76 and 82. All rules cited with these parts are Federal Air Quality Rules.
3. *Georgia Department of Natural Resources, Environmental Protection Division, Air Protection Branch, Procedures for Testing and Monitoring Sources of Air Pollutants.*
4. *Georgia Department of Natural Resources, Environmental Protection Division, Air Protection Branch, Procedures for Calculating Air Permit Fees.*
5. Compilation of Air Pollutant Emission Factors, AP-42, Fifth Edition, Volume I: Stationary Point and Area Sources. This information may be obtained from EPA's TTN web site at www.epa.gov/ttn/chieff/ap42/index.html.
6. The latest properly functioning version of EPA's TANKS emission estimation software. The software may be obtained from EPA's TTN web site at www.epa.gov/ttn/chieff/software/tanks/index.html.
7. The Clean Air Act (42 U.S.C. 7401 et seq).
8. White Paper for Streamlined Development of Part 70 Permit Applications, July 10, 1995 (White Paper #1).
9. White Paper Number 2 for Improved Implementation of the Part 70 Operating Permits Program, March 5, 1996 (White Paper #2).

ATTACHMENT D

U.S. EPA Acid Rain Program Phase II Permit Application