



Vermont Department of Environmental Conservation

Watershed Management Division
1 National Life Drive, Main 2
Montpelier VT 05620-3522
<http://dec.vermont.gov/watershed>

Agency of Natural Resources

[phone] 802-828-1535

[fax] 802-828-1544

May 20, 2016

Mr. Doug Pastula,
Danville Selectboard
P.O. Box 183
Danville, VT 05282

Re: Draft Discharge Permit #3-1235

Dear Mr. Pastula:

We are proposing to issue you the above referenced permit for the discharge of treated wastewater from the Danville Wastewater Treatment Facility to the Water Andric. A draft of this permit is enclosed for your review and comment. Please note that there are significant changes proposed in this permit, which are discussed in the enclosed fact sheet to the permit. Of note, this permit includes the requirements of EPA's Long Island Sound Nitrogen TMDL (See Condition I.B). The TMDL requires the Town to monitor for Total Nitrogen, develop and implement a Nitrogen Optimization Plan, assess the adequacy of the Plan, and annually report the Total Nitrogen discharged from your facility. Additionally, because of ammonia and nutrient concerns, the draft permit proposes increased monitoring both of the discharge and the stream.

In order to facilitate the issuance of your permit in the shortest possible time, we are also placing it on the required 30-day public notice immediately. If we do not hear from you within 30 days of the date of this letter and if there is no response within 30 days which requires a public hearing or major permit modification, the permit will be sent to the Secretary of the Agency of Natural Resources or her designated representative for final approval and signature.

If you have questions regarding the draft permit or you wish to meet with us to discuss it, please contact Julia Butzler at (802) 490-6182.

Sincerely,

A handwritten signature in black ink that reads "Ernest F. Kelley".

Ernest F. Kelley, Manager
Wastewater Management Program

Enclosures (3)

cc:

Leslie Parker, Chief Operator - Danville
Jeff Fehrs, Wastewater Management Program VT DEC

AGENCY OF NATURAL RESOURCES
DEPARTMENT OF ENVIRONMENTAL CONSERVATION
WATERSHED MANAGEMENT DIVISION
ONE NATIONAL LIFE DRIVE, MAIN BUILDING, 2nd FLOOR
MONTPELIER, VT 05620-3522

Permit No.: 3-1235
PIN: SJ99-0128
NPDES No.: VT0100633

Name of Applicant: Town of Danville
P.O. Box 183
Danville, VT 05828

Expiration Date: June 30, 2021

DRAFT
DISCHARGE PERMIT

In compliance with the provisions of the Vermont Water Pollution Control Act as amended (10 V.S.A. chapter 47), the Vermont Water Pollution Control Permit Regulations as amended, and the federal Clean Water Act as amended (33 U.S.C. § 1251 *et seq.*), the Town of Danville, Vermont (hereinafter referred to as the "Permittee") is authorized by the Secretary of Natural Resources (Secretary) to discharge from the Danville Wastewater Treatment Facility to the Water Andric in accordance with the following conditions.

This permit shall become effective on August 1, 2016.

Alyssa B. Schuren, Commissioner
Department of Environmental Conservation

By: _____ Date: _____
Ernest F. Kelley, Program Manager
Wastewater and Residuals Management Program
Watershed Management Division

I. SPECIAL CONDITIONS

A. EFFLUENT LIMITS

1. Until June 30, 2021, the Permittee is authorized to discharge from outfall serial number S/N 001 of the Danville Wastewater Treatment Facility to the Water Andric, an effluent for which the characteristics shall not exceed the values listed below:

EFFLUENT CHARACTERISTICS	DISCHARGE LIMITATIONS							
	Annual Average	Monthly Average	Weekly Average	Maximum Day	Monthly Average	Weekly Average	Maximum Day	Instantaneous Maximum
	Mass (lbs/day)				Concentration (mg/L)			

Flow	0.060 MGD							
Ultimate Oxygen Demand (UOD) ¹	As necessary to meet the Vermont Water Quality Standards							
Biochemical Oxygen Demand (5-day, 20° C) (BOD ₅) ²		15	22.5		45	45	50	
Total Suspended Solids (TSS) ²		15	22.5		45	45	50	
Total Phosphorus (TP)							Monitor only	
Total Nitrogen (TN) ^{3,4}	See Special Condition I.B						Monitor only	
Total Kjeldahl Nitrogen (TKN)							Monitor only	
Nitrate/Nitrite Nitrogen (NO _x)							Monitor only	
Ammonia (NH ₃)							Monitor only	
Settleable Solids								1.0 mL/L
<i>Escherichia coli</i>								77/100 mL
pH					Between 6.5-8.5 Standard Units			

¹ During the period of June 1 through September 30, the discharge of UOD shall be restricted in accordance with the calculations and requirements specified in Section I.H.5 of this permit, and in no case shall the discharge exceed the BOD₅ limitation specified above.

² The Permittee shall comply with the mass limitations or the concentration limitations, whichever is more restrictive.

³ TN = TKN + NO_x

⁴ See Total Nitrogen Form WR-43-TN

2. The effluent shall not have concentrations or combinations of contaminants including oil, grease, scum, foam, or floating solids which would cause a violation of the Vermont Water Quality Standards.
3. The effluent shall not cause visible discoloration of the receiving waters.
4. The monthly average concentrations of Biochemical Oxygen Demand (BOD₅) and Total Suspended Solids (TSS) in the effluent shall not exceed 15 percent of the monthly average concentrations of BOD₅ and TSS in the influent into the Permittee's wastewater treatment facility. For the purposes of determining whether the Permittee is in compliance with this condition, samples from the effluent and the influent shall be taken with appropriate allowance for detention times.
5. If the effluent discharged for a period of 90 consecutive days exceeds 80 percent of the permitted flow limitation, the Permittee shall submit to the Agency projected loadings and a program for maintaining satisfactory treatment levels consistent with approved water quality management plans.
6. The Permittee shall clean the quartz sleeves of the ultraviolet (UV) light disinfection system at a frequency that assures that effective disinfection is maintained and the Permittee shall replace the UV light disinfection system lamps as necessary to maintain compliance with the *E. coli* bacteria limitation. **The dates and a description of the UV light disinfection system maintenance activities shall be included on the applicable Discharge Monitoring Report (DMR) form WR-43.**
7. Any action on the part of the Agency in reviewing, commenting upon or approving plans and specifications for the construction of wastewater treatment facilities shall not relieve the Permittee from the responsibility to achieve effluent limitations set forth in this permit and shall not constitute a waiver of, or act of estoppel against any remedy available to the Agency, the State of Vermont or the federal government for failure to meet any requirement set forth in this permit or imposed by state or federal law.

B. TOTAL NITROGEN

1. Optimization Plan

By **December 31, 2016**, the Permittee shall develop and submit to the Agency of Natural Resources (Agency) for review and approval a Nitrogen Removal Optimization Evaluation Plan for the evaluation of alternative methods of operating the existing wastewater treatment facility to optimize the removal of nitrogen. The methods to be evaluated include: operational, process, equipment changes designed to enhance nitrification and denitrification (seasonal and year-round); incorporation of anoxic zones; septage receiving policies and procedures; and side stream management. The Permittee shall implement these recommended operational changes to maintain the existing mass discharge loading of total nitrogen (TN). The baseline annual average daily TN load discharge from this facility is estimated to be **approximately 12 lbs/day**.

This plan shall be developed by a qualified professional with experience in the operation and/or design of municipal wastewater treatment facilities in conjunction with the Chief Operator of the facility.

This plan shall be provided to the Agency for review and approval prior to implementation and shall be revised by the Permittee upon the Agency's request to address equipment or operational changes.

Implementation of the plan shall commence within 30 days of its approval by the Agency.

2. Plan Evaluation

Within one year following the implementation, the Permittee shall evaluate the effectiveness of the plan. The evaluation shall be conducted by a qualified professional with experience in the operation and/or design of municipal wastewater treatment facilities in conjunction with the Chief Operator of the facility. The results of the evaluation shall be submitted to the Agency for review and approval within one year and six months following the implementation of the plan and shall be revised at the Agency's request. Actions to implement the approved nitrogen removal optimization practices, if any, shall be initiated within 90 days of the Agency's approval.

3. Reporting

Annually, the Permittee shall submit a report to the Agency as an attachment to the **December** DMR form WR-43 that documents the annual average TN discharged (in pounds per day) from the facility, summarizes nitrogen removal optimization and efficiencies, and tracks trends relative to the previous year. The first annual report shall include data collected during 2017, and shall be attached to the December 2017 DMR form WR-43.

TN = Total Kjeldahl Nitrogen (TKN) + Nitrite/Nitrate (NO_x).

TN pounds per day, annual average, shall be calculated as follows:

1. Calculate the pounds of TN discharged on each sample date:

$$\text{TN (lbs/day)} = \text{TN (mg/L)} \times \text{volume discharged (million gallons) on day of sample} \times 8.34$$

2. Calculate the TN, pounds per day, annual average:

$$\text{TN (lbs/day, annual average)} = (\text{Sum of all TN [lbs/day]}) / (\text{count of TN samples})$$

4. Wasteload Allocation

This permit does not establish a formal Waste Load Allocation for the facility nor does it convey any right to ownership of the facility's estimated baseline annual average TN load.

The Agency reserves the right to reopen and amend this permit to include an alternate TN limitation and/or additional monitoring requirements based on the monitoring data, the results

of nitrogen optimization activities, or a formal Waste Load Allocation promulgated under Vermont's Waste Load Allocation Rule for Total Nitrogen in the Connecticut River Watershed based on the Long Island Sound Total Nitrogen Total Maximum Daily Load.

C. WASTE MANAGEMENT ZONE

In accordance with 10 V.S.A. § 1252, this permit hereby establishes a waste management zone that extends from the outfall of the Danville Wastewater Treatment Facility in the Water Andric downstream 1 mile.

D. REAPPLICATION

If the Permittee desires to continue to discharge after the expiration of this permit, the Permittee shall reapply on the application forms then in use at least 180 days before this permit expires.

Reapply for a Discharge Permit by: December 31, 2020

E. OPERATING FEES

This discharge is subject to operating fees as required by 3 V.S.A. § 2822.

F. INSTREAM MONITORING

The Permittee shall perform biological and water quality monitoring in the Water Andric above and below the Danville Wastewater Treatment Facility outfall S/N 001. The Permittee shall submit a study plan, outlining the locations of the collections, sampling methodology, and analysis of the data, to the Agency's Monitoring, Assessment and Planning Program for approval before sampling begins.

1. The Permittee shall perform macroinvertebrate assessments during **September 2016**. The biological data shall be submitted electronically (Excel); taxonomic data shall be submitted using VT taxonomic codes. The results of the 2016 assessment shall be submitted as an attachment to the **March 2017 DMR form WR-43**.

If the biological conditions below the outfall do not achieve Class B standards for aquatic biota and aquatic habitat uses for Small High Gradient stream types, the Permittee shall optimize the operation of the facility, to the extent feasible, to eliminate the instream toxic impact or the instream excursion above the water quality standards due to this discharge.

2. The Permittee shall perform macroinvertebrate assessments during **September 2018**. The biological data shall be submitted electronically (Excel); taxonomic data shall be submitted using VT taxonomic codes. The results of the 2018 assessment shall be submitted as an attachment to the **March 2019 DMR form WR-43**.

If the biological conditions below the outfall do not achieve Class B standards for aquatic biota and aquatic habitat uses for Small High Gradient stream types, the Permittee shall

optimize the operation of the facility, to the extent feasible, to eliminate the instream toxic impact or the instream excursion above the water quality standards due to this discharge

3. The Permittee shall monitor TP, pH, turbidity and DO **during the months of June through October of 2016, 2017 and 2018**. Sampling shall occur once per month. Streamflow characteristics should be documented for each sample collection. The results of the sampling shall be submitted as an attachment to the **appropriate DMR form WR-43**.

The Agency reserves the right to reopen and amend this permit to include additional monitoring or effluent limitations

G. WHOLE EFFLUENT TOXICITY (WET) TESTING

During **August or September 2016**, the Permittee shall conduct a two-species (*Pimephales promelas* and *Ceriodaphnia dubia*) acute WET test on a composite effluent sample collected from S/N 001. The results shall be submitted to the Agency by **December 31, 2016**.

The WET tests shall be conducted according to the procedures and guidelines specified in "Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms" (October 2002 or, if a newer edition is available, the most recent edition) U.S. EPA document.

Based upon the results of these tests or any other toxicity tests conducted, the Agency reserves the right to reopen and amend this permit to require additional WET testing or a Toxicity Reduction Evaluation be conducted.

H. MONITORING AND REPORTING

1. Sampling and Analysis

The sampling, preservation, handling, and analytical methods used shall conform to the test procedures published in 40 C.F.R. Part 136.

Samples shall be representative of the volume and quality of effluent discharged over the sampling and reporting period. All samples are to be taken during normal operating hours. The Permittee shall identify the effluent sampling location used for each discharge.

2. Effluent Monitoring

The Permittee shall monitor and record the quality and quantity of discharge(s) at outfall serial number S/N 001 of the Danville Wastewater Treatment Facility, according to the following schedule and other provisions: until June 30, 2021

For the period of October 1 through May 14:

PARAMETER	MINIMUM FREQUENCY OF ANALYSIS	SAMPLE TYPE
-----------	-------------------------------	-------------

Flow	Continuous	Daily Total, Max., Min.
Biochemical Oxygen Demand (BOD ₅) ¹	1 × month	composite
Total Suspended Solids (TSS) ¹	1 × month	composite
Total Phosphorus (TP) ¹	1 × month	composite
Total Nitrogen (TN) ^{2,3}	1 × month	[calculated]
Total Kjeldahl Nitrogen (TKN) ^{1,3}	1 × month	composite
Nitrate/Nitrite Nitrogen (NO _x) ^{1,3}	1 × month	composite
Ammonia (NH ₃)	1 × month	grab
Settleable Solids ⁴	1 × day	grab
<i>Escherichia coli</i>	2 × month	grab
pH	1 × day	grab

¹ Composite samples for BOD₅, TSS, TP, TKN and NO_x shall, at a minimum, be taken during the hours 6:00 AM to 6:00 PM, unless otherwise specified. Eight hours is the minimum period for the composite, 24 hours is the maximum for the composite.

² TN = TKN + NO_x

³ Submit results on Total Nitrogen Monitoring Report Form WR-43-TN.

⁴ Settleable Solids samples shall be collected between 10:00 AM and 2:00 PM or during the period of peak flow.

For the period of May 15 through September 30:

PARAMETER	MINIMUM FREQUENCY OF ANALYSIS	SAMPLE TYPE
Stream Flow ¹	Daily	Instantaneous
Calculated Effluent Flow ¹	Daily	Calculated
Flow	Continuous	Daily Total, Max., Min.
Biochemical Oxygen Demand (BOD ₅) ^{2,3}	2 × month	composite
Total Suspended Solids (TSS) ²	1 × month	composite
Total Phosphorus (TP) ²	1 × month	composite
Total Nitrogen (TN) ^{4,5}	1 × month	[calculated]
Total Kjeldahl Nitrogen (TKN) ^{2,3,5}	2 × month	composite
Nitrate/Nitrite Nitrogen (NO _x) ^{2,5}	1 × month	composite
Ammonia (NH ₃)	1 × month	grab
Settleable Solids ⁶	1 × day	grab
<i>Escherichia coli</i>	2 × month	grab
pH	1 × day	grab

¹ Stream Flow and Calculated Effluent Flow monitoring is only required from June 1st through September 30th.

² Composite samples for BOD₅, TSS, TP, TKN and NO_x shall, at a minimum, be taken during the hours 6:00 AM to 6:00 PM, unless otherwise specified. Eight hours is the minimum period for the composite, 24 hours is the maximum for the composite.

³ BOD₅ and TKN samples shall be collected during the first and third weeks of each month. BOD₅ and TKN samples do not have to be collected for the third week in September.

⁴ TN = TKN + NO_x

⁵ Submit results on Total Nitrogen Monitoring Report Form WR-43-TN.

⁶ Settleable Solids samples shall be collected between 10:00 AM and 2:00 PM or during the period of peak flow.

3. Influent Monitoring

The Permittee shall monitor the quality of the influent according to the following schedule and other provisions.

PARAMETER	MINIMUM FREQUENCY OF ANALYSIS	SAMPLE TYPE
Biochemical Oxygen Demand (BOD ₅) ¹	1 × month	composite
Total Suspended Solids (TSS) ¹	1 × month	composite
Total Nitrogen (TN) ^{2,3}	1 × quarter	[calculated]
Total Kjeldahl Nitrogen (TKN) ^{1,3,4}	1 × quarter	composite
Nitrate/Nitrite Nitrogen (NO _x) ^{1,3,4}	1 × quarter	composite

¹ Composite samples for BOD₅, TSS, TKN and NO_x shall, at a minimum, be taken during the hours 6:00 AM to 6:00 PM, unless otherwise specified. Eight hours is the minimum period for the composite, 24 hours is the maximum for a composite.

² TN = TKN + NO_x

³ Submit results on Total Nitrogen Monitoring Report Form WR-43-TN.

⁴ The influent TKN and NO_x sample shall be collected on the same day as an effluent TKN and NO_x sample.

4. Stream Flow Monitoring

- a. During the period of June 1st through September 30th, the Permittee shall monitor and record, on a daily basis, the stream flow of the Water Andric at the gauging station located immediately upstream of the wastewater treatment facility outfall. Stream flow results shall be recorded as cubic feet per second (CFS) and reported on the DMR form WR-43.
- b. **By December 31, 2016**, the Permittee, in conjunction with a qualified professional, shall perform a calibration on the gauging station. The Permittee shall determine a long-term schedule to calibrate or verify the gauging station at intervals sufficient to ensure acceptable accuracy and reliability. The proposed schedule shall be submitted by December 31, 2016.
- c. The Permittee shall actively maintain the gauging station to control and address any factors that could affect stream flow measurements.

5. Calculating Allowable Discharge Volume

During the period of June 1st through September 30th, the Permittee shall restrict the discharge volume from the wastewater treatment facility in order to meet the Ultimate Oxygen Demand (UOD) permit limitations in accord with the equations and conditions specified here (an example calculation is provided in Attachment A):

Step 1: Determine the UOD of the wastewater from the previous BOD₅ and TKN values as follows:

$$\text{UOD (mg/L)} = (1.43 \times \text{BOD}_5 \text{ (mg/L)}) + (4.57 \times \text{TKN (mg/L)})$$

Step 2: Using the UOD value calculated following the instructions above, the daily stream flow measurement, and the equation specified below, the Permittee shall calculate and record, on a daily basis, the allowable discharge volume from the wastewater treatment facility

$$\text{Allowable Discharge Volume (MGD)} = \frac{100 \times Q_s}{\text{UOD (mg/L)} \times 8.34}$$

where,

Q_s = daily stream flow measurement in cubic feet per second (CFS)

Step 3: The Permittee shall adjust the discharge volume at the ball valve on the discharge line (located in the UV room) on a daily basis (or as necessary) such that the actual discharge volume does not exceed the calculated discharge volume.

6. Reporting

The Permittee is required to submit monthly reports of monitoring results on DMR form WR-43. Reports are due on the 15th day of each month, beginning with the month following the effective date of this permit.

If, in any reporting period, there has been no discharge, the Permittee must submit that information by the report due date.

Signed copies of these, and all other reports required herein, shall be submitted to the Secretary at the following address:

Agency of Natural Resources
Department of Environmental Conservation
Watershed Management Division
One National Life Drive, Main Building, 2nd Floor
Montpelier, VT 05620-3522

All reports shall be signed:

- a. In the case of corporations, by a principal executive officer of at least the level of vice president, or his/her duly authorized representative, if such representative is responsible for the overall operation of the facility from which the discharge described in the permit form originates and the authorization is made in writing and submitted to the Agency;
- b. In the case of a partnership, by a general partner;
- c. In the case of a sole proprietorship, by the proprietor; or

- d. In the case of a municipal, State, or other public facility, by either a principal executive officer, ranking elected official, or other duly authorized employee.

In addition to the monitoring and reporting requirements given above, daily monitoring of certain parameters for operational control shall be submitted to the Agency on the DMR form WR-43. Operations reports shall be submitted monthly.

7. Recording of Results

The Permittee shall maintain records of all information resulting from any monitoring activities required, including:

- a. The exact place, date, and time of sampling or measurement;
- b. The individual(s) who performed the sampling or measurements;
- c. The dates and times the analyses were performed;
- d. The individual(s) who performed the analyses;
- e. The analytical techniques and methods used including sample collection handling and preservation techniques;
- f. The results of such analyses;
- g. The records of monitoring activities and results, including all instrumentation and calibration and maintenance records; and
- h. The original calculation and data bench sheets of the operator who performed analysis of the influent or effluent pursuant to requirements of Section I.A of this permit.

The results of monitoring requirements shall be reported (in the units specified) on the DMR form WR-43 or other forms approved by the Agency.

8. Additional Monitoring

If the Permittee monitors any pollutant at the location(s) designated herein more frequently than required by this permit, using approved analytical methods as specified above, the results of such monitoring shall be included in the calculation and reporting of the values required in the DMR form WR-43. Such increased frequency shall also be indicated.

I. DRY WEATHER FLOWS

Dry weather flows of untreated municipal wastewater from any sanitary or combined sewers are not authorized by this permit and are specifically prohibited by state and federal laws and regulations.

J. OPERATION, MANAGEMENT, AND EMERGENCY RESPONSE PLANS

1. The Permittee shall implement the Operation, Management, and Emergency Response Plan for the wastewater treatment facility, pump stations, and stream crossings as approved by the Agency on August 7, 2008.
2. The Permittee shall implement the Operation, Management, and Emergency Response Plan for the sewage collection system upon approval by the Agency.

The Permittee shall revise these plans upon the Agency's request or on its own motion to reflect equipment or operational changes.

K. EMERGENCY ACTION - ELECTRIC POWER FAILURE

The Permittee shall indicate in writing to the Agency **within 30 days after the effective date of this permit** that the discharge shall be handled in such a manner that, in the event the primary source of electric power to the wastewater treatment facility (including pump stations) fails, any discharge into the receiving waters will attempt to comply with the conditions of this permit, but in no case shall the wastes receive less than primary treatment (or in the case of ultraviolet light disinfection systems, not less than secondary treatment) plus disinfection.

The Permittee shall either provide an alternative source of power for the operation of its wastewater treatment facility, or demonstrate that the treatment facility has the capacity to store the wastewater volume that would be generated over the duration of the longest power failure that would have affected the facility in the last five years, excluding catastrophic events.

The alternative power supply, whether from a generating unit located at the wastewater treatment facility or purchased from an independent source of electricity, must be separate from the existing power source used to operate the wastewater treatment facility. If a separate unit located at the wastewater treatment facility is to be used, the Permittee shall certify in writing to the Agency when the unit is completed and prepared to generate power.

The determination of treatment system storage capacity shall be submitted to the Agency upon completion.

L. SEWER ORDINANCE

The Permittee shall have in effect a sewer use ordinance acceptable to the Agency which, at a minimum, shall

1. Prohibit the introduction by any person into the Permittee's sewerage system or wastewater treatment facility of any pollutant which:
 - a. Is a toxic pollutant in toxic amounts as defined in standards issued from time to time under Section 307(a) of the Clean Water Act;
 - b. Creates a fire or explosion hazard in the Permittee's treatment works;

- c. Causes corrosive structural damage to the Permittee's treatment works, including all wastes with a pH lower than 5.0;
 - d. Contains solid or viscous substances in amounts which would cause obstruction to the flow in sewers or other interference with proper operation of the Permittee's treatment works; or
 - e. In the case of a major contributing industry, as defined in this permit, contains an incompatible pollutant, as defined in this permit, in an amount or concentration in excess of that allowed under standards or guidelines issued from time to time pursuant to Sections 304, 306, and/or 307 of the Clean Water Act.
2. Require 45 days prior notification to the Permittee by any person or persons of a:
 - a. Proposed substantial change in volume or character of pollutants over that being discharged into the Permittee's treatment works at the time of issuance of this permit;
 - b. Proposed new discharge into the Permittee's treatment works of pollutants from any source which would be a new source as defined in Section 306 of the Clean Water Act if such source were discharging pollutants; or
 - c. Proposed new discharge into the Permittee's treatment works of pollutants from any source which would be subject to Section 301 of the Clean Water Act if it were discharging such pollutants.
3. Require any industry discharging into the Permittee's treatment works to perform such monitoring of its discharge as the Permittee may reasonably require, including the installation, use, and maintenance of monitoring equipment and monitoring methods, keeping records of the results of such monitoring, and reporting the results of such monitoring to the Permittee. Such records shall be made available by the Permittee to the Agency upon request.
4. Authorize the Permittee's authorized representatives to enter into, upon, or through the premises of any industry discharging into the Permittee's treatment works to have access to and copy any records, to inspect any monitoring equipment or method required under subsection 3 above, and to sample any discharge into the Permittee's treatment works.

The Permittee shall notify the Agency of any discharge specified in subsection 2 above within 30 days of the date on which the Permittee is notified of such discharge. This permit may be modified accordingly.

II. GENERAL CONDITIONS

A. MANAGEMENT REQUIREMENTS

1. Facility Modification / Change in Discharge

All discharges authorized herein shall be consistent with the terms and conditions of this permit. The discharge of any pollutant more frequently than, or at a level in excess of, that identified and authorized by this permit shall constitute a violation of the terms and conditions of this permit. Such a violation may result in the imposition of civil and/or criminal penalties pursuant to 10 V.S.A. chapters 47, 201, and/or 211. Any anticipated facility alterations or expansions or process modifications which will result in new, different, or increased discharges of any pollutants must be reported by submission of a new permit application or, if such changes will not violate the effluent limitations specified in this permit, by notice to the Agency of such changes. Following such notice, the permit may be modified to specify and limit any pollutants not previously limited.

In addition, the Permittee shall provide notice to the Agency of the following:

- a. Any new introduction of pollutants into the treatment works from a source which would be a new source as defined in Section 306 of the Clean Water Act if such source were discharging pollutants;
- b. Except for such categories and classes of point sources or discharges specified by the Agency, any new introduction of pollutants into the treatment works from a source which would be subject to Section 301 of the Clean Water Act if such source were discharging pollutants; and
- c. Any substantial change in volume or character of pollutants being introduced into the treatment works by a source introducing pollutants into such works at the time of issuance of the permit.

The notice shall include:

- i. The quality and quantity of the discharge to be introduced into the system, and
- ii. The anticipated impact of such change in the quality or quantity of the effluent to be discharged from the wastewater treatment facility.

2. Noncompliance Notification

The Permittee shall give advance notice to the Agency of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.

In the event the Permittee is unable to comply with any of the conditions of this permit due, among other reasons, to:

- a. Breakdown or maintenance of waste treatment equipment (biological and physical-chemical systems including all pipes, transfer pumps, compressors, collection ponds or tanks for the segregation of treated or untreated wastes, ion exchange columns, or carbon absorption units);
- b. Accidents caused by human error or negligence;
- c. Any unanticipated bypass or upset which exceeds any effluent limitation in the permit;
- d. Violation of a maximum day discharge limitation for any of the pollutants listed by the Agency in this permit; or
- e. Other causes such as acts of nature,

the Permittee shall notify the Agency within 24 hours of becoming aware of such condition and shall provide the Agency with the following information, in writing, within five days:

- i. Cause of non-compliance;
- ii. A description of the non-complying discharge including its impact upon the receiving water;
- iii. Anticipated time the condition of non-compliance is expected to continue or, if such condition has been corrected, the duration of the period of non-compliance;
- iv. Steps taken by the Permittee to reduce and eliminate the non-complying discharge; and
- v. Steps to be taken by the Permittee to prevent recurrence of the condition of non-compliance.

3. Operation and Maintenance

All waste collection, control, treatment, and disposal facilities shall be operated in a manner consistent with the following:

- a. The Permittee shall, at all times, maintain in good working order and operate as efficiently as possible all treatment and control facilities and systems (and related appurtenances) installed or used by the Permittee to achieve compliance with the terms and conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems which are installed by the Permittee only when the operation is necessary to achieve compliance with the conditions of this permit.
- b. The Permittee shall provide an adequate operating staff which is duly qualified to carry out the operation, maintenance, and testing functions required to insure compliance with the conditions of this permit; and

- c. The operation and maintenance of this facility shall be performed only by qualified personnel. The personnel shall be certified as required under the Vermont Wastewater Treatment Facility Operator Certification Rule.

4. Quality Control

The Permittee shall calibrate and perform maintenance procedures on all monitoring and analytical instrumentation at regular intervals to ensure accuracy of measurements, or shall ensure that both activities will be conducted.

The Permittee shall keep records of these activities and shall provide such records upon request of the Agency.

The Permittee shall demonstrate the accuracy of the effluent flow measurement device weekly and report the results on the monthly report forms. The acceptable limit of error is $\pm 10\%$.

The Permittee shall analyze any additional samples as may be required by the Agency to ensure analytical quality control.

5. Bypass

The bypass of facilities (including pump stations) is prohibited, except where authorized under the terms and conditions of an Emergency Pollution Permit issued pursuant to 10 V.S.A. § 1268. It shall not be a defense for the Permittee in an enforcement action that it would have been necessary to halt or reduce the activity in order to maintain compliance with the conditions of this permit.

6. Duty to Mitigate

The Permittee shall take all reasonable steps to minimize or prevent any adverse impact to waters of the State resulting from non-compliance with any condition specified in this permit, including accelerated or additional monitoring as necessary to determine the nature and impact of the non-complying discharge.

7. Records Retention

All records and information resulting from the monitoring activities required by this permit including all records of analyses performed, all calibration and maintenance of instrumentation records and all original chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit shall be retained for a minimum of three years, and shall be submitted to the Agency upon request. This period shall be extended during the course of unresolved litigation regarding the discharge of pollutants or when requested by the Agency.

8. Solids Management

Collected screenings, sludges, and other solids removed in the course of treatment and control of wastewaters shall be stored, treated and disposed of in accordance with 10 V.S.A. chapter 159 and with the terms and conditions of any certification, interim or final, transitional operation authorization or order issued pursuant to 10 V.S.A. chapter 159 that is in effect on the effective date of this permit or is issued during the term of this permit.

9. Emergency Pollution Permits

Maintenance activities, or emergencies resulting from equipment failure or malfunction, including power outages, which result in an effluent which exceeds the effluent limitations specified herein, shall be considered a violation of the conditions of this permit, unless the Permittee immediately applies for, and obtains, an emergency pollution permit under the provisions of 10 V.S.A. § 1268. The Permittee shall notify the Agency of the emergency situation by the next working day.

10 V.S.A. § Section 1268 reads as follows:

When a discharge permit holder finds that pollution abatement facilities require repairs, replacement or other corrective action in order for them to continue to meet standards specified in the permit, he may apply in the manner specified by the secretary for an emergency pollution permit for a term sufficient to effect repairs, replacements or other corrective action. The permit may be issued without prior public notice if the nature of the emergency will not provide sufficient time to give notice; provided that the secretary shall give public notice as soon as possible but in any event no later than five days after the effective date of the emergency pollution permit. No emergency pollution permit shall be issued unless the applicant certifies and the secretary finds that:

- (1) there is no present, reasonable alternative means of disposing of the waste other than by discharging it into the waters of the state during the limited period of time of the emergency;
- (2) the denial of an emergency pollution permit would work an extreme hardship upon the applicant;
- (3) the granting of an emergency pollution permit will result in some public benefit;
- (4) the discharge will not be unreasonably harmful to the quality of the receiving waters;
- (5) the cause or reason for the emergency is not due to wilful or intended acts or omissions of the applicant.

Application shall be made to the Secretary at the following address: Agency of Natural Resources, Department of Environmental Conservation, One National Life Drive, Main Building, 2nd Floor, Montpelier VT 05620-3522.

B. RESPONSIBILITIES

1. Right of Entry

The Permittee shall allow the Agency or authorized representative, upon the presentation of proper credentials:

- a. To enter upon the Permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;
- b. To have access to and copy, at reasonable times, any records required to be kept under the terms and conditions of this permit;
- c. To inspect, at reasonable times, any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit; and
- d. To sample or monitor, at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the Clean Water Act, any substances or parameters at any location.

2. Transfer of Ownership or Control

This permit is not transferable without prior written approval of the Agency. All application and operating fees must be paid in full prior to transfer of this permit. In the event of any change in control or ownership of facilities from which the authorized discharges emanate, the Permittee shall provide a copy of this permit to the succeeding owner or controller and shall send written notification of the change in ownership or control to the Agency **at least 30 days in advance of the proposed transfer date**. The notice to the Agency shall include a written agreement between the existing and new Permittees containing a specific date for transfer of permit responsibility, coverage, and liability between them. The Permittee shall also inform the prospective owner or operator of their responsibility to make an application for transfer of this permit.

This request for transfer application must include as a minimum:

- a. A properly completed application form provided by the Agency and the applicable processing fee.
- b. A written statement from the prospective owner or operator certifying:
 - i. The conditions of the operation that contribute to, or affect, the discharge will not be materially different under the new ownership;
 - ii. The prospective owner or operator has read and is familiar with the terms of the permit and agrees to comply with all terms and conditions of the permit; and

- iii. The prospective owner or operator has adequate funding to operate and maintain the treatment system and remain in compliance with the terms and conditions of the permit.
- c. The date of the sale or transfer.

The Agency may require additional information dependent upon the current status of the facility operation, maintenance, and permit compliance.

3. Confidentiality

Pursuant to 10 V.S.A. § 1259(b):

Any records, reports or information obtained under this permit program shall be available to the public for inspection and copying. However, upon a showing satisfactory to the secretary that any records, reports or information or part thereof, other than effluent data, would, if made public, divulge methods or processes entitled to protection as trade secrets, the secretary shall treat and protect those records, reports or information as confidential. Any records, reports or information accorded confidential treatment will be disclosed to authorized representatives of the state and the United States when relevant to any proceedings under this chapter.

Claims for confidentiality for the following information will be denied:

- a. The name and address of any permit applicant or Permittee.
- b. Permit applications, permits, and effluent data.
- c. Information required by application forms, including information submitted on the forms themselves and any attachments used to supply information required by the forms.

4. Permit Modification, Suspension, and Revocation

After notice and opportunity for a hearing, this permit may be modified, suspended, or revoked in whole or in part during its term for cause including the following:

- a. Violation of any terms or conditions of this permit;
- b. Obtaining this permit by misrepresentation or failure to disclose fully all relevant facts;
or
- c. A change in any condition that requires either a temporary or permanent reduction or elimination of the permitted discharge.

The filing of a request by the Permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance shall not stay any permit condition.

The Permittee shall provide to the Agency, within a reasonable time, any information which the Agency may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit or to determine compliance with this permit. The Permittee shall also furnish to the Agency upon request, copies of records required to be kept by this permit.

5. Toxic Effluent Standards

If a toxic effluent standard or prohibition (including any schedule of compliance specified in such effluent standard or prohibition) is established under section 307(a) of the Clean Water Act for a toxic pollutant which is present in the Permittee's discharge and such standard or prohibition is more stringent than any limitation upon such pollutant in this permit, then this permit shall be modified or revoked and reissued in accordance with the toxic effluent standard or prohibition and the Permittee so notified.

6. Oil and Hazardous Substance Liability

Nothing in this permit shall be construed to preclude the institution of legal action or relieve the Permittee from any responsibilities, liabilities, or penalties to which the Permittee is or may be subject under 10 V.S.A. § 1281.

7. Other Materials

Other materials ordinarily produced or used in the operation of this facility, which have been specifically identified in the application, may be discharged at the maximum frequency and maximum level identified in the application, provided:

- a.** They are not:
 - i.** Designated as toxic or hazardous under provisions of Sections 307 and 311, respectively, of the Clean Water Act, or
 - ii.** Known to be hazardous or toxic by the Permittee, except that such materials indicated in (a) and (b) above may be discharged in certain limited amounts with the written approval of, and under special conditions established by, the Agency or his designated representative, if the substances will not pose any imminent hazard to the public health or safety;
- b.** The discharge of such materials will not violate the Vermont Water Quality Standards; and
- c.** The Permittee is not notified by the Agency to eliminate or reduce the quantity of such materials entering the watercourse.

8. Navigable Waters

This permit does not authorize or approve the construction of any onshore or offshore physical structures or facilities or the undertaking of any work in any navigable waters.

9. Civil and Criminal Liability

Except as provided in “Emergency Action – Electric Power Failure” (Section I.K), “Bypass” (Section II.A.5), and “Emergency Pollution Permits” (Section II.A.9), nothing in this permit shall be construed to relieve the Permittee from civil or criminal penalties for noncompliance. Civil and criminal penalties for non-compliance are provided for in 10 V.S.A. Chapters 47, 201, and 211.

10. State Laws

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the Permittee from any responsibilities, liabilities, or penalties established pursuant to any applicable state law or regulation under authority preserved by Section 510 of the Clean Water Act.

11. Property Rights

Issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of federal, state, or local laws or regulations.

12. Other Information

If the Permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Agency, it shall promptly submit such facts or information.

13. Severability

The provisions of this permit are severable, and if any provision of this permit, or the application of any provision of this permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.

14. Authority

This permit is issued under authority of 10 V.S.A. §§1258 and 1259 of the Vermont Water Pollution Control Act, the Vermont Water Pollution Control Permit Regulation, and Section 402 of the Clean Water Act, as amended.

15. Definitions

For purposes of this permit, the following definitions shall apply.

Agency – The Vermont Agency of Natural Resources

Annual Average - The highest allowable average of daily discharges calculated as the sum of all daily discharges (mg/L, lbs or gallons) measured during a calendar year divided by the number of daily discharges measured during that year.

Average - The arithmetic means of values taken at the frequency required for each parameter over the specified period.

Bypass – The intentional diversion of waste streams from any portion of the treatment facility.

The Clean Water Act - The federal Clean Water Act, as amended (33 U.S.C. § 1251, *et seq.*).

Composite Sample - A sample consisting of a minimum of one grab sample per hour collected during a 24-hour period (or lesser period as specified in the section on Monitoring and Reporting) and combined proportionally to flow over that same time period.

Daily Discharge - The discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling.

For pollutants with limitations expressed in pounds the daily discharge is calculated as the total pounds of pollutants discharged over the day.

For pollutants with limitations expressed in mg/L the daily discharge is calculated as the average measurement of the pollutant over the day.

Discharge – Any wastes, directly or indirectly, that are placed, deposited or emitted into waters of the state.

Grab Sample - An individual sample collected in a period of less than 15 minutes.

Incompatible Substance – Any waste being discharged into the treatment works which interferes with, passes through without treatment, or is otherwise incompatible with said works or would have a substantial adverse effect on the works or on water quality. This includes all pollutants required to be regulated under the Clean Water Act.

Instantaneous Maximum - A value not to be exceeded in any grab sample.

Major Contributing Industry - One that: (1) has a flow of 50,000 gallons or more per average work day; (2) has a flow greater than five percent of the flow carried by the municipal system receiving the waste; (3) has in its wastes a toxic pollutant in toxic

amounts as defined in standards issued under Section 307(a) of the Clean Water Act; or (4) has a significant impact, either singly or in combination with other contributing industries, on a publicly owned treatment works or on the quality of effluent from that treatment works.

Maximum Day (maximum daily discharge limitation) - The highest allowable “daily discharge” (mg/L, lbs or gallons).

Mean - The mean value is the arithmetic mean.

Monthly Average (Average monthly discharge limitation) - The highest allowable average of daily discharges (mg/L, lbs or gallons) over a calendar month, calculated as the sum of all daily discharges (mg/L, lbs or gallons) measured during a calendar month divided by the number of daily discharges measured during that month.

NPDES - The National Pollutant Discharge Elimination System.

Secretary - The Secretary of the Agency of Natural Resources

State Certifying Agency Agency of Natural Resources
Department of Environmental Conservation
Watershed Management Division
One National Life Drive, Main Building, 2nd Floor
Montpelier, VT 05620-3522

Waste – Effluent, sewage or any substance or material, liquid, gaseous, solid or radioactive, including heated liquids, whether or not harmful or deleterious to waters.

Waste Management Zone – A specific reach of Class B waters designated by a permit to accept the discharge of properly treated wastes that prior to treatment contained organisms pathogenic to human beings. Throughout the receiving waters, water quality criteria must be achieved but increased health risks exist due to the authorized discharge.

Weekly Average - (Average weekly discharge limitation) - The highest allowable average of daily discharges (mg/L, lbs or gallons) over a calendar week, calculated as the sum of all daily discharges (mg/L, lbs or gallons) measured during a calendar week divided by the number of daily discharges measured during that week.

This is an example of how to use the equations in Condition I.G.5 of this permit to restrict the Danville Wastewater Treatment Facility effluent flow during June 1 through September 30 to ensure that the discharge does not cause water quality violations.

On June 1st, the operator shall begin daily monitoring of the stream flow at the staff gauge on the Water Andric and restrict effluent flow by using the following procedure:

1. Using **BOD₅** and **TKN** results from the samples collected during the third week in May:

$$\mathbf{BOD_5} = 25 \text{ mg/L}$$

$$\mathbf{TKN} = 20 \text{ mg/L}$$

the operator shall calculate a **UOD** value to be used for the first half of the month of June:

$$\begin{aligned} \mathbf{UOD} &= (1.43 \times \mathbf{BOD_5} \text{ (mg/L)}) + (4.57 \times \mathbf{TKN} \text{ (mg/L)}) \\ &= (1.43 \times 25) + (4.57 \times 20) \\ &= 127.2 \text{ mg/L} \end{aligned}$$

2. Using this calculated **UOD** value and the stream flow (**Q_s**) of the Water Andric on June 1st:

$$\mathbf{UOD} = 127.2 \text{ mg/L}$$

$$\mathbf{Q_s} = 0.558 \text{ CFS}$$

the operator shall calculate the permitted discharge volume:

$$\begin{aligned} \mathbf{Allowable Discharge Volume (MGD)} &= \frac{100 \times \mathbf{Q_s}}{\mathbf{UOD} \text{ (mg/L)} \times 8.34} \\ &= \frac{100 \times 0.558}{127.2 \times 8.34} \\ &= 0.526 \text{ MGD} \end{aligned}$$

The stream flow shall be monitored daily, and used to calculate a new **Allowable Discharge Volume** *each day*. The same calculated **UOD** value shall also be used for June 2nd through June 15th. A new **UOD** value to be used in the second half of the month shall be calculated using the most recent **BOD₅** and **TKN** values (i.e., the samples collected during the first week in June).

AGENCY OF NATURAL RESOURCES
DEPARTMENT OF ENVIRONMENTAL CONSERVATION
WATERSHED MANAGEMENT DIVISION
ONE NATIONAL LIFE DRIVE, MAIN BUILDING, 2ND FLOOR
MONTPELIER, VT 05620-3522

FACT SHEET
(May 2016)

**DRAFT NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES) PERMIT
TO DISCHARGE TO WATERS OF THE UNITED STATES**

PERMIT NO: 3-1235
PIN: SJ99-0128
NPDES NO: VT0100633

NAME AND ADDRESS OF APPLICANT:

Town of Danville
P.O. Box 183
Danville, VT 05828

NAME AND ADDRESS OF FACILITY WHERE DISCHARGE OCCURS:

Danville Wastewater Treatment Facility
Danville, Vermont

RECEIVING WATER: Water Andric

CLASSIFICATION: Class B with a waste management zone. Class B waters are suitable for swimming and other forms of water-based recreation and irrigation of crops and other agricultural uses without treatment; good aesthetic value; aquatic biota and wildlife sustained by high quality aquatic habitat; suitable for boating, fishing, and other recreational uses; acceptable for public water supply with filtration and disinfection. A waste management zone is a specific reach of Class B waters designated by a permit to accept the discharge of properly treated wastes that prior to treatment contained organisms pathogenic to human beings.

I. Proposed Action, Type of Facility, and Discharge Location

The Vermont Agency of Natural Resources (Agency) received a renewal application for the permit to discharge into the designated receiving water from the above named applicant on June 29, 2011. At this time the Agency has made a tentative decision to reissue the discharge permit. The facility is engaged in the treatment of municipal wastewater. The discharge is from the outfall of the Town of Danville's Wastewater Treatment Facility to the Water Andric.

II. Description of Discharge

A quantitative description of the discharge in terms of significant effluent parameters is based on state and federal laws and regulations, the discharge permit application, and the recent self-monitoring data.

III. Limitations and Conditions

The effluent limitations of the draft permit, the monitoring requirements, and any implementation schedule (if required), may be found on the following pages of the draft permit:

Effluent Limitations:	Page 2
Monitoring Requirements:	Pages 6-10

IV. Receiving Water

The receiving water for this discharge is the Water Andric, a designated Cold Water Fish Habitat. At the point of discharge, the river has a contributing drainage area of 2.05 square miles. The summer 7Q10 flow of the river is estimated to be 0.54 cubic feet per second (CFS) and the summer Low Median Monthly flow is estimated to be 1.14 CFS. The instream waste concentration at the summer 7Q10 flow is 0.146 (14.6%) and the instream waste concentration at the summer Low Median Monthly flow is 0.076 (7.6%).

V. Facility History and Background

The Town of Danville owns and operates the Danville Wastewater Treatment Facility. The facility is an aerated lagoon system, and utilizes ultraviolet lamp disinfection system. The collection system services the Danville village area, with extensions out Peacham Road, Walden Hill Road, Crystal Avenue, Route 2 East and the Sugar Ridge development.

VI. Permit Basis and Explanation of Effluent Limitation Derivation

Flow – The effluent flow limitation remains at 0.060 MGD, annual average, based on the facility's design flow.

Ultimate Oxygen Demand (UOD) – The permit requires the Permittee to restrict the discharge of oxygen-demanding pollutants during the summer months (June 1 through September 30) due to the extremely limited assimilative capacity of the Water Andric (approximately 15 lbs of UOD at a low flow of 0.15 CFS). Discharge restrictions are based on the UOD content of the effluent and the daily stream flows of the Water Andric. This draft permit proposes to utilize the same procedure as the current permit to determine the allowable daily discharge volume during the summer months. The formulae are found in Section I.H.5 of the draft permit.

Biochemical Oxygen Demand (BOD₅) – The effluent limitations for BOD₅ remain unchanged from the current permit. The monthly average (45 mg/L) and weekly average (45 mg/L) reflect the minimum level of effluent quality specified for treatment equivalent to secondary treatment (aerated lagoons) in 40 CFR Part 133.105. In addition, the draft permit contains a 50 mg/L, maximum day, BOD₅ limitation. This is the Agency standard applied to all such discharges

pursuant to 13.4 c. of the Vermont Water Pollution Control Permit Regulations. The Agency implements the limit to supplement the federal technology based limitations to prevent a gross one-day permit effluent violation to be offset by multiple weekly and monthly sampling events which would enable a discharger to comply with the weekly average and monthly average permit limitations. Mass limits (15 lbs/day, monthly average and 22.5 lbs/day, weekly average), established in the discharge permit issued in 1983 for the recently constructed facility, were derived by multiplying the then-permitted concentration limits (30 and 45 mg/L, respectively) by the permitted flow. The BOD₅ monitoring requirements are unchanged from the current permit, remaining once per month for the period of October 1 through May 14, and twice per month during the summer months.

Total Suspended Solids (TSS) – The effluent limitations for TSS remain unchanged from the current permit. The monthly average (45 mg/L) and weekly average (45 mg/L) reflect the minimum level of effluent quality specified for treatment equivalent to secondary treatment (aerated lagoons) in 40 CFR Part 133.105. In addition, the draft permit contains a 50 mg/L, maximum day, TSS limitation. This is the Agency standard applied to all such discharges pursuant to 13.4 c. of the Vermont Water Pollution Control Permit Regulations. The Agency implements the limit to supplement the federal technology based limitations to prevent a gross one-day permit effluent violation to be offset by multiple weekly and monthly sampling events which would enable a discharger to comply with the weekly average and monthly average permit limitations. Mass limits (15 lbs/day, monthly average and 22.5 lbs/day, weekly average), established in the discharge permit issued in 1988, were derived by multiplying the then-permitted concentration limits (30 and 45 mg/L, respectively) by the permitted flow. The TSS monthly monitoring requirement is unchanged from the current permit.

Total Phosphorus (TP) – In light of the recent adoption of numeric water quality criteria for phosphorus, the Agency is including requirements in discharge permits to monitor for discharges of TP. For future permit reissuance, the criteria will be used to determine the potential of discharges to cause or contribute to eutrophication and/or to adversely impact the aquatic biota downstream of the discharge. The Permittee shall monitor the discharge for TP once per month to be consistent with wastewater treatment facilities of similar size in Vermont.

Total Nitrogen (TN) – On November 10, 2011, a letter from the EPA (Region I) to the Agency indicated that Vermont must establish TN limitations in permits such that the TN load from all facilities in the Connecticut River watershed is consistent with the requirements of the Long Island Sound Total Maximum Daily Load (TMDL).

Section I.B in this draft permit requires the Permittee have a qualified professional develop and submit a Nitrogen Removal Optimization Evaluation Plan by December 31, 2016. The plan shall be provided to the Agency before implementation. Additionally, an annual report will be due to the Agency documenting the pounds of TN discharged as well as removal optimization and efficiencies; the first annual report shall be submitted by January 15, 2018, as an attachment to the December 2017 DMR WR-43 report. Finally, this Condition contains a clause that allows the Agency to reopen the permit to include a wasteload allocation for this facility based on the LIS TMDL.

TN is a calculated value based on Total Kjeldahl Nitrogen (TKN) and Nitrate/Nitrite (NO_x) Nitrogen. Monthly monitoring will be required for NO_x; TKN shall be sampled once per month

for the period of October 1 through May 14, and twice monthly during the summer months. The sum of TKN and NO_x shall be used to derive TN.

Ammonia – The draft permit proposes to extend the monthly ammonia analysis on their discharge to encompass all months of the year. The past 5 years of summer ammonia monitoring provided data for the warm weather periods; however, because of the temperature dependence of ammonia, the monitoring period will include the cold weather months to provide additional data for evaluation.

Settleable Solids – The limitation of 1.0 mL/L instantaneous maximum and daily monitoring remain unchanged from the current permit. This numeric limit was established in support of the narrative standard in Section 3-01 B.5 of the Vermont Water Quality Standards.

Escherichia coli – The *E. coli* limitation is 77 colonies/100 mL as specified in Section 3-04 B.3, Vermont Water Quality Standards. Monitoring requirement remains once per month.

pH – The pH limitation remains at 6.5 - 8.5 Standard Units as specified in Section 3-01 B.9. in the Vermont Water Quality Standards. Monitoring remains at daily.

Waste Management Zone – As defined under 10 V.S.A. §1251(16), a waste management zone is “a specific reach of Class B waters designated by a permit to accept the discharge of properly treated wastes that prior to treatment contained organisms pathogenic to human beings. Throughout the receiving waters, water quality criteria must be achieved but increased health risks exist due to the authorized discharge”.

The draft permit retains the existing waste management zone that extends downstream from the outfall for approximately one mile in the Water Andric.

Instream Monitoring – Although biological assessments conducted in 2010 and 2012 below the outfall exceeded the Class B standards for a Small High Gradient stream type, the assessment in 2015 indicated that receiving water did not. Furthermore, instream water chemistry data collected by the Agency show that TP is significantly and consistently higher below the outfall in comparison to above the outfall.

Therefore, the draft permit includes instream water quality monitoring above and below the outfall to determine compliance with the Vermont Water Quality Standards. If the results of this monitoring verify a reasonable potential to cause an instream excursion about the water quality criteria, the Permittee shall optimize the facility to remove the responsible pollutants.

Toxicity Testing – 40 CFR Part 122.44(d)(1) requires the Agency to assess whether the discharge causes, or has the reasonable potential to cause or contribute to an excursion above any narrative or numeric water quality criteria. Whole Effluent Toxicity (WET) testing is being required in accordance with the 1994 Vermont Toxic Discharge Control Strategy. The draft permit includes a requirement to conduct a two-species WET test in August of September of 2016. If the results of this test indicate a reasonable potential to cause an instream toxic impact, the Agency may require additional WET testing, establish a WET limit, or require a Toxicity Reduction Evaluation.

Stream Flow Monitoring – The stream flow monitoring requirement is necessary to calculate the summer discharges (Section I.H.4). Maintenance and scheduled calibrations of the stream gauge are required in order to obtain correct flow information for the discharge calculations. The assignment of calibration intervals can be a formal process based on the results of previous calibrations.

Operation, Management, and Emergency Response Plans – As required by the revisions to 10 V.S.A. Section 1278, promulgated in the 2006 legislative session, Section I.I has been included in the draft permit. This condition requires that the Permittee implement the Operation, Management and Emergency Response Plans for the Wastewater Treatment Facility, sewage pump/ejector stations, and stream crossings as approved by the Agency on August 7, 2008, and for the sewage collection system upon approval by the Agency.

Electric Power Failure – Within 30 days of the effective date of the permit, the Permittee must submit to the Agency updated documentation addressing how the discharge will be handled in the event of an electric power outage. The effluent must receive a minimum of primary treatment (or in the case of ultraviolet light disinfection systems, not less than secondary treatment) plus disinfection.

VII. Procedures for Formulation of Final Determinations

The public comment period for receiving comments on this draft permit is from **May 30 through June 30, 2016** during which time interested persons may submit their written views on the draft permit. All written comments received by 4:30 PM on **June 30, 2016** will be retained by the Agency and considered in the formulation of the final determination to issue, deny or modify the draft permit. The period of comment may be extended at the discretion of the Agency.

Written comments should be sent to:

Agency of Natural Resources
Department of Environmental Conservation
Watershed Management Division
One National Life Drive, Main Building, 2nd Floor
Montpelier, VT 05620-3522

Comments may also be faxed to: 802-828-1544 or submitted by e-mail using the e-mail comment provisions included at <http://www.watershedmanagement.vt.gov/>

Any interested person or groups of persons may request or petition for a public hearing with respect to this draft permit. Any such request or petition for a public hearing shall be filed within the public comment period described above and shall indicate the interest of the party filing such request and the reasons why a hearing is warranted.

The Agency will hold a hearing if there is significant public interest in holding such a hearing. Any public hearing brought in response to such a request or petition will be held in the geographical area of the proposed discharge or other appropriate area, at the discretion of the Agency and may, as appropriate, consider related groups of draft permits. Any person may submit oral or written statements and data concerning the draft permit at the public hearing. The Agency

may establish reasonable limits on the time allowed for oral statements and may require the submission of statements in writing. All statements, comments, and data presented at the public hearing will be retained by the Agency and considered in the formulation of the final determination to issue, deny, or modify the draft permit.

The complete application, draft permit, and other information are on file and may be inspected by appointment on the 2nd floor of the Main Building at One National Life Drive, Montpelier, Vermont. Copies may be obtained by calling 802-828-1535 from 7:45 AM to 4:30 PM Monday through Friday, and will be made at a cost based upon the current Secretary of State Official Fee Schedule for Copying Public Records. The draft permit and fact sheet may also be viewed on the Division's website at <http://www.watershedmanagement.vt.gov/>

AGENCY OF NATURAL RESOURCES
DEPARTMENT OF ENVIRONMENTAL CONSERVATION
WATERSHED MANAGEMENT DIVISION
1 NATIONAL LIFE DRIVE – MAIN 2
MONTPELIER, VERMONT 05620-3522

NOTICE: **DRAFT DISCHARGE PERMIT**

PUBLIC NOTICE NUMBER: 3-1235

PUBLIC COMMENT PERIOD: May 30 – June 30, 2016

PERMITTEE INFORMATION

PERMITTEE NAME: Town of Danville

PERMITTEE ADDRESS: P.O. Box 183
Danville, VT 05828

PERMIT NUMBER: 3-1235

PROJECT ID NUMBER: SJ99-0128

DISCHARGE INFORMATION

NATURE: Treated and disinfected municipal wastewater

VOLUME: 0.060 MDG, annual average

RECEIVING WATER: Water Andric

EXPIRATION DATE:

DESCRIPTION: This is a draft discharge permit proposed for issuance to the Town of Danville for the discharge of treated municipal wastewater from the Danville Wastewater Treatment Facility. This permit is a renewal, and implements the requirements for the Long Island Sound Total Maximum Daily Load for Nitrogen.

TENTATIVE DETERMINATIONS

Tentative determinations regarding effluent limitations and other conditions to be imposed on the pending Vermont permit have been made by the State of Vermont Agency of Natural Resources (VANR). The limitations imposed will assure that the Vermont Water Quality Standards and applicable provisions of the Federal Clean Water Act, PL 92-500, as amended, will be met.

FURTHER INFORMATION

The complete application, proposed permit, and other information are on file and may be inspected by appointment on the 2nd floor of the Main Building at 1 National Life Drive, Montpelier, Vermont. Copies, obtained by calling 802-828-1535 from 7:45 AM to 4:30 PM Monday through Friday, will be made at a cost based upon the current Secretary of State Official Fee Schedule for Copying Public Records. The draft permit and fact sheet may also be viewed on the Division's website at <http://www.watershedmanagement.vt.gov/>

PUBLIC COMMENTS/PUBLIC HEARINGS

Written public comments on the proposed permit are invited and must be received on or before the close of business day (4:30 pm) **June 30, 2016** to the Agency of Natural Resources, Department of Environmental Conservation, Watershed Management Division, 1 National Life Drive – Main 2, Vermont 05620-3522. Comments may also be submitted by e-mail using the e-mail comment provisions included at <http://www.watershedmanagement.vt.gov/>. All comments received by the above date will be considered in formulation of the final determinations.

During the notice period, any person may submit a written request to this office for a public hearing to consider the proposed permit. The request must state the interest of the party filing such request and the reasons why a hearing is warranted. A hearing will be held if there is a significant public interest (including the filing of requests or petitions for such hearing) in holding such a hearing.

FINAL ACTION/RIGHTS TO APPEAL TO THE ENVIRONMENTAL COURT

At the conclusion of the public notice period and after consideration of additional information received during the public notice period, the VANR will make a final determination to issue or to deny the permit. Pursuant to 10 V.S.A. Chapter 220, any appeal of this decision must be filed with the clerk of the Environmental Court within 30 days of the date of the decision. The appellant must submit the Notice of Appeal and include the applicable filing fee, payable to the state of Vermont.

The Notice of Appeal must specify the parties taking the appeal and the statutory provision under which each party claims party status; must designate the act or decision appealed from; must name the Environmental Court; and must be signed by the appellant or their attorney. In addition, the appeal must give the address or location and the description of the property, project or facility with which the appeal is concerned and the name of the applicant or any permit involved in the appeal.

The appellant must also serve a copy of the Notice of Appeal in accordance with Rule 5(b)(4)(B) of the Vermont Rules for Environmental Court Proceedings.

The address for the Vermont Environmental Court is: Vermont Superior Court, Environmental Division, 32 Cherry Street, 2nd Floor, Suite 303, Burlington VT 05401 (Tel. (802) 951-1740). For further information, see the Vermont Rules for Environmental Court Proceedings, available online at www.vermontjudiciary.org.

Alyssa B. Schuren, Commissioner
Department of Environmental Conservation