

AUTHORIZATION TO DISCHARGE TO WATERS OF THE UNITED STATES,
NPDES PERMIT NO. NM0030503.

The applicant's mailing address is:

Village of Angel Fire
P.O. Box 610
Angel Fire, NM 87710

Under the Standard Industrial Classification (SIC) Code 4952, the applicant currently operates a publicly owned treatment works (POTW). The facility is located at 67 Servises Road, Angel Fire, in Colfax County, New Mexico. The treatment facility is a sequential batch reactor (SBR) system with ultra-violet (UV) disinfection. The facility has two lagoons that store wastewater prior to discharge either to the receiving stream or to a land application area. The facility has a design flow capacity of 0.50 million gallons per day (MGD). The single outfall of the facility is located on Cieneguilla Creek at:

Latitude 36° 24' 17" North, Longitude 105° 17' 00" West

Changes from the permit previously issued October 4, 2007, with an effective date of November 1, 2007, and an expiration date of October 31, 2012, include:

- (a) Add effluent loading limitations and monitoring requirements for total nitrogen and total phosphorous with a three-year compliance schedule.
- (b) Add effluent limitations and monitoring requirements for dissolved oxygen with a three-year compliance schedule.
- (c) Delete effluent limitations and monitoring requirements for aluminum.

This Notice also serves as Public Notice of the intent of the New Mexico Environment Department, Surface Water Quality Bureau to consider issuing Clean Water Act (CWA) Section 401 Certification. The purpose of such certification is to reasonably ensure that the permitted activities will be conducted in a manner that will comply with applicable New Mexico water quality standards, including the antidegradation policy, and the statewide water quality management plan. The NPDES permit will not be issued until the certification requirements of Section 401 have been met.

If you want to comment on State Certification submit written comments within the 30 day period to:

Sarah Holcomb, Acting Program Manager-PSRS
New Mexico Environment Department
Surface Water Quality Bureau (N2050)
1190 Saint Francis Drive
P.O. Box 5469
Santa Fe, NM 87502-5469
Phone: 505-827-2798
Fax: 505-827-0160
sarah.holcomb@state.nm.us