

NPDES authorization to discharge to waters of the United States, Permit No. TX0133991
The applicant's mailing address is:

Corpus Christi Liquefaction, LLC
700 Milam St. Suite 800
Houston, TX 77002

The discharge point is as described in the table below:

Outfall Reference Number	Discharge Coordinates Latitude Deg° Min' Sec'' Longitude Deg° Min' Sec''	County	Average Flow MGD	Receiving Water	Segment #
001	Latitude 27° 52' 57" N; Longitude 97° 16' 3" W	Nueces and San Patricio	0.44	La Quinta Channel of Corpus Christi Bay	2481

Under the SIC code 4925, the applicant operates natural gas liquefaction and export plant as well as import facilities with regasification capabilities.

This is a revoke and reissue to a current permit issued on January 28, 2014, with an effective date of February 1, 2014, and an expiration date of January 31, 2019. The current permit authorizes the discharges of reverse osmosis (RO) reject water from the facility. The proposed permit includes two additional sources of wastewater, including discharges associated with a sanitary Treatment Plant and Inlet Air Chillers. In addition, the permitted outfall location was slightly relocated. The proposed changes from the current permit are:

1. Two sources of wastewater, including discharges associated with a sanitary Treatment Plant and Inlet Air Chillers are being added to the proposed permit.
2. Biomonitoring requirements have been established in the proposed permit based on the fact that the facility added additional sources of wastewater which has the potential to cause toxicity in the receiving stream.
3. An internal outfall 101, discharge from the sanitary treatment plant with DO, BOD₅, TSS, NH₃-N, and fecal coliform limits are established in the permit.
4. Electronic Discharge monitoring reports requirements have been included in the proposed permit.

A Statement of Basis is available, and describes the rationale for permit conditions.

