

Technical Support Document (TSD) for the Cross State Air Pollution Rule Addendum

Docket ID No. EPA-HQ-OAR-2009-0491

Technical Revisions to State Budgets and New Unit Set-Asides

U.S Environmental Protection Agency

Office of Air and Radiation

October 2011

EPA finalized the Transport Rule in July of 2011¹. As described in the proposed “Revisions to Federal Implementation Plans to Reduce Interstate Transport of Fine Particulate Matter and Ozone” preamble, EPA is proposing to make revisions to several states’ emission budgets under the Transport Rule. EPA is also proposing to revise the new unit set-asides (NUSAs) in certain states. This technical support document shows the underlying data and calculations used to quantify each proposed revision to state budgets and provides the information used to determine revised NUSAs in certain states. The first section below summarizes revisions to state budget and NUSAs. The second section provides a description of each revision and accompanying tables demonstrating the data and calculations associated with each revision. Each proposed revision to a state budget also entails corresponding revisions to the absolute number of allowances put into the relevant new unit set-aside² as well as to the absolute assurance level³ for the relevant pollutant in that state, as NUSAs and assurance levels are both calculated by applying percentage values to the relevant state budget (using the methodologies described in the final Transport Rule).

Section A: Summary of Revisions to States’ Emission Budgets and NUSAs.

EPA is proposing revisions to state emission budgets and/or NUSAs for Arkansas, Florida, Louisiana, Michigan, Mississippi, Nebraska, New Jersey, New York, Texas, and Wisconsin. These revisions to certain input assumptions at the unit level maintain a consistent application of the methodology described in the final Transport Rule to quantify and eliminate emissions that significantly contribute to nonattainment and interfere with maintenance of the NAAQS assessed in that rulemaking. These changes are minor relative to the scope of each Transport Rule program. The proposed revisions to the Transport Rule state budgets and NUSAs are summarized in the table below.

¹ Federal Implementation Plans: Interstate Transport of Fine Particulate Matter and Ozone and Correction of SIP Approvals (76 FR 48208).

² The “Total NUSAs” presented for each state in section B of this document include allowances under both the State NUSA and the Indian Country NUSA (where the latter exists in the given state).

³ EPA has also proposed in this action to amend the effective date of the assurance provisions in all states to start in 2014 instead of in 2012.

Proposed Revisions to Transport Rule State Budgets and NUSAs									
	2012 – 2013 State Budgets			2014 and beyond State Budgets			NUSA*		
	SO ₂	Annual NO _x	Ozone Season NO _x	SO ₂	Annual NO _x	Ozone Season NO _x	SO ₂	Annual NO _x	Ozone Season NO _x
Florida			819						2%
New York	3,527	3,485	1,911	3,527	3,485	1,911	2%	2%	2%
New Jersey	2,096	420	592	0	112	195	2%	2%	2%
Louisiana			4,231			4,231			3%
Mississippi			2,136			2,136			2%
Texas	70,067	1,375	1,375	70,067	1,375	1,375	5%	4%	4%
Wisconsin		2,473		7,757	2,473		4%	6%	
Nebraska		3,599			3,599			6%	
Michigan		5,228			5,228			2%	
Arkansas									5%
Total Revisions to Each Transport Rule Program	75,690	16,580	11,064	81,351	16,272	9,848	N/A	N/A	N/A

* Approximate set-aside amounts, may be adjusted upwards or downwards slightly following rounding of existing unit allocations

Section B: Technical Revisions to States' TR Emission Budgets and NUSAs.

1) Michigan

EPA is proposing to increase Michigan's 2012 and 2014 annual NO_x budgets to correct for the assumption that Selective Catalytic Reduction (SCR) technology is currently installed at Monroe Unit 2. This SCR is planned for future installation but is not expected to be operating by 2012 or by 2014. Therefore, EPA is proposing to revise the state's 2012 and 2014 annual NO_x emission budgets⁴ to reflect projected emissions without this unit operating an SCR. This results in a 5,228 ton increase to the state's annual NO_x budgets in 2012 and 2014. EPA also recognizes that this revised input assumption would

⁴ Throughout this TSD and throughout the preamble to this proposal, EPA refers to a state budget for 2012 and 2013 as a "2012" state budget and refers to a state budget for 2014 and thereafter as a "2014" state budget. Therefore, any proposed revision of a 2012 state budget would apply to the state budget for 2012 and 2013, and any proposed revision of a 2014 state budget would apply to the state budget for 2014 and thereafter.

affect the calculation of the state’s ozone-season NO_x budget, and EPA will address that budget when finalizing the Transport Rule Supplemental Notice of Proposed Rulemaking (SNPR).

Table 1.a: Calculation to Determine Michigan Annual NO_x Budget Revision - Assuming no SCR at Monroe Unit 2							
		<i>A</i>	<i>B</i>	<i>C</i>	<i>D</i>	<i>E</i>	<i>F</i>
Plant	Unit	Emissions from TR_Remedies_Final_2012 (1000 tons)	Heat Input from TR_Remedies_Final_2012 (Tbtu)	Remedy Emission Rate from TR_Remedies_Final_2012 (lbs/mmbtu)	Revised Emission Rate (lbs/mmbtu)	Revised Emissions	Net Budget Revision (1000 tons)
<i>Calculation</i>				<i>A/B</i>		<i>D x B</i>	<i>E - A</i>
Monroe	2	1.540	44.437	0.0693	0.3046	6.768	5.228

Columns A, B, and C show the NO_x emissions, heat input, and emission rate from the TR_Remedies_Final_2012 modeling when an SCR is assumed to be present at Monroe Unit 2. Because no SCR is present, EPA modified the emission rate to reflect the “controlled NO_x policy rate” in the NEEDS version from the September 1, 2010 TR Notice of Data Availability (NODA) (column D).⁵ This value reflects the NO_x emission rate assumed in EPA’s modeling of the Transport Rule as originally proposed, when EPA did not assume an SCR to be present at the unit. This value approximates the emission rate expected at the unit at a cost threshold of \$500/ton when no SCR is present at the unit. EPA multiplied this NO_x rate by the remedy heat input shown in column B to obtain a revised emissions projection for the unit (column E). The difference between this revised emission projection (no SCR assumed) and the final Transport Rule remedy analysis emission projection (SCR assumed) determines the amount of the proposed increase to the state’s annual NO_x budget (column F).

This budget change would not result in any impact to the percent of the budget set aside for new units. Under the methodology in the final Transport Rule, the NUSA for annual NO_x in Michigan would remain at 2%. The original and revised values for the state annual NO_x budget, assurance level, and new unit set-aside are described in the table below.

⁵ See National Electric Energy Data System (NEEDS) v4.10 available at <http://www.epa.gov/airmarkets/progsregs/epa-ipm/BaseCasev410.html>

	Annual NO _x Budget	Assurance Level		Total New Unit Set-Aside *	
		% of Budget	Tons	% of Budget	Tons
2012 Initial	60,193	118%	71,028	2%	1,204
2012 Revised	65,421	118%	77,197	2%	1,308
2014 Initial	57,812	118%	68,218	2%	1,156
2014 Revised	63,040	118%	74,387	2%	1,261

*Approximate set-aside amounts, may be adjusted upwards or downwards slightly following rounding of existing unit allocations

2) Nebraska

EPA is proposing to increase Nebraska’s 2012 and 2014 annual NO_x budgets to correct for the assumption that SCR technology is currently installed at Nebraska City Unit 1. There is no SCR existing, planned, or under construction at the unit. There will likely be no SCR available at the time of the 2012 and 2014 compliance periods as originally assumed in EPA’s determination of Nebraska’s annual NO_x budgets. Therefore, EPA is proposing to revise the state’s 2012 and 2014 annual NO_x emission budgets to reflect this unit operating without an SCR. This results in a 3,599 ton increase to the state’s 2012 and 2014 annual NO_x budgets. The calculations to quantify this revision are shown in the table below.

		<i>A</i>	<i>B</i>	<i>C</i>	<i>D</i>	<i>E</i>	<i>F</i>
Plant	Unit	Emissions from TR_Remedies_Final_2012 (1000 tons)	Heat Input from TR_Remedies_Final_2012 (Tbtu)	Remedy Emission Rate from TR_Remedies_Final_2012 (lbs/mmbtu)	Revised Emission Rate (lbs/mmbtu)	Revised Emissions (1000 tons)	Net Budget Revision (1000 tons)
<i>Calculation</i>				<i>A/B</i>		<i>D x B</i>	<i>E - A</i>
Nebraska City	1	1.602	45.765208	0.070	0.2273	5.201	3.599

Columns A, B, and C show the NO_x emissions, heat input, and emission rate from the TR_Remedies_Final_2012 modeling when an SCR is assumed to be present. Because no SCR is present, EPA modified the emission rate to reflect the “controlled NO_x policy rate” in the NEEDS version from the

September 1, 2010 TR Notice of Data Availability (NODA) (column D).⁶ This value reflects the NO_x emission rate assumed in EPA’s modeling of the Transport Rule as originally proposed, when EPA did not assume an SCR to be present at the unit. This value approximates the emission rate expected at the unit at a cost threshold of \$500/ton when no SCR is present at the unit. This NO_x rate was multiplied by the final remedy heat input shown in column B to obtain a revised emissions value for the unit (column E). The difference between this revised emission projection (no SCR assumed, column E) and the remedy emission projection (SCR assumed, column A) determines the amount of the proposed increase to the state’s annual NO_x budget (column F).

The proposed change to the annual NO_x emission budget in Nebraska would result in a small change to the state’s new unit set-aside percentage for annual NO_x. The reason for the change is that under the methodology established in the final Transport Rule, the state-specific portion of the NUSA is calculated as the percentage equal to the projected emissions from “planned units” divided by the 2014 state budget for the relevant pollutant. In the case of Nebraska, the projected emissions from planned units remain unchanged, but the budget is increasing. Because the numerator remains unchanged but the denominator is increasing, the total new unit set-aside percentage decreases. That is, a smaller percentage of the state emission budget is needed to cover emissions from “planned” new units, because the budget is larger. For Nebraska, the proposed budget revision would decrease the NUSA percentage for annual NO_x from 7% to 6% as a result. This is applying the same NUSA methodology that is used for every state in the final Transport Rule, and the change in percentage is simply an outgrowth of the state’s budget revision. This change in the NUSA percentage yields only a marginal change in the absolute number of allowances in the Nebraska NUSA. The original and revised values for the state annual NO_x budget, assurance level, and new unit set-aside are described in the table below.

⁶ See National Electric Energy Data System (NEEDS) v4.10 available at <http://www.epa.gov/airmarkets/progsregs/epa-ipm/BaseCasev410.html>

Table 2.b.: Impact of Nebraska Annual NO_x Budget Revision – Assuming no SCR at Nebraska City Unit 1 (tons)					
	Annual NO _x Budget	Assurance Level		Total New Unit Set-Aside *	
		% of Budget	Tons	% of Budget	Tons
2012 Initial	26,440	118%	31,199	7%	1,851
2012 Revised	30,039	118%	35,446	6%	1,802
2014 Initial	26,440	118%	31,199	7%	1,851
2014 Revised	30,039	118%	35,446	6%	1,802

*Approximate set-aside amounts, may be adjusted upwards or downwards slightly following rounding of existing unit allocations

3) **Texas (Removed FGDs)**

EPA is proposing to increase Texas’s 2012 and 2014 SO₂ budgets to correct for the assumption that Flue Gas Desulfurization (FGD) technology will be installed by 2012 for W.A. Parish Unit 6, J.T. Deely Unit 1, and J.T. Deely Unit 2. Although the facility owners had previously announced plans to install FGD technology at these facilities, those plans have since been modified.^{7 8} There will likely be no FGD available at these units during the 2012 and 2014 compliance periods under the Transport Rule programs. Therefore, EPA is proposing to revise the state’s 2012 and 2014 SO₂ emission budgets to reflect these units operating without an FGD. This results in a 26,359 ton increase to the state’s 2012 and 2014 SO₂ budgets. The calculations to quantify this revision are shown in the table below.

⁷ “Corporate Sustainability Report”, CPS Energy, 2010. P.57. Retrieved from http://www.cpsenergy.com/files/Sustainability_Report.pdf

⁸ Business Wire, (2006). NRG Announces Comprehensive Repowering Initiative [Press release]. Retrieved from http://phx.corporate-ir.net/phoenix.zhtml?c=121544&p=irol-newsArticle_Print&ID=874575&highlight

		<i>A</i>	<i>B</i>	<i>C</i>	<i>D</i>	<i>E</i>	<i>F</i>
Plant	Unit	Emissions from TR_Remedy_Final_2012 (1000 tons)	Heat Input from TR_Remedy_Final_2012 (Tbtu)	Remedy Emission Rate from TR_Remedy_Final_2012 (lbs/mmbtu)	Revised Emission Rate (lbs/mmbtu)	Revised Emissions (1000 tons)	Net Budget Revision (1000 tons)
<i>Calculation</i>				<i>A/B</i>		<i>D x B</i>	<i>E - A</i>
J T Deely	1	0.917	30.55183083	0.060	0.5800	8.860	7.943
J T Deely	2	0.914	30.46546708	0.060	0.5800	8.835	7.921
W A Parish	6	1.211	40.3658592	0.060	0.5800	11.706	10.495
Total							26.359

Columns A, B, and C show the SO₂ emissions, heat input, and emission rate from the TR_Remedy_Final_2012 modeling when an FGD is assumed to be present at these three units. Because no FGD is present, EPA is recalculating projected emissions at these units using the emission rates shown for these units in EPA’s analysis of the base case for the final Transport Rule, as found in the TR_Base_Case_Final for 2012 (column D). These SO₂ emission rates reflect generation at these units without the operation of the assumed FGDs, which did not operate in the final Transport Rule base case because they were modeled as “dispatchable” controls that were not found to be economic to operate in that scenario.⁹ The revised SO₂ emission rate in column D is multiplied by the final remedy heat input shown in column B to obtain a revised emissions projection for the unit (column E). The difference between this revised emission projection (no FGD assumed, column E) and the remedy emission projection (FGD assumed, column A) determines the amount of the proposed increase to the state’s SO₂ budget (column F).

The impacts of all proposed revisions to the Texas state budgets on the state’s NUSAs and assurance levels are shown in Table 13.e.

4) Texas (FGD Capture)

EPA is also proposing to increase Texas’s 2012 and 2014 SO₂ budgets to correct for the assumption that the existing FGD technology currently installed at five facilities in Texas (Monticello, Martin Lake, Sandow, Oklaunion, and W A Parish) is capable of treating 100% of the flue gas at those units. Although EPA originally assumed removal rates at those units that the facility operators have previously reported, those facility operators have clarified to

⁹ See "WebReady_ParsedFile_TR_Base_Case_Final_2012" in the Transport Rule docket or on EPA’s CSAPR website

EPA that those reported removal rates only applied to the flue gas treated at the unit. Because of design limitations, these facilities may be substantially limited in the amount of flue gas that can be passed through the existing FGD. These facilities report less than 100% pass-through of flue gas on their most recent EIA 860 form. Consequently, at these facilities, the effective removal rate of the FGD as applied to total SO₂ emissions at the affected units would be lower than the reported removal rate would otherwise indicate. Therefore, EPA is proposing to revise the state’s SO₂ emission budget to reflect the removal rates achieved by these FGDs in 2008 as reported on the EIA 923 form. This recalculation to projected emissions at these units results in a 43,708 ton increase to the state’s SO₂ budget. The calculations to quantify this revision are shown in the table below.

Table 4: Calculation to Determine Texas SO₂ Budget Revision – Assuming Revised SO₂ removal Rates at FGD							
		<i>A</i>	<i>B</i>	<i>C</i>	<i>D</i>	<i>E</i>	<i>F</i>
Plant Name	Unit ID	Total SO₂ Emission from TR_Remedy_Final_2012 (1000 Tons)	EIA 860 SO₂ Removal Rate (used in budget determination)	2008 EIA 923 SO₂ Removal Rate (used for budget revision)	Uncontrolled Emissions (assuming no FGD) (1000 tons)	Revised Emissions (assuming FGD with revised removal rate) (1000 tons)	Net Budget Revision (1000 tons)
<i>Calculation</i>					$A/(1-B)$	$D*(1-C)$	$E-A$
Martin Lake	1	1.86284104	0.95	0.657	37.25682081	12.77908954	10.9162485
Martin Lake	2	1.854018172	0.95	0.795	37.08036345	7.601474507	5.747456334
Martin Lake	3	1.745038028	0.95	0.748	34.90076056	8.794991661	7.049953633
Monticello	3	2.548471002	0.95	0.659	50.96942003	17.38057223	14.83210123
Oklunion	1	2.232109754	0.868	0.726	16.90992238	4.633318731	2.401208977
Sandow	4	1.252293549	0.92	0.766	15.65366936	3.662958629	2.410665081
W A Parish	WAP8	1.594838503	0.85	0.817	10.63225669	1.945702974	0.350864471
Total		13.090				56.798	43.708

Column A shows the projected emissions at these units as originally modeled in the final Transport Rule remedy for 2012. Column B shows the SO₂ removal rate that those 2012 emission projections are based on. Column C shows the revised emission rate based on EIA 923 data. Column D shows a calculation of projected emissions at each unit if the previously assumed FGD removal hadn’t occurred at all; these “uncontrolled emissions” are calculated in order to allow application of the revised FGD removal rate shown in column C to these uncontrolled emissions, which yields the revised emission projection for each unit in column E. The difference between this revised emission projection (lower FGD capture assumed, column E) and the remedy emission projection (higher FGD capture assumed, column A) determines the amount of the proposed increase to the state’s SO₂ budget (column F).

The impacts of all proposed revisions to Texas state budgets on the state’s NUSAs and assurance levels are shown in Tables 13.d and 13.e.

5) **Florida**

EPA is proposing a revision to Florida’s 2012 ozone-season NO_x budget to correct for the assumption that Crystal River Unit 3, a nuclear unit with no NO_x emissions, will be available for dispatch in 2012. This unit is not expected to operate in 2012 as it is undergoing an extended outage for repair work. EPA is proposing to increase the state’s 2012 ozone season NO_x budget by 819 tons to reflect projected emissions from increased dispatch of fossil-fuel-fired capacity needed to substitute for the generation that EPA originally projected to come from Crystal River Unit 3. The calculations to quantify this revision are shown in the table below.

Table 5.a: Calculation to Determine Florida Ozone-Season NO_x Budget Revisions to Offset Crystal River 3 Outage					
		<i>A</i>	<i>B</i>	<i>C</i>	<i>D</i>
Plant Name	Unit ID	Ozone-Season Generation from TR_Remedied_Final_2012 (GWh)	Average Heat Rate of Replacement Generation (BTU/kWh)	Average Ozone-Season NO_x Emission Rate of Replacement Generation (lbs/MMBTU)	Ozone-Season NO_x Emissions from Replacement Generation (tons)
<i>Calculation</i>					<i>A*B*C/2000</i>
Crystal River	3	2,976	8,340	0.066	819

Column A shows the ozone-season generation projected from the Crystal River Unit 3 under the final Transport Rule 2012 remedy modeling. Columns B and C show the capacity-weighted average heat rate and ozone-season NO_x emission rate from combined cycle natural gas units in Florida that EPA assumes would be likely to increase their dispatch to replace the generation that would otherwise be available from Crystal River Unit 3.¹⁰ To characterize the emissions of this replacement generation, EPA selected combined cycle units that reported higher utilization in 2010 (when Crystal River Unit 3 was also out of service for repair) compared to their projected utilization under the final Transport Rule 2012 remedy modeling (that assumed Crystal River Unit 3 would operate). Because the originally projected operation of Crystal River Unit 3 did not include any NO_x emissions covered by the Transport Rule, the emissions from likely replacement generation calculated in column D determine the amount of the proposed increase to the state’s 2012 ozone-season NO_x budget.

¹⁰ These capacity-weighted average heat rates and emission rates are derived using calculations found in the Excel workbook titled “Calculation of heat rate and emission rate averages used in Budget Revisions” found in the docket for this rulemaking.

The change to the ozone-season NO_x budget for Florida does not impact the percentage of the budget set aside for new units in Florida, which remains at 2%. The original and revised values for the state ozone-season NO_x budget, assurance level, and new unit set-aside are described in the Table below. EPA’s proposed revision does not affect Florida’s 2014 ozone-season NO_x budget as originally finalized, as Crystal River Unit 3 is expected to re-enter service by that time.

Table 5.b.: Impact of Florida Ozone-Season NO_x Budget Revision – Assuming Crystal River Unit 3 Outage (tons)					
	Ozone-Season NO _x Budget	Assurance Level		Total Ozone Season NO _x New Unit Set-Aside*	
		% of Budget	Tons	% of Budget	Tons
2012 Initial	27,825	121%	33,668	2%	557
2012 Revised	28,644	121%	34,659	2%	573
*Approximate set-aside amounts, may be adjusted upwards or downwards slightly following rounding of existing unit allocations					

6) Arkansas

Plum Point Unit 1 in Arkansas commenced commercial operation on or after January 1, 2010. Such a date qualifies Plum Point Unit 1 as a “planned” new unit by the definition of that category described in the “Allowance Allocation Final Rule TSD” for the Transport Rule. However, in the final Transport Rule, EPA did not recognize Plum Point Unit 1 as a new unit and therefore omitted its projected emissions in the determination of the ozone-season NO_x new unit set-aside for Arkansas. Because there were no other units identified as “planned” new units in Arkansas, that state’s NUSA was set at the minimum value of 2%.¹¹ EPA is now proposing to revise the calculation of the Arkansas ozone-season NO_x new unit set-aside to reflect the “new unit” status of Plum Point Unit 1. The calculations to quantify this revision are shown in the table below.

¹¹ As explained in the final Transport Rule, the minimum size of any state’s new unit set-aside is this “base percentage” amount, to which “state-specific” percentages are added if the given state has projected emissions from “planned” new units (76 FR 48291).

Table 6.a: Calculation for Arkansas's NUSA		
<i>A</i>	Projected 2020 Ozone-Season NO _x Emissions from Plum Point (tons)	478
<i>B</i>	Arkansas Ozone Season NO _x State Budget (tons)	15,037
<i>C</i>	Plum Point's Emissions as a % of Arkansas State Budget (<i>A/B</i>)	3%
<i>D</i>	Base percentage for new unit set-aside	2%
<i>E</i>	Total New Unit Set-Aside (<i>C + D</i>)	5%

Because Plum Point was the only “planned” new unit for the state of Arkansas, EPA divided its projected emissions into the state budget to derive the state-specific percentage for the new unit set-aside in Arkansas, which rounds to 3%. This value was added to the base percentage for new unit set-aside (2%). The resulting new unit set-aside percentage for ozone season NO_x in Arkansas is 5%. This change does not impact the state budget or assurance level in any way. However, the new unit set-aside would change by the levels shown below.¹²

Table 6.b: Impact of Ozone Season NO_x NUSA revision for Arkansas				
	Initial %	Updated%	Initial tons	Revised tons*
New Unit Set-Aside	2%	5%	301	752
Existing Unit Allocation	98%	95%	14,736	14,285
Total	100%	100%	15,037	15,037

*Approximate set-aside amounts, may be adjusted upwards or downwards slightly following rounding of existing unit allocations

7) Texas (NUSA)

The Oak Grove Unit 2 in Texas commenced commercial operation on or after January 1, 2010. Such a date qualifies Oak Grove Unit 2 as a “planned” new unit by the definition of that category described in the “Allowance Allocation Final Rule TSD”. However, in the final Transport Rule, EPA did not recognize Oak Grove Unit 2 as a new unit and therefore omitted its projected emissions in the determination of the new unit set-asides for Texas, which EPA then calculated to be set at 5%, 3%, and 3% for SO₂, annual NO_x, and ozone-season NO_x, respectively. EPA is now proposing to revise the Texas new unit set-asides to reflect the “new unit” status of Oak Grove Unit 2. The calculations to quantify these revisions are shown in the table below.

¹² The proposed increase to the new unit set-aside would necessarily change existing unit allowance allocations in order to maintain the state budget. To review the existing unit allowance allocations associated with this proposed revision, please see the document entitled “FIP Unit Level Allocations with Proposed Revisions to CSAPR” found in the docket to this rulemaking.

Table 7: Calculation for Texas's NUSAs				
		SO ₂	NO _x	Ozone Season NO _x
<i>A</i>	Projected 2020 Emissions from planned new fossil (tons)*	9,855	2,727	1,216
<i>B</i>	TX State Budget (tons)	331,734	134,970	64,418
<i>C</i>	Planned new unit emissions as a % of Texas's State Budget (<i>A/B</i>)	3%	2%	2%
<i>D</i>	Base percentage for new unit set-aside	2%	2%	2%
<i>E</i>	Total New Unit Set-Aside (<i>C+D</i>)	5%	4%	4%
*Revised to include emissions from Oak Grove Unit 2				

The impact of all proposed revisions to Texas state budgets (and these revisions to the NUSAs) on the state's NUSAs and assurance levels are shown in Tables 13.e.

8) Wisconsin

EPA is proposing a revision to Wisconsin's 2014 SO₂ budget to correct for the assumption that FGD technology will be installed by 2014 for Weston Unit 3. In the final Transport Rule analysis, this unit was not modeled to build an FGD purely in response to the \$2,300 per ton threshold informing Wisconsin's 2014 state SO₂ budget; instead, its FGD was added as an input assumption in the base case related to information suggesting that this control was already scheduled for installation. However, Wisconsin Department of Natural Resources (WDNR) has informed EPA that this assumption was erroneous. Therefore, EPA is proposing to revise the state's SO₂ emission budget for 2014 to reflect this unit operating without an FGD. This results in a 5,605 ton increase to the state's 2014 SO₂ budget. This unit was not originally assumed to have an FGD by 2012, so EPA is not proposing any revision related to this unit for the state's 2012 SO₂ budget. The calculations to quantify this revision are shown in the table below.

Table 8.a.: Calculation to Determine Wisconsin's SO₂ Budget Revision – Assuming no FGD at Weston Unit 3 in 2014 (1000 tons)				
		<i>A</i>	<i>B</i>	<i>C</i>
Plant Name	Unit ID	Emissions from TR_Remedy Final_2014	Emissions from TR_Remedy Final_2012	Net Budget Revision
<i>Calculation</i>				<i>B-A</i>
Weston	3	0.647	6.252	5.605

Columns A and B show Weston’s Unit 3 SO₂ remedy case emissions in 2014 and 2012, respectively. In its modeling of the final Transport Rule remedy, EPA projected the same total heat input for Weston Unit 3 in both years. However, the total projected emissions are lower in 2014 because the FGD was assumed to be operating in that year. Because the projected heat input is constant at this unit between these years, EPA has calculated the difference between the projected emissions at this unit in 2012 (no FGD assumed, column B) and in 2014 (FGD assumed, column A) to determine the amount of the proposed increase to Wisconsin’s 2014 SO₂ budget related to this unit, shown in column C.

EPA is also proposing a revision to Wisconsin’s 2014 SO₂ budget related to scrubbers being installed at Columbia units 1 and 2. In the final Transport Rule analysis, EPA assumed these installations would be wet scrubbers; however, the Wisconsin Department of Natural Resources (WDNR) has informed EPA that they have been planned and approved as dry scrubbers instead. In its analysis of the final Transport Rule, EPA assumed SO₂ removal rates of 96% for new wet scrubbers and 92% for new dry scrubbers. Therefore, the projected emissions from these units reflected a higher SO₂ removal rate (and consequently lower emissions) than these units would be assumed to achieve with dry scrubber technology. In accordance with this revision, EPA is proposing a 2,152 ton increase to the Wisconsin 2014 SO₂ emission budget. These units were not originally assumed to have FGD by 2012, so EPA is not proposing any revision related to these units for the state’s 2012 SO₂ budget.

Table 8.b.: Calculation to Determine Wisconsin SO₂ Budget Revision - Assuming Dry FGD at Columbia in 2014 (1000 tons)					
		<i>A</i>	<i>B</i>	<i>C</i>	<i>D</i>
Plant Name	Unit ID	Emissions from TR_Remedy Final_2014 (assuming 96% removal)	Uncontrolled Emissions (assuming no FGD)	Revised Emissions (assuming 92% removal)	Net Budget Revision
<i>Calculation</i>			$A/(1-0.96)$	$B *(1-0.92)$	$C-A$
Columbia	1	1.089	27.231	2.179	1.09
Columbia	2	1.063	26.572	2.126	1.063
Total		2.152	53.804	4.304	2.152*
*Total reflects rounding of calculation performed for both units together					

Column A shows the Columbia units' projected emissions assuming 96% removal characteristic of a new wet scrubber. Column B shows a calculation of projected emissions at each unit if the previously assumed FGD removal hadn't occurred at all; these "uncontrolled emissions" are calculated in order to allow application of the revised FGD removal rate of 92% to these uncontrolled emissions, which yields the revised emission projection for each unit in column C. The difference between this revised emission projection (dry scrubbers assumed, column C) and the remedy emission projection (wet scrubbers assumed, column A) determines the amount of the proposed increase to the state's 2014 SO₂ budget (column D).

EPA is also proposing a revision to Wisconsin's annual NO_x budget for 2012 and 2014 to correct for the assumption that an SCR will be in place at John P. Madgett Unit 1 in 2012 and 2014. There are currently no plans to have an SCR in place by 2014 at the unit. Therefore, EPA is proposing to revise the state's 2012 and 2014 annual NO_x budgets by 2,473 tons to reflect the operation of the unit without an SCR. The calculations to quantify this revision are shown in the table below.

		<i>A</i>	<i>B</i>	<i>C</i>	<i>D</i>	<i>E</i>	<i>F</i>
Plant Name	Unit ID	Emissions from TR_Remedy_Final_2012 (1000 tons)	Heat Input from TR_Remedy_Final_2012 (Tbtu)	Remedy Emission Rate from TR_Remedy_Final_2012 (lbs/mmbtu)	Revised Emission Rate (lbs/mmbtu)	Revised Emissions (1000 tons)	Net Budget Revision (1000 tons)
<i>Calculation</i>				<i>A/B</i>		<i>D x B/2</i>	<i>E - A</i>
J P Madgett	B1	0.588922429	23.55689678	0.05	0.26	3.062	2.473

Columns A, B, and C shows the emissions, heat input, and emission rate from the 2012 remedy modeling for the J P Madgett unit. Because no SCR is present, EPA is recalculating projected emissions at this unit using the emission rate shown for this units in EPA’s analysis of the base case for the final Transport Rule, as found in the TR_Base_Case_Final for 2012 (column D). This annual NO_x emission rate reflects generation at this unit without the operation of the assumed SCR, which did not operate in the final Transport Rule base case because it was modeled as a “dispatchable” control that was not found to be economic to operate in that scenario.¹³ The J P Madgett emission rate without operating an SCR (column D) multiplied by the remedy heat input (column B) yields the projected emissions from the unit if no SCR were assumed to be in place. The difference between the projected emissions when no SCR is in place (column E) and the projected emissions when an SCR is assumed (column A) determines the amount of the proposed increase to the state’s 2012 and 2014 annual NO_x budgets (column F).

The proposed revisions to the SO₂ emission budget for Wisconsin would result in a small change to the state’s new unit set-aside percentage for SO₂. The reason for the change is that under the methodology established in the final Transport Rule, the state-specific portion of the NUSA is calculated as the percentage equal to the projected emissions from “planned units” divided by the state budget for the relevant pollutant. In the case of Wisconsin, the projected emissions from planned units remain unchanged, but the budget is increasing.¹⁴ Because the numerator remains unchanged but the denominator is increasing, the total new unit set-aside percentage for SO₂ decreases. That is, a smaller percentage of the state emission budget is needed to cover emissions from “planned” new units, because the budget is larger. For Wisconsin, the proposed budget revision would decrease the NUSA percentage for SO₂ from 5% to 4% as a result. This is applying the same NUSA methodology that is used for every state in the final Transport Rule, and the change in percentage is simply an outgrowth of the state’s budget revision. While this change in the NUSA percentage would reduce the absolute number of allowances in the Wisconsin NUSA for SO₂ as compared to the amount under the final Transport Rule, the revised NUSA still contains more than enough allowances in 2012

¹³ See "WebReady_ParsedFile_TR_Base_Case_Final_2012" in the Transport Rule docket or on EPA's CSAPR website

¹⁴ While this relationship is also true for annual NO_x, the proposed revisions to Wisconsin’s annual NO_x budget do not yield a different calculated NUSA percentage than the originally determined 6% under the final Transport Rule.

and 2014 to cover projected emissions from “planned” new units in Wisconsin, with the remainder still available for “potential” new units to enter the programs during that time. The original and revised values for the state SO₂ budget, assurance level, and new unit set-aside are described in the table below.

Table 8.d.: Impact of Wisconsin Budget Revisions – Assuming no FGD at Weston Unit 3, no SCR at JP Madgett, and dry FGD at Columbia (tons)

	Program	Budget	Assurance Level		Total New Unit Set-Aside*	
			% of Budget	Tons	% of Budget	Tons
2012 Initial	SO ₂	79,480	118%	93,786	5%	3,974
2012 Revised	SO ₂	79,480	118%	93,786	4%	3,179
2014 Initial	SO ₂	40,126	118%	47,349	5%	2,006
2014 Revised	SO ₂	47,883	118%	56,502	4%	1,915
2012 Initial	Annual NO _x	31,628	118%	37,321	6%	1,898
2012 Revised	Annual NO _x	34,101	118%	40,239	6%	2,046
2014 Initial	Annual NO _x	30,398	118%	35,870	6%	1,824
2014 Revised	Annual NO _x	32,871	118%	38,788	6%	1,972

*Approximate set-aside amounts, may be adjusted upwards or downwards slightly following rounding of existing unit allocations

9) New York

EPA is proposing to increase the New York state annual NO_x, ozone-season NO_x, and SO₂ budgets to reflect the assumption of near-term operational constraints affecting specific units in New York City and Long Island. These revisions are based on three types of local operating constraints that apply to certain generators in New York City and Long Island, which are referred to here as the N-1-1 Contingency, the Minimum Oil Burn Rules, and local out-of-merit-order dispatch conditions. Each calculation of the near-term emission impact found to be associated with these constraints is documented below; the results are summarized in Table 9.f.

N-1-1 Contingency

Certain parts of the Con Edison system in New York City are required to be designed and operated for the occurrence of a second contingency, also known as an N-1-1 contingency; these requirements are in addition to any requirements for the first (N-1) contingency on which the overall New York State power system is operated. The local rules that determine the operation and unit commitment for New York City are New York State Reliability Council (NYSRC) rules I-R1 through I-R4.¹⁵ To meet the requirements of these rules, the New York ISO (NYISO) performs a supplemental commitment of units in the New York City zone. The rules require additional reserves from in-city combustion turbines (CTs), as well as unit commitment of steam units where needed to ensure sufficient locational reserves and to guard against a potential interruption in gas supply at any given facility that could disrupt its generation and perturb local grid stability. These rules are in effect throughout the year and are implemented by NYISO in a daily and hourly unit commitment process specific to New York City. Depending on the expected load level and the pattern of load during the day, NYISO will commit steam units to meet intermediate load levels, while placing CTs in reserve to meet morning and afternoon peak requirements if needed. As the NYISO must meet multiple requirements for reserves and energy and comply with the NYSRC rules, the exact pattern of dispatch that satisfies all of these constraints varies throughout the year. Because the steam units in the city have long startup times and 24-hour minimum run times, NYISO must commit these units in advance in order to preserve the ability to dispatch the CTs during peak load or in response to grid disruption contingencies.

The dispatch requirements apply throughout the year, but there are also additional environmental requirements unique to ozone season operation. During the ozone season, the NYISO determines generator operations subject to local environmental regulations that require NYISO to dispatch certain steam units before seeking additional power from CTs when needed, to balance the need to meet energy and reserve requirements against daily local emissions for these units. NYISO implements these requirements through an operational procedure that requires commitment of oil/gas steam units at specific plants that would otherwise not be economic to dispatch, in order to ensure these combustion turbines can be dispatched when needed. For the steam units in New York City (Arthur Kill, Ravenswood and Astoria), these procedures mean that one or more steam units must be running for the entire ozone season.¹⁶

Minimum Oil Burn Rules

In order to ensure that units do not go offline if there is a loss of natural gas supply to New York City, the NYSRC rules incorporate special provisions that require natural gas units to be prepared to switch from natural gas to oil immediately upon notice of a loss of natural gas supply. These provisions are implemented through utility applications to the NYISO for special summer and winter dispatch conditions designed to govern when

¹⁵ See Rule I-R1, *NYSRC Reliability Rules For Planning and Operating the New York State Power System*, Version 29, New York State Reliability Council (NYSRC), January 7, 2011, p. 66.

¹⁶ See *Analysis of New York City Averaging Plans for Compliance with NOx Emissions Limitations*, New York Independent System Operator, Inc., 2011

generators must be prepared to burn oil in each season.¹⁷ For certain oil/gas steam units that do not have the ability to switch immediately from natural gas to oil, this provision means that they must already be burning oil at the times that they may be notified to switch. As a result, it is necessary for these units to operate using oil at certain times of the year. For New York City, Con Edison applies to revise this procedure twice each year based on expected conditions for the winter or summer season.¹⁸ There is a separate and similar minimum oil burn rule affecting units in Long Island.¹⁹

Since in the current outlook the price of oil is much higher than gas for the same heat input, EPA recognizes that these operations would not be captured in projections of economic generating behavior. As such, EPA has calculated revised emission projections at the units affected by the minimum oil burn rules based on the fraction of heat input each unit reported as oil in 2010 to the Energy Information Administration.²⁰

Local Out-of-Merit-Order Dispatch

Long Island's ability to import electricity is limited to tie lines within the state between Con Ed and the Long Island Power Authority (LIPA), and interstate cables connecting Long Island with the Independent System Operator for New England (ISO-NE) and the PJM Interconnection. Because the lines from ISO-NE and PJM are direct current (DC) lines that are not dispatched in real time and not controlled by the NYISO, the ability to serve Long Island load from within New York State is subject to overall import limitations. Local conditions limiting the immediate-term ability of NYISO to move power between southern New York state and Long Island lead NYISO to dispatch more generation from units on Long Island than regional economic dispatch modeling, such as EPA's IPM projections, would suggest. The NYISO Operating Study²¹ shows that NYISO is limited to approximately 860 MW of dispatchable import capacity into Long Island on a sustainable hourly basis. Even if this line were fully loaded for all hours of the year, the maximum amount of imports into Long Island that NYISO can dispatch would be 7.5 TWh; however, in EPA's modeling of the final Transport Rule, Long Island has 9.7 TWh of net imports from NYISO dispatch. Under these conditions, NYISO would have to increase local Long Island generation by 2.2 TWh to meet local load while respecting the 7.5 TWh limitation on imports from the rest of NYISO, notwithstanding the economic merit of that imported generation. To determine projected emissions associated with this local out-of-merit-order dispatch, EPA assumed that this generation would come from the Northport plant, on the basis that one unit at Northport is modeled to have economic generation even without this local import limitation represented, and the remaining units at Northport have heat rates that differ by less than one percent from the Northport unit that was modeled to dispatch.

Calculation of New York City Revised Generation and Emissions – Plant Level

¹⁷ NYSRC Reliability Rules For Planning and Operating the New York State Power System, Version 29, New York State Reliability Council (NYSRC), January 7, 2011, I-R3 & I-R5 Reliability Rule Applications. Rule I-R3 governs New York City operations, Rule I-R5 Long Island Operations.

¹⁸ See ConEd, *Application for the Loss of Generator Gas Supply – New York City, OC Meeting – May 12, 2011*, for the requirements for the summer 2011 procedures.

¹⁹ See the document, *Long Island Gas Burn Procedures – 2011*, in the docket for the TR Rule Revisions Proposal, Docket.

²⁰ The EIA data used for this calculation is available at: http://www.eia.gov/cneaf/electricity/page/eia906_920.html.

²¹ See NYISO Operating Study Summer 2011 and Appendices, New York Independent System Operator, July 14, 2011, page C-3.

To reflect the requirements of the NYSRC rules as implemented by the NYISO for New York City, EPA is assuming that additional commitment of units at three steam plants in New York City (Arthur Kill, Ravenswood, and Astoria) would occur in the form of two units at each facility dispatched at a minimum of 50% capacity at the times that the contingency conditions apply to necessitate non-economic operation of these steam units. These calculations establish the assumed minimum generation at each facility that would dispatch in the immediate term to meet the conditions of the NYSRC rules independent of the economic merit of that generation within the larger region as originally modeled. Where EPA's originally projected generation for the unit was less than this minimum, EPA has calculated here the difference in generation from the unit and, most importantly, the associated emissions from that generation, in order to inform the proposed revision to the New York state budgets under the Transport Rule. Calculations were performed separately for ozone season and non-ozone season periods. During the ozone season, these dispatch conditions were assumed to apply 100% of the time; during the rest of the year (non-ozone season), they were assumed to apply 40% of the time, reflecting historically observed seasonal differences in operation of these units. The NO_x emissions from this additional generation at these units were calculated using each unit's heat rate and NO_x emission rate from EPA's assumptions in its IPM modeling. The results from these unit-level calculations are shown in Tables 9.a and 9.b.

To account for the effects of the minimum oil burn rule in New York City, EPA calculated SO₂ emissions from the revised generation at each unit by assuming that the unit would burn oil for the same share of its projected heat input (including the revisions discussed above) as reported to EIA in 2010. These calculations for New York City units are shown in Table 9.b. To estimate additional SO₂ emissions, the IPM emission rate of 1.04 lbs/mmBtu for residual fuel oil was used. The IPM emission rate for NO_x is the same for natural gas and oil, so no changes in NO_x emissions were needed to represent the additional use of oil.

Table 9.a Ozone Season NO_x Revised Unit-Level Emission Projections for New York City for N-1-1 Contingency Operation											
Affected Facilities		Operations as modeled for the Transport Rule in IPM						Revisions to Generation and Emissions			
<i>A</i>	<i>B</i>	<i>C</i>	<i>D</i>	<i>E</i>	<i>F</i>	<i>G</i>	<i>H</i>	<i>I</i>	<i>J</i>	<i>K</i>	<i>L</i>
UniqueID	Plant Name	Capacity (MW)	Capacity Factor	Heat Rate (BTU/kWh)	NO_x Rate (lbs/mmBtu)	Heat Input (Tbtu)	Generation (GWh)	Minimum Capacity Factor	Revised Generation (GWh)	Additional Generation beyond IPM (GWh)	Additional NO_x Emissions (tons)
<i>Calculation</i>										<i>(I-H)</i>	<i>(E*J*F)/2000</i>
2490_B_20	Arthur Kill	335	31.7%	10389	0.08	4.056	390	50.0%	615	225	90.5
2490_B_30	Arthur Kill	491	31.7%	10198	0.10	5.836	572	50.0%	901	329	165.6
2500_B_10	Ravenswood	356	0.0%	11714	0.07	0.000	0	50.0%	653	653	256.5
2500_B_30	Ravenswood	940	0.0%	11624	0.07	0.000	0	50.0%	1,726	1,726	697.7
8906_B_30	Astoria	366	44.4%	10123	0.06	6.039	597	50.0%	672	75	23.3
8906_B_40	Astoria	373	44.4%	10117	0.06	6.150	608	50.0%	685	77	23.8

Table 9.b Annual NO_x and SO₂ Revised Unit-Level Emission Projections for New York City for N-1-1 Contingency Operation and Minimum Oil Burn Rule

Affected Facilities		Operations as modeled for the Transport Rule in IPM						Revisions to Generation and Emissions					
A	B	C	D	E	F	G	H	I	J	K	L	M	N
Unique ID	Plant Name	Capacity (MW)	Capacity Factor	Heat Rate (BTU/kWh)	NO _x Rate (lbs/mmBtu)	Heat Input (Tbtu)	Generation (GWh)	Minimum Capacity Factor	Revised Generation (GWh)	Additional Generation beyond IPM (GWh)	Additional NO _x Emissions (tons)	2010 Oil Fraction	Additional SO ₂ Emissions (tons)*
Calculation										(I-H)	(E*J*F)/2000		M*J*1.04*E/2000
2490_B_20	Arthur Kill	335	13.3%	10389	0.08	4.056	390	32.6%	956	566	227.9	0.000	0.0
2490_B_30	Arthur Kill	491	13.3%	10198	0.10	5.836	572	32.6%	1,401	829	416.9	0.000	0.0
2500_B_10	Ravenswood	356	0.0%	11714	0.07	0.000	0	32.6%	1,015	1,015	398.7	0.039	243.1
2500_B_30	Ravenswood	940	0.0%	11624	0.07	0.000	0	32.6%	2,682	2,682	1084.4	0.039	637.7
8906_B_30	Astoria	366	18.6%	10123	0.06	6.039	597	32.6%	1,044	448	138.6	0.065	358.3
8906_B_40	Astoria	373	18.6%	10117	0.06	6.150	608	32.6%	1,064	456	141.1	0.065	364.9
8906_B_50	Astoria	359	18.6%	10120	0.06	5.921	585	18.6%	585	0	0.0	0.065	200.7

*Assumes the IPM v.4.10_FTtransport SO2 emission rate of 1.04 lbs/MMBTU for oil-fired generation

Calculation of Long Island Revised Generation and Emissions – Plant Level

As discussed above, EPA is assuming that an additional 2.2 TWh of generation beyond the level projected in IPM modeling of the Transport Rule will occur on Long Island in the immediate term to allow NYISO to dispatch enough power to meet local load while respecting the limited import capacity into Long Island. EPA is assuming that this additional generation would occur at the Northport facility distributed across its three units. Since the three units have virtually identical heat rates, EPA assumes that these units would be operated at the same capacity factors; EPA therefore establishes a minimum capacity factor at each unit in order to produce an additional 2.2 TWh beyond the original IPM projection. In concert with these assumptions, EPA calculated additional ozone-season NO_x, annual NO_x, and SO₂ emissions from these Long Island units in the same way as for the New York City units shown above. These calculations are provided in Tables 9.c and 9.d below.

Affected Facilities		Operations as modeled for the Transport Rule in IPM						Revisions to Generation and Emissions			
A	B	C	D	E	F	G	H	I	J	K	L
UniqueID	Plant Name	Capacity (MW)	Capacity Factor	Heat Rate (BTU/kWh)	NO _x Rate (lbs/mmBtu)	Heat Input (Tbtu)	Generation (GWh)	Minimum Capacity Factor	Required Generation (GWh)	Additional Generation (GWh)	Additional NO _x Emissions (tons)
Calculation										(I-H)	(E*J*F)/2000
2516_B_2	Northport	390	23.4%	10580	0.11	3.534	334	38.5%	551	217	129.6
2516_B_3	Northport	391	0.0%	10634	0.14	0.000	0	38.5%	552	552	399.0
2516_B_4	Northport	385	0.0%	10663	0.10	0.000	0	38.5%	544	544	292.2

Affected Facilities		Operations as modeled for the Transport Rule in IPM						Revisions to Generation and Emissions					
A	B	C	D	E	F	G	H	I	J	K	L	M	N
Unique ID	Plant Name	Capacity (MW)	Capacity Factor	Heat Rate (BTU/kWh)	NO _x Rate (lbs/mmBtu)	Heat Input (Tbtu)	Generation (GWh)	Minimum Capacity Factor	Revised Generation (GWh)	Additional Generation beyond IPM (GWh)	Additional NO _x Emissions (tons)	2010 Oil Fraction	Additional SO ₂ Emissions (tons)*
Calculation										(I-H)	(E*J*F)/2000		M*J*1.04*E/2000
2516_B_2	Northport	390	9.8%	10580	0.11	3.534	334	25.1%	858	524	313.4	0.122	573.7
2516_B_3	Northport	391	0.0%	10634	0.14	0.000	0	25.1%	860	860	621.6	0.122	578.1
2516_B_4	Northport	385	0.0%	10663	0.10	0.000	0	25.1%	847	847	455.2	0.122	570.8

Assumes the IPM v.4.10_FTransport SO₂ emission rate of 1.04 lbs/MMBTU for oil-fired generation

Calculation of Revisions to New York State Budgets

In order to maintain the balance of electricity supply and demand as originally projected in the Transport Rule analysis, EPA is assuming that increased generation at the units shown above would offset the need for an equivalent amount of generation originally projected in IPM to occur at more efficient generators in the system. To calculate the net change in projected emissions for each pollutant relevant to establishing state budgets under the Transport Rule, EPA assumes that the increased generation at the units shown above displaces previously projected generation from a combined cycle unit in New York City, as that unit is representative of more efficient generation that is preferred in IPM determinations of least-cost dispatch. These calculations are shown in Table 9.e.

Table 9.e: Calculation of Emissions from Displaced Generation at a Representative Combined Cycle Unit in New York*				
	<i>A</i>	<i>B</i>	<i>C</i>	<i>D</i>
Program Period	Displaced Generation (GWh)	Heat Rate (BTU/kWh)	NO_x Emission Rate (lbs/MMBTU)	Displaced NO_x Emissions (tons)
<i>Calculation</i>				$A*B*C/2000$
Annual	8,227	7,600	0.01	313
Ozone Season	4,397	7,600	0.01	167

*Assumed heat rate and emission rates are taken from the 500 CC unit in New York City, as shown in NEEDS v4.10_FTtransport.

To quantify the proposed revisions to Transport Rule state budgets in New York, EPA has calculated the net emissions change associated with the revisions to unit-level generation presented in this section, including the displaced emissions shown in table 9.e. These calculations are shown in Table 9.f.

Table 9.f: Calculation to Determine Net New York SO₂, Annual NO_x, and Ozone Season NO_x Budget Revisions				
		SO₂	Annual NO_x	Ozone Season NO_x
<i>A</i>	Additional Emissions Due to New York City Revisions	1,805	2,408	1,257
<i>B</i>	Additional Emissions Due to Long Island Revisions	1,723	1,390	821
<i>C</i>	Displaced Emissions	0	313	167
<i>D</i>	Net Emissions Change For New York (A+B-C)	3,527	3,485	1,911

The proposed revisions to the annual and ozone season NO_x emission budgets for New York would result in small changes to the state’s new unit set-aside percentages for annual NO_x and ozone season NO_x. The reason for these changes is that under the methodology established in the final Transport Rule, the state-specific portion of the NUSA is calculated as the percentage equal to the projected emissions from “planned units” divided by the state budget for the relevant pollutant. In the case of New York, the projected emissions from planned units remain unchanged, but the budgets are increasing.²² Because the numerator remains unchanged but the denominator is increasing, the total new unit set-aside percentage for annual NO_x and ozone season NO_x decreases. That is, a smaller percentage of the state emission budgets is needed to cover emissions from “planned” new units, because the budgets are larger. For New York, the proposed budget revisions would decrease the NUSA percentages for both annual NO_x and ozone season NO_x from 3% to 2% as a result. This is applying the same NUSA methodology that is used for every state in the final Transport Rule, and the change in percentages is simply an outgrowth of the state’s budget revisions. Despite the lower percentage values, the absolute number of allowances in the New York NUSAs would rise in accordance with the proposed budget revisions for New York. The original and revised values for the state’s emission budgets, assurance levels, and new unit set-asides are described in the Table 9.g below.

²² While this relationship is also true for SO₂, the proposed revisions to New York’s SO₂ budget do not yield a different calculated NUSA percentage than the originally determined 2% under the final Transport Rule.

Table 9.g.: Impact of New York Budget Revisions – Assuming Out-of-Merit-Order Dispatch at New York City and Long Island Units (tons)						
	Program	Budget	Assurance Level		Total New Unit Set-Aside*	
			% of Budget	Tons	% of Budget	Tons
2012 Initial	SO ₂	27,325	118%	32,244	2%	547
2012 Revised	SO ₂	30,852	118%	36,405	2%	617
2014 Initial	SO ₂	18,585	118%	21,930	2%	372
2014 Revised	SO ₂	22,112	118%	26,092	2%	442
2012 Initial	Annual NO _x	17,543	118%	20,701	3%	351
2012 Revised	Annual NO _x	21,028	118%	24,813	2%	421
2014 Initial	Annual NO _x	17,543	118%	20,701	3%	351
2014 Revised	Annual NO _x	21,028	118%	24,813	2%	421
2012 Initial	Ozone-Season NO _x	8,331	121%	10,081	3%	167
2012 Revised	Ozone-Season NO _x	10,242	121%	12,393	2%	205
2014 Initial	Ozone-Season NO _x	8,331	121%	10,081	3%	167
2014 Revised	Ozone-Season NO _x	10,242	121%	12,393	2%	205

*Approximate set-aside amounts, may be adjusted upwards or downwards slightly following rounding of existing unit allocations

10) New Jersey

EPA is proposing to increase New Jersey’s SO₂, annual NO_x, and ozone season NO_x budgets to correct for the assumption that scrubber and SCR technology would be installed by 2012 at BL England Unit 1. The scrubber and SCR had been planned to meet an Administrative Consent Order (AO) with New Jersey, but an agreement with the state allowed for a delay in installation of the control technology until the end of 2013. Additionally, the AO requires that this unit only run during the ozone season²³. Therefore, EPA is adjusting the state’s 2012 emission budgets to reflect this unit operating only in the ozone season and without a scrubber or SCR. This results in a 2,096 ton increase to the state’s SO₂ budget; a 308 ton increase to the state’s annual NO_x budget; and a 397 ton increase to the state’s ozone season NO_x budget. As discussed later in this section, EPA assumes that the generation previously

²³ Personal Correspondence from Bill O’Sullivan, New Jersey Department of Environmental Protection, to Sam Napolitano. September 26, 2011.

projected at BL England Unit 1 outside of the ozone season (and thus inconsistent with the AO) would occur instead at well-controlled combined cycle units within the state, and their associated emissions are factored into the proposed revisions to New Jersey state budgets.

The calculations of revised 2012 emissions from ozone-season operation of BL England Unit 1 are shown in Table 10.a.

Table 10.a.: Calculation to Determine Revised Ozone Season Emissions at BL England Unit 1						
	<i>A</i>	<i>B</i>	<i>C</i>	<i>D</i>	<i>E</i>	<i>F</i>
Pollutant	Ozone Season Emissions from TR_Remedies_Final_2012 (1000 tons)	Ozone Season Heat Input from TR_Remedies_Final_2012 (Tbtu)	Remedy Emission Rate from TR_Remedies_Final_2012 (lbs/mmbtu)	Revised Emission Rate (lbs/mmbtu)	Revised Ozone Season Emissions (1000 tons)	Net Change in Ozone Season Emissions (1000 tons)
<i>Calculation</i>			$2 * A / B$		$D \times B / 2$	$E - A$
SO ₂	0.175	2.282	0.150	2.190	2.499	2.324
NO _x	0.105	2.282	0.092	0.440	0.502	0.397

Columns A, B, and C show the emissions, heat input, and emission rate from the TR_Remedies_Final_2012 modeling when the pollution control devices were originally assumed to be present at BL England Unit 1. Because neither a scrubber nor SCR is required by the AO in 2012, EPA modified the emission rates by removing the impact of the scrubber²⁴ and adopting the “controlled NO_x policy rate” in the NEEDS version from the September 1, 2010 TR Notice of Data Availability (NODA), which does not reflect operation of an SCR at that unit (column D).²⁵ These values approximate the emission rates expected at the unit at a cost threshold of \$500/ton when no scrubber or SCR is present at the unit. These emission rates were multiplied by the remedy heat input shown in column B to obtain a revised emissions value for the unit (column E). The difference between these revised emission projections (no scrubber or SCR assumed, column E) and the remedy emission projections (scrubber and SCR assumed, column A) determines the net change to this unit’s ozone-season emissions (column F).

Since the AO does not allow BL England Unit 1 to run outside of the ozone season, EPA has also determined the emissions impact from replacing the previously projected generation for that unit occurring outside of the ozone season. EPA assumes that this decrease in previously projected generation at

²⁴ The SO₂ emission rate for BL England Unit 1 in TR_Remedies_Final_2012 was 0.153 lbs/mmBtu. Removing the impact of that previously assumed scrubber’s SO₂ removal rate of 93% yields an uncontrolled SO₂ emission rate of 2.19 lbs/mmBtu.

²⁵ See National Electric Energy Data System (NEEDS) v4.10 available at <http://www.epa.gov/airmarkets/progsregs/epa-ipm/BaseCasev410.html>

BL England Unit 1 would be offset by increasing generation at New Jersey combined cycle units,²⁶ represented in these calculations as a generic unit with a heat rate and emission rates equal to the capacity-weighted average of New Jersey combined cycle units.²⁷ The calculations of emissions from this replaced generation are shown in Table 10.b.

Table 10.b.: Calculation of Emissions at New Jersey Combined Cycle Units from Replacing BL England Unit 1's Non-Ozone-Season Generation				
	<i>A</i>	<i>B</i>	<i>C</i>	<i>D</i>
Pollutant	BL England Unit 1 Non-Ozone Season Generation from TR_Remedy Final_2012 (GWh)	Average Heat Rate of Replacement Generation (Btu/kWh)	Emission Rate of Replacement Generation (lbs/mmBtu)	Emissions from Replacement Generation (1000 tons)
<i>Calculation</i>				$A*B*C/(2000*1000)$
SO ₂	253.3	8550	0	0
NO _x	253.3	8550	0.044	0.048

EPA calculated the SO₂ and NO_x emissions in table 10.b by multiplying the replaced generation (column A) by the generic unit's heat rate (column B) and relevant emission rate (column C).

In order to calculate appropriate revisions to New Jersey's 2012 SO₂, annual NO_x, and ozone season NO_x state budgets in accordance with the revisions to BL England Unit 1, EPA calculated the net change in projected emissions of each pollutant as shown in Table 10.c below.

²⁶ Excluding cogeneration facilities, whose generation is not solely based on electricity demand.

²⁷ These capacity-weighted average heat rates and emission rates are derived using calculations found in the Excel workbook titled "Calculation of heat rate and emission rate averages used in Budget Revisions" found in the docket for this rulemaking.

Table 10.c.: Calculation to Determine New Jersey 2012 Budget Revisions Due to Changes at BL England Unit 1 (1000 tons)			
	Quantity	Calculation	Value
<i>A</i>	Additional SO ₂ Emissions from BL England		2.324
<i>B</i>	SO ₂ Emissions from Replacement Generation		0
<i>C</i>	BL England Unit 1 Non-Ozone Season SO ₂ Emissions from TR_Remedey Final_2012		0.228
<i>D</i>	Net SO₂ Emissions Due to Revisions of BL England Unit 1	<i>A+B-C</i>	2.096
<i>E</i>	Additional Ozone Season NO _x Emissions from BL England		0.397
<i>F</i>	Annual NO _x Emissions from Replacement Generation		0.048
<i>G</i>	BL England Unit 1 Non-Ozone Season NO _x Emissions from TR_Remedey Final_2012		0.137
<i>H</i>	Net Annual NO_x Emissions Due to Revisions of BL England Unit 1	<i>E+F-G</i>	0.308
<i>I</i>	Net Ozone Season NO_x Emissions Due to Revisions of BL England Unit 1	<i>=E</i>	0.397

The revisions to New Jersey's 2012 SO₂ and annual NO_x budgets are determined by combining the revised emissions from ozone season operation without FGD or SCR at BL England Unit 1 (rows A and E) with the net change in emissions from replacing BL England's generation during the rest of the year (row B minus row C for SO₂, row D minus row E for NO_x). The revision to New Jersey's 2012 ozone-season NO_x budget is equivalent to the change in ozone season NO_x emissions at BL England due to removing the SCR (row E).

EPA is also proposing to increase New Jersey's annual NO_x and ozone season NO_x budgets to reflect the assumption of near-term operational constraints affecting six plants, based on information provided by the system operator demonstrating that northern New Jersey is an out-of-merit-order dispatch area. EPA's analysis in the final Transport Rule did not incorporate the immediate-term local conditions described in recently submitted documentation that appear likely to necessitate non-economic generation at the units displayed below during the implementation of the Transport Rule programs. Specifically, EPA is assuming additional generation will be dispatched at six plants (Bergen, Edison, Essex, Kearny, Linden, and Sewaren

Generating Stations) based on the average capacity factor representing the frequency the unit has recently been called on to operate out of merit order, calculated from dispatch logbook data provided by PSEG²⁸. As discussed later in this section, EPA assumes that the additional generation dispatched from these six facilities would offset generation that would otherwise come from combined cycle units within the state, and the proposed revisions to New Jersey state budgets are based on the net change to projected emissions taking that offsetting factor into account. The net impact of these changes on the state's 2012 and 2014 budgets are a 112 ton increase in annual NO_x and a 195 ton increase in ozone season NO_x.

The calculations of the increase in ozone season NO_x and annual NO_x emissions due to out-of-merit-order dispatch at the six facilities are shown in Tables 10.d and 10.e, respectively. For each unit with out-of-merit-order dispatch, the capacity, 2012 emissions from TR_Remedy Final_2012, heat rate, generation, and emission rate are shown (columns A to G). The average out-of-merit-order capacity factor is shown in column H. The additional generation for out-of-merit-order dispatch was calculated by multiplying the capacity, the average out-of-merit-order capacity factor, and the number of hours in either the ozone season or year (column I). The additional heat input required was calculated by multiplying the incremental generation by the unit's heat rate (column J). Finally, the additional emissions associated with the out-of-merit-order generation was calculated by multiplying the additional heat input by the unit's NO_x emission rate.

Table 10.d: Calculation to Determine New Jersey Ozone Season NO_x Budget Revisions - Assuming Out-of-Merit-Order Dispatch at Six Plants										
<i>A</i>	<i>B</i>	<i>C</i>	<i>D</i>	<i>E</i>	<i>F</i>	<i>G</i>	<i>H</i>	<i>I</i>	<i>J</i>	<i>K</i>
Plant Name	Unique ID	Capacity (MW)	2012 Ozone Season NO_x Emission from TR_Remedy Final_2012 (1000 tons)	Heat Rate (BTU/kWh)	Ozone Season Generation from TR_Remedy Final_2012 (GWh)	NO_x Emission Rate from TR_Remedy Final_2012 (lbs/mmBtu)	Ozone Season Average Out-Of-Merit-Order Capacity Factor	Additional Ozone Season Generation (GWh)*	Additional Ozone Season Heat Input (mmBtu)	Additional Ozone Season NO_x Emissions (tons)
<i>Calculation</i>								$C*H*3.672$	$E*I$	$G*J/2000$
Bergen	2398_G_1101	114	0.010	8841	55.18	0.04	20.1%	84.16	744,050	15.6
Bergen	2398_G_1201	114	0.010	8841	55.18	0.04	20.1%	84.16	744,050	15.6
Bergen	2398_	114	0.010	8841	55.18	0.04	20.1%	84.16	744,050	15.6

²⁸ See the spreadsheet "New Jersey Minimum Noneconomic Dispatch" provided by PSEG on September 26, 2011, in the docket for this rule making.

	G_1301									
Bergen	2398_ G_1401	114	0.010	8841	55.18	0.04	20.1%	84.16	744,050	15.6
Bergen	2398_ G_1501	219	0.020	8841	106.00	0.04	20.1%	161.67	1,429,359	30.0
Bergen	2398_ G_2101	163	0.004	9241	78.89	0.01	22.0%	131.73	1,217,340	7.3
Bergen	2398_ G_2201	163	0.004	9241	78.89	0.01	22.0%	131.73	1,217,340	7.3
Bergen	2398_ G_2301	224	0.006	9241	108.42	0.01	22.0%	181.03	1,672,908	10.0
PSEG Edison	2400_ G_11	42	0.003	16763	1.37	0.27	2.1%	3.29	55,100	7.4
PSEG Edison	2400_ G_12	42	0.003	16862	1.37	0.27	2.1%	3.17	53,375	7.1
PSEG Edison	2400_ G_13	42	0.003	16893	1.37	0.27	1.8%	2.79	47,161	6.3
PSEG Edison	2400_ G_14	42	0.003	16947	1.37	0.26	1.7%	2.60	44,143	5.8
PSEG Edison	2400_ G_21	42	0.003	17182	1.37	0.28	2.0%	3.04	52,261	7.2
PSEG Edison	2400_ G_22	42	0.003	16846	1.37	0.27	2.0%	3.07	51,731	6.9
PSEG Edison	2400_ G_23	42	0.003	16979	1.37	0.27	1.9%	2.87	48,679	6.6
PSEG Edison	2400_ G_24	42	0.004	17184	1.37	0.30	1.6%	2.53	43,451	6.5
PSEG Edison	2400_ G_31	42	0.003	16953	1.37	0.27	1.6%	2.52	42,653	5.7
PSEG Edison	2400_ G_32	42	0.003	16984	1.37	0.27	1.8%	2.76	46,909	6.3
PSEG Edison	2400_ G_33	42	0.003	17033	1.37	0.27	1.9%	2.87	48,964	6.6
PSEG Edison	2400_ G_34	42	0.003	16950	1.37	0.26	1.7%	2.68	45,443	6.0

PSEG Essex	2401_ G_101	42	0.003	16968	1.37	0.30	2.6%	4.00	67,800	10.2
PSEG Essex	2401_ G_102	42	0.004	17066	1.37	0.30	2.4%	3.66	62,382	9.3
PSEG Essex	2401_ G_103	42	0.004	17188	1.37	0.30	2.1%	3.31	56,950	8.5
PSEG Essex	2401_ G_104	42	0.004	17167	1.37	0.30	2.2%	3.33	57,220	8.6
PSEG Essex	2401_ G_111	46	0.004	16816	1.50	0.30	2.5%	4.16	69,880	10.5
PSEG Essex	2401_ G_112	46	0.004	17154	1.50	0.30	2.6%	4.48	76,769	11.5
PSEG Essex	2401_ G_113	46	0.004	16847	1.50	0.30	2.3%	3.92	66,007	9.9
PSEG Essex	2401_ G_114	46	0.004	16726	1.50	0.30	2.3%	3.86	64,566	9.7
PSEG Essex	2401_ G_121	46	0.004	16455	1.50	0.30	2.2%	3.80	62,517	9.4
PSEG Essex	2401_ G_122	46	0.004	16889	1.50	0.30	2.2%	3.78	63,867	9.6
PSEG Essex	2401_ G_123	46	0.004	16771	1.50	0.30	2.3%	3.83	64,166	9.6
PSEG Essex	2401_ G_124	46	0.001	16758	1.50	0.08	2.2%	3.67	61,540	2.6
PSEG Essex	2401_ G_9	81	0.022	10633	13.67	0.30	0.0%	0.00	0	0.0
PSEG Kearny	2404_ G_10	134	0.012	18700	4.45	0.30	0.5%	2.37	44,361	6.7
PSEG Kearny	2404_ G_11	134	0.012	18700	4.45	0.30	0.3%	1.47	27,572	4.1
PSEG Kearny	2404_ G_N121	43.8	0.003	9667	7.28	0.09	0.2%	0.26	2,534	0.1
PSEG Kearny	2404_ G_N122	43.7	0.003	9791	7.26	0.09	0.2%	0.27	2,670	0.1
PSEG Kearny	2404_ G_N123	43.8	0.003	10109	7.28	0.09	0.0%	0.02	201	0.0

PSEG Kearny	2404_ G_N124	43.7	0.003	9704	7.26	0.09	0.2%	0.26	2,475	0.1
PSEG Linden	2406_ G_5	86	0.005	12110	14.51	0.06	2.1%	6.58	79,681	2.4
PSEG Linden	2406_ G_6	86	0.005	12601	14.51	0.05	2.1%	6.60	83,206	2.1
PSEG Linden	2406_ G_7	84	0.005	12155	14.17	0.06	2.5%	7.83	95,173	2.8
PSEG Linden	2406_ G_8	84	0.006	13314	14.17	0.06	2.6%	8.03	106,922	3.4
PSEG Sewaren	2411_ B_1	104	-	12377	0.00	0.12	6.4%	24.28	300,531	17.6
PSEG Sewaren	2411_ B_2	118	-	13581	0.00	0.16	4.7%	20.31	275,884	22.1
PSEG Sewaren	2411_ B_3	107	-	14500	0.00	0.15	6.0%	23.73	344,085	26.1
PSEG Sewaren	2411_ B_4	124	-	14500	0.00	0.14	3.8%	17.38	251,965	17.6
TOTAL								1,142	11,483,943	410.2

*The formula used to calculate Column I uses a multiplier of 3.672 because there are 3,672 hours of possible operation in the ozone season; that factor is divided by 1,000 to yield units in GWh.

Table 10.e: Calculation to Determine New Jersey Annual NO_x Budget Revisions - Assuming Out-of-Merit-Order Dispatch at Six Plants

A	B	C	D	E	F	G	H	I	J	K
Plant Name	NEEDS Unique ID	Capacity (MW)	2012 Annual NO _x Emission (1000 tons) from TR_Remedy Final_2012	Heat Rate from TR_Remedy Final_2012	GWh Annual from TR_Remedy Final_2012	NO _x Emission Rate from TR_Remedy Final_2012 (lbs/mmBtu)	Annual Average Out-Of-Merit-Order Capacity Factor	Additional Annual Generation (GWh)*	Additional Annual Heat Input (mmBtu)	Additional Annual NO _x Emissions (tons)
Calculation								C*H*8.760	E*I	G*J/2000
Bergen	2398_G_1101	114	0.015	8841	78.98	0.04	36.3%	362.43	3,204,207	67.3
Bergen	2398_G_1201	114	0.015	8841	78.98	0.04	36.3%	362.43	3,204,207	67.3
Bergen	2398_G_1301	114	0.015	8841	78.98	0.04	36.3%	362.43	3,204,207	67.3
Bergen	2398_G_1401	114	0.015	8841	78.98	0.04	36.3%	362.43	3,204,207	67.3
Bergen	2398_G_1501	219	0.028	8841	151.72	0.04	36.3%	696.24	6,155,451	129.3
Bergen	2398_G_2101	163	0.005	9241	86.87	0.01	35.5%	507.55	4,690,299	28.1
Bergen	2398_G_2201	163	0.005	9241	86.87	0.01	35.5%	507.55	4,690,299	28.1
Bergen	2398_G_2301	224	0.007	9241	119.38	0.01	35.5%	697.50	6,445,565	38.7
PSEG Edison	2400_G_11	42	0.003	16763	1.37	0.27	1.0%	3.76	63,093	8.5
PSEG Edison	2400_G_12	42	0.003	16862	1.37	0.27	1.0%	3.56	59,944	8.0

PSEG Edison	2400_G_13	42	0.003	16893	1.37	0.27	0.8%	2.85	48,155	6.5
PSEG Edison	2400_G_14	42	0.003	16947	1.37	0.26	0.7%	2.67	45,259	6.0
PSEG Edison	2400_G_21	42	0.003	17182	1.37	0.28	1.0%	3.59	61,750	8.5
PSEG Edison	2400_G_22	42	0.003	16846	1.37	0.27	1.0%	3.60	60,655	8.1
PSEG Edison	2400_G_23	42	0.003	16979	1.37	0.27	0.8%	3.02	51,338	7.0
PSEG Edison	2400_G_24	42	0.004	17184	1.37	0.30	0.7%	2.68	46,125	6.9
PSEG Edison	2400_G_31	42	0.003	16953	1.37	0.27	0.8%	2.88	48,831	6.5
PSEG Edison	2400_G_32	42	0.003	16984	1.37	0.27	0.8%	3.10	52,620	7.1
PSEG Edison	2400_G_33	42	0.003	17033	1.37	0.27	0.8%	2.94	50,000	6.7
PSEG Edison	2400_G_34	42	0.003	16950	1.37	0.26	0.7%	2.74	46,491	6.1
PSEG Essex	2401_G_101	42	0.003	16968	1.37	0.30	1.6%	6.07	102,945	15.4
PSEG Essex	2401_G_102	42	0.004	17066	1.37	0.30	1.5%	5.39	91,989	13.8
PSEG Essex	2401_G_103	42	0.004	17188	1.37	0.30	1.3%	4.79	82,370	12.3
PSEG Essex	2401_G_104	42	0.004	17167	1.37	0.30	1.4%	5.21	89,408	13.4
PSEG Essex	2401_G_111	46	0.004	16816	1.50	0.30	1.7%	6.70	112,614	16.9
PSEG Essex	2401_G_112	46	0.004	17154	1.50	0.30	1.8%	7.15	122,683	18.4
PSEG Essex	2401_G_113	46	0.004	16847	1.50	0.30	1.5%	6.20	104,513	15.7
PSEG Essex	2401_G_114	46	0.004	16726	1.50	0.30	1.6%	6.53	109,251	16.4

PSEG Essex	2401_ G_121	46	0.004	16455	1.50	0.30	1.9%	7.49	123,289	18.5
PSEG Essex	2401_ G_122	46	0.004	16889	1.50	0.30	2.0%	7.90	133,445	20.0
PSEG Essex	2401_ G_123	46	0.004	16771	1.50	0.30	1.9%	7.60	127,493	19.1
PSEG Essex	2401_ G_124	46	0.001	16758	1.50	0.08	1.8%	7.24	121,333	5.1
PSEG Essex	2401_ G_9	81	0.022	10633	13.67	0.30	0.1%	0.57	6,026	0.9
PSEG Kearny	2404_ G_10	134	0.012	18700	4	0.30	0.3%	3.63	67,789	10.2
PSEG Kearny	2404_ G_11	134	0.012	18700	4	0.30	0.2%	2.78	51,981	7.8
PSEG Kearny	2404_ G_N121	43.8	0.004	9667	9	0.09	0.3%	1.25	12,097	0.6
PSEG Kearny	2404_ G_N122	43.7	0.004	9791	9	0.09	0.3%	1.15	11,299	0.5
PSEG Kearny	2404_ G_N123	43.8	0.004	10109	9	0.09	0.3%	1.33	13,463	0.6
PSEG Kearny	2404_ G_N124	43.7	0.004	9704	9	0.09	0.4%	1.39	13,488	0.6
PSEG Linden	2406_ G_5	86	0.005	12110	15	0.06	1.2%	9.20	111,371	3.3
PSEG Linden	2406_ G_6	86	0.005	12601	15	0.05	1.3%	9.55	120,318	3.0
PSEG Linden	2406_ G_7	84	0.005	12155	14	0.06	1.9%	14.25	173,152	5.1
PSEG Linden	2406_ G_8	84	0.006	13314	14	0.06	1.6%	11.99	159,613	5.1
PSEG Sewaren	2411_ B_1	104	-	12377	0	0.12	2.8%	25.71	318,163	18.6
PSEG Sewaren	2411_ B_2	118	-	13581	0	0.16	1.9%	19.24	261,271	21.0
PSEG Sewaren	2411_ B_3	107	-	14500	0	0.15	2.7%	25.45	368,953	28.0

PSEG Sewaren	2411_B_4	124	-	14500	0	0.14	1.6%	17.37	251,901	17.6
TOTAL								4,119	38,694,923	886.9

*The formula used to calculate Column I uses a multiplier of 8.760 because there are 8,760 hours of possible operation in the year; that factor is divided by 1,000 to yield units in GWh.

As calculated in Table 10.f, EPA is assuming that the increase in generation reflecting out-of-merit-order dispatch would be offset by decreasing generation at New Jersey combined cycle units, shown in these calculations as a representative unit with a heat rate (column B) and emission rate (column C) equal to the capacity-weighted average of New Jersey combined cycle units.²⁹ The ozone season and annual NO_x emissions associated with the displaced generation (column D) were calculated by multiplying that generation by the average heat rate and the relevant emission rate at the representative combined cycle unit.

Table 10.f: Calculation of Emissions from Displaced Generation at New Jersey Combined Cycle Units				
	<i>A</i>	<i>B</i>	<i>C</i>	<i>D</i>
Program Period	Displaced Generation (GWh)	Heat Rate (BTU/kWh)	NO_x Emission Rate (lbs/MMBTU)	Displaced NO_x Emissions (tons)
<i>Calculation</i>				<i>A*B*C/2000</i>
Annual	4,119	8,850	0.044	775
Ozone Season	1,142	8,850	0.044	215

The total revisions proposed to New Jersey’s state budgets due to the revisions at BL England and accounting for the out-of-merit-order dispatch are demonstrated in Table 10.g. The increase in emissions due to the changes at BL England Unit 1, which only impact the 2012 budgets, were added to the increase in emissions due to the out-of-merit-order generation, which impact both the 2012 and 2014 budgets. The emissions associated with the generation displaced by the out-of-merit-order generation was subtracted from the increase in emissions to determine the net emission budget changes for New Jersey (row D).

²⁹ These capacity-weighted average heat rates and emission rates are derived using calculations found in the Excel workbook titled “Calculation of heat rate and emission rate averages used in Budget Revisions” found in the docket for this rulemaking.

Table 10.g: Calculation to Determine Net New Jersey SO₂, Annual NO_x, and Ozone Season NO_x Budget Revisions (tons)							
		2012			2014		
		SO₂	Annual NO_x	Ozone Season NO_x	SO₂	Annual NO_x	Ozone Season NO_x
<i>A</i>	Net Emissions Increases Due to Changes at BL England Unit 1	2,096	308	397	0	0	0
<i>B</i>	Additional Emissions Due to Out-Of-Merit-Order Generation	0	887	410	0	887	410
<i>C</i>	Displaced Emissions from Out-Of-Merit-Order Generation	0	775	215	0	775	215
<i>D</i>	Net Budget Revisions for New Jersey (A+B-C)	2096	420	592	0	112	195

The original and revised values for the state SO₂, annual NO_x, and ozone season NO_x budgets, assurance levels, and new unit set-asides are described in Table 10.h.

Table 10.h.: Impact of New Jersey Budget Revisions – Assuming No FGD or SCR at BL England Unit 1 in 2012 and Out-of-Merit-Order Dispatch at Six Facilities (tons)						
	Program	Budget	Assurance Level		Total New Unit Set-Aside*	
			% of Budget	Tons	% of Budget	Tons
2012 Initial	SO ₂	5,574	118%	6,577	2%	111
2012 Revised	SO ₂	7,670	118%	9,051	2%	153
2014 Initial	SO ₂	5,574	118%	6,577	2%	111
2014 Revised	SO ₂	5,574	118%	6,577	2%	111
2012 Initial	Annual NO _x	7,266	118%	8,574	2%	145
2012 Revised	Annual NO _x	7,686	118%	9,069	2%	154
2014 Initial	Annual NO _x	7,266	118%	8,574	2%	145
2014 Revised	Annual NO _x	7,378	118%	8,706	2%	148
2012 Initial	Ozone-Season NO _x	3,382	121%	4,092	2%	68
2012 Revised	Ozone-Season NO _x	3,974	121%	4,809	2%	79
2014 Initial	Ozone-Season NO _x	3,382	121%	4,092	2%	68
2014 Revised	Ozone-Season NO _x	3,577	121%	4,328	2%	72

*Approximate set-aside amounts, may be adjusted upwards or downwards slightly following rounding of existing unit allocations

11) Louisiana

EPA is proposing to increase Louisiana's ozone season NO_x budget for 2012 and 2014 to reflect the assumption of near-term operational constraints affecting units at five plants, based on information provided by the system operator demonstrating that there are three out-of-merit-order dispatch areas in Louisiana: the West of the Atchafalaya Basin (WOTAB), Down Stream of Gypsy (DSG), and Amite South regions. EPA's analysis in the final Transport Rule did not incorporate the immediate-term local conditions described in recently submitted documentation that appear likely to necessitate non-economic generation at the units displayed below during the implementation of the Transport Rule programs. Specifically, EPA is assuming additional generation will be dispatched at five plants (Nelson, Nine Mile Point, Michoud, Little Gypsy, and Waterford) based on the average capacity factor representing the frequency the unit is projected to be called to operate out-of-merit-order, derived from immediate-term dispatch modeling projections provided by Entergy.³⁰ As discussed later in this section, EPA assumes that the additional generation dispatched from these five facilities would offset generation that would otherwise come from combined cycle units within the state, and the proposed revision to Louisiana's state budget is based on the net change to projected emissions taking that offsetting factor into account. The net impact of these changes on the state's ozone season NO_x budget is a 4,231 ton increase.

The calculations of the increase in ozone season NO_x emissions due to out-of-merit-order dispatch at the five facilities is shown in Table 11.a. For each unit with out-of-merit-order dispatch, the capacity, 2012 emissions from TR_Remedies_Final_2012, heat rate, generation from TR_Remedies_Final_2012, and emission rate from EPA's NEEDS database are shown (columns A to G). The average out-of-merit-order capacity factor is shown in column H. The additional generation for out-of-merit-order dispatch was calculated by multiplying the capacity, the average out-of-merit-order capacity factor, and the number of hours in the ozone season (column I). The additional heat input required was calculated by multiplying the incremental generation by the unit's heat rate (column J). Finally, the additional emissions associated with the out-of-merit-order generation was calculated by multiplying the additional heat input by the unit's NO_x emission rate.

³⁰ Correspondence from Entergy to EPA, September 29, 2011. Please see the document "Transmission System Considerations – Entergy" in the docket for this rule making.

Table 11.a: Calculation to Determine Louisiana Ozone Season NO_x Budget Revisions - Assuming Out-of-Merit-Order Dispatch at Five Plants

A	B	C	D	E	F	G	H	I	J	K
Plant Name	Unique Id	Capacity (MW)	2012 Ozone Season NO _x Emissions from TR_Remedy Final_2012 (1000 tons)	Heat Rate (BTU/kWh)	Ozone Season Generation from TR_Remedy Final_2012 (GWh)	Ozone Season NO _x Rate (lbs/mmBtu)	Ozone Season Average Out-Of-Merit-Order Capacity Factor	Additional Ozone Season Generation*	Additional Ozone Season Heat Input (mmBtu)	Additional Ozone Season NO _x Emissions (tons)
<i>Calculation</i>								$C*H*3.672$	$E*I$	$G*J/2000$
R S Nelson	1393_B_3	153	0	10476	0	0.151	16%	89.89	941,694	70.9
R S Nelson	1393_B_4	500	0	10419	0	0.128	23%	422.28	4,399,735	281.3
Little Gypsy	1402_B_1	244	0	9978	0	0.278	7%	62.72	625,798	86.8
Little Gypsy	1402_B_2	415	0	10032	0	0.098	3%	45.72	458,627	22.5
Little Gypsy	1402_B_3	545	0	10179	0	0.311	24%	480.30	4,888,949	760.0
Nine Mile Point	1403_B_3	132	0	10264	0	0.149	11%	53.32	547,250	40.9
Nine Mile Point	1403_B_4	738	0	9955	0	0.337	31%	840.08	8,362,998	1,409.0
Nine Mile Point	1403_B_5	753	0	9841	0	0.298	34%	940.11	9,251,578	1,380.0
Michoud	1409_B_1	100	0	11427	0	0.042	0%	0.00	0	0.0
Michoud	1409_B_2	230	0	10997	0	0.207	30%	253.37	2,786,288	287.9
Michoud	1409_B_3	530	0	11288	0	0.105	45%	875.77	9,885,714	518.7
Waterford 1 & 2	8056_B_1	400	0	10238	0	0.123	3%	44.06	451,127	27.9

Waterford 1 & 2	8056_B_2	405	0	10137	0	0.116	7%	104.10	1,055,274	61.2
Total								4,211.71	43,655,032	4,947.1

*The formula used to calculate Column I uses a multiplier of 3.672 because there are 3,672 hours of possible operation in the ozone season; that factor is divided by 1,000 to yield units in GWh.

As calculated in Table 11.b, EPA is assuming that the increase in generation reflecting out-of-merit-order dispatch would be offset by decreasing generation at Louisiana combined cycle units, shown in these calculations as a representative unit with a heat rate (column B) and emission rate (column C) equal to the capacity-weighted average of Louisiana combined cycle units.³¹ The ozone season NO_x emissions associated with the displaced generation (column D) were calculated by multiplying that generation by the average heat rate and the relevant emission rate at the representative combined cycle unit.

Table 11.b: Calculation of Emissions from Displaced Generation at Louisiana Combined Cycle Units				
	<i>A</i>	<i>B</i>	<i>C</i>	<i>D</i>
Program Period	Displaced Generation (GWh)	Heat Rate (BTU/kWh)	NO_x Emission Rate (lbs/MMBTU)	Displaced NO_x Emissions (tons)
<i>Calculation</i>				<i>A*B*C/2000</i>
Ozone Season	4,212	6,798	0.05	716

The total revision proposed to Louisiana’s state budget due to the out-of-merit-order dispatch is calculated in Table 11.c. The emissions associated with the generation displaced by the out-of-merit-order generation (row B) were subtracted from the increase in emissions due to the out-of-merit-order generation (row A) to determine the net emission budget changes for Louisiana (row C).

³¹ These capacity-weighted average heat rates and emission rates are derived using calculations found in the Excel workbook titled “Calculation of heat rate and emission rate averages used in Budget Revisions” found in the docket for this rulemaking.

Table 11.c: Calculation to Determine Net Louisiana Ozone Season NO_x Budget Revisions (tons)		
<i>A</i>	Additional Emissions Due to Out-Of-Order-Merit Dispatch	4,947
<i>B</i>	Displaced Emissions From Out-Of-Order-Merit Dispatch	716
<i>C</i>	Net Emission budget Change For Louisiana (A-B)	4,231

The original and revised values for the state ozone season NO_x budget, assurance level, and new unit set-aside are described in Table 11.d.

Table 11.d.: Impact of Louisiana Ozone-Season NO_x Budget Revisions – Assuming Out-of-Merit-Order Dispatch at Five Facilities (tons)					
	Budget	Assurance Level		Total New Unit Set-Aside*	
		% of Budget	Tons	% of Budget	Tons
2012 Initial	13,432	121%	16,253	3%	403
2012 Revised	17,663	121%	21,372	3%	530
2014 Initial	13,432	121%	16,253	3%	403
2014 Revised	17,663	121%	21,372	3%	530

*Approximate set-aside amounts, may be adjusted upwards or downwards slightly following rounding of existing unit allocations

12) Mississippi

EPA is proposing to increase Mississippi’s ozone season NO_x budget in 2012 and 2014 to reflect the assumption of near-term operational constraints affecting units at three plants, based on information provided by the system operator demonstrating that the Mississippi Region is an out-of-merit-order dispatch area. EPA's analysis in the final Transport Rule did not incorporate the immediate-term local conditions described in recently submitted documentation that appear likely to necessitate non-economic generation at the units displayed below during the implementation of the Transport Rule

programs. Specifically, EPA is assuming additional generation will be dispatched at three plants (Rex Brown, Gerald Andrus, and Baxter Wilson) based on the average capacity factor representing the frequency the unit is projected to be called to operate out-of-merit-order, derived from immediate-term dispatch modeling projections provided by Entergy.³² As discussed later in this section, EPA assumes that the additional generation dispatched from these three facilities would offset generation that would otherwise come from combined cycle units within the state, and the proposed revision to Mississippi's state budget is based on the net change to projected emissions taking that offsetting factor into account. The net impact of these changes on the state's ozone season NO_x budget is a 2,136 ton increase.

The calculations of the increase in ozone season NO_x emissions due to out-of-merit-order dispatch at the three facilities is shown in Table 12.a. For each unit with out-of-merit-order dispatch, the capacity, 2012 emissions from TR_Remedies_Final_2012, heat rate, generation from TR_Remedies_Final_2012, and emission rate from EPA's NEEDS database are shown (columns A to G). The average out-of-merit-order capacity factor is shown in column H. The additional generation for out-of-merit-order dispatch was calculated by multiplying the capacity, the average out-of-merit-order capacity factor, and the number of hours in the ozone season (column I). The additional heat input required was calculated by multiplying the incremental generation by the unit's heat rate (column J). Finally, the additional emissions associated with the out-of-merit-order generation was calculated by multiplying the additional heat input by the unit's NO_x emission rate.

³² Correspondence from Entergy to EPA, September 29, 2011. Please see the document "Transmission System Considerations – Entergy" in the docket for this rule making.

<i>A</i>	<i>B</i>	<i>C</i>	<i>D</i>	<i>E</i>	<i>F</i>	<i>G</i>	<i>H</i>	<i>I</i>	<i>J</i>	<i>K</i>
Plant Name	Unique Id	Capacity (MW)	2012 Ozone Season NO_x Emissions from TR_Remedy Final_2012 (1000 tons)	Heat Rate (BTU/kWh)	Ozone Season Generation from TR_Remedy Final_2012 (GWh)	Ozone Season NO_x Rate (lbs/mmBtu)	Ozone Season Average Out-Of-Merit-Order Capacity Factor	Additional Ozone Season Generation*	Additional Ozone Season Heat Input (mmBtu)	Additional Ozone Season NO_x Emissions (tons)
<i>Calculation</i>								$C*H*3.672$	$E*I$	$G*J/2000$
Rex Brown	2053_B_4	200	0	14500	0	0.228	4%	29.38	425,952	48.6
Baxter Wilson	2050_B_1	475	0	10655	0	0.318	7%	122.09	1,300,912	207.1
Baxter Wilson	2050_B_2	771	0	10511	0	0.422	18%	509.60	5,356,407	1130.5
Gerald Andrus	8054_B_1	670	0	10748	0	0.209	33%	811.88	8,726,078	912.8
Total								1472.95	15,809,348	2299.1
*The formula used to calculate Column I uses a multiplier of 3.672 because there are 3,672 hours of possible operation in the ozone season; that factor is divided by 1,000 to yield units in GWh.										

As calculated in Table 12.b, EPA is assuming that the increase in generation reflecting out-of-merit-order dispatch would be offset by decreasing generation at Mississippi combined cycle units, shown in these calculations as a representative unit with a heat rate (column B) and emission rate (column C) equal to the capacity-weighted average of Mississippi combined cycle units.³³ The ozone season NO_x emissions associated with the displaced generation (column D) were calculated by multiplying that generation by the average heat rate and the relevant emission rate at the representative combined cycle unit.

³³ These capacity-weighted average heat rates and emission rates are derived using calculations found in the Excel workbook titled “Calculation of heat rate and emission rate averages used in Budget Revisions” found in the docket for this rulemaking.

Table 12.b: Calculation of Emissions from Displaced Generation at Mississippi Combined Cycle Units				
	<i>A</i>	<i>B</i>	<i>C</i>	<i>D</i>
Program Period	Displaced Generation (GWh)	Heat Rate (BTU/kWh)	NO_x Emission Rate (lbs/MMBTU)	Displaced NO_x Emissions (tons)
<i>Calculation</i>				<i>A*B*C/2000</i>
Ozone Season	1,473	7,388	0.03	163

The total revision proposed to Mississippi’s state budget due to the out-of-merit-order dispatch is calculated in Table 12.c. The emissions associated with the generation displaced by the out-of-merit-order generation (row B) were subtracted from the increase in emissions due to the out-of-merit-order generation (row A) to determine the net emission budget changes for Mississippi (row C).

Table 12.c: Calculation to Determine Net Mississippi Ozone Season NO_x Budget Revisions		
A	Additional Emissions Due to Out-Of-Order-Merit Dispatch	2,299
B	Displaced Emissions From Out-Of-Order-Merit Dispatch	163
C	Net Change in Emission budget For Mississippi (A-B)	2,136

The original and revised values for the state ozone season NO_x budget, assurance level, and new unit set-aside are described in Table 12.d.

Table 12.d.: Impact of Mississippi Ozone-Season NO_x Budget Revisions – Assuming Out-of-Merit-Order Dispatch at Three Facilities (tons)					
	Budget	Assurance Level		Total New Unit Set-Aside*	
		% of Budget	Tons	% of Budget	Tons
2012 Initial	10,160	121%	12,294	2%	203
2012 Revised	12,296	121%	14,878	2%	246
2014 Initial	10,160	121%	12,294	2%	203
2014 Revised	12,296	121%	14,878	2%	246

*Approximate set-aside amounts, may be adjusted upwards or downwards slightly following rounding of existing unit allocations

13) Texas (Out-of-Merit-Order Dispatch)

EPA is proposing to increase Texas’s annual NO_x and ozone season NO_x budgets in 2012 and 2014 to reflect the assumption of near-term operational constraints affecting units at two plants, based on information provided by the system operator demonstrating that the Western and West of the Atchafalaya regions are out-of-merit-order dispatch areas. EPA’s analysis in the final Transport Rule did not incorporate the immediate-term local conditions described in recently submitted documentation that appear likely to necessitate non-economic generation at the units displayed below during the implementation of the Transport Rule programs. Specifically, EPA is assuming additional generation will be dispatched at two plants (Lewis Creek and Sabine) based on the average capacity factor representing the frequency the unit is projected to be called to operate out-of-merit-order, derived from immediate-term dispatch projections provided by Entergy.³⁴ As discussed later in this section, EPA assumes that the additional generation dispatched from these two facilities would offset generation that would otherwise come from combined cycle units within the state, and the proposed revisions to Texas’s state budgets are based on the net change to projected emissions taking that offsetting factor into account. The net impact of these changes on the state’s annual NO_x and ozone season NO_x budgets is a 1,375 ton increase to each budget.

³⁴ Correspondence from Entergy to EPA, September 29, 2011. Please see the document “Transmission System Considerations – Entergy” in the docket for this rule making.

The calculations of the increase in annual and ozone season NO_x emissions due to out-of-merit-order dispatch at the two facilities is shown in Table 13.a. For each unit with out-of-merit-order dispatch, the capacity, 2012 emissions from TR_Remedey Final_2012, heat rate, generation from TR_Remedey Final_2012, and emission rate from EPA's NEEDS database are shown (columns A to G). The average out-of-merit-order capacity factor is shown in column H. The additional generation for out-of-merit-order dispatch was calculated by multiplying the capacity, the average out-of-merit-order capacity factor, and the number of hours in the ozone season (column I). The additional heat input required was calculated by multiplying the incremental generation by the unit's heat rate (column J). Finally, the additional emissions associated with the out-of-merit-order generation was calculated by multiplying the additional heat input by the unit's NO_x emission rate.

Table 13.a: Calculation to Determine Texas NO_x* Budget Revisions - Assuming Out-of-Merit-Order Dispatch at Two Plants

A	B	C	D	E	F	G	H	I	J	K
Plant Name	Unique ID	Capacity (MW)	2012 Ozone Season NO _x Emission from TR_Remedy Final_2012 (1000 tons)	Heat Rate (BTU/kWh)	Ozone Season Generation from TR_Remedy Final_2012 (GWh)	Ozone Season NO _x Rate (lbs/mmBtu)	Ozone Season Average Out-Of-Merit-Order Capacity Factor	Additional Ozone Season Generation**	Additional Ozone Season Heat Input (mmBtu)	Additional Ozone Season NO _x Emissions (tons)
<i>Calculation</i>								$C*H*3.672$	$E*I$	$G*J/2000$
Lewis Creek	3457_B_1	229	0	10325	0	0.020	47%	395.22	4,080,619	40.5
Lewis Creek	3457_B_2	230	0	10600	0	0.020	55%	464.51	4,923,785	48.5
Sabine	3459_B_1	230	0	11172	0	0.168	37%	312.49	3,491,107	293.8
Sabine	3459_B_2	230	0	10225	0	0.152	30%	253.37	2,590,688	197.2
Sabine	3459_B_3	420	0	10588	0	0.104	32%	493.52	5,225,356	271.7
Sabine	3459_B_4	530	0	9800	0	0.143	45%	875.77	8,582,566	613.5
Sabine	3459_B_5	480	0	10442	0	0.090	15%	264.38	2,760,698	124.8
Total								3,059.25	31,654,818	1,589.8

*Note: Since the increase in generation at these units is limited to the ozone season, the revised emissions calculated here apply equally to determination of the annual NO_x and ozone-season NO_x state budgets.
 **The formula used to calculate Column I uses a multiplier of 3.672 because there are 3,672 hours of possible operation in the ozone season; that factor is divided by 1,000 to yield units in GWh.

As calculated in Table 13.b, EPA is assuming that the increase in generation reflecting out-of-merit-order dispatch would be offset by decreasing generation at Texas combined cycle units, shown in these calculations as a representative unit with a heat rate (column B) and emission rate (column C)

equal to the capacity-weighted average of Texas combined cycle units.³⁵ The ozone season NO_x emissions associated with the displaced generation (column D) were calculated by multiplying that generation by the average heat rate and the relevant emission rate at the representative combined cycle unit.

Table 13.b: Calculation of Emissions from Displaced Generation at Texas Combined Cycle Units				
	<i>A</i>	<i>B</i>	<i>C</i>	<i>D</i>
Program Period	Displaced Generation (GWh)	Heat Rate (BTU/kWh)	NO_x Emission Rate (lbs/MMBTU)	Displaced NO_x Emissions (tons)
<i>Calculation</i>				<i>A*B*C/2000</i>
Annual	3,059	7,376	0.019	214
Ozone Season	3,059	7,376	0.019	214

The total revisions proposed to the Texas state budgets due to out-of-merit-order dispatch are calculated in Table 13.c. The emissions associated with the generation displaced by the out-of-merit-order generation (row B) were subtracted from the increase in emissions due to the out-of-merit-order generation (row A) to determine the net emission budget changes for Texas (row C).

Table 13.c: Calculation to Determine Net Texas Annual NO_x and Ozone Season NO_x Budget Revisions*		
<i>A</i>	Additional Emissions Due to Out-Of-Order-Merit Dispatch	1,590
<i>B</i>	Displaced Emissions From Out-Of-Order-Merit Dispatch	214
<i>C</i>	Net Emission budget Change For Texas (A-B)	1,375
*Note: Since the increase in generation at these units is limited to the ozone season, the revised emissions calculated here apply equally to determination of the annual NO _x and ozone-season NO _x state budgets.		

³⁵ These capacity-weighted average heat rates and emission rates are derived using calculations found in the Excel workbook titled “Calculation of heat rate and emission rate averages used in Budget Revisions” found in the docket for this rulemaking.

In addition to the revisions summarized in Table 13.c., the revisions to Texas state budgets outlined above in sections 3, 4, and 7 of this technical support document are summarized in Table 13.d. The cumulative impacts of all of the technical revisions to the Texas budgets and NUSAs are summarized in Table 13.e.

Table 13.d.: Summary of Texas SO ₂ Budget Revisions	
Removed FGD Revision	26,359
FGD Capture Revision	43,708
Total SO₂ Budget Revision	70,067

Table 13.e.: Impact of Texas Budget Revisions – Assuming Removed FGDs and Revised FGD Capture at Certain Units, Revised NUSAs for Oak Grove 2, and Out-of-Merit-Order Dispatch at Two Facilities (tons)						
	Program	Budget	Assurance Level		Total New Unit Set-Aside*	
			% of Budget	Tons	% of Budget	Tons
2012 Initial	SO ₂	243,954	118%	287,866	5%	12,198
2012 Revised	SO ₂	314,021	118%	370,545	5%	15,701
2014 Initial	SO ₂	243,954	118%	287,866	5%	12,198
2014 Revised	SO ₂	314,021	118%	370,545	5%	15,701
2012 Initial	Annual NO _x	133,595	118%	157,642	3%	4,008
2012 Revised	Annual NO _x	134,970	118%	159,265	4%	5,399
2014 Initial	Annual NO _x	133,595	118%	157,642	3%	4,008
2014 Revised	Annual NO _x	134,970	118%	159,265	4%	5,399
2012 Initial	Ozone-Season NO _x	63,043	121%	76,282	3%	1,891
2012 Revised	Ozone-Season NO _x	64,418	121%	77,946	4%	2,577
2014 Initial	Ozone-Season NO _x	63,043	121%	76,282	3%	1,891
2014 Revised	Ozone-Season NO _x	64,418	121%	77,946	4%	2,577

*Approximate set-aside amounts, may be adjusted upwards or downwards slightly following rounding of existing unit allocations