

AMERICAN IRON & STEEL WAIVER REQUEST REVIEW APPLICATION

NEW JERSEY AMERICAN WATER
(Project Owner)

RM RAW WATER PUMPING IMPROVEMENTS Contract 2B
(Name of Project)

2004002-011
(NJSRF Clean Water Funded Project Number)

GENERAL

Description of the Construction Material: _____

Qty. (2) 16" VAG SKR Slanted Seat Tilting Disk Check valve CI 150 _____

Quantity and Unit of Measure: _____

Qty 2

Price: [REDACTED]

Time of delivery or availability: August 2017

Location of the construction project: Bridgewater, NJ

Name and address of proposed supplier and/or Manufacturer:

VGA, USA LLC, 9025 Marshall Road, Cranbury Township, PA 16066

Detailed justification for the use of foreign construction materials: _____

Iron and steel products are not produced in the United States in sufficient and reasonably available quantities and of a satisfactory quality

AVAILABILITY WAIVER REQUEST

Domestic Supplier Information: Not available domestically

Project Schedule (provide NTP date and completion date along with project schedule)

NTP: March 27, 2017, Substantial Completion: June 30, 2018; Final Completion: December 15, 2018

List and provide supporting documentation:

See attached letter from NJAW Contractor, Allied Construction Group

Efforts to Locate Available Domestic Source:

The valve design is unique to VAG. There aren't any other domestic sources to go to unless the spec requirements are changed. A compact body valve is required to fit in the available space in the pump pit.

NJDEP Project Engineer: Robert M. Hopkins, P.E.

NJDEP Section Chief: William P. Machotka, P.E.
