

NPDES authorization to discharge to waters of the United States, Permit No. LA0124664

The applicant's mailing address is:

Jena Band of Choctaw Indians Choctaw Pines Casino WWTP  
P.O. Drawer 14  
Jena, LA 71342-0014

As described in the application, the facility is located at 149 Chahta Trails Dry Prong, Louisiana 71428, in Grant Parish. Hwy 167 South Prospect, Louisiana 71342, in Grant Parish, Louisiana.

Under the North American Industry Classification System (NAICS) code 2213. The applicant operates a privately owned sanitary wastewater treatment facility that is equivalent to a publicly owned treatment works (POTW). The facility has a design flow capacity of 0.05 MGD serving a transient population of approximately 500. The discharge from the POTW is through Outfall 001 at Latitude 31° 26' 12.79" North and Longitude 92° 29' 38.2" West, to an unmanned creek thence to Hudson Creek thence into Bayou Rigolette in Grant Parish, LA.

Under the Standard Industrial Classification (SIC) Code 4952, the applicant operates a Tribe Casino's wastewater treatment plant with a design capacity of 0.05 million gallons per day (MGD).

This is a reissuance of the current NPDES permit issued May 31, 2012, with an effective date of July 1, 2012 and an expiration date of June 30, 2017.

Changes from the previous permit are:

1. Removed Fecal Coliforms limit based on compliance with *E.coli* limit while still meeting State's Fecal Coliform Standards.
2. Decrease measurement frequency from once/week to twice/month for *E.coli*, Ammonia-total as N, and DO based on flow of WWTP and compliance history.
3. For DO measurement, added the word minimum for its measurement.
4. CBOD<sub>5</sub> and TSS removal limits have been added.
5. TDS monitoring frequency increased to once/year.

A fact sheet is available.

If you want to comment submit written comments within the 30 day period to:

Evelyn Rosborough (6WQ-PO)  
U.S. Environmental Protection Agency  
Region 6  
1445 Ross Avenue  
Dallas, Texas 75202-2733  
Phone (214) 665-7515  
[rosborough.evelyn@epa.gov](mailto:rosborough.evelyn@epa.gov)