

OPERATING PERMIT CONDITIONS
PERMIT NO. OP-18-0005
COMPANY: International Paper Company.

(3) This Operating Permit amends Operating Permit No. 18-302-015B and Plan Approval No. 18-302-017B for the incorporation of NOX/VOC Reasonably Available Control Technology (RACT) requirements of 25 PA Code Section 129.91-95. Sources covered by this Operating Permit shall also comply with the terms and conditions of Operating Permit No. 18-302-015B and Plan Approval 18-302-017B.

(4) The expiration date shown in this Permit is for State purposes. For Federal Enforcement purposes, the Operating Permit shall remain in affect as part of the State Implementation Plan (SIP) until replaced pursuant to 40 CFR 51 and approved by the US Environmental Protection Agency (EPA). The Operating Permit shall become enforceable by the US EPA upon its approval of the above as a revision to the SIP.

(5) NOX RACT for existing Riley Stoker Corp., bituminous coal-fired boilers Nos. 1 and 2 shall be the performance of an annual adjustment or tuneup in accordance with the minimum requirements of Section 129.93(b)(2).

(6) Units 1 and 2 shall comply with the following never to exceed NOX emission limits:

	30 Day Rolling Average (lb/MMbtu)	Annual Average (TPY)
Unit 1	0.70	780
Unit 2	0.70	885

The Department reserves the right to revise the NOx emission rates based upon CEM data.

(7) (a) Continuous emission monitors for nitrogen oxides on Boilers 1 and 2 shall be operated and maintained in accordance with the Department's "Continuous Source Monitoring Manual" (Revision No. 5 - March 1993).

(b) Continuous monitoring shall be conducted in accordance with 25 PA Code Chapter 139 and 40 CFR 75 and be approved by the Department.

(8) RACT for boiler No. 53, a 165 MMBtu/hr Iron City boiler is its permanent shut down on or before May 31, 1995.

OPERATING PERMIT CONDITIONS
PERMIT NO. OP-18-0005
COMPANY: International Paper Company.

- (9) (a) RACT for the diesel fire pump (Cummings Model NT-280-IF) shall be such that its annual operating hours do not exceed 500 hours in a consecutive 12 month period.
- (b) RACT for the Cummings diesel fire pump and 24 propane heaters (PA Radiant Products Model RSTP17-L5 and RSCA10-L5D) shall be the installation, maintenance and operation if the sources in accordance with manufacturers specifications.
- (10) Facility VOC emissions shall be less than 50 TPY.
- (11) Company shall maintain records as follows:
- (a) The Company shall maintain records in accordance with the minimum record keeping requirements of 25 PA Code Section 129.95.
- (1) The records shall provide sufficient data and calculations to clearly demonstrate that the requirements of Conditions 5, 9, 10 and 25 PA Code Sections 129.91-94 are met.
- (2) Records shall be retained for at least 2 years and shall be made available to the Department on request.
- (b) All CEM reports shall be submitted to the Department within thirty (30) days after each quarter but no later than the time frame established in the Department's latest Continuous Source Monitoring Manual. The Department reserves the right to require the report submissions in floppy disk with a format acceptable to the Department.
- (12) Any notification required as a result of any condition herein should be directed to: Mr. Rhett McLaren, Air Quality Specialist, P.O. Box 209, Hawk Run, PA 16840, telephone 814-342-0410.

