

Appendix B.

Docket No. RCRA-CWA-EPCRA-CAA-03-2018-0014

Kiln Temperature – Incinerator 440

Hourly Rolling Average: The average should be at least 1305.5F

| Date     | Incinerator Unit # | Time Period    |
|----------|--------------------|----------------|
| 7/3/12   | 440                | 7:29 – 7:36 PM |
| 11/29/12 | 440                | 6:15-6:24 AM   |

Kiln Afterburner Temperature – Incinerator 440

Hourly Rolling Average: The average should be at least 1604.5 F

| Date     | Incinerator Unit # | Time Period    |
|----------|--------------------|----------------|
| 7/3/12   | 440                | 7:29 – 7:36 PM |
| 11/29/12 | 440                | 6:15-6:24 AM   |

Scrubber Flowrate – Incinerator 441

Hourly Rolling Average: The average for the minimum scrubber water flow rate is 69.5

| Date     | Unit # | Time period   |
|----------|--------|---------------|
| 11/26/12 | 441    | 12:10-1:06 PM |