



Fact Sheet

The U.S. Environmental Protection Agency (EPA) Proposes to Reissue a National Pollutant Discharge Elimination System (NPDES) Permit to Discharge Pollutants Pursuant to the Provisions of the Clean Water Act (CWA) to the:

City of Filer Wastewater Treatment Plant

Public Comment Start Date: February 9, 2016

Public Comment Expiration Date: March 10, 2016

Technical Contact: Jill Nogi
(206) 553-1841
800-424-4372, ext. 1841 (within Alaska, Idaho, Oregon and Washington)
nogi.jill@epa.gov

The EPA Proposes To Reissue NPDES Permit

The EPA proposes to reissue the NPDES Permit for the facility referenced above. The Draft wastewater treatment plant (WWTP) NPDES Permit (Draft Permit) will place conditions on the discharge of pollutants from the City of Filer WWTP to surface waters of the United States (U.S.) when issued as a Final Permit. In order to ensure the protection of water quality and human health, the Draft Permit includes limits on the types and amounts of pollutants that can be discharged from the facility.

This Fact Sheet includes:

- information on public comment, public hearing, and appeal procedures
- a listing of proposed effluent limitations and other conditions for the facility
- a map and description of the discharge location
- technical material supporting the conditions in the Permit

State Certification

The EPA is requesting that the Idaho Department of Environmental Quality (IDEQ) certify the NPDES Permit for this facility, under Section 401 of the Clean Water Act (CWA). This Draft Permit includes any requirements provided by IDEQ in their draft 401 certification. IDEQ provided a draft certification for this Draft Permit and will provide a final certification for the Proposed Final Permit. Comments regarding the IDEQ draft CWA 401 certification should be directed to:

Idaho Department of Environmental Quality
Twin Falls Regional Office

650 Addison Avenue West, Suite 110
Twin Falls, ID 83301

Public Comment

Persons wishing to comment on, or request a Public Hearing for the Draft Permit may do so in writing by the expiration date of the Public Comment period. A request for a Public Hearing must state the nature of the issues to be raised as well as the requester's name, address, and telephone number. All comments and requests for Public Hearings must be in writing and should be submitted to the EPA as described in the Public Comments Section of the attached Public Notice.

After the Public Notice expires, and all comments have been considered, the EPA's Regional Director for the Office of Water and Watersheds will make a final decision regarding Permit issuance. If no substantive comments are received, the tentative conditions in the Draft Permit will become final, and the Permit will become effective upon issuance. If substantive comments are received, the EPA will address the comments and issue the Permit. The Permit will become effective no less than 30 days after the issuance date, unless an appeal is submitted to the Environmental Appeals Board within 30 days, pursuant to 40 CFR 124.19.

Documents are Available for Review

The Draft Permit and related documents can be reviewed or obtained by visiting or contacting the EPA's Regional Office in Seattle between 8:30 a.m. and 4:00 p.m., Monday through Friday at the address below. The Draft Permit, Fact Sheet, and other information can also be found by visiting the Region 10 NPDES website at <http://EPA.gov/r10earth/waterpermits.htm>.

United States Environmental Protection Agency
Region 10
1200 Sixth Avenue, OWW-130
Seattle, Washington 98101
(206) 553-0523 or
Toll Free 1-800-424-4372 (within Alaska, Idaho, Oregon and Washington)

The Draft Permit and Fact Sheet are also available at:

EPA Idaho Operations Office
950 W. Bannock Street, Suite 900
Boise, ID 83702
(208) 378-5746

IDEQ
Twin Falls Regional Office
650 Addison Avenue West, Suite 110
Twin Falls, ID 83301
(208) 736-2190

Table of Contents

Acronyms..... 5

I. Applicant..... 7

 A. General Information..... 7

 B. Permit History..... 7

II. Facility Information..... 7

 A. Treatment Plant Description 7

 B. Background Information..... 8

III. Receiving Water..... 9

 A. Water Quality Standards..... 9

 B. Receiving Water Low Flow Conditions 11

 C. Receiving Water Quality..... 12

 D. Water Quality Limited Waters..... 12

IV. Effluent Limitations..... 13

 A. Basis for Effluent Limitations..... 13

 B. Technology-Based Effluent Limits..... 13

 C. Water Quality-Based Effluent Limits 15

 D. Anti-backsliding Provisions..... 19

 E. Antidegradation..... 20

 F. Facility Specific Limits..... 20

 G. Proposed Effluent Limitations..... 25

 H. Effluent Limit Changes from the Previous Permit 26

V. Monitoring Requirements..... 27

 A. Basis for Influent, Effluent and Surface Water Monitoring 27

 B. Influent and Effluent Monitoring..... 27

 C. Effluent Monitoring Changes from the Previous Permit 29

 D. Surface Water Monitoring 29

 E. Electronic Submission of Discharge Monitoring Reports 30

VI. Sludge (Biosolids) Requirements..... 30

VII. Other Permit Conditions..... 31

 A. Quality Assurance Plan..... 31

 B. Operation and Maintenance Plan..... 31

 C. Sanitary Sewer Overflows and Proper Operation and Maintenance of the Collection System..... 31

 D. Design Criteria 33

 E. Industrial Waste Management Requirements 33

 F. Environmental Justice..... 35

 G. Standard Permit Provisions..... 36

VIII. Other Legal Requirements 36

 A. Endangered Species Act 36

 B. Essential Fish Habitat 37

C. State Certification	37
D. Permit Expiration	37
IX. References	37
Appendix A: Facility Information	38
Appendix B: Facility Discharge Monitoring Report Data Analyzed During Permit Development	41
Appendix C: Water Quality Criteria Summary	42
A. General Criteria (IDAPA 58.01.02.200)	42
B. Surface Water Criteria To Protect Aquatic Life Uses (IDAPA 58.01.02.250)	42
C. Surface Water Quality Criteria for Recreational Use Designation (IDAPA 58.01.02.251)	42
D. Surface Water Quality Criteria for Salmonid Spawning Use Designation (IDAPA 58.01.02.250.02.f)	43
Appendix D: Preliminary Clean Water Act Section 401 Certification from the Idaho Department of Environmental Quality	44
Table of Tables	
Table 1. City of Filer WWTP Effluent Limit Violations	9
Table 2. Low Flow Data for the Cedar Draw Creek at USGS Gaging Station 13093550	11
Table 3. Receiving Water Quality Data for Cedar Draw Creek	12
Table 4. Federal Secondary Treatment Limits	14
Table 5. RPA for Ammonia	17
Table 6. Calculating TSS Limits from the LTA	22
Table 7. Calculating TP Limits from the AML	25
Table 8. Proposed Effluent Limits for the City of Filer WWTP	25
Table 9. Changes in Effluent Limits from the Previous Permit	27
Table 10. Proposed Monitoring Requirements for the Filer WWTP	28
Table 11. Proposed Surface Water Monitoring Requirements for the City of Filer WWTP	30

Acronyms

1Q10	1 day, 10 year low flow
7Q10	7 day, 10 year low flow
30B3	Biologically-based design flow intended to ensure an excursion frequency of less than once every three years, for a 30-day average flow.
30Q10	30 day, 10 year low flow
AML	Average Monthly Limit
AWL	Average Weekly Limit
BE	Biological Evaluation
BOD ₅	Biochemical Oxygen Demand, five-day
°C	Degrees Celsius
CFR	Code of Federal Regulations
CFS	Cubic Feet per Second
CV	Coefficient of Variation
CWA	Clean Water Act
DMR	Discharge Monitoring Report
DO	Dissolved oxygen
EFH	Essential Fish Habitat
ELG	Effluent Limitation Guidelines
EPA	U.S. Environmental Protection Agency
ESA	Endangered Species Act
FR	Federal Register
GPD	Gallons per day
HUC	Hydrologic Unit Code
ICIS	Integrated Compliance Information System
IDEQ	Idaho Department of Environmental Quality
LA	Load Allocation
lbs/day	Pounds per day
LTA	Long Term Average
MBR	Membrane Bioreactor (type of Wastewater Treatment Plant)
mg/L	Milligrams per liter

ml	milliliters
ML	Minimum Level
µg/L	Micrograms per liter
mgd	Million gallons per day
MDL	Maximum Daily Limit or Method Detection Limit
N	Nitrogen
NOAA	National Oceanic and Atmospheric Administration
NPDES	National Pollutant Discharge Elimination System
O&M	Operations and Maintenance
POTW	Publicly Owned Treatment Works
QAP	Quality Assurance Plan
RP	Reasonable Potential
SS	Suspended Solids
SSO	Sanitary Sewer Overflow
s.u.	Standard Units
TBEL	Technology-Based Effluent Limit
TKN	Total Kjeldahl Nitrogen
TMDL	Total Maximum Daily Load
TP	Total Phosphorus
TRC	Total Residual Chlorine
TSD	Technical Support Document for Water Quality-based Toxics Control (EPA/505/2-90-001)
TSS	Total Suspended Solids
USFWS	U.S. Fish and Wildlife Service
UV	Ultraviolet (Radiation for Disinfection)
WLA	Wasteload Allocation
WQBEL	Water Quality-Based Effluent Limit
WQS	Water Quality Standards
WWTP	Wastewater Treatment Plant

I. Applicant

A. General Information

This Fact Sheet provides information on the Draft Permit for the following entity:

City of Filer
Wastewater Treatment Facility
NPDES Permit # ID0020061

Physical Address:
4030 North 2200 East
Filer, ID 83328

Mailing Address:
P.O. Box 140
Filer, ID 83328

Contact:
Mr. John Hurley, Operator
(208) 326-5000

B. Permit History

The most recent NPDES Permit for the City of Filer WWTP was issued on September 14, 2007, became effective on November 1, 2007, and expired on October 31, 2012 (Previous Permit). An application for NPDES Permit renewal was signed and submitted by the Permittee on May 3, 2012. Pursuant to 40 CFR 122.6, the Previous Permit has been administratively extended and remains fully effective and enforceable until such time as a new Permit is issued to the facility.

II. Facility Information

A. Treatment Plant Description

Service Area

The City of Filer owns and operates the City of Filer WWTP located in Filer, Idaho. The collection system has no combined sewers. The facility serves a resident population of 1,975. The treatment plant receives wastewater from domestic and commercial sources.

Treatment Process

The maximum monthly design flow of the facility is 0.5 million gallons per day (mgd), but according to the City's application, the facility has been discharging an average flow of 0.18 mgd. The monthly design flow is used to calculate mass loading effluent limits, therefore 0.5 mgd is used to calculate these limits in the Draft Permit.

Prior to October 2011, the City operated a treatment system utilizing influent coarse screening and flow measurement, two aerated lagoons and two facultative lagoons, and disinfection with chlorine gas. The City retired this treatment system in October 2011 and replaced it with a membrane bioreactor (MBR) treatment system. The treatment process now consists of: an influent lift station, mechanical fine screening, a headworks booster pump, an equalization basin, biological treatment (consisting of two anaerobic basins, a deoxygenation basin, two anoxic basins, and two aeration basins), the MBR, a backpulse tank, and disinfection using ultraviolet (UV) radiation. Chlorination is limited to short periods for filter backwashing and emergency back-up.

The City of Filer still uses the retired lagoons for other purposes: lagoon #1 is used for storing untreated influent during emergency operations, and lagoons #2 and #4 are used for storing treated and disinfected effluent for land application.

Details about the wastewater treatment process, as well as a map showing the location of the treatment facility and discharge, are included in Appendix A. The facility is classified as a minor facility in the NPDES universe. Current EPA policy classifies publicly owned treatment works (POTWs) discharging at 1.0 mgd or greater, or having an approved pretreatment program, as Major facilities. Since the City of Filer WWTP is discharging at less than 1 mgd, EPA has classified the POTW as a minor facility.

Outfall Description

The facility discharges to Cedar Draw Creek near the City of Filer, Idaho from November 1 to March 31 each year. Outfall 001 is located at latitude 42.583004 North and longitude -114.612804 West. During the irrigation season (April-October), the facility's effluent is land-applied through their IDEQ Land Application Permit, LA-000079-02.

B. Background Information

Effluent Characterization

In order to determine the potential pollutants of concern present in the facility's effluent, the EPA evaluated data available in discharge monitoring reports (DMRs), the NPDES Application Form 2A, and the nature of the discharge.

The wastewater treatment process for this facility includes both primary and secondary treatment, as well as UV disinfection. Pollutants expected to be in the discharge of a typical sewage treatment plant include five-day biochemical oxygen demand (BOD₅), total suspended solids (TSS), *E. coli* bacteria, pH, ammonia, temperature, phosphorus, and dissolved oxygen (DO). The effluent concentrations and monitoring results were all included in DMRs and Application Form 2A. Based on all the above information, the complete list of pollutants of concern to be evaluated for this Permit are:

- 5-day Biological Oxygen Demand (BOD₅)
- Total Suspended Solids (TSS)
- *E. coli* bacteria
- Total Residual Chlorine (TRC)
- pH

- Temperature
- Phosphorus
- DO
- Ammonia
- Total Kjeldahl Nitrogen (TKN)
- Nitrate + Nitrite
- Oil and Grease
- Total Dissolved Solids (TDS)

Compliance History

The EPA reviewed the last three (3) years of effluent monitoring data (October 2011 – August 2014) from the DMRs. This time period coincides with the date that the MBR system was online and operational. The DMR data submitted by the facility during this time period is presented in Appendix B and violations are summarized below:

Table 1. City of Filer WWTP Effluent Limit Violations

Parameter	Limit	Units	Number of Instances
TSS	Weekly Average	mg/L	1
TSS	Weekly Average	lbs/day	2
TSS	Monthly Average	lbs/day	2

III. Receiving Water

This facility discharges to Cedar Draw Creek near the City of Filer, Idaho, from November through March each year. During the irrigation season, the effluent is land applied through an IDEQ Land Application Permit. The State of Idaho water quality standards (WQS), found at the Idaho Administrative Procedures Act (IDAPA) at IDAPA 58.01.02, designate the uses for Cedar Draw Creek to be cold water aquatic life, secondary contact recreation, and salmonid spawning.

A. Water Quality Standards

Overview

Section 301(b)(1)(C) of the CWA requires the development of effluent limitations in NPDES Permits that are determined to be necessary in order to meet state and tribal WQS for surface waters. Federal regulations found at 40 CFR 122.4(d) require that the effluent limitations and other conditions included in NPDES Permits ensure compliance with the WQS of the receiving water, and waters downstream of the receiving water. A state or tribe’s WQS for surface water are composed of designated use classifications, numeric and/or narrative water quality criteria set at levels to protect those designated uses and an antidegradation policy with implementation procedures, in order to protect the water quality into the future [40 CFR 131.10, 131.11, and 131.12].

The use classification system designates the beneficial uses of each water body over which the state or tribe has jurisdiction. Uses can be designated for drinking water supply, contact

recreation, and aquatic life protection, among others. Narrative provisions are developed and numeric water quality criteria are derived by the state or tribe to ensure that the beneficial uses of each water body are attained and maintained. The antidegradation policy represents a three-tiered approach to protecting and maintaining current water quality and uses into the future.

Designated Beneficial Uses

The overall objective of CWA is to restore and maintain the chemical, physical, and biological integrity of the Nation's waters. Section 101(a)(2) of the CWA states that water quality should provide for the protection and propagation of fish, shellfish, and wildlife, and recreation in and on the water, wherever attainable. This provision is sometimes referred to as the "fishable/swimmable" goal of the CWA. Consistent with this goal, states are required to designate all waters of the U.S. within the state with fishable/swimmable use designations unless the state can meet the requirements found at 40 CFR 131.10 to remove or "downgrade" the fishable/swimmable uses through a use attainability analysis.

At Outfall 001, Cedar Draw Creek has been designated for cold water aquatic life, salmonid spawning, and secondary contact recreation (IDAPA 58.01.02). In addition, the Idaho WQS require all waters of the State of Idaho to be protected for industrial and agricultural water supply, wildlife habitats, and aesthetics (IDAPA 58.01.02.100.03.b and c, 100.04 and 100.05). The WQS and water quality criteria that apply to the receiving water of the facility's discharge come from the designated uses of the water body.

Surface Water Quality Criteria

The criteria applicable to the unnamed tributary of Cedar Draw Creek are found in the following sections of the State of Idaho WQS:

- a) The narrative criteria applicable to all surface waters of the State are found at IDAPA 58.01.02.200 (General Surface Water Quality Criteria);
- b) The numeric criteria for toxic substances for the protection of aquatic life and secondary contact recreation are found at IDAPA 58.01.02.210 (Numeric Criteria for Toxic Substances for Waters Designated for Aquatic Life, Recreation, or Domestic Water Supply Use);
- c) Additional numeric criteria necessary for the protection of aquatic life can be found at IDAPA 58.01.02.250 (Surface Water Quality Criteria for Aquatic Life Use Designations);
- d) Numeric criteria necessary for the protection of recreation uses can be found at IDAPA 58.01.02.251 (Surface Water Quality Criteria for Recreation Use Designations); and,
- e) Water quality criteria for agricultural water supply can be found in the EPA's *Water Quality Criteria 1972*, also referred to as the "Blue Book" (EPA R3-73-033) (See also IDAPA 58.01.02.252.02).

Antidegradation

The antidegradation policy of a state's WQS represents a three-tiered approach to protecting and maintaining current water quality and uses into the future [40 CFR 131.12]. Tier I of antidegradation protection applies to all water bodies under the CWA and ensures that existing in-stream water uses and the water quality necessary to protect those uses will be maintained and protected. Tier II protection applies to any water bodies considered to be high quality waters (where the water quality exceeds levels necessary to support propagation of fish, shellfish, wildlife, and recreation in and on the water) and provides that water quality will be maintained and protected unless allowing for lower water quality is deemed by the state as necessary to accommodate important economic or social development in the area. In allowing any lowering of water quality, the state must ensure adequate water quality to fully protect existing uses, as well as designated uses. Tier III protection applies to water bodies that have been designated by the state as outstanding national resource waters and provides that water quality is to be maintained and protected.

B. Receiving Water Low Flow Conditions

The EPA *Technical Support Document for Water Quality-Based Toxics Control* (TSD) (EPA, 1991) and the State of Idaho WQS recommend the receiving water flow conditions for use in calculating water quality-based effluent limits (WQBELs) for point source dischargers using steady-state modeling. The TSD and the Idaho WQS state that WQBELs intended to protect aquatic life uses should be based on the lowest seven (7) day average flow rate expected to occur once every 10 years for protection at the level of the chronic criterion (7Q10), and the lowest one (1) day average flow rate expected to occur once every 10 years for protection at the level of the acute criterion (1Q10). The EPA uses a biologically-based flow rate designed to protect the receiving water for ammonia at an excursion frequency (violations of the water quality criteria derived for protection of the water body and aquatic life from ammonia) of no more than once every three (3) years for a 30 day average flow (30B3). This evaluation criterion aligns with basing the numeric ammonia criteria on the 30-day average concentration not to be exceeded more than once every three (3) years. The lowest 30-day average flow rate expected to occur once every 10 years may be used for ammonia in cases where seasonal variation in flow is used (30Q10). The State of Idaho WQS recommend the lowest 30-day average flow rate expected to occur once every five (5) years (30Q5), for WQBELs intended to protect human health from non-carcinogens, and the harmonic mean flow rate for protecting human health from carcinogens. The low flow conditions of a receiving water body are used to assess the need for and develop WQBELs.

EPA reviewed information on Cedar Draw Creek flows from the USGS gaging Station 13093550, Cedar Draw Near Filer. That station is about 4 miles downstream of the City, just before the confluence of Cedar Draw with the Snake, and has recorded flow data from 1985-1991. That data was used to calculate the 30B3 flow, in order to evaluate the impact on the receiving water of the ammonia concentrations in the effluent. The table below shows the 30B3 flow using the EPA BASINS DFLOW Program.

Table 2. Low Flow Data for the Cedar Draw Creek at USGS Gaging Station 13093550

Flow	cfs
30B3	34.4

Additional flow calculations done by EPA on the USGS data included 1Q5 and 7Q5. When performing a reasonable potential analysis of a pollutant in the facility’s effluent to cause or contribute to an excursion of the water quality criterion for that pollutant, the flows correspond to acute and chronic criterion values. When developing this Draft Permit, EPA determined that there is no reasonable potential (RP) of the facility to exceed the chlorine criteria, as the facility upgraded and switched to UV radiation for disinfection. In that case, additional flow data for use in determining water quality-based effluent limitations that may be needed in the Draft Permit, was not utilized. Therefore, only the 30B3 flow for ammonia was utilized in the calculations for this Draft Permit.

C. Receiving Water Quality

Ambient data from Cedar Draw Creek was collected from a number of sources between 1985 and 2012, including the USGS, IDEQ, and the facility. The table below summarizes the receiving water data that were used to assess the need for and develop water quality based effluent limits in this Draft Permit.

Table 3. Receiving Water Quality Data for Cedar Draw Creek

Receiving Water Quality Data			
Parameter	Units	Percentile	Value
Flow	mgd	Min - Max	0.141 – 272
Temperature	°C	95 th	13.6
pH	Standard units	5 th – 95 th	7.47 – 8.90
Ammonia	mg/L	Maximum	0.525
Total Residual Chlorine	mg/L	5 th – 95 th	(not detected)
Total Phosphorus	mg/L	5 th – 95 th	0.08 – 0.368

D. Water Quality Limited Waters

Any waterbody for which the water quality does not, and/or is not expected to, meet the applicable WQS is defined as a “water quality limited segment.” Section 303(d) of the CWA requires states to develop a Total Maximum Daily Load (TMDL) pollutant management plan for water bodies determined to be water quality limited segments. A TMDL is a detailed analysis of the water body to determine its assimilative capacity. The assimilative capacity of a water body is the amount of loading of a pollutant that the water body can absorb without causing or contributing to a violation of WQS. Once the assimilative capacity of the water body has been determined, the TMDL will allocate that capacity among all the point and non-point pollutant sources in the area, taking into account natural background levels and a margin of safety. Allocations for non-point sources are known as “load allocations” (LAs) and typically involve the implementation of best management practices (BMPs) for pollution source control. The allocations for point sources, known as “waste load allocations” (WLAs), are implemented through effluent limitations in NPDES Permits. Effluent limitations for point sources must be consistent with the applicable TMDL WLAs.

The State of Idaho's 2012 Integrated Report Category 5 [related to CWA Section 303(d)] lists Cedar Draw Creek, from source to the mouth, as impaired for fecal coliform, total phosphorus (TP) and total suspended solids (TSS). The assessment unit (AU) for this segment of Cedar Draw is ID17040212SK012_02 (Cedar Draw – Source to Mouth).

In 1997, EPA approved IDEQ's *Middle Snake River Watershed Management Plan* (Mid-Snake TMDL), which included WLAs for TP for the City of Filer WWTP. IDEQ made minor corrections to the TMDL in 1998.

In 2000, the EPA approved IDEQ's *Upper Snake Rock Watershed Management Plan* (Upper Snake Rock TMDL) and the supplementary information provided by IDEQ in July 2000, which included WLAs for TP, TSS, and fecal coliform for the City of Filer. The TP WLAs were just carried over from the Mid-Snake TMDL and incorporated directly into the Upper Snake Rock TMDL. <http://www.epa.gov/waters/tmdl/docs/TMDL%20Exec%20Summary%20Upper%20Snake%20July%202000.pdf>

In April 2010, IDEQ submitted the *Upper Snake Rock/Middle Snake TMDLs 5-Year TMDL Review* to the EPA, which stated the Snake River has been able to meet the applicable TSS criteria since the Upper Snake Rock TMDL was issued and has been implemented. However, the Snake River is still not meeting the applicable TP criteria in the Idaho WQS, even after the approval and implementation of both TMDL Watershed Management Plans.

The City of Filer WWTP requested, in their 2012 NPDES Permit application to the EPA, approval of a year-round discharge, which would increase the total annual loading of TP to an impaired water body. In subsequent communications with the facility operator, the EPA was informed that the City of Filer purchased additional property for land application purposes, and was no longer in need of a year-round discharge via their NPDES Permit. In addition, because of the continued impairment of the Snake River, the EPA cannot approve a request for additional authorization to discharge to surface waters under the CWA. For both of these reasons, EPA authorization of a **seasonal discharge** remains in the Draft Permit.

IV. Effluent Limitations

A. Basis for Effluent Limitations

In general, the CWA requires that the effluent limits for a particular pollutant be the more stringent of either technology-based effluent limits (TBELs) or water quality-based effluent limits (WQBELs). TBELs are set nationally according to the level of treatment that is technologically and economically achievable at a national scale. A WQBEL is designed to ensure that the WQS applicable to a water body are being met. The basis for all of the effluent limits included in the Draft Permit are provided below.

B. Technology-Based Effluent Limits

Federal Secondary Treatment Effluent Limits

The CWA requires POTWs to meet performance-based requirements based on available wastewater treatment technology. Section 301 of the CWA established a required performance level, referred to as “secondary treatment,” which all POTWs were required to meet by July 1, 1977. The EPA has developed and promulgated “secondary treatment” effluent limitations, which are found in 40 CFR 133.102. These TBELs apply to all municipal wastewater treatment plants and identify the minimum level of effluent quality attainable by application of secondary treatment for BOD₅, TSS, and pH. The federally promulgated secondary treatment effluent limits are listed in the table below.

Table 4. Federal Secondary Treatment Limits

Secondary Treatment Effluent Limits (40 CFR 133.102)		
Parameter	30-day average	7-day average
BOD ₅	30 mg/L	45 mg/L
TSS	30 mg/L	45 mg/L
Removal for BOD ₅ and TSS (concentration)	85% (minimum)	---
pH	within the limits of 6.0 - 9.0 s.u.	

Mass-Based Limits

40 CFR 122.45(f) requires that effluent limits be expressed in terms of mass, if possible. The regulation at 40 CFR 122.45(b)(1) requires that effluent limitations for POTWs be calculated based on the design flow of the facility. The mass based limits are expressed in pounds per day and are calculated as follows:

$$\text{Mass based limit (lbs/day)} = \text{concentration limit (mg/L)} \times \text{design flow (mgd)} \times 8.34^1$$

Chlorine (TRC)

Chlorine is often used to disinfect municipal wastewater prior to discharge. A 0.5 mg/L average monthly limit for total residual chlorine (TRC) is derived from standard operating practices and is considered a technology based limit. The Water Pollution Control Federation’s *Chlorination of Wastewater* (1976) states that a properly designed and maintained wastewater treatment plant can achieve adequate disinfection if a 0.5 mg/L chlorine residual is maintained after 15 minutes of contact time. Therefore, a WWTP that provides adequate chlorine contact time can meet a 0.5 mg/L TRC limit on a monthly average basis. In addition to average monthly limits (AMLs), NPDES regulations require effluent limits for POTWs to be expressed as average weekly limits (AWLs) unless impracticable. For TBELs, the AWL is 1.5 times the AML, consistent with the “secondary treatment” limits for BOD₅ and TSS. This results in an AWL for TRC of 0.75 mg/L.

¹ 8.34 is a conversion factor with units (lbs × L)/(mg × gallon × 10⁶)

Since the federal regulations at 40 CFR 122.45 (b) and (f) require limitations for POTWs to be expressed as mass-based limits using the design flow of the facility, mass-based limits for chlorine are calculated as follows:

$$\text{Monthly average Limit} = 0.5 \text{ mg/L} \times 0.5 \text{ mgd} \times 8.34 = 2.09 \text{ lbs/day}$$

$$\text{Weekly average Limit} = 0.75 \text{ mg/L} \times 0.5 \text{ mgd} \times 8.34 = 3.13 \text{ lbs/day}$$

The State of Idaho has promulgated water quality criteria to protect surface waters of the state from total residual chlorine (TRC) (it can be toxic to aquatic life). Permit writing procedures require that the Permit writer compare the applicable water quality based effluent limit (WQBEL) to the applicable technology based effluent limit and put the most stringent limit in the Permit.

In this case, since the City of Filer upgraded its WWTP in 2011, UV light is used for bacterial disinfection, and there is no TRC discharged to Cedar Draw Creek with the facility's effluent. Therefore, there is no RP to exceed the water quality criteria for TRC, and no need for a WQBEL for TRC. It is not detectable in the effluent, based on the facility DMR data submitted to the EPA to date. However, there is a requirement to monitor for TRC, once a day on days of use, to cover the possibility that sometimes chlorine may be run through the system for cleaning and disinfection of the membranes.

C. Water Quality-Based Effluent Limits

Statutory and Regulatory Basis

Section 301(b)(1)(C) of the CWA requires the development of limitations in Permits necessary to meet state or tribal WQS. Point source discharges to state or tribal waters must also comply with limitations imposed by the state or tribe as part of its certification of each NPDES Permit developed under section 401 of the CWA. 40 CFR 122.4(d) prohibits the issuance of an NPDES Permit that does not ensure compliance with the WQS of all affected states (i.e., the WQS of the receiving water body and downstream waters).

The NPDES regulations require that point source permits include limits for all pollutants or parameters which are or may be discharged in an amount which will cause, have the reasonable potential (RP) to cause, or to contribute to an excursion above any state or tribal WQS, including narrative criteria for water quality, and that the level of water quality to be achieved by limits on point sources must be derived from and comply with all applicable state or tribal WQS [40 CFR 122.44(d)(1)].

40 CFR 122.44(d)(1) requires the permitting authority to make this evaluation (called a "reasonable potential analysis or RPA") using procedures which account for existing controls on point and nonpoint sources of pollution, the variability of the pollutant in the effluent, species sensitivity (for toxicity), and where appropriate, dilution in the receiving water. The Permit limits must be stringent enough to ensure that state or tribal WQS are met, and must be consistent with any available WLA provided by an EPA-approved TMDL assessment, if applicable. In the case of an available TMDL, the WLA provided by the TMDL for a particular pollutant will override the mass-based calculations, when it is the more stringent of the two options.

RPAs

The EPA projects the downstream receiving water concentration for each pollutant of concern when evaluating the RP to cause or contribute to an excursion above any State/Tribal water quality criterion. The EPA uses the concentration of the pollutant in the effluent and receiving water and, if appropriate, the dilution available from the receiving water, to project the receiving water concentration. If the projected concentration of the pollutant in the receiving water exceeds the numeric criterion for that specific pollutant, then the discharge has the RP to cause or contribute to an excursion above the applicable WQS, and a QBEL is required.

Sometimes it may be appropriate to allow a small area of the receiving water to provide dilution of the effluent. These areas are called mixing zones. Mixing zone allowances will increase the mass loadings of the pollutant to the water body and will decrease treatment requirements. Mixing zones can be used only when there is adequate receiving water flow volume and the concentration of the pollutant in the receiving water is less than the criterion necessary to protect the designated uses of the water body. Mixing zones must be authorized by the State in the 401 certification. As discussed previously, no mixing zones were authorized for this Draft Permit. The QBELs in this Draft Permit were developed to meet water quality criteria at the outfall

Pollutants Present with Reasonable Potential

As discussed above, TRC is not a concern for this facility since the 2011 upgrade. The EPA therefore conducted a reasonable potential analysis (RP/RPA) of the possibility for the ammonia concentrations present in the facility's effluent to cause or contribute to an exceedance of the Idaho WQS for these parameters, therefore impairing Cedar Draw Creek. The DMR data from the facility on TRC concentrations were used in the analysis, and results showed that there is no RP for the effluent to exceed the ammonia water quality criteria applicable to Cedar Draw. The mixing zone required in Cedar Draw to show no RP to exceed the water quality criteria is 4%. The preliminary IDEQ CWA Section 401 certification grants the facility a 4% mixing zone in Cedar Draw Creek for ammonia. In addition, the ammonia concentrations in both the effluent and the receiving water will be monitored once a month during this Permit cycle, in order to collect additional data that may inform the next Permit.

Table 5. RPA for Ammonia

Reasonable Potential Analysis (RPA) and QBEL Calculations

Facility Name	City of Filer WWTP
Design Flow (MGD)	0.50

Dilution Factors	(IDAPA 58.01.02 03. b)	Annual Crit. Flows
Aquatic Life - Acute Criteria - Criterion Max. Concentration (CMC)	1Q10	1.0
Aquatic Life - Chronic Criteria - Criterion Continuous Concentration (CCC)	7Q10 or 4B3	1.0
Ammonia	30B3/30Q10 (seasonal)	2.8
Human Health - Non-Carcinogen	30Q5	1.0
Human Health - carcinogen	Harmonic Mean Flow	1.0

Receiving Water Data	Notes:	Annual Crit. Flows
Hardness, as mg/L CaCO ₃	*** Enter Hardness on WQ Criteria tab ***	5 th % at critical flows
Temperature, °C	Temperature, °C	95 th percentile
pH, S.U.	pH, S.U.	95 th percentile

Pollutants of Concern		AMMONIA, default: cold water, fish early life stages
Effluent Data	Number of Samples in Data Set (n)	15
	Coefficient of Variation (CV) = Std. Dev./Mean (default CV = 0.6)	1.38
	Effluent Concentration, µg/L (Max. or 95th Percentile) - (C _e)	179
	Calculated 50 th % Effluent Conc. (when n>10), Human Health Only	
Dilution Factors	Aquatic Life - Acute	1Q10
	Aquatic Life - Chronic	7Q10 or 4B3
	Ammonia	30B3 or 30Q10
	Human Health - Non-Carcinogen	30Q5
	Human Health - carcinogen	Harmonic Mean
Receiving Water Data	90 th Percentile Conc., µg/L - (C _u)	266
	Geometric Mean, µg/L, Human Health Criteria Only	
Applicable Water Quality Criteria	Aquatic Life Criteria, µg/L	Acute
	Aquatic Life Criteria, µg/L	Chronic
	Human Health Water and Organism, µg/L	
	Human Health, Organism Only, µg/L	
	Metals Criteria Translator, decimal (or default use Conversion Factor)	Acute
		Chronic
	Carcinogen (Y/N), Human Health Criteria Only	

Aquatic Life Reasonable Potential Analysis

σ	$\sigma^2 = \ln(CV^2 + 1)$	1.033
P _n	$= (1 - \text{confidence level})^{1/n}$, where confidence level = 99%	0.736
Multiplier (TSD p. 57)	$= \exp(z\sigma - 0.5\sigma^2) / \exp[\text{normsinv}(P_n) - 0.5\sigma^2]$, where 99%	5.8
Statistically projected critical discharge concentration (C _e)		1031.78
Predicted max. conc.(ug/L) at Edge-of-Mixing Zone (note: for metals, concentration as dissolved using conversion factor as translator)	Acute	1031.78
	Chronic	541.57
Reasonable Potential to exceed Aquatic Life Criteria		NO

Procedure for Deriving Water Quality-based Effluent Limits

The first step in developing a WQBEL is to develop a WLA for the pollutant. A WLA is the concentration or loading of a pollutant that the Permittee may discharge without causing or contributing to an exceedance of WQS in the receiving water. WLAs are determined in one of the following ways:

1. TMDL-Based WLA

Where the receiving water quality does not meet WQS, Section 303(d) of the CWA requires States to develop TMDLs, in order to ensure that these waters will come into compliance with WQS. A TMDL determines of the amount of a pollutant from point, non-point, and natural background sources that may be discharged to a water body without causing the water body to exceed the criterion for that pollutant. Any loading above this capacity risks violating WQS. For those water bodies that will not meet WQS even after the imposition of TBELs, WLAs are developed for each discharger and included in the TMDL developed by the State (and approved by the EPA).

The Mid-Snake TMDL established a TP WLA for the City of Filer WWTP. The Upper Snake Rock TMDL contains the Mid-Snake TP WLA carried over, plus TSS and fecal coliform WLAs for the City of Filer WWTP. In August 2005, IDEQ submitted the *Upper Snake Rock TMDL Modification* to EPA for review and approval. The TMDL modification contained TSS and TP WLAs for aquaculture facilities, as well as revised TSS WLAs for several municipal WWTPs, including the City of Filer. On September 14, 2005, EPA approved the WLAs for the aquaculture facilities, but **did not approve the revised TSS WLAs for the municipal WWTPs**, therefore, the WLAs in the Upper Snake Rock TMDL were used to derive the proposed effluent limits for TP and TSS in this Draft Permit.

2. Mixing zone based WLA

When the State authorizes a mixing zone for the discharge, the WLA is calculated by using a simple mass balance equation. The equation takes into account the available dilution provided by the mixing zone and the background concentrations of the pollutant. No mixing zones are authorized in this Draft Permit, so none of the Draft Permit WLAs were derived in this way.

3. Criterion as the WLA

In some cases a mixing zone cannot be authorized, either because the receiving water is at, or exceeds, the criterion; the receiving water flow is too low to provide dilution; or the facility can achieve the effluent limit without a mixing zone. In such cases, the criterion becomes the WLA. Establishing the criterion as the WLA ensures that the effluent discharge will not contribute to an exceedance of the criteria. The WLA for chlorine was derived using this method.

Once the WLA has been developed, the EPA applies the statistical Permit limit derivation approach described in Chapter 5 of the *Technical Support Document for Water Quality-*

Based Toxics Control (EPA/505/2-90-001, March 1991, hereafter referred to as the TSD) to obtain monthly average, weekly average, and/or daily maximum Permit limits. This approach takes into account effluent variability, sampling frequency, and Idaho's WQS.

D. Anti-backsliding Provisions

Section 402(o) of the CWA and 40 CFR 122.44(l) generally prohibit the renewal, reissuance, or modification of an existing NPDES Permit that contains effluent limits, Permit conditions, or standards that are less stringent than those established in the Previous Permit (i.e., anti-backsliding) with limited exceptions. Section 402(o)(1) of the CWA states that a Permit may not be reissued with less-stringent limits if those limits were established based on Sections 301(b)(1)(C), 303(d) or 303(e) (i.e. WQBELs or limits established in accordance with State treatment standards) except in compliance with Section 303(d)(4). Section 402(o)(1) also prohibits backsliding on TBELs established using best professional judgment (BPJ) (i.e. based on Section 402(a)(1)(B)).

Section 303(d)(4) of the CWA states that, for water bodies where the water quality meets or exceeds the level necessary to support the water body's designated uses, WQBELs may be revised as long as the revision is consistent with the State's antidegradation policy. Additionally, Section 402(o)(2) contains exceptions to the general prohibition on backsliding in 402(o)(1). According to the EPA NPDES Permit Writers' Manual (EPA-833-K-10-001) the 402(o)(2) exceptions are applicable to WQBELs (except for 402(o)(2)(B)(ii) and 402(o)(2)(D)) and are independent of the requirements of 303(d)(4). Therefore, WQBELs may be relaxed as long as either the 402(o)(2) exceptions or the requirements of 303(d)(4) are satisfied.

The Previous Permit included chlorine limits of 0.3 mg/L (0.4 lbs/day) AML and 0.5 mg/L (0.6 lbs/day) MDL. In 2011, the City of Filer upgraded the WWTP to an MBR system, utilizing UV light for bacterial disinfection. The current DMR data reviewed by the EPA shows no discharge of TRC in the effluent. Therefore, the facility does not have the reasonable potential (RP) to exceed the TRC criterion applicable to Cedar Draw. Chlorine may be occasionally used in emergency situations or for cleaning the filters, but that stream is cycled back through the WWTP and is not discharged to Cedar Draw Creek. Therefore, there is no TRC limit proposed in this Draft Permit, however; the Draft Permit contains a monitoring requirement to sample chlorine daily, whenever it is used, and to report concentrations on the DMR submitted monthly to the EPA.

The Cedar Draw Creek is not impaired in IDEQ's most recent Integrated Report for chlorine, therefore, it is meeting the Idaho WQS for TRC. The discharge from the Filer WWTP is still in compliance with the Idaho antidegradation policy, see the preliminary Clean Water Act Section 401 certification from IDEQ. The EPA can backslide on the TRC limits in this case because with the upgrade of the facility to an MBR system utilizing UV light for bacterial disinfection, there is no discharge of TRC in the effluent at this time.

In addition, the TSS and TP loading limits proposed in the Draft Permit were calculated differently than in the Previous Permit. The loading limits for TSS are now consistent with

the assumptions of the Upper Snake Rock TMDL and the averaging period that was used in assigning the WLA to the Filer WWTP. The loading limits for TP are now more stringent than before. See more about the TSS and TP mass loading limit calculations below. When an effluent limit is based on a WLA from a TMDL, the NPDES regulations at 40 CFR 122.44(d)(vii) state that the effluent limit must be derived from and comply with the applicable WQS and be consistent with the assumptions and requirements of any approved WLA. Now that the limits are based off of a long term average (LTA) that was converted from tons/year in the TMDL to pounds/day, and then subsequently, the AML for mass loading and average weekly limit (AWL) for mass loading were calculated from that LTA. The limits in the Permit can be traced directly back to the TMDL WLAs. Therefore, these changes to the TSS and TP mass loading limits are not backsliding, as they comply with the State of Idaho WQS, applicable TMDLs, and the antidegradation policy.

Due to the prohibitions on backsliding in NPDES Permits, the EPA proposes to retain the existing BOD₅ mass loading limits from the Previous Permit, even though the upgraded facility has an increased design capacity. In this case, a review of the Filer DMR data shows that, since the facility upgrade, the effluent includes low levels of BOD₅, as expected from a new MBR treatment plant. The facility does not need higher BOD₅ limits; therefore the EPA proposes to retain the calculated mass loading limits from the Previous Permit.

E. Antidegradation

The proposed issuance of a NPDES Permit triggers the need to ensure that the conditions in the Permit ensure that Tier I, II, and III of the State's antidegradation policy are met. The IDEQ has completed an antidegradation review, which is included in the draft CWA 401 water quality certification for this Draft Permit. Refer to Appendix D for the State's draft 401 certification. The EPA has reviewed IDEQ's antidegradation analysis and finds that it is consistent with the State of Idaho's 401 certification requirements and antidegradation implementation procedures. Comments on the 401 certification, including the antidegradation review, can be submitted to the IDEQ as stated above on Page 1 of this Fact Sheet (see State Certification). This Draft Permit includes any Permit requirements provided by IDEQ as a part of their antidegradation analysis or 401 certification.

F. Facility Specific Limits

The final effluent limits for each parameter in NPDES Permits are the more stringent of technology treatment requirements, WQBELs, WLAs, or limits retained as the result of anti-backsliding analysis or to meet the State's anti-degradation policy. See the table of proposed limits in Section IV.G of this Fact Sheet, below. The discussion below details each parameter in the table.

Floating, Suspended, Submerged Matter

The Idaho WQS have a narrative provision for floating, suspended, or submerged matter that has been incorporated into the Draft Permit as an effluent limitation. Narrative criteria describe the desired water quality goal and can be used in instances where numeric criteria have not been developed or are not appropriate for the condition.

Biochemical Oxygen Demand, five-day (BOD₅)

All secondary treatment facilities are subject to the federal technology-based requirements for BOD₅. These requirements state that the 30-day average must not exceed 30 mg/L, the 7-day average must not exceed 45 mg/L, and the 30-day average percent removal must not be less than 85 percent.

Since the facility is currently operating well below the mass loading limits required by the Previous Permit; then even with increased design capacity, it is not necessary to increase the BOD₅ mass loading for the Filer WWTP at this time.

Therefore, the Draft Permit proposes to retain the BOD₅ concentration and mass-based loading limits from the Previous Permit: 30 mg/L (70 lbs/day) AML, 45 mg/L (105 lbs/day) AWL, and an AML of >85% removal.

Total Suspended Solids (TSS)

The Idaho WQS state that sediment shall not exceed quantities which impair designated beneficial uses. (IDAPA 58.01.02.200). The Upper Snake Rock TMDL assigned a WLA for TSS of 2.1 tons/year for the City of Filer WWTP (see Section 3.5.2.3 of the TMDL) and set an in-stream target of 52.0 mg/L TSS for tributaries to the Snake River. When an effluent limit is based on a WLA from a TMDL, the NPDES regulations at 40 CFR 122.44(d)(vii) state that the effluent limit must be derived from and comply with the applicable WQS and be consistent with the assumptions and requirements of any approved WLA. Also, the federal NPDES regulation at 40 CFR 122.45(d)(2) require that effluent limitations for continuous discharges from POTWs be expressed as average monthly and average weekly limits, unless impracticable. Additionally, the terms “average monthly limit” and “average weekly limit” are defined in 40 CFR 122.2 as being arithmetic (as opposed to geometric) averages. In translating the WLA into Permit limits, the EPA followed procedures in the TSD. The first step in developing limits is to determine the time frame over which the WLAs apply.

The mean annual load, converted to pounds/day helps the EPA to propose permit limits for TSS, following the procedures specified in the TSD. 2.1 tons/year converts to 11 lbs/day (2.1 x 2000/365). There are 2000 pounds in one ton and 365 days in one year. The 11 lbs/day becomes the long term average (LTA) that’s used to calculate the AML and AWL for TSS; which means that the EPA can convert the mean annual load allocation of TSS in the TMDL into average monthly and weekly effluent limits for TSS, in pounds per day.

The LTA is the starting point, and using the TSD, you can derive a multiplier for the LTA, in order to arrive at the AML. Afterwards, you can derive a multiplier for the AML, in order to arrive at the AWL. For Filer, using 11 lbs/day as the starting point, the AWL for TSS is 22.1 lbs/day and the MDL for TSS is 57.3 lbs/day.

The objective in setting effluent limits is to establish limits that will result in the effluent meeting the LTA under normal operating conditions virtually all the time (consistent with the WLA in the TMDL). Having both an AML and AWL also ensures good performance of the treatment system. Setting an AWL establishes an upper bound on effluent values used to

determine the monthly average and provides a measure of effluent compliance during operational periods between monthly sampling.

As in the previous Permit, the AWL was calculated by multiplying the AML by the following relationship (see Table 5-3 of the TSD):

Table 6. Calculating TSS Limits from the LTA

Multiplier to Calculate Permit Limits from LTA

Reference: TSD Page 103

Number of Samples per Month (n)		4
Coefficient of Variation (CV) = Std. Dev./Mean		1.07
σ = std deviation	$\sigma^2 = \ln(CV^2 + 1)$	0.874
Average Monthly Limit (AML),	$\exp(z\sigma_n - 0.5z\sigma_n^2)$; where % probability basis =	95% 2.01
Maximum Daily Limit (MDL),	$\exp(z\sigma - 0.5z\sigma^2)$; where % probability basis =	99% 5.21

Calculation:

AML = LTA, limiting x Multiplier

MDL = LTA, limiting x Multiplier

LTA, Limiting	x	Multiplier	=	Limit
11	x	2.01	=	22.14
0	x	5.21	=	0

Multiplier to Calculate Average Weekly Limit (AWL) from Average Monthly Limit

Adapted from TSD Page 106, where n = (default AWL/AML Multiplier = 1.5)

Number of Samples per Month Set (n)		4
Number of Samples per Week Set (n/4)		1
Coefficient of Variation (CV) = Std. Dev./Mean		1.07
σ = std deviation	$\sigma^2 = \ln(CV^2 + 1)$	0.874
Average Monthly Limit (AML),	$\exp(z\sigma_n - 0.5z\sigma_n^2)$; where % probability basis =	95% 2.01
Average Weekly Limit (AWL),	$\exp(z\sigma_{n/4} - 0.5z\sigma_{n/4}^2)$; where % probability basis =	99% 5.21
Ratio AWL/AML		2.59

Calculation:

AWL = AML x Multiplier

AML	x	Multiplier	=	AWL
22.14	x	2.59	=	57.31

The Draft Permit retains the concentration limits, at the secondary treatment standards, but proposes new mass loading limits from the Previous Permit: TSS limits: 30 mg/L (22.1 lbs/day) AML, 45 mg/L (57.3 lbs/day) AWL, and >85% removal.

The objective in setting effluent limits is to establish limits that will result in the effluent meeting the WLA under normal operating conditions virtually all the time. Developing both an AML and an AWL for POTWs is consistent with the requirements of the EPA’s regulations and also assures that the long-term average (LTA) loading requirements of TSS to the river system, as specified in the management plan, is being met. Having both an AML and AWL also ensures good performance of the treatment system. Setting an AWL establishes an upper bound on effluent values used to determine the monthly average and provides a measure of effluent compliance during operational periods between monthly sampling.

Bacteria / E. coli

The *Upper Snake Rock Watershed Management Plan* established a fecal coliform bacteria WLA for the City of Filer of 2.3 CFU. This WLA was based on a secondary contact recreation criterion in the state WQS, which required that the numeric criteria:

“was not to exceed 800 colonies/100 mL at any time, 400 colonies/100 mL in more than 10 % of the samples taken over a 30-day period, and a geometric mean of 200 colonies/100 mL based on a minimum of five samples taken over a 30-day period.”

When the Upper Snake Rock TMDL was developed, the Idaho WQS contained a water quality criterion for fecal coliform bacteria that was used as an indicator of potential human health risks associated with recreational use, which was determined to be secondary contact recreation for Cedar Draw Creek in the Upper Snake TMDL. Since the TMDL was developed, the State of Idaho has revised the WQS and adopted *E. coli* bacteria as the indicator organism for the protection of human health during water contact recreation. This is consistent with the EPA's nationally recommended 1986 *E. coli* bacteria criteria. In 1986, the EPA recommended using either *enterococci* or *E. coli* for bacteria criteria to protect for human health because EPA studies found that there was a strong correlation between the densities of *enterococci* and gastrointestinal disease and that there was a correlation between *E. coli* and gastrointestinal disease. These EPA studies also found that no correlation between fecal coliform or total coliform and gastrointestinal disease, and do not recommend that these be used as indicator species for the protection of human health during water contact recreation.

When an effluent limit is based on a WLA from a TMDL, the NPDES regulations at 40 CFR 122.44(d)(vii) state that the effluent limit must be derived from and comply with the applicable WQS and be consistent with the assumptions and requirements of any approved WLA. Although an approved TMDL WLA exists for fecal coliform for the Filer WWTP, the **WLA is not derived from the currently applicable WQS**. Therefore, the EPA has not incorporated the WLA into the Draft Permit. Rather, the effluent limits for the Draft Permit are based on the **Idaho WQS *E. coli* bacteria criteria** being achieved prior to the effluent being discharged to the receiving water.

The Idaho WQS state that waters of the State of Idaho that are designated for secondary contact recreation uses are not to contain *E. coli* bacteria in concentrations exceeding 126 organisms per 100 ml based on a minimum of five samples taken every three (3) to seven (7) days over a 30-day period. Therefore, the Draft Permit contains a monthly geometric mean effluent limit for *E. coli* of 126 organisms per 100 mL [IDAPA 58.01.02.251.01.a].

The Idaho WQS also state that a water sample that exceeds certain “single sample maximum” values indicates a likely exceedance of the geometric mean criterion, although it is not, in and of itself, a violation of WQS. For waters designated for secondary contact recreation, the “single sample maximum” value is 576 organisms per 100 mL [IDAPA 58.01.02.251.01.b.ii].

The goal of a WQBEL is to ensure a low probability that WQS will be exceeded in the receiving water as a result of a discharge, while considering the variability of the pollutant in the effluent. Because a single sample value exceeding 576 organisms per 100 ml indicates a likely exceedance of the geometric mean criterion, the EPA has imposed an instantaneous (single grab sample) maximum effluent limit for *E. coli* of 576 organisms per 100 ml, in addition to a monthly geometric mean limit of 126 organisms per 100 ml, which directly implements the water quality criterion for secondary recreation for *E. coli*. This will ensure that the discharge will have a low probability of exceeding the WQS for *E. coli*.

Regulations at 40 CFR 122.45(d)(2) require that effluent limitations for continuous discharges from POTWs be expressed as average monthly and average weekly limits, unless impracticable. Additionally, the terms “average monthly limit” and “average weekly limit” are defined in 40 CFR 122.2 as being arithmetic (as opposed to geometric) averages. It is impracticable to properly implement a 30-day geometric mean criterion in a Permit using monthly and weekly arithmetic average limits. The geometric mean of a given data set is equal to the arithmetic mean of that data set if and only if all of the values in that data set are equal. Otherwise, the geometric mean is always less than the arithmetic mean. In order to ensure that the effluent limits are “derived from and comply with” the geometric mean water quality criterion, as required by 40 CFR 122.44(d)(1)(vii)(A), it is necessary to express the effluent limits as a monthly geometric mean and an instantaneous maximum limit.

The Draft Permit retains the existing *E. coli* limits: 126 colonies/100 mL AML based on a geometric mean of all samples taken during the month and 576 colonies/100 mL as an instantaneous maximum limit.

Phosphorus

The Mid-Snake TMDL assigned a WLA for total phosphorus (TP) of 16.4 lbs/day for the City of Filer WWTP (see Table 24 of the 1997 TMDL). The 1999 Upper Snake Rock TMDL retained the WLAs for the City of Filer WWTP and set an in-stream target concentration of 0.100 mg/L for total phosphorus for tributaries within the Upper Snake Rock Sub basin, which includes Cedar Draw. The federal regulation at 40 CFR 122.44(d)(vii)(B) requires the EPA to incorporate effluent limits based on WLAs from the State’s watershed management plan into NPDES Permits. However, similarly to the TSS discussion above, the TP mass loading limits from the Previous Permit were recalculated for this Draft Permit.

The Draft Permit proposes TP limits calculated to be consistent with the TMDL WLA and the procedures in the TSD for deriving effluent limits. The WLA of 16.4 lbs/day is considered to be the AML, as the pounds/day limit in the TMDL is the same each season, and therefore, each month. The AWL was calculated with a multiplier, and TP data from the DMRs, as instructed in the TSD. The AWL for TP is 36.7 lbs/day.

Table 7. Calculating TP Limits from the AML

Multiplier to Calculate Average Weekly Limit (AWL) from Average Monthly Limit

Number of Samples per Month Set (n)	4
Number of Samples per Week Set (n/4)	1
Coefficient of Variation (CV) = Std. Dev./Mean	0.76
σ = std deviation	$\sigma^2 = \ln(CV^2 + 1)$ 0.675
Average Monthly Limit (AML)	$\exp(z\sigma_n - 0.5z\sigma_n^2)$; where % probability basis = 95% 1.71
Average Weekly Limit (AWL)	$\exp(z\sigma_{n/4} - 0.5z\sigma_{n/4}^2)$; where % probability basis = 99% 3.83
Ratio AWL/AML	2.24

Adapted from TSD Page 106, where n = (default AWL/AML Multiplier = 1.5)
 CV for TP monthly loading from DMR dataset

Calculation:
 AWL = AML x Multiplier

AML	x	Multiplier	=	AWL
16.4	x	2.24	=	36.72

pH

The TBEL for pH at 40 CFR 133, require POTWs to be within the range of 6.0 - 9.0 standard units (s.u.). The Idaho WQS, at IDAPA 58.01.02.250.01.a, requires pH values in the river to be within the range of 6.5 to 9.0 s.u.

Effluent pH data was collected 3 times per week at the facility from October 2011 through February 2015. The data ranged from 6.52 – 8.7 s.u. The pH range of the effluent is within the State’s water quality criterion of 6.5 – 9.0 s.u.

When there are both QBEL and TBEL, the more stringent of the two become the proposed limits. In this case, the QBEL are more stringent limits, and are proposed to ensure protection of the receiving water.

The Draft Permit retains the pH limit range of 6.5 to 9.0 s.u. from the Previous Permit.

G. Proposed Effluent Limitations

Narrative Limitations

The Permittee must not discharge floating, suspended, or submerged matter of any kind in concentrations causing nuisance or objectionable conditions or that may impair designated beneficial uses.

Numeric Limitations

The table below presents the proposed effluent limits.

Table 8. Proposed Effluent Limits for the City of Filer WWTP

Proposed Effluent Limits for the City of Filer WWTP					
Parameter	Units	Effluent Limits			Basis for Limit
		Average Monthly Limit	Average Weekly Limit	Maximum Daily Limit	
Floating, Suspended, Submerged Matter	Visual Observation	See Part I.B.1 of the Permit			Idaho WQS

Proposed Effluent Limits for the City of Filer WWTP					
Parameter	Units	Effluent Limits			Basis for Limit
		Average Monthly Limit	Average Weekly Limit	Maximum Daily Limit	
Five-Day Biochemical Oxygen Demand (BOD ₅) ¹	mg/L	30	45	---	Federal Secondary Treatment Regulations [40 CFR 133]
	lbs/day	70	105	---	40 CFR 122.45(f)
BOD ₅ Removal	percent	85 minimum	---	---	40 CFR 133
Total Suspended Solids (TSS) ¹	mg/L	30	45	---	Federal Secondary Treatment Regulations [40 CFR 133]
	lbs/day	22.1	57.3	---	TMDL WLA
TSS Removal	percent	85 minimum	---	---	40 CFR 133
<i>E. coli</i> ²	#/100 ml	126 (geometric mean)	---	576 (instantaneous maximum)	Idaho WQS
Total Phosphorus	lbs/day	16.4	36.7	---	TMDL WLA
pH	s.u.	pH must not be less than 6.5 standard units nor greater than 9.0 standard units			Idaho WQS
1. Loading (in lbs/day) is calculated by multiplying the concentration in mg/L by the flow in mgd and a conversion factor of 8.34. If the concentration is measured in µg/L, the conversion factor is 0.00834. For more information on calculating, averaging, and reporting loads and concentrations see the <i>NPDES Self-Monitoring System User Guide</i> (EPA 833-B-85-100, March 1985). 2. Reporting is required within 24 hours of a MDL or instantaneous maximum limit violation.					

H. Effluent Limit Changes from the Previous Permit

In their Permit application, the City of Filer WWTP requested the following two revisions to existing Permit conditions:

- That the EPA revise the effluent mass limits for TSS to either the secondary treatment standard or the WLA in the 2005 Upper Snake/Rock TMDL Modification; and,
- That the EPA allow for year-round discharge (January 1 – December 31) to Cedar Draw.

The EPA was not able to revise the conditions for this Draft Permit. The 2005 TMDL Modification to TSS for municipal WWTPs was not approved by the EPA, therefore, the requirements and conditions found in the 1999 Upper Snake/Rock Sub basin TMDL continue to apply. If a future modification to the TMDL is approved by EPA, the WLAs for the Filer WWTP can be revisited; but at this time, the only approved WLA for the City of Filer for TSS is from 1999.

In addition, the previous seasonal discharge requirements are carried over into this Draft Permit. The Snake River and its tributaries continue to be listed as impaired for a number of pollutants, including TP, and the flow in the river has decreased over the past several years.

Therefore, any additional loadings to the Snake River, via Cedar Draw, of pollutants identified as inhibiting the Snake River from fully supporting the designated uses assigned to it are not warranted at this time. IDEQ has relayed that position to the Filer WWTP in personal communications.

Also, the facility has been in conversations with the EPA over the course of developing this Draft Permit. The City of Filer has purchased additional property for land application purposes. The WWTP operator has stated that the current seasonal discharge is adequate for the WWTP’s needs.

The table below illustrates changes in the proposed effluent limits from the Previous Permit.

Table 9. Changes in Effluent Limits from the Previous Permit

Parameter	Previous Permit	Draft Permit
Floating, Suspended, Solid Matter	--	Included the narrative provision as an effluent limitation, visual observation 1/month
Total Residual Chlorine	0.4 lbs/day AML	Monitoring Daily When In Use
	0.6 lbs/day MDL	Monitoring Daily When In Use
TSS mass loading	12 lbs/day AML	22.1 lbs/day AML
	19 lbs/day AWL	57.3 lbs/day AWL
TP mass loading	17 lbs/day AML	16.4 lbs/day AML
	33 lbs/day AWL	36.7 lbs/day AWL

V. Monitoring Requirements

A. Basis for Influent, Effluent and Surface Water Monitoring

Section 308 of the CWA and 40 CFR 122.44(i) require monitoring in Permits to determine compliance with effluent limitations. Monitoring may also be required to gather effluent and surface water data to determine if additional effluent limitations are required and/or to monitor effluent impacts on receiving water quality.

The Draft Permit also requires the Permittee to perform effluent monitoring required by the NPDES Form 2A Application, so that these data will be available when the Permittee applies for a renewal of its NPDES Permit. This includes the Permittee performing the effluent monitoring required by Parts A.12 and B.6 of the NPDES Form 2A Application so that these data will be available when the Permittee applies for a renewal of its NPDES Permit. The Permittee is responsible for conducting the monitoring and for reporting results on DMRs or on the application for renewal, as appropriate, to the EPA.

B. Influent and Effluent Monitoring

Monitoring frequencies are based on the nature and effect of the pollutant, as well as a determination of the minimum sampling necessary to adequately monitor the facility’s

performance. Permittees have the option of taking more frequent samples than are required by the Permit. These samples must be used for averaging if they are conducted using EPA-approved test methods (generally found in 40 CFR 136) or as specified in the Draft Permit.

The table below presents the proposed effluent monitoring requirements in the Draft Permit. The influent sampling location must be prior to the first treatment unit. The effluent sampling location must be after the last treatment unit and prior to discharge to the receiving water. The samples must be representative of the volume and nature of the monitored discharge. If no discharge occurs during the reporting period, “no discharge” shall be reported on the DMR.

Continuous Temperature Monitoring

The Previous Permit required continuous temperature monitoring, and it is carried over in this Draft Permit. Continuous temperature monitoring is necessary in order to assist in collecting the necessary data for development of WLAs in any IDEQ temperature TMDL.

The temperature monitoring values for influent and effluent monitoring should be generated from a recording device with a minimum of 24 evenly spaced measurements in a 24-hour period (i.e., every hour). The temperature monitoring results must be reported monthly with the DMR to the EPA.

Reporting of the instantaneous maximum and the maximum daily average temperatures recorded at both the influent and the effluent continuous recording devices is required. The Permittee must submit an electronic ASCII text file to IDEQ and the EPA annually, so that both agencies can receive all recorded data.

Table 10. Proposed Monitoring Requirements for the Filer WWTP

Proposed Effluent Monitoring Requirements for the Filer WWTP				
Parameter	Units	Sample Location	Sample Frequency	Sample Type
Flow	mgd	Effluent	Continuous	Recording
Floating, Suspended, Submerged Matter	--	--	1/month	Visual Observation
BOD ₅	mg/L	Influent & Effluent	1/week	24-hour composite
	lbs/day	Influent & Effluent	1/week	Calculation ¹
	% Removal	--	1/month	Calculation ²
TSS	mg/L	Influent & Effluent	1/week	24-hour composite
	lbs/day	Influent & Effluent	1/week	Calculation ¹
	% Removal	--	1/month	Calculation ²
Temperature ³	°C	Influent & Effluent	Continuous	Recording
pH	standard units	Effluent	3/week	Grab
<i>E. coli</i> ⁴	#/100 ml	Effluent	5/month	Grab
Total Residual Chlorine ⁵	µg/L	Effluent	1/day when in use	Grab
	lbs/day	Effluent	1/day when in use	Calculation ¹
Total Ammonia (as N)	mg/L	Effluent	1/month	24-hour composite
Total Phosphorus (as P)	mg/L	Effluent	1/week	24-hour composite
	lbs/day	Effluent	1/week	Calculation ¹

Proposed Effluent Monitoring Requirements for the Filer WWTP				
Parameter	Units	Sample Location	Sample Frequency	Sample Type
Parameters Needed for the NPDES Form 2A Application				
Dissolved Oxygen	mg/L	Effluent	1/year	Grab
Total Kjeldahl Nitrogen (TKN)	mg/L	Effluent	1/year	24-hour composite
Nitrate + Nitrite	mg/L	Effluent	1/year	24-hour composite
Oil and Grease	mg/L	Effluent	1/year	Grab
Total Dissolved Solids (TDS)	mg/L	Effluent	1/year	24-hour composite
Notes:				
<ol style="list-style-type: none"> 1. Loading is calculated by multiplying the concentration (in mg/L) by the flow (in mgd) on the day sampling occurred and a conversion factor of 8.34. 2. The monthly average percent removal must be calculated from the arithmetic mean of the influent values and the arithmetic mean of the effluent values for that month, i.e. (average monthly influent – average monthly effluent) ÷ average monthly influent. Influent and effluent samples must be taken over approximately the same time period. 3. Continuous temperature monitoring means recording temperature in 1-hour intervals, 24 hours per day. 4. The average monthly <i>E. coli</i> bacteria counts must not exceed a geometric mean of 126/100 mL based on a minimum of five samples taken every 3-7 days within a calendar month. See Part VI of the Draft Permit for a definition of geometric mean. 5. Monitoring is required only when chlorine or chlorine containing compounds are used for cleaning or emergency disinfection purposes. 				

C. Effluent Monitoring Changes from the Previous Permit

The changes in monitoring requirements from the Previous Permit include:

- The addition of the once a month visual observation of the receiving water, in order to report floating, suspended, or submerged matter in excess of the narrative criterion; and,
- The addition of the once a year monitoring of the required parameters for the NPDES Form 2A application.

D. Surface Water Monitoring

In general, surface water monitoring may be required for pollutants of concern to assess the assimilative capacity of the receiving water for the pollutant. In addition, surface water monitoring may be required for pollutants upon which the water quality criteria are dependent and to collect data for TMDL development if the facility discharges to an impaired water body.

The table below presents the surface water monitoring requirements in the Draft Permit. The City of Filer should continue receiving water monitoring at the established locations agreed upon between IDEQ and the WWTP. Surface water monitoring results must be submitted to the EPA and IDEQ with the DMR.

The changes in the surface water monitoring requirements from the Previous Permit include:

- Monitoring of TRC in the receiving water has been removed in this Draft Permit, as it is no longer in the effluent; and,
- Monitoring of Total Phosphorus (TP) in the receiving water has been added to the surface water monitoring requirements in this Draft Permit.

Table 11. Proposed Surface Water Monitoring Requirements for the City of Filer WWTP

Proposed Surface Water Monitoring Requirements for the City of Filer WWTP				
Parameter	Units	Sample Location¹	Sample Frequency²	Sample Type
Flow	mgd	Upstream	1/month	Grab
pH	standard units	Upstream	1/month	Grab
Total Ammonia (as N)	mg/L	Upstream	1/month	Grab
Total Phosphorus (as P)	mg/L	Upstream	1/month	Grab
Temperature	°C	Upstream & Downstream	Continuous	Recording
Notes:				
1. Monitoring must occur downstream of the discharge at a location where the effluent and receiving water are completely mixed. Upstream and downstream sample locations must be approved by IDEQ.				
2. To the extent practicable, surface water sample collection must occur on the same day as effluent sample collection.				

E. Electronic Submission of Discharge Monitoring Reports

During the period between the effective date of the Permit and the submission of the October 2016 DMR, the Permittee must either submit monitoring data and other reports in paper form, or must report electronically using NetDMR, a web-based tool that allows Permittees to electronically submit DMRs, and other required reports, via a secure internet connection.

Beginning with the submission of the November 2016 DMR (due December 20, 2016) and thereafter, the Permittee must submit monitoring data and other reports electronically using NetDMR.

The specific requirements regarding the submittal of data and reports in paper form and the use of NetDMR are included in the Draft Permit Part III.B.

VI. Sludge (Biosolids) Requirements

The EPA Region 10 separates wastewater and sludge permitting. The EPA has authority under the CWA to issue separate sludge-only permits for the purposes of regulating biosolids. The EPA may issue a sludge-only permit to each facility at a later date, as appropriate.

Until future issuance of a sludge-only permit, sludge management and disposal activities at each facility continue to be subject to the national sewage sludge standards at 40 CFR Part 503 and any requirements of the State’s biosolids program. The Part 503 regulations are self-

implementing, which means that facilities must comply with them whether or not a Permit has been issued.

VII. Other Permit Conditions

A. Quality Assurance Plan

In order to ensure compliance with the federal regulation at 40 CFR 122.41(e) for proper operation and maintenance, the Draft Permit requires the Permittee to develop procedures to ensure that the monitoring data submitted is accurate and to explain data anomalies if they occur. The City of Filer is required to update their existing Quality Assurance Plan (QAP) to meet the requirements of this Draft Permit within 180 days of the effective date of the final Permit. The QAP must include the standard operating procedures the Permittee must follow for collecting, handling, storing and shipping samples, laboratory analysis, and data reporting. The QAP must be retained on site and be made available to the EPA and the IDEQ upon request.

B. Operation and Maintenance Plan

The Draft Permit requires the City of Filer to properly operate and maintain all facilities and systems of treatment and control. [40 CFR 122.41(d) and (e)]. Proper operation and maintenance (O&M) is essential to meeting discharge limits, monitoring requirements, and all other permit requirements at all times. The Permittee is required to update their existing O&M Plan to meet the requirements of this Draft Permit within 180 days of the effective date of the final Permit. The O&M Plan must be retained on site and made available to the EPA and the IDEQ upon request.

C. Sanitary Sewer Overflows and Proper Operation and Maintenance of the Collection System

Untreated or partially treated discharges from separate sanitary sewer systems are referred to as sanitary sewer overflows (SSOs). SSOs may present serious risks of human exposure when released to certain areas, such as streets, private property, basements, and receiving waters used for drinking water, fish and shellfish habitat, or contact recreation. Untreated sewage contains pathogens and other pollutants, which are toxic. SSOs are not authorized under this Draft Permit.

Pursuant to the NPDES regulations, discharges from separate sanitary sewer systems authorized by NPDES Permits must meet effluent limitations that are based upon secondary treatment. Further, discharges must meet any more stringent effluent limitations that are established to meet EPA-approved WQS.

The Draft Permit contains language to address SSO reporting and public notice, and operation and maintenance of the collection system. It requires that the Permittee identify SSO occurrences and their causes. In addition, the Draft Permit establishes reporting and record keeping requirements, and requires third party notification of SSOs and the

development of an Emergency Response and Public Notification Plan. Finally, the Draft Permit also requires proper O&M of the collection system. The following specific Permit conditions apply:

Proper Operation and Maintenance

The Draft Permit requires proper operation and maintenance of the collection system [40 CFR 122.41(d) and (e)]. SSOs may be indicative of improper operation and maintenance of the collection system. The Permittee may consider the development and implementation of a capacity, management, operation, and maintenance (CMOM) program.

The Permittee may refer to the *Guide for Evaluating Capacity, Management, Operation, and Maintenance (CMOM) Programs at Sanitary Sewer Collection Systems* (EPA 305-B-05-002). This guide identifies some of the criteria used by EPA inspectors to evaluate sewer collection system management, operation, and maintenance program activities. Owners/operators can review their own systems against the checklist (found in Chapter 3 of the Guide) to reduce the occurrence of sewer overflows and improve or maintain compliance.

Immediate (24-hour) Reporting

The Permittee is required to notify the EPA of an SSO within 24 hours of the Permittee becoming aware of the overflow [40 CFR 122.41(l)(6)].

Third Party Notice

The Draft Permit requires that the Permittee establish a process to notify specified third parties of SSOs that may endanger health due to a likelihood of human exposure; or unanticipated bypass and upset that exceeds any effluent limitation in the Permit or that may endanger health due to a likelihood of human exposure. The Permittee is required to develop, in consultation with appropriate authorities at the local, county, tribal, and/or state level, a Plan that describes how, under various overflow (and unanticipated bypass and upset) scenarios, the public, as well as other entities, would be notified of overflows that may endanger health. The Plan should identify all overflows that would be reported and to whom, and the specific information that would be reported. The plan should include a description of lines of communication and the identities of responsible officials [40 CFR 122.41(l)(6)].

Written Reports

The Permittee is required to provide the EPA with a written report within 5 days of the time it became aware of any overflow that is subject to the immediate reporting provision [40 CFR 122.41(l)(6)(i)].

Record Keeping

The Permittee is required to keep records of SSOs. The Permittee must retain the reports submitted to the EPA and other appropriate reports which could include work orders associated with investigation of system problems related to a SSO, and which describe the steps -- either taken or planned -- to reduce, eliminate, and prevent reoccurrence of the SSO [40 CFR 122.41(j)].

Development of an Emergency Response and Public Notification Plan

Under the Draft Permit and pursuant to the regulations cited above, the Permittee must develop and implement an emergency response and public notification plan that identifies measures to protect the public from overflows and unanticipated bypasses or upsets that exceed any effluent limitation in the Permit.

The Permittee must submit written notice to EPA and IDEQ that the plan has been developed and implemented within 180 days of the effective date of this Permit. Any existing emergency response and public notification plan may be modified for compliance with this section of the Permit.

D. Design Criteria

The Draft Permit includes design criteria requirements. The provision requires the Permittee to compare influent flow to the facility's design flow and, if necessary, prepare a Facility Plan for maintaining compliance with NPDES Permit effluent limits whenever the actual influent flow exceeds the facility's design flow for any two (2) months during a 12-month period.

E. Industrial Waste Management Requirements

The EPA implements and enforces the National Pretreatment Program regulations of 40 CFR 403, per authority from sections 204(b)(1)(C), 208(b)(2)(C)(iii), 301(b)(1)(A)(ii), 301(b)(2)(A)(ii), 301(h)(5) and 301(i)(2), 304(e) and (g), 307, 308, 309, 402(b), 405, and 501(a) of the Federal Water Pollutant Control Act as amended by the CWA of 1977. Because Idaho does not have an approved state pretreatment program per 40 CFR 403.10, the EPA is the Approval Authority for Idaho POTWs. Because the City of Filer WWTP does not have an approved POTW pretreatment program per 40 CFR 403.8, the EPA is also the Control Authority of industrial users that might introduce pollutants into the City of Filer WWTP.

The national specific prohibitions of the General Pretreatment Program are applicable to all nondomestic sources introducing pollutants into a POTW [40 CFR 403.5(b)]. These sources of indirect discharges are more commonly referred to as Industrial Users (IUs).

All IUs, regardless of whether they are subject to any other national, state, or local pretreatment requirements, are subject to the general and specific prohibitions identified in 40 CFR 403.5(a) and (b), respectively. General prohibitions forbid the discharge (the regulations use the term introduction) of any pollutant(s) to a POTW that cause pass through or interference. Pass through and interference are terms with very specific meaning in the regulations. *Pass through is defined as a discharge that exits the POTW into waters of the United States in quantities or concentrations that, alone or in conjunction with a discharge or discharges from other sources, is a cause of a violation of any requirement of the POTW's NPDES Permit. Interference is defined as a discharge that, alone or in conjunction with a discharge or discharges from other sources, both (1) inhibits or disrupts the POTW, its treatment processes or operations, or its sludge processes, use, or disposal and (2) therefore is a cause of a violation of any requirement of the POTW's NPDES Permit.*

Specific prohibitions in 40 CFR 403.5(b) forbid the following eight categories of pollutant discharges:

- a) Discharges containing pollutants that create a fire or explosion hazard in the POTW, including waste streams with a closed-cup flashpoint of less than 140 °F (60 °C) using the test methods specified in 40 CFR 261.21;
- b) Discharges containing pollutants causing corrosive structural damage to the POTW, but in no case discharges with a pH lower than 5.0, unless the POTW is specifically designed to accommodate such discharges;
- c) Discharges containing pollutants in amounts causing obstruction to the flow in the POTW resulting in interference;
- d) Discharges of any pollutants released at a flow rate or concentration that will cause interference with the POTW;
- e) Discharges of heat in amounts that will inhibit biological activity in the POTW resulting in interference, but in no case heat in such quantities that the temperature at the POTW treatment plant exceeds 104 °F (40 °C) unless the Approval Authority, at the POTW's request, approves alternative temperature limits;
- f) Discharges of petroleum oil, non-biodegradable cutting oil, or products of mineral oil origin in amounts that will cause interference or pass through;
- g) Discharges that result in the presence of toxic gases, vapors, or fumes within the POTW in a quantity that could cause acute worker health and safety problems; and,
- h) Discharges of trucked or hauled pollutants, except at discharge points designated by the POTW.

Special Conditions II.D.1 and II.D.2 of the Draft Permit remind the City that it cannot authorize discharges which may violate the national specific prohibitions of the General Pretreatment Program.

Because an IU can be as simple as an automated, coin-operated car wash or as complex as an automobile manufacturing plant or a synthetic organic chemical producer, the EPA developed four criteria that define a significant IU (SIU). Many of the General Pretreatment Regulations apply to SIUs as opposed to IUs. Where a smaller IU has the potential to adversely affect the POTW, the POTW would be expected to designate the facility as a SIU.

An SIU is defined in 40 CFR 403.3(v) as any of the following:

- a) An IU subject to federal categorical pretreatment standards;

- b) An IU that discharges an average of 25,000 gallons per day (gpd) or more of process wastewater to the POTW;
- c) An IU that contributes a process waste stream making up 5 percent or more of the average dry-weather hydraulic or organic capacity of the POTW treatment plant; and,
- d) An IU designated by the POTW as such because of its reasonable potential to adversely affect the POTW's operation or violate any pretreatment standard or requirement.

In order to enable the Permittee to determine which industries have the potential to impact the POTW and to establish local limits if necessary to protect both the treatment plant and receiving water body, the EPA is requiring the Permittee to develop a master list of industrial users and obtain information specific to each industry's wastewater discharge characteristics. (See Special Conditions Industrial Waste Management in the permit.) Procedures for designing, implementing, and documenting this list may be found Chapter 2, Industrial Waste Survey in the following document: *Guidance Manual for POTW Pretreatment Program Development*, EPA October, 1983.

Although not a Permit requirement, the Permittee may wish to consider developing the legal authority enforceable in Federal, State, or local courts that authorizes or enables the POTW to apply and to enforce the requirement of sections 307(b) and (c) and 402(b)(8) of the Clean Water Act, as described in 40 CFR 403.8(f)(1). Where the POTW is a municipality, legal authority is typically provided through a sewer use ordinance, which is usually part of the city or county code. The EPA has a Model Pretreatment Ordinance for use by municipalities operating POTWs that are required to develop pretreatment programs to regulate industrial discharges to their systems (EPA, 2007). The model ordinance should also be useful for communities with POTWs that are not required to implement a pretreatment program in drafting local ordinances to control nondomestic dischargers within their jurisdictions.

F. Environmental Justice

Executive Order 12898, *Federal Actions to Address Environmental Justice in Minority Populations and Low-Income Populations*, directs each federal agency to “make achieving environmental justice part of its mission by identifying and addressing, as appropriate, disproportionately high and adverse human health or environmental effects of its programs, policies, and activities.” The EPA strives to enhance the ability of overburdened communities to participate fully and meaningfully in the permitting process for EPA-issued permits, including NPDES permits. “Overburdened” communities can include minority, low-income, tribal, and indigenous populations or communities that potentially experience disproportionate environmental harms and risks. As part of an agency-wide effort, the EPA Region 10 will consider prioritizing enhanced public involvement opportunities for EPA-issued permits that may involve activities with significant public health or environmental impacts on already overburdened communities. For more information, please visit <http://www.epa.gov/compliance/ej/plan-ej/>.

As part of the Permit development process, the EPA conducted a screening analysis to determine whether this Permit action could affect overburdened communities. The EPA used a nationally consistent geospatial tool that contains demographic and environmental data for the United States at the Census block group level. This tool is used to identify Permits for which enhanced outreach may be warranted.

The EJ Screen score for the facility was at the 71st percentile (71%ile), and this is below the 80%ile cut-off for engaging in enhanced outreach around the availability of the Draft Permit for review and comment. Therefore, the City of Filer WWTP is not considered to be discharging in an EJ community and no enhanced outreach is necessary.

However, regardless of whether or not a WWTP is located near a potentially overburdened community, the EPA encourages Permittees to review (and to consider adopting, where appropriate) the *Promising Practices for Permit Applicants Seeking EPA-Issued Permits: Ways To Engage Neighboring Communities* (see <https://www.federalregister.gov/articles/2013/05/09/2013-10945/epa-activities-to-promote-environmental-justice-in-the-permit-application-process#p-104>).

Examples of promising practices include: thinking ahead about community's characteristics and the effects of the Permit on the community, engaging the right community leaders, providing progress or status reports, inviting members of the community for tours of the facility, providing informational materials translated into different languages, setting up a hotline for community members to voice concerns or request information, and following up with the community.

G. Standard Permit Provisions

Sections III, IV, and V of the Draft Permit contain standard regulatory language that must be included in all NPDES Permits. The standard regulatory language covers requirements such as monitoring, recording, and reporting requirements, compliance responsibilities, and other general requirements.

VIII. Other Legal Requirements

A. Endangered Species Act

The Endangered Species Act requires federal agencies to consult with National Oceanic and Atmospheric Administration Fisheries (NOAA Fisheries) and the U.S. Fish and Wildlife Service (USFWS) if their actions could beneficially or adversely affect any threatened or endangered species. A review of the threatened and endangered species located in Twin Falls County, Idaho, designated by the USFWS, finds that this permitting action has no effect on any threatened or endangered species. http://ecos.fws.gov/tess_public/reports/species-by-current-range-county?fips=16083

There are no federally listed, endangered, or threatened species within the vicinity of the discharge, under NOAA Fisheries jurisdiction.

B. Essential Fish Habitat

Essential fish habitat (EFH) is the waters and substrate (sediments, etc.) necessary for fish to spawn, breed, feed, or grow to maturity. The Magnuson-Stevens Fishery Conservation and Management Act (January 21, 1999) requires the EPA to consult with NOAA Fisheries when a proposed discharge has the potential to adversely affect EFH (i.e., reduce quality and/or quantity of EFH). According to information obtained from the NOAA Fisheries website, there is no designated EFH in the vicinity of the Filer WWTP discharge.

<http://www.habitat.noaa.gov/protection/efh/efhmapper/index.html>

C. State Certification

Section 401 of the CWA requires the EPA to seek State certification before issuing a final permit. As a result of the certification, the State may require more stringent permit conditions or additional monitoring requirements to ensure that the permit complies with WQS, or treatment standards established pursuant to any State law or regulation.

D. Permit Expiration

The Permit will expire five years from the effective date.

IX. References

EPA. 1991. *Technical Support Document for Water Quality-based Toxics Control*. US Environmental Protection Agency, Office of Water, EPA/505/2-90-001.

Water Pollution Control Federation. Subcommittee on Chlorination of Wastewater. *Chlorination of Wastewater*. Water Pollution Control Federation. Washington, D.C. 1976.

EPA. 2010. *NPDES Permit Writers' Manual*. Environmental Protection Agency, Office of Wastewater Management, EPA-833-K-10-001.

IDEQ WQS

NPDES Permit Application/supplemental materials

IDEQ. 1998. *Middle Snake River Watershed Management Plan*. Idaho Division of Environmental Quality, Twin Falls Regional Office. January 29, 1998

IDEQ. 1999. *The Upper Snake Rock Watershed Management Plan*. Idaho Division of Environmental Quality, Twin Falls Regional Office. December 20, 1999.

IDEQ. 2010. *Upper Snake Rock/Middle Snake TMDLs 5-Year TMDL Review*. Idaho Department of Environmental Quality, Twin Falls Regional Office. April 2010.

Appendix A: Facility Information

General Information

NPDES ID Number: ID0020061

Physical Location: 4030 North 2200 East
Filer, ID 83328

Mailing Address: P.O. Box 140
Filer, ID 83328

Facility Background: The Previous Permit became effective on November 1, 2007 and expired on October 31, 2012. An NPDES Application Form 2A for Permit renewal was signed and submitted to EPA on May 3, 2012. The Previous Permit was administratively extended pursuant to 40 CFR 122.6.

Facility Information

Type of Facility: Publicly Owned Treatment Works (POTW)

Treatment Train: Flow measurement and recording

- Solids Removal (screening)
- Equalization Basin
- Anaerobic Basins
- Deoxygenation Basin
- Anoxic Basins
- Aerobic Basins
- Membrane Bioreactor
- Backpulse Tank
- UV Disinfection

Sludge (biosolids) Handling: Belt filter press and disposal

Flow: Monthly Design flow is 0.50 mgd.


Outfall Location: Latitude 45° 34' 56" North and longitude 114° 36' 45" West

Receiving Water Information

Receiving Water: Cedar Draw Creek

Beneficial Uses: Cold water aquatic life, secondary contact recreation, and salmonid spawning.





B4 PROCESS FLOW SCHEMATIC
NOT TO SCALE

GENERAL NOTES:
1. THE HYDRAULIC PROFILE IS BASED ON AN EQUAL SPLIT BETWEEN TWO PROPOSED TRUNK PROPOSED BASINS AND EQUIPMENT ITEMS.

- LEGEND**
- > PRIMARY FLOW PATH
 - - - -> BYPASS OR SECONDARY FLOW PATH
 - > FUTURE FLOW PATH
 - > SOLIDS STREAM
 - - - -> ALTERNATE SOLIDS STREAM
 - (with M) (with S) (with P) (with F) (with R) (with D) (with E) (with G) (with H) (with I) (with J) (with K) (with L) (with M) (with N) (with O) (with P) (with Q) (with R) (with S) (with T) (with U) (with V) (with W) (with X) (with Y) (with Z) (with AA) (with AB) (with AC) (with AD) (with AE) (with AF) (with AG) (with AH) (with AI) (with AJ) (with AK) (with AL) (with AM) (with AN) (with AO) (with AP) (with AQ) (with AR) (with AS) (with AT) (with AU) (with AV) (with AW) (with AX) (with AY) (with AZ) (with BA) (with BB) (with BC) (with BD) (with BE) (with BF) (with BG) (with BH) (with BI) (with BJ) (with BK) (with BL) (with BM) (with BN) (with BO) (with BP) (with BQ) (with BR) (with BS) (with BT) (with BU) (with BV) (with BW) (with BX) (with BY) (with BZ) (with CA) (with CB) (with CC) (with CD) (with CE) (with CF) (with CG) (with CH) (with CI) (with CJ) (with CK) (with CL) (with CM) (with CN) (with CO) (with CP) (with CQ) (with CR) (with CS) (with CT) (with CU) (with CV) (with CW) (with CX) (with CY) (with CZ) (with DA) (with DB) (with DC) (with DD) (with DE) (with DF) (with DG) (with DH) (with DI) (with DJ) (with DK) (with DL) (with DM) (with DN) (with DO) (with DP) (with DQ) (with DR) (with DS) (with DT) (with DU) (with DV) (with DW) (with DX) (with DY) (with DZ) (with EA) (with EB) (with EC) (with ED) (with EE) (with EF) (with EG) (with EH) (with EI) (with EJ) (with EK) (with EL) (with EM) (with EN) (with EO) (with EP) (with EQ) (with ER) (with ES) (with ET) (with EU) (with EV) (with EW) (with EX) (with EY) (with EZ) (with FA) (with FB) (with FC) (with FD) (with FE) (with FF) (with FG) (with FH) (with FI) (with FJ) (with FK) (with FL) (with FM) (with FN) (with FO) (with FP) (with FQ) (with FR) (with FS) (with FT) (with FU) (with FV) (with FW) (with FX) (with FY) (with FZ) (with GA) (with GB) (with GC) (with GD) (with GE) (with GF) (with GG) (with GH) (with GI) (with GJ) (with GK) (with GL) (with GM) (with GN) (with GO) (with GP) (with GQ) (with GR) (with GS) (with GT) (with GU) (with GV) (with GW) (with GX) (with GY) (with GZ) (with HA) (with HB) (with HC) (with HD) (with HE) (with HF) (with HG) (with HH) (with HI) (with HJ) (with HK) (with HL) (with HM) (with HN) (with HO) (with HP) (with HQ) (with HR) (with HS) (with HT) (with HU) (with HV) (with HW) (with HX) (with HY) (with HZ) (with IA) (with IB) (with IC) (with ID) (with IE) (with IF) (with IG) (with IH) (with II) (with IJ) (with IK) (with IL) (with IM) (with IN) (with IO) (with IP) (with IQ) (with IR) (with IS) (with IT) (with IU) (with IV) (with IW) (with IX) (with IY) (with IZ) (with JA) (with JB) (with JC) (with JD) (with JE) (with JF) (with JG) (with JH) (with JI) (with JJ) (with JK) (with JL) (with JM) (with JN) (with JO) (with JP) (with JQ) (with JR) (with JS) (with JT) (with JU) (with JV) (with JW) (with JX) (with JY) (with JZ) (with KA) (with KB) (with KC) (with KD) (with KE) (with KF) (with KG) (with KH) (with KI) (with KJ) (with KK) (with KL) (with KM) (with KN) (with KO) (with KP) (with KQ) (with KR) (with KS) (with KT) (with KU) (with KV) (with KW) (with KX) (with KY) (with KZ) (with LA) (with LB) (with LC) (with LD) (with LE) (with LF) (with LG) (with LH) (with LI) (with LJ) (with LK) (with LL) (with LM) (with LN) (with LO) (with LP) (with LQ) (with LR) (with LS) (with LT) (with LU) (with LV) (with LW) (with LX) (with LY) (with LZ) (with MA) (with MB) (with MC) (with MD) (with ME) (with MF) (with MG) (with MH) (with MI) (with MJ) (with MK) (with ML) (with MM) (with MN) (with MO) (with MP) (with MQ) (with MR) (with MS) (with MT) (with MU) (with MV) (with MW) (with MX) (with MY) (with MZ) (with NA) (with NB) (with NC) (with ND) (with NE) (with NF) (with NG) (with NH) (with NI) (with NJ) (with NK) (with NL) (with NM) (with NN) (with NO) (with NP) (with NQ) (with NR) (with NS) (with NT) (with NU) (with NV) (with NW) (with NX) (with NY) (with NZ) (with OA) (with OB) (with OC) (with OD) (with OE) (with OF) (with OG) (with OH) (with OI) (with OJ) (with OK) (with OL) (with OM) (with ON) (with OO) (with OP) (with OQ) (with OR) (with OS) (with OT) (with OU) (with OV) (with OW) (with OX) (with OY) (with OZ) (with PA) (with PB) (with PC) (with PD) (with PE) (with PF) (with PG) (with PH) (with PI) (with PJ) (with PK) (with PL) (with PM) (with PN) (with PO) (with PP) (with PQ) (with PR) (with PS) (with PT) (with PU) (with PV) (with PW) (with PX) (with PY) (with PZ) (with QA) (with QB) (with QC) (with QD) (with QE) (with QF) (with QG) (with QH) (with QI) (with QJ) (with QK) (with QL) (with QM) (with QN) (with QO) (with QP) (with QQ) (with QR) (with QS) (with QT) (with QU) (with QV) (with QW) (with QX) (with QY) (with QZ) (with RA) (with RB) (with RC) (with RD) (with RE) (with RF) (with RG) (with RH) (with RI) (with RJ) (with RK) (with RL) (with RM) (with RN) (with RO) (with RP) (with RQ) (with RR) (with RS) (with RT) (with RU) (with RV) (with RW) (with RX) (with RY) (with RZ) (with SA) (with SB) (with SC) (with SD) (with SE) (with SF) (with SG) (with SH) (with SI) (with SJ) (with SK) (with SL) (with SM) (with SN) (with SO) (with SP) (with SQ) (with SR) (with SS) (with ST) (with SU) (with SV) (with SW) (with SX) (with SY) (with SZ) (with TA) (with TB) (with TC) (with TD) (with TE) (with TF) (with TG) (with TH) (with TI) (with TJ) (with TK) (with TL) (with TM) (with TN) (with TO) (with TP) (with TQ) (with TR) (with TS) (with TT) (with TU) (with TV) (with TW) (with TX) (with TY) (with TZ) (with UA) (with UB) (with UC) (with UD) (with UE) (with UF) (with UG) (with UH) (with UI) (with UJ) (with UK) (with UL) (with UM) (with UN) (with UO) (with UP) (with UQ) (with UR) (with US) (with UT) (with UY) (with UZ) (with VA) (with VB) (with VC) (with VD) (with VE) (with VF) (with VG) (with VH) (with VI) (with VJ) (with VK) (with VL) (with VM) (with VN) (with VO) (with VP) (with VQ) (with VR) (with VS) (with VT) (with VU) (with VV) (with VW) (with VX) (with VY) (with VZ) (with WA) (with WB) (with WC) (with WD) (with WE) (with WF) (with WG) (with WH) (with WI) (with WJ) (with WK) (with WL) (with WM) (with WN) (with WO) (with WP) (with WQ) (with WR) (with WS) (with WT) (with WU) (with WV) (with WW) (with WX) (with WY) (with WZ) (with XA) (with XB) (with XC) (with XD) (with XE) (with XF) (with XG) (with XH) (with XI) (with XJ) (with XK) (with XL) (with XM) (with XN) (with XO) (with XP) (with XQ) (with XR) (with XS) (with XT) (with XU) (with XV) (with XW) (with XX) (with XY) (with XZ) (with YA) (with YB) (with YC) (with YD) (with YE) (with YF) (with YG) (with YH) (with YI) (with YJ) (with YK) (with YL) (with YM) (with YN) (with YO) (with YP) (with YQ) (with YR) (with YS) (with YT) (with YU) (with YV) (with YW) (with YX) (with YY) (with YZ) (with ZA) (with ZB) (with ZC) (with ZD) (with ZE) (with ZF) (with ZG) (with ZH) (with ZI) (with ZJ) (with ZK) (with ZL) (with ZM) (with ZN) (with ZO) (with ZP) (with ZQ) (with ZR) (with ZS) (with ZT) (with ZU) (with ZV) (with ZW) (with ZX) (with ZY) (with ZZ)

RECORD DRAWING CERTIFICATIONS
These Record Drawings represent the locations of improvements based on field observations made during construction and from information provided by others.

JUB

JUB ENGINEERS, INC.
1115 Northstar Avenue
Twin Falls, Idaho 83301
Phone: 208.733.2414
Fax: 208.733.1455
www.jub.com

RECORD ORIGINAL SIGNED BY: LEV T. SHOOLROY
DATE ORIGINAL SIGNED: 02/12/12

DRAWINGS

CITY OF FILER 2009 WWTP IMPROVEMENTS	GENERAL PROCESS FLOW SCHEMATIC
---	-----------------------------------

Appendix C: Water Quality Criteria Summary

This appendix provides a summary of water quality criteria applicable to Cedar Draw Creek.

Idaho WQS include criteria necessary to protect designated beneficial uses. The standards are divided into three sections: General Water Quality Criteria, Surface Water Quality Criteria for Use Classifications, and Site-Specific Surface Water Quality Criteria. The EPA has determined that the criteria listed below are applicable to Cedar Draw Creek. This determination was based on (1) the applicable beneficial uses of the river (cold water aquatic life, secondary contact recreation, and salmonid spawning), (2) the type of facility, (3) a review of the application materials submitted by the Permittee, and (4) the quality of the water in Cedar Draw Creek.

A. General Criteria (IDAPA 58.01.02.200)

Surface waters of the state shall be free from:

- hazardous materials in concentrations found to be of public health significance or to impair designated beneficial uses;
- toxic substances in concentrations that impair designated beneficial uses;
- deleterious materials in concentrations that impair designated beneficial uses;
- floating, suspended, or submerged matter of any kind in concentrations causing nuisance or objectionable conditions or that may impair designated beneficial uses;
- excess nutrients that can cause visible slime growths or other nuisance aquatic growths impairing designated beneficial uses; and,
- oxygen demanding materials in concentrations that would result in an anaerobic water condition.

Surface water levels shall not exceed allowable level for:

- radioactive materials; and,
- sediments

B. Surface Water Criteria To Protect Aquatic Life Uses (IDAPA 58.01.02.250)

1. pH: Within the range of 6.5 to 9.0
2. Dissolved Oxygen: Not to exceed 6 mg/L at all times.
3. Temperature: Water temperatures of 22°C or less with a maximum daily average of no greater than 19°C.

C. Surface Water Quality Criteria for Recreational Use Designation (IDAPA 58.01.02.251)

- a. Geometric Mean Criterion. Waters designated for primary or secondary contact recreation are not to contain *E. coli* in concentrations exceeding a geometric mean of 126 *E. coli*

organisms per 100 ml based on a minimum of 5 samples taken every 3 to 7 days over a 30 day period.

b. Use of Single Sample Values: This section states that a water sample that exceeds certain “single sample maximum” values indicates a likely exceedance of the geometric mean criterion, although it is not, in and of itself, a violation of water quality standards. For waters designated for secondary contact recreation, the “single sample maximum” value is 576 organisms per 100 ml (IDAPA 58.01.02.251.01.b.i.).

D. Surface Water Quality Criteria for Salmonid Spawning Use Designation (IDAPA 58.01.02.250.02.f)

The Department shall determine spawning periods on a waterbody specific basis taking into account knowledge of local fisheries biologists, published literature, records of the Idaho Department of Fish and Game, and other appropriate records of spawning and incubation, as further described in the current version of the “Water Body Assessment Guidance” published by the Idaho Department of Environmental Quality. Waters designated for salmonid spawning in areas used for spawning and during the time spawning and incubation occurs, are not to vary from the following characteristics due to human activities.

- i. Dissolved Oxygen
 - (1) Intergravel Dissolved Oxygen
 - (a) One (1) day minimum of not less than 5.0 mg/l.
 - (b) Seven (7) day average mean of not less than 6.0 mg/l.
 - (2) Water column Dissolved Oxygen
 - (a) One (1) day minimum of not less than 6.0 mg/l or 90% of saturation whichever is greater.
- ii. Water temperatures of 13°C or less with a maximum daily average no greater than 9°C.

**Appendix D: Preliminary Clean Water Act Section 401
Certification from the Idaho Department of Environmental Quality**



Idaho Department of Environmental Quality Draft §401 Water Quality Certification

January 28, 2016

NPDES Permit Number(s): ID0020061 / City of Filer Wastewater Treatment Plant (WWTP)

Receiving Water Body: Cedar Draw (Source to Mouth)

Pursuant to the provisions of Section 401(a) (1) of the Federal Water Pollution Control Act (Clean Water Act), as amended; 33 U.S.C. Section 1341(a)(1); and Idaho Code §§ 39-101 et seq. and 39-3601 et seq., the Idaho Department of Environmental Quality (DEQ) has authority to review National Pollutant Discharge Elimination System (NPDES) permits and issue water quality certification decisions.

Based upon its review of the above-referenced permit and associated fact sheet, DEQ certifies that if the permittee complies with the terms and conditions imposed by the permit along with the conditions set forth in this water quality certification, then there is reasonable assurance the discharge will comply with the applicable requirements of Sections 301, 302, 303, 306, and 307 of the Clean Water Act, the Idaho Water Quality Standards (WQS) (IDAPA 58.01.02), and other appropriate water quality requirements of state law.

This certification does not constitute authorization of the permitted activities by any other state or federal agency or private person or entity. This certification does not excuse the permit holder from the obligation to obtain any other necessary approvals, authorizations, or permits, including without limitation, the approval from the owner of a private water conveyance system, if one is required, to use the system in connection with the permitted activities.

Antidegradation Review

The WQS contain an antidegradation policy providing three levels of protection to water bodies in Idaho (IDAPA 58.01.02.051).

- Tier 1 Protection. The first level of protection applies to all water bodies subject to Clean Water Act jurisdiction and ensures that existing uses of a water body and the level of water quality necessary to protect those existing uses will be maintained and protected (IDAPA 58.01.02.051.01; 58.01.02.052.01). Additionally, a Tier 1 review is performed for all new or reissued permits or licenses (IDAPA 58.01.02.052.07).
- Tier 2 Protection. The second level of protection applies to those water bodies considered high quality and ensures that no lowering of water quality will be allowed unless deemed necessary to accommodate important economic or social development (IDAPA 58.01.02.051.02; 58.01.02.052.08).

- Tier 3 Protection. The third level of protection applies to water bodies that have been designated outstanding resource waters and requires that activities not cause a lowering of water quality (IDAPA 58.01.02.051.03; 58.01.02.052.09).

DEQ is employing a water body by water body approach to implementing Idaho's antidegradation policy. This approach means that any water body fully supporting its beneficial uses will be considered high quality (IDAPA 58.01.02.052.05.a). Any water body not fully supporting its beneficial uses will be provided Tier 1 protection for that use, unless specific circumstances warranting Tier 2 protection are met (IDAPA 58.01.02.052.05.c). The most recent federally approved Integrated Report and supporting data are used to determine support status and the tier of protection (IDAPA 58.01.02.052.05).

Pollutants of Concern

The City of Filer WWTP discharges the following pollutants of concern: BOD₅, total suspended solids (TSS), pH, Escherichia coli (E. coli), total phosphorus (TP), total ammonia, temperature, total Kjeldahl nitrogen (TKN), nitrate + nitrite (NO_x), total residual chlorine (TRC), dissolved oxygen (DO), oil & grease, and total dissolved solids (TDS). Effluent limits have been developed for BOD₅, TSS, pH and TP. No effluent limits are proposed for total ammonia, temperature, TKN, NO_x, TRC, DO, oil & grease, and TDS.

Receiving Water Body Level of Protection

The City of Filer WWTP discharges to the Cedar Draw within the Upper Snake Rock Subbasin assessment unit (AU) ID17040212SK012_02 (Cedar Draw – Source to mouth). This AU has the following designated beneficial uses: cold water aquatic life, salmonid spawning and secondary contact recreation. In addition to these uses, all waters of the state are protected for agricultural and industrial water supply, wildlife habitat, and aesthetics (IDAPA 58.01.02.100).

According to DEQ's 2012 Integrated Report, this AU is not fully supporting one or more of its assessed uses. The aquatic life uses (i.e. cold water aquatic life and salmonid spawning) and contact recreation uses are not fully supported. The causes of impairment include TP and TSS for aquatic life and bacteria (E. coli) for contact recreation. As such, DEQ will provide Tier 1 protection (IDAPA 58.01.02.051.01) for the aquatic life and contact recreation uses.

Protection and Maintenance of Existing Uses (Tier 1 Protection)

As noted above, a Tier 1 review is performed for all new or reissued permits or licenses, applies to all waters subject to the jurisdiction of the Clean Water Act, and requires demonstration that existing uses and the level of water quality necessary to protect existing uses shall be maintained and protected. In order to protect and maintain designated and existing beneficial uses, a permitted discharge must comply with narrative and numeric criteria of the Idaho WQS, as well as other provisions of the WQS such as Section 055, which addresses water quality limited waters. The numeric and narrative criteria in the WQS are set at levels that ensure protection of designated beneficial uses. The effluent limitations and associated requirements contained in the City of Filer WWTP permit are set at levels that ensure compliance with the narrative and numeric criteria in the WQS.

Water bodies not supporting existing or designated beneficial uses must be identified as water quality limited, and a total maximum daily load (TMDL) must be prepared for those pollutants causing impairment. A central purpose of TMDLs is to establish wasteload allocations for point source discharges, which are set at levels designed to help restore the water body to a condition that supports existing and designated beneficial uses. Discharge permits must contain limitations that are consistent with wasteload allocations in the approved TMDL.

Prior to the development of the TMDL, the WQS require the application of the antidegradation policy and implementation provisions to maintain and protect uses (IDAPA 58.01.02.055.04).

The EPA-approved *Mid-Snake TMDL (1997) and the Upper Snake Rock TMDL (2000 and 2005)* establishes wasteload allocations for TP, TSS and E. coli. These wasteload allocations are designed to ensure that Cedar Draw will achieve the water quality necessary to support its existing and designated beneficial uses and comply with the applicable numeric and narrative criteria. The effluent limitations and associated requirements contained in the City of Filer WWTP permit are set at levels that comply with these wasteload allocations.

In sum, the effluent limitations and associated requirements contained in the City of Filer WWTP permit are set at levels that ensure compliance with the narrative and numeric criteria in the WQS and the wasteload allocations established in the *Mid-Snake TMDL (1997) and the Upper Snake Rock TMDL (2000 and 2005)*. Therefore, DEQ has determined the permit will protect and maintain existing and designated beneficial uses in the Cedar Draw in compliance with the Tier 1 provisions of Idaho's WQS (IDAPA 58.01.02.051.01 and 58.01.02.052.07).

Mixing Zones

Pursuant to IDAPA 58.01.02.060, DEQ authorizes a mixing zone that utilizes 4% of the critical flow volumes (1Q10 and 7Q10 flow) of Snake River for ammonia. This is based on EPA's reasonable potential to exceed analysis in the Fact Sheet (pages 16-17).

Other Conditions

This certification is conditioned upon the requirement that any material modification of the permit or the permitted activities—including without limitation, any modifications of the permit to reflect new or modified TMDLs, wasteload allocations, site-specific criteria, variances, or other new information—shall first be provided to DEQ for review to determine compliance with Idaho WQS and to provide additional certification pursuant to Section 401.

Right to Appeal Final Certification

The final Section 401 Water Quality Certification may be appealed by submitting a petition to initiate a contested case, pursuant to Idaho Code § 39-107(5) and the "Rules of Administrative Procedure before the Board of Environmental Quality" (IDAPA 58.01.23), within 35 days of the date of the final certification.

Questions or comments regarding the actions taken in this certification should be directed to Dr. Balthasar Buhidar, Twin Falls Regional Office, (208) 736-2190, or at Balthasar.buhidar@deq.idaho.gov.

“DRAFT”

David Anderson
Regional Administrator
Twin Falls Regional Office