

STATEMENT OF BASIS

FOR THE REISSUANCE OF A NPDES PERMIT

U.S. Environmental Protection Agency
Region 5, NPDES Programs Branch - WN-15J
77 West Jackson Boulevard
Chicago, Illinois 60604
(312) 886-6106

Public Notice No.: 18-06-01-A

Public Notice Issued On: June 27, 2018

Comment Period Ends: July 27, 2018

Permit No.: WI-0071315-3 (REISSUANCE)

Application No.: WI-0071315-3

Name and Address of Applicant:

**Name and Address of Facility Where
Discharge Occurs:**

Menominee Indian Tribe of Wisconsin
Menominee Tribal Utilities
N 700 Go Around Road
Keshena, Wisconsin 54135

Keshena WWTP
N 700 Go Around Road
Menominee County, WI
(Section 25, T28N, R15E)

Receiving Water: Unnamed Wetland.

DESCRIPTION OF APPLICANT'S FACILITY AND DISCHARGE

The above named applicant has applied for an NPDES Permit to discharge into the designated receiving water. The facility and discharge are located within the Menominee Indian Reservation. The permit will be issued by the U.S. Environmental Protection Agency.

The application and plans indicate that the permittee owns and operates a 0.335 mgd extended oxidation ditch system with phosphorus removal followed by ultraviolet disinfection.

In addition, the permittee has for use its original lagoon treatment system. The previous system consisted of two primary cells and three secondary cells and was designed to remove phosphorus by alum addition to the secondary cell to be discharged. The permittee no longer uses this practice as the infrastructure is no longer available. During the summer months, some of the influent flow is diverted away from the oxidation ditch to the old lagoons so that they do not dry out. The lagoons still have a discharge control structure. Normally, there will be no discharge from these cells, however, if one is needed, the effluent must meet the limits required for the oxidation ditch.

The discharge goes east about 1700 feet through a pipe where it hits a splash pad, then the discharge flows about 900 feet through manmade trench constructed of riprap to a diversion structure where the flow spreads out and spills over a weir into an unnamed wetland through Outfall 001 (Lat: 44° 52' 40", Long: 88° 37' 05"). The discharge is continuous.

The sludge from the facility is aerobically digested on site. As needed the sludge is then put into the lagoon's primary cells for additional treatment. The facility does not plan to use or dispose of sludge from this facility during the permit term.

Wastewater is from domestic sources only, including a casino and a hotel.

Receiving Water

The surface waters of the Menominee Reservation are protected under the Menominee Tribal Surface Water Quality Regulations, within the exterior boundaries of the Menominee Indian Reservation, to protect aquatic life, public health, safety or welfare and serve the purposes of CWA. These regulations have not been federally approved and are used as guidance in the development of permit limits.

Proposed Effluent Limitations:

Monitoring Point 001A- the permittee is authorized to discharge of treated municipal wastewater from Monitoring Point 001A through Outfall 001. Outfall 001 discharges to an unnamed wetland.

Parameter	Maximum Limits for Quantity or Loading				Maximum Limits for Quality or Concentration				Comments
	30-Day	7-Day	Daily	Units	30-Day	7-Day	Daily	Units	
Flow	Report	---	Report	MGD	---	---	---	---	PWJ
Carbonaceous Biochemical Oxygen Demand (CBOD ₅)									
	56	84	---	lbs/day	20	30	---	mg/L	STS/PWJ
Total Suspended Solids (TSS)									
	56	84	---	lbs/day	20	30	---	mg/L	STS/PWJ
Ammonia (asN)									
May-October	15.6	---	27.6	lbs/day	5.59	---	9.87	mg/L	WQS
Nov-April	---	---	27.6	lbs/day	---	---	9.87	mg/L	
Total Phosphorus (as P)									
	2.8	---	5.6	lbs/day	1.0	---	2.0	mg/L	WQC/PWJ
E. coli	---	---	---	---	126*	---	235	E.coli/100 ml	WQS
Total Mercury	---	---	---	---	---	---	Report	ng/L	WQC
					Minimum Daily		Maximum Daily		
pH	---	---	---	---	6.0	---	8.5	S.U.	STS/WQS

Dissolved Oxygen	---	---	---	---	5.0	---	---	mg/l	WQS
Temperature	---	---	---	---	Report	Report	Report	°F	WQC

* Geometric Mean

Loading limits in the permit were calculated using the following formula:
 $0.335 \text{ mgd} \times \text{limit (mg/L)} \times 8.34 = \text{Loading (lbs/d)}.$

Comment Key

WQS – Water Quality Standards

WQC – Water Quality Concern

STS – Secondary Treatment Standards (40 CFR part 133)

PWJ – Permit Writer’s Judgment

Section 401 Water Quality Certification

EPA is the appropriate authority for purposes of certifying the proposed discharge under Section 401 of the Clean Water Act. Section 401 certification is not needed from the state or the tribe as neither has federally approved water quality standards applicable to the receiving water at the point of discharge.

ESA and NHPA Compliance

EPA believes it has satisfied its requirements under the Endangered Species Act and the National Historical Preservation Act. There are two endangered species (Gray wolf and Karner blue butterfly) and one threatened species (Northern long-eared bat) within the county. This is an existing facility with no planned construction during the permit term. This permit has been issued by EPA in the past. The site does not have the critical habitat needed for the identified species. Therefore, it is believed that the reissuance of the permit and the continued operation of the facility and associated discharge will have no effect on endangered or threatened species or their critical habitat.

Also, due to the previously disturbed nature of the project location, it is highly unlikely that cultural resources and historical properties exist, and therefore the project, discharge and issuance of the permit will have no effect on cultural resources and historical properties.

Basis for Permit Requirements

The limits were developed to ensure compliance with 40 CFR Parts 131 and 133 and protection of Menominee’s Tribal Surface Water Quality Regulations and Wisconsin’s water quality standards where they are applicable. We also looked at compliance with EPA’s water quality criteria. The limits were calculated using WDNR procedures to be protective of a “Limited Aquatic Life” (LAL) designated use as the discharge is to a wetland. Though the state’s water quality standards are not applicable at the point of discharge, EPA believes that the limits will also be protective of Menominee’s water quality regulations at the point of discharge. EPA believes the LAL designation is still appropriate for the receiving water because of the size of the wetland complex and that the effluent is diffused over a large area so as not to cause channelization through the wetland.

pH

The limits for pH are based on secondary treatment requirements pursuant to 40 CFR Part 133 and permit writer's judgment to ensure the daily maximum ammonia limit will not be toxic at higher pH levels. The minimum and maximum limits are carried over from previous permit. Data indicate that the permittee has been in substantial compliance with the limits.

Chemical Biochemical Oxygen Demand (CBOD₅)

The limits in the previous permit were meant to be protective of a LAL designated use. The limits for CBOD₅ are 30 mg/L as a 7-day average and 20 mg/L as a 30-day average. These limits are still appropriate for this permit term. The 7-day average and the 30-day average are the arithmetic mean of pollutant parameter values for samples collected in a period of 7 and 30 consecutive days, respectively. The permit does not require percent removal calculations as 85% reduction is assured due to the stringency of the concentration limits.

Total Suspended Solids (TSS)

The limits in the previous permit were meant to be protective of a LAL designated use. The limits for TSS are 30 mg/L as a 7-day average and 20 mg/L as a 30-day average. These limits are still appropriate for this permit term. The 7-day average and the 30-day average are the arithmetic mean of pollutant parameter values for samples collected in a period of 7 and 30 consecutive days, respectively. The permit does not require percent removal calculations as 85% reduction is assured due to the stringency of the concentration limits.

E. coli

The limits for E. coli are based on the Menominee Tribe's water quality criteria and EPA's water quality criteria and continuation of the limit from the existing permit. The limits are applicable from May 1 through September 30. The geometric mean of samples collected over a 30-day period shall not exceed an E. coli count of 126 Colony Forming Units (CFU) per 100 milliliters (ml). Any single sample shall not exceed an E. coli count of 235 CFU per 100 ml. New water quality criteria were published in 2012 (EPA's 2012 Recreational Water Quality Criteria). The geometric mean of samples collected over a 30-day period shall not exceed 126 E. coli per 100 milliliters (ml). The statistical threshold value of 410 E. coli per 100 ml is set as the daily maximum. Since the permittee has been in substantial compliance with the existing permit limits, in accordance with 40 CFR 122.44(l) (anti-backsliding), the limits from the previous permit have been carried over into the draft permit.

Ammonia

The limits in the previous permit were meant to be protective of a LAL designated use. We used WDNR procedures and standards that were appropriate at the time the last permit was issued. WDNR has since revised its procedures and standards for calculating ammonia limits. Using this new information, we calculated new ammonia limits. The daily maximum limit remained unchanged, however, the 30-day average limits became much less stringent. The ammonia worksheet is included in the administrative record. Since the permittee has been in substantial compliance with the existing permit limits, in accordance with 40 CFR 122.44(l) (anti-backsliding), the limits from the previous permit have been carried over into the draft permit. It should be noted that we also calculated limits based on EPA's 2013 water quality criteria for

ammonia. Again, the calculated limits were much less stringent than the previous permit limits. These calculations are also in the administrative record.

Temperature

Monitoring for temperature has been included to ensure the state's thermal water quality standards are met.

Phosphorus

According to Menominee Environmental staff, the receiving waters are not impaired for phosphorus at the point of discharge. In addition, the Menominee Tribe's water quality regulations and Wisconsin's water quality standards for phosphorus are not applicable in wetlands. However, there is still concern related to excessive phosphorus loads being discharged to waters of the U.S. and its effects in downstream waters. To continue protection of the receiving stream against nuisance plant growth and ensure that Wisconsin's water quality standards for phosphorus are met at the reservation boundary, the limits in the previous permit have been carried over into the draft permit. It should also be noted that WDNR is working on a TMDL that would include this facility's discharge. Compliance with the TMDL would be voluntary for the permittee since the TMDL is not applicable to reservation waters. The draft voluntary TMDL limit would be 0.17 mg/L.

Dissolved Oxygen

A minimum dissolved oxygen discharge limit of 5.0 mg/L is included in the permit based on the Menominee Tribe's water quality regulations and is a continuation from the previous permit.

Mercury

The previous permit required quarterly monitoring of the effluent for mercury to help determine whether the permittee can meet the Menominee Tribe's fish and aquatic life water quality criterion of 12 ng/L. Insufficient data was collected and therefore, the permit will require quarterly monitoring for mercury for this permit term. A PMP for mercury is also included in the draft permit to help identify possible sources of mercury in the system if monitoring indicates that mercury is being discharged at levels of concern.

Additional Monitoring

Also, additional monitoring for Total Kjeldahl Nitrogen (TKN), Oil and Grease, Nitrate plus Nitrite Nitrogen and Total Dissolved Solids (TDS) is required for discharges with a design flow greater than 0.1 MGD. This monitoring is an application requirement of 40 CFR § 122.21(j).

Asset Management – Operation & Maintenance Plan

Regulations regarding proper operation and maintenance are found at 40 CFR § 122.41(e). These regulations require, "that the permittee shall at all times operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of the permit." The treatment plant and the collection system are included in the definition of "facilities and systems of treatment and control" and are therefore subject to the proper operation and maintenance requirements of 40 CFR § 122.41(e).

Similarly, a permittee has a “duty to mitigate” pursuant to 40 CFR §122.41(d), which requires the permittee to “take all reasonable steps to minimize or prevent any discharge in violation of the permit which has a reasonable likelihood of adversely affecting human health or the environment.”

The draft permit requirements are the first steps of an asset management program which contains goals of effective performance, adequate funding, adequate operator staffing and training. Asset management is a planning process that ensures that you get the most value from each of your assets and have the financial resources to rehabilitate and replace them when necessary, and typically includes five core elements which identify: 1) the current state of the asset; 2) the desired level of service (e.g., per the permit, or for the customer); 3) the most critical asset(s) to sustain performance; 4) the best life cycle cost; and 5) the long term funding strategy to sustain service and performance.

EPA believes that requiring a certified wastewater operator and adequate staffing is also essential to ensure that the treatment facilities will be properly operated and maintained. Mapping the collection system with the service area will help the operator better identify the assets that he/she is responsible for and consider the resources needed to properly operate and maintain them. This will help in the development of a budget and a user rate structure that is necessary to sustain the operation. The development and implementation of a proactive preventive maintenance program is one reasonable step that the permittee can take to demonstrate that it is at all times, operating and maintaining all the equipment necessary to meet the effluent limitations of the permit.

Special Conditions

- Electronic reporting is required.
- A mercury pollutant minimization plan is required if effluent concentrations are shown to be high.
- Monitoring is required for the additional pollutants as required in 40 CFR 122.21(j).
- The permit requires the development and implementation of an Operation & Maintenance Plan. The plan covers the use of a certified operator to oversee the facility, having adequate staff to help ensure compliance with the permit, mapping the treatment system, developing a preventive maintenance program and other items.
- The permit contains Industrial Waste Pretreatment Program requirements in accordance with 40 CFR Parts 122 and 403.
- The draft permit contains requirements related to sludge disposal in accordance with 40 CFR parts 122 and 503. It is not expected that sewage sludge will be used or disposed of during the permit term. The permit does require annual reporting of sludge taken to the Keshena Lagoons and a one-time sampling event for metals and PCBs.
- Approval must be given before a discharge from the lagoon system can occur.

Significant Changes from the Last Permit

Following are the significant changes in the draft permit:

- Added ‘Summary of Regular Reporting’.
- Added temperature monitoring of the effluent. (Part I.A.1)
- The Reporting requirement has been changed to require electronic submittal of DMRs.

(Part I.B.2)

- Additional requirements related to Asset Management have been added. (Part I.B.3)
- The 'Sludge Disposal Requirements' have been updated including metals and PCBs monitoring. (Part I.B.5)
- Part III has been added.

The permit is based on an application with a received date of February 10, 2017, and additional supporting documents found in the administrative record.

The permit will be effective for approximately five years from the date of reissuance as allowed by 40 CFR 122.46.

Written by: John Colletti
U.S. EPA, Region 5, WN-15J
77 West Jackson Blvd.
Chicago, IL 60604
(312) 886-6106

June 2018