

ATTACHMENT
AQUIFER RECHARGE AND AQUIFER STORAGE AND RECOVERY
BASELINE PARAMETER LIST

List of constituents to be analyzed for baseline evaluations

Note: All analytical testing must be done in a state certified laboratory to ensure that permit limits can be met.

General

Parameter Name	Regulatory Limit (mg/l) or specified unit	Standard Type	Analytical Methods
pH	6.5 – 8.5	secondary	150.1
Ambient Temperature			
Electricity Conductivity			SM 2510B, 120.1
Total Dissolved Solids	500	secondary	
Total Organic Carbon			
Alkalinity, Total	Mg/l as CaCO ₃	0.006	

Anions

Parameter Name	Regulatory Limit (mg/l) or specified unit	Standard Type	Analytical Methods
Aluminum	200 ug/l		
Carbonate			SM 2330B
Chloride	250	secondary	
Cyanide	0.2	MCL	EPA 335.4
Nitrate (as N)	10	MCL	353.2
Nitrite (as N)	1	MCL	353.2
Nitrate-Nitrite (both as N)			
Bicarbonate			SM2330B
Sulfate	250	secondary	
Fluoride	4	MCL	SM4500-F C

Cations

Parameter Name	Regulatory Limit (mg/l) or specified unit	Standard Type	Analytical Methods
Ammonia	30 mg/l	HA - Lifetime	EPA 350.1, 350.2, 350.3
Calcium			
Magnesium			
Potassium			
Sodium			

Metals

Parameter Name	Regulatory Limit (mg/L)	Standard Type	Analytical Methods
Asbestos (fibers/1>10 um in length)	7 million fibers/L	MCL	EPA 100.1, 100.2

Parameter Name	Regulatory Limit (mg/L)	Standard Type	Analytical Methods
Antimony	0.006	MCL	EPA 200.8, 200.9
Arsenic	0.01	MCL	EPA 200.7, 200.8, 200.9
Barium	2	MCL	EPA 200.7, 200.8
Beryllium	0.004	MCL	EPA 200.7, 200.8, 200.9
Boron	6	HA-Lifetime	EPA 200.7, 212.3
Cadmium	0.005	MCL	EPA 200.7, 200.8, 200.9
Chromium (total)	0.1	MCL	EPA 200.7, 200.8, 200.9
Copper	1.3	MCL-TT	EPA 200.7, 200.8, 200.9
Iron	5	Region 8 Permit Limit	EPA 200.7, 200.9
Lead	0.015	MCL-TT	EPA 200.8, 200.9
Manganese	0.3	HA-Lifetime	EPA 200.7, 200.8, 200.9
Mercury (inorganic)	0.002	MCL	EPA 245.1, 245.2, 200.8
Molybdenum	0.04	HA-Lifetime	EPA 200.7, 246.1, 246.2
Nickel	0.1	HA-Lifetime	EPA 200.7, 200.8, 200.9
Selenium	0.05	MCL	EPA 200.8, 200.9
Silver	0.1	HA-Lifetime	EPA 200.7, 200.8, 200.9
Strontium	4	HA-Lifetime	EPA 272.1, 272.2, 200.7
Thallium	0.002	MCL	EPA 200.8, 200.9
Zinc	2	HA-Lifetime	EPA 200.7, 200.8

Inorganics

Parameter Name	Regulatory Limit (mg/l) or specified unit	Standard Type	Analytical Methods
Ammonia	30 mg/L	HA-Lifetime	EPA 350.1, 350.2, 350.3
Asbestos (fibers/1>10µm in length)	7 million fibers/L	MCL	EPA 100.1,100.2
Cyanide	0.2 mg/L	MCL	EPA 335.4
Fluoride	4 mg/L	MCL	EPA 300.0
Nitrate (as N)	10 mg/L	MCL	EPA 300.0
Nitrate-Nitrite (both as N)	10 mg/L	MCL	EPA 300.0
Nitrite (as N)	1 mg/L	MCL	EPA 300.0

Radionuclides

Parameter Name	Regulatory Limit (mg/l) or specified unit	Standard Type	Analytical Methods
Radium 226 & 228 combined	5 pCi/L	MCL	Standard Method 304
Gross alpha particle activity (excluding Ra-226, radon, and uranium)	15 pCi/L	MCL	EPA 900.0
Uranium	0.03 mg/L	MCL	EPA 908.0, 908.1

Volatile Organics using EPA Method 524.2 or 8260

Parameter Name	CAS No	Regulatory Limit (mg/l) or specified unit	Standard Type
1,1,1,2-Tetrachloroethane	630-20-6	0.07	HA-Lifetime
1,1,1-Trichloroethane	71-55-6	0.2	MCL
1,1,2,2-Tetrachloroethane	79-34-5	0.04	Region 8 Permit Limit 10 ⁻⁴ Cancer Risk
1,1,2-Trichloroethane	79-00-5	0.005	MCL
1,1-Dichloroethylene	75-35-4	0.007	MCL
1,2-(cis)Dichloroethylene	156-59-2	0.07	MCL
1,2-(trans)Dichloroethylene	156-60-5	0.1	MCL
1,2,3-Trichloropropane	96-18-4	0.02	Region 8 Permit Limit
1,2,4-Trichlorobenzene	120-82-1	0.07	MCL
1,2-Dibromomethane (Ethylene Dibromide EDB)	106-93-4	0.00005	MCL
1,2-Dichlorobenzene o-	95-50-1	0.6	MCL
1,2-Dichloroethane	107-06-2	0.005	MCL
1,2-Dichloropropane	78-87-5	0.005	MCL
1,3-Dichlorobenzene m-	541-73-1	0.6	HA-Lifetime
1,4-Dichlorobenzene p-	106-46-7	0.075	MCL
2-Chlorotoluene (o-)	95-49-8	0.1	HA-Lifetime
4-Chlorotoluene (p-)	106-43-4	0.1	HA-Lifetime
Acetone	67-64-1	6	Region 8 Permit Limit
Acrylonitrile	107-13-1	0.006	Region 8 Permit Limit 10 ⁻⁴ Cancer Risk
Benzene	71-43-2	0.005	MCL
Bromobenzene	108-86-1	0.06	HA-Lifetime
Bromochloromethane	74-97-5	0.09	HA-Lifetime
Bromodichloromethane (THM)	75-27-4	0.02	Region 8 Permit Limit
Bromoform (THM)	75-25-2	0.2	Region 8 Permit Limit

Parameter Name	CAS No	Regulatory Limit (mg/l) or specified unit	Standard Type
Bromomethane	74-83-9	0.01	HA-Lifetime
Carbon tetrachloride	56-23-5	0.005	MCL
Chlorobenzene (Monochlorobenzene)	108-90-7	0.1	MCL
Chlorodibromomethane (Dibromochloromethane) (THM)	124-48-1	0.06	HA-Lifetime
Chloroform (THM)	67-66-3	0.07	HA-Lifetime
Chloromethane	74-87-3	0.4	10-day HA for a 10 kg child
Cyanogen Chloride (testing not needed if cyanide is present in source water and alkaline chlorination is used, pH 8.5)	506-77-4	0.4	Region 8 Permit Limit
Dichlorodifluoromethane	75-71-8	1	HA-Lifetime
Dichloromethane (Methylene chloride)	75-09-2	0.005	MCL
Ethylbenzene	100-41-4	0.7	MCL
Hexachlorobutadiene	87-68-3	0.002	Region 8 Permit Limit
Hexachloroethane	67-72-1	0.001	HA-Lifetime
Isopropylbenzene (cumene)	98-82-8	0.8	Region 8 Permit Limit
Methyl Ethyl Ketone	78-93-3	4	HA-Lifetime
Naphthalene	91-20-3	0.1	HA-Lifetime
Perchloroethylene (PCE) (Tetrachloroethylene)	127-18-4	0.005	MCL
Styrene	100-42-5	0.1	MCL
Toluene	108-88-3	1	MCL
Total Trihalomethanes		0.08	MCL
Trichloroethylene (TCE)	79-01-6	0.005	MCL
Trichlorofluoromethane	75-69-4	2	HA-Lifetime
Vinyl chloride	75-01-4	0.002	MCL
Total Xylenes	1330-20-7	10	MCL

Semi-volatile Organics using EPA Method 525.2

Parameter Name	CAS No	Regulatory Limit (mg/l) or specified unit	Standard Type
1,2,4-Trichlorobenzene	120-82-1	0.07	MCL
1,2-Dichlorobenzene	95-50-1	0.6	MCL
1,3-Dichlorobenzene	541-73-1	0.6	HAL
1,4-Dichlorobenzene	106-46-7	0.075	MCL
2,4,6-Trichlorophenol	88-06-2	0.002	Region 8 Permit Limit
2,4-Dichlorophenol	120-83-2	0.02	HA-Lifetime
2,4-Dinitrotoluene	121-14-2	0.005	Region 8 Permit Limit

Parameter Name	CAS No	Regulatory Limit (mg/l) or specified unit	Standard Type
			10 ⁻⁴ Cancer Risk
2,6-Dinitrotoluene	606-20-2	0.005	Region 8 Permit Limit 10 ⁻⁴ Cancer Risk
2-Chlorophenol	95-57-8	0.04	HA-Lifetime
4-Nitrophenol	100-02-7	0.06	HA-Lifetime
Acenaphthene	83-32-9	0.4	Region 8 Permit Limit
Aldrin	309-00-2	0.0002	Region 8 Permit Limit 10 ⁻⁴ Cancer Risk
Anthracene	120-12-7	2	Region 8 Permit Limit
Benzo(a)pyrene	50-32-8	0.0002	MCL
bis(2-Ethylhexyl) phthalate	117-81-7	0.006	MCL
Butyl benzyl phthalate	85-68-7	1	Region 8 Permit Limit
Chlordane	57-74-9	0.002	MCL
Dieldrin	60-57-1	0.0002	Region 8 Permit Limit 10 ⁻⁴ Cancer Risk
Diethyl phthalate	84-66-2	6	Region 8 Permit Limit
Di-n-butyl phthalate	84-74-2	0.8	Region 8 Permit Limit
Endrin	72-20-8	0.002	MCL
Fluorene	86-73-7	0.2	Region 8 Permit Limit
Heptachlor	76-44-8	0.0004	MCL
Heptachlor epoxide	1024-57-3	0.0002	MCL
Hexachlorobenzene	118-74-1	0.001	MCL
Hexachlorobutadiene	87-68-3	0.002	Region 8 Permit Limit
Hexachlorocyclopentadiene	77-47-4	0.05	MCL
Hexachloroethane	67-72-1	0.001	HA-Lifetime
Isophorone	78-59-1	0.1	HA-Lifetime
Lindane	58-89-9	0.0002	MCL
Naphthalene	91-20-3	0.1	HA-Lifetime
Pentachlorophenol	87-86-5	0.001	MCL
Phenol	108-95-2	2	HA-Lifetime
Pyrene	129-00-0	0.2	Region 8 Permit Limit
Toxaphene	8001-35-2	0.003	MCL

Pesticides and Herbicides

Parameter Name	CAS No	Regulatory Limit (mg/l) or specified unit	Standard Type	Analytical Methods
Alachlor	15972-60-8	0.002	MCL	EPA 505, 507, 525
Aldicarb	116-06-03	0.003	MCL	EPA 531.1
Aldicarb sulfone	1646-87-4	0.002	MCL	EPA 531.1
Aldicarb sulfoxide	1646-87-3	0.004	MCL	EPA 531.1
Aldrin	309-00-2	0.0002	Region 8 Permit Limit 10 ⁻⁴ Cancer Risk	EPA 505, 508
Ametryn	834-12-8	0.06	HA-Lifetime	EPA 507
Atrazine	1912-24-9	0.003	MCL	EPA 505, 507
Bromacil	314-40-9	0.07	HA-Lifetime	EPA 507
Butylate	2008-41-5	0.4	HA-Lifetime	EPA 507
Carbaryl	63-25-2	0.08	Region 8 Permit Limit	EPA 531.1
Carbofuran	1563-66-2	0.04	MCL	EPA 531.1
Carboxin	5234-68-4	0.7	HA-Lifetime	EPA 507
Chlordane	57-74-9	0.002	MCL	EPA 505, 508, 525
Chlorothalonil	1897-45-6	0.1	Region 8 Permit Limit	EPA 508
DCPA (Dactyl)	1861-32-1	0.07	HA-Lifetime	EPA 508
Diazinon	333-41-5	0.001	HA-Lifetime	EPA 507
Dieldrin	60-57-1	0.0002	Region 8 Permit Limit 10 ⁻⁴ Cancer Risk	EPA 505, 508
Diphenamid	957-51-7	0.2	HA-Lifetime	EPA 507
Disulfoton	298-04-4	0.0007	HA-Lifetime	EPA 507
Endrin	72-20-8	0.002	MCL	EPA 505, 508, 525.1
Fenamiphos	22224-92-6	0.0007	HA-Lifetime	EPA 507
Heptachlor	76-44-8	0.0004	MCL	EPA 505, 508
Heptachlor epoxide	1024-57-3	0.0002	MCL	EPA 505, 508
Hexachlorobenzene	118-74-1	0.001	MCL	EPA 505, 508, 525.1
Hexachlorocyclopentadiene	77-47-4	0.05	MCL	EPA 505, 525.1
Hexazinone	51235-04-2	0.4	HA-Lifetime	EPA 507
Lindane	58-89-9	0.0002	MCL	EPA 505, 508
Methomyl	16752-77-5	0.2	HA-Lifetime	EPA 531.1
Methoxychlor	72-43-5	0.04	MCL	EPA 505, 508, 525
Metolachlor	51218-45-2	0.7	HA-Lifetime	EPA 507
Metribuzin	21087-64-9	0.07	HA-Lifetime	EPA 507
Oxamyl (Vydate)	23135-22-0	0.007	MCL	EPA 531.1
Prometon	1610-18-0	0.4	HA-Lifetime	EPA 507
Pronamide	23950-58-5	0.1	Region 8 Permit Limit 10 ⁻⁴ Cancer Risk	EPA 507
Propachlor	1918-16-7	0.1	Region 8 Permit Limit 10 ⁻⁴ Cancer Risk	EPA 508

Parameter Name	CAS No	Regulatory Limit (mg/l) or specified unit	Standard Type	Analytical Methods
Propazine	139-40-2	0.01	HA-Lifetime	EPA 507
Simazine	122-34-9	0.004	MCL	EPA 505, 507, 525.1
Tebuthiuron	34014-18-1	0.5	HA-Lifetime	EPA 507
Terbacil	5902-51-2	0.09	HA-Lifetime	EPA 507
Terbufos	13071-79-9	0.0004	HA-Lifetime	EPA 507
Trifluralin	1582-09-8	0.01	HA-Lifetime	EPA 508

Disinfectants and Disinfection Byproducts

Parameter Name	Regulatory Limit (mg/l) or specified unit	Standard Type	Analytical Method
Bromate	0.01	MCL	EPA 317.0, Revision 2 321.8, 326.0
Chloramine (as free chlorine)	4	MCL	
Chlorine (free chlorine, combined)	4	MCL	Standard Methods 20 th edition: 4500-Cl D 4500-Cl F 4500-Cl G 4500-Cl H
Chlorine dioxide	0.8	MCL	EPA 327, Revision 1 Standard Method 20 th edition: 4500-ClO ₂ D 4500-ClO ₂ E
Chlorite	1.0	MCL	EPA 300.0, 300.1
Total Haloacetic Acids (HAA5s) Bromoacetic acid Dibromoacetic acid Dichloroacetic acid Monochloroacetic acid Trichloroacetic acid	0.06	MCL	EPA 552.3
Total Trihalomethanes (TTHMs) Chloroform Bromodichloromethane Dibromochloromethane Bromoform	0.08	MCL	EPA 502.2, 524.2
N-nitroso-dimethylamine (NDMA)	NA		EPA 521
N-nitroso-diethylamine (NDEA)	NA		EPA 521
N-nitroso-di-n-butylamine (NDBA)	NA		EPA 521
N-nitroso-di-n-propylamine (NDPA)	NA		EPA 521
N-nitroso-methylethylamine (NMEA)	NA		EPA 521
N-nitroso-pyrrolidine (NPYR)	NA		EPA 521

MCL: Maximum Contaminant Level. The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLG as feasible using the best available analytical and treatment technologies and taking cost into consideration. MCLs are enforceable standards.

MCLG: Maximum Contaminant Level Goal. A non-enforceable health goal which is set at a level at which no known or anticipated adverse effect on the health of persons occurs and which allows an adequate margin of safety.

TT: Treatment Technique. A required process intended to reduce the level of a contaminant in drinking water.

HA: Health Advisory. An estimate of acceptable drinking water levels for a chemical substance based on health effects information; a Health Advisory is not a legally enforceable Federal standard, but serves as technical guidance to assist Federal, State, and local officials.

HA-Lifetime: The concentration of a chemical in drinking water that is not expected to cause any adverse non-carcinogenic effects for a lifetime of exposure. The Lifetime HA is based on exposure of a 70-kg adult consuming 2 liters of water per day. The Lifetime HA for Group C carcinogens includes an adjustment for possible carcinogenicity.

Region 8 Permit Limit: Permit limit calculated by Region 8 Drinking Water Toxicologist based on human health criteria.

10⁻⁴ Cancer Risk: The concentration of a chemical in drinking water corresponding to an excess estimated lifetime cancer risk of 1 in 10,000

HA-Ten Day: The concentration of a chemical in drinking water that is not expected to cause any adverse non-carcinogenic effects for up to ten days of exposure for a 10 kg child consuming 1 liter per day.