

NPDES authorization to discharge to waters of the United States, Permit No. TX0005886

The applicant's mailing address is:

ONEOK Hydrocarbons Southwest, L.L.C.
P.O. Box 550
Mont Belvieu, TX 77580

The discharges from this facility are as described in the table below:

Outfall Reference Number	Discharge Coordinates: Latitude Deg° Min' Sec" Longitude Deg° Min' Sec"	Type of Discharge	Maximum Discharge Rate (MGD)	Receiving Water	Water Body Segment
001	29° 50' 55" N 94° 56' 48.52" W	Cooling, backwash, fire protection and equipment washdown water	0.246	Cedar Bayou above Tidal	0902 of the Trinity-San Jacinto River Basin
002	29° 51' 22.99" N 94° 54' 34.64" W	Stormwater runoff and hydrostatic test water	0.108	Cedar Bayou above Tidal	0902 of the Trinity-San Jacinto River Basin

Under the Standard Industrial Classification (SIC) Code No. 1321, the applicant operates a natural gas liquids plant. The facility processes and fractionates natural gas feedstock into ethane, butane, propane and natural gasoline. Gulf Coast Fractionators supplies water for the facility. The supplied water is used for cooling, equipment washdown and fire protection. Backwash water from the filter system is routed to settling tanks to remove solids and then discharge through Outfall 001 to Cedar Bayou above Tidal. Equipment washdown and blowdown from cooling towers and heat exchangers are also discharged to this outfall. Meanwhile, intermittent hydrostatic test water, stormwater runoff (MSGP permit #TXR05J330), and fire water are discharged through Outfall 002 to an unnamed ditch thence to Cedar Bayou above Tidal.

This is a permit reissuance.

A fact sheet is available.