STATEMENT OF BASIS

FOR THE REISSUANCE OF A NPDES PERMIT

U.S. Environmental Protection Agency Region 5, Permits Branch - WP-16J 77 West Jackson Boulevard Chicago, Illinois 60604 (312) 886-6106

Public Notice No.: 20-07-02-A

Public Notice Issued On: July 17, 2020 Comment Period Ends: August 17, 2020

Permit No.: MN-0064688-5 (REISSUANCE) Application No.: MN-0064688-5

Name and Address of Applicant:

Name and Address of Facility
Where Discharge Occurs:

City of Bejou P.O. Box 2098 Bejou, Minnesota 56516 City of Bejou WWTF Bejou, Minnesota 56516 Mahnomen County (NW ¼ of SE ¼ of S22, T146N, R42W)

Receiving Water: Marsh Creek, also known as Judicial Ditch # 91, and eventually the Wild Rice River.

Description of Applicant's Facility and Discharge

The above named applicant has applied for an NPDES Permit to discharge into the designated receiving water. The facility is located within the boundaries of the White Earth Indian Reservation. The U.S. Environmental Protection Agency has retained the authority to issue NPDES permits to facilities with discharges to waters of the United States within Indian Country. The permit will be issued by the EPA under the authorities of the Clean Water Act.

The application and plans indicate that the existing wastewater treatment system consists of two lift stations, approximately 2150 feet of 5-inch and 140 feet of 4-inch force main, and a 2-cell stabilization pond system.


The facility has a controlled discharge (discharge 001) to Marsh Creek, also known as Judicial Ditch # 91. The facility is designed to treat an average wet weather influent flow of 17,700 gallons per day (gpd) with five-day biochemical oxygen demand (BOD₅) strength of 144.0 milligrams per liter (mg/L). The primary cell has a surface area of approximately 1.83 acres at an average operating depth of 4 feet. The secondary cell has a surface area of approximately 0.92 acres. The pond system has a total detention time of approximately 200 days.

The facility is further described in plans and specifications on file with the Minnesota Pollution Control Agency and in an engineering report by the firm of Ulteig Engineers, Inc. (formerly Larson-Peterson and Associates, Inc.), Detroit Lakes, Minnesota. Wastewater is from domestic sources only. The facility is rated as a Class D under Minnesota regulations.

The permittee does not plan to remove any solids from the pond during the permit term.

Topographic Map of Permitted Facility

MNT064688:Bejou Wastewater Treatment Facility T145N, R42W, Section 22 Bejou, Mahnomen County, Minnesota



Proposed Effluent Limitations:

Outfall 001- the permittee is authorized to discharge treated municipal wastewater from Outfall 001. Outfall 001 discharges to Marsh Creek.

	Date	Monthly average	Weekly	Daily Maximum	Daily	
Parameter			Average		Minimum	Comments
Flow	All year	Report	Report			PWJ
Carbonaceous	All Year	25 mg/L	40 mg/L			STS
Biochemical Oxygen						
Demand (CBOD ₅)						
Total Suspended Solids	All Year	45 mg/L	65 mg/L			STS
Ammonia Nitrogen, Total (as N) (mg/L)	All Year	Report				WQC
Nitrite Plus Nitrate, Total (as N) (mg/L)	All Year	Report				WQC
Nitrogen, Kjeldahl, Total	All Year	Report				WQC
Nitrogen, Total (as N) (mg/L)	All Year	Report				WQC
Dissolved Oxygen	All Year				Report	PWJ
E.coli	April 1 – October 31	126 E. coli/100 ml (geometric mean)		410 E. coli/100 ml		WQS
Total Phosphorus	All Year	Report				WQC
pH	All Year			9.0 S.U.	6.0 S.U.	STS

Loading limits in the permit were calculated using the following formula based on the design flow:

 $0.92~acres~*~(3.259~*~10^5~gallons/acre/foot)~*~0.5ft/d = 0.15~mgd$

0.15 mgd x limit (mg/l) x 3.78 = Loading (kgs/d).

Comment Key

WQS – Water Quality Standards

WQC – Water Quality Concern

STS – Secondary Treatment Standards (40 CFR part 133)

PWJ – Permit Writer's Judgment

Basis for Permit Requirements

The limits were developed to ensure compliance with 40 CFR Parts 131 and 133 and protection of human health and EPA's water quality criteria, and protection of Minnesota's WQS where they are applicable. Though not applicable at the point of discharge, the receiving water (Marsh Creek) would be classified by the state as Class 2C, 3C, 4A, 4B, 5, and 6 Water. It should be noted that the Minnesota Pollution Control Agency has also issued a State Disposal System permit to this facility. EPA's draft permit is consistent with the MPCA permit. Information developed by MPCA supporting their permit was also used by EPA in the development of this

draft permit and can be found in the Administrative Record.

<u>рН</u>

The limits for pH are based on secondary treatment standards pursuant 40 CFR 133. Monitoring indicates the permittee is in substantial compliance with the limits.

5-day Carbonaceous Biochemical Oxygen Demand (CBOD₅)

The limits for CBOD₅ are based on secondary treatment requirements pursuant to 40 CFR Part 133. A weekly average limit of 40 mg/L and a monthly average limit of 25 mg/L are carried from the previous permit. The permittee has been in substantial compliance with these limits. The weekly average and the monthly average are the arithmetic mean of pollutant parameter values for samples collected in a period of 7 and 30 consecutive days, respectively. We believe the limits are protective of Minnesota's dissolved oxygen standard at the boundary of the reservation.

Total Suspended Solids (TSS)

The limits for TSS are based on secondary treatment requirements pursuant to 40 CFR Part 133. A weekly average limit of 65 mg/L and a monthly average limit of 45 mg/L are carried from the previous permit. The permittee has been in substantial compliance with these limits. The weekly average and the monthly average are the arithmetic mean of pollutant parameter values for samples collected in a period of 7 and 30 consecutive days, respectively.

Wild Rice River Watershed Turbidity Total Maximum Daily Load (TMDL) Study: To address water quality impairments, a TMDL study of the Wild Rice River Watershed was conducted. The Facility was assigned a wasteload allocation (WLA) of 57.2 pounds per day for Total Suspended Solids (TSS). The existing Facility's permit includes a mass loading limit for TSS of 26 kilograms per day which is essentially equivalent to the WLA. Information related to the study can be found at http://www.pca.state.mn.us/index.php/water/water-types-and-programs/minnesotas-impaired-waters-and-tmdls/tmdl-projects/red-river-basin-tmdl/project-lower-wild-rice-river-turbidity.html .

Dissolve Oxygen (DO)

Monitoring for dissolved oxygen is carried over from the previous permit as we believe it is still appropriate. There are no water quality criteria applicable at the point of discharge.

E. coli

The limits for E. coli are based on the EPA's 2012 Recreational Water Quality Criteria. The geometric mean of samples collected over a 30-day period shall not exceed 126 E. coli per 100 milliliters (ml). The statistical threshold value of 410 E. coli per 100 ml is set as the daily maximum. The limits are applicable April through October. Monitoring indicates the permittee is in substantial compliance with the limits.

Phosphorus

Phosphorus is a common constituent in many wastewater discharges and a pollutant that has the potential to negatively impact the quality of Minnesota's lakes, wetlands, rivers, and streams. Phosphorus promotes algae and aquatic plant growth often resulting in decreased water clarity and oxygen levels. In addition to creating general aesthetic problems, these conditions can also

impact a water body's ability to support healthy fish and other aquatic species. Therefore, phosphorus discharges are being carefully evaluated throughout the state.

In the development of the State SDS permit, MPCA did a phosphorus review to determine the need for limits in the SDS permit (Total phosphorus effluent limit review: Wild Rice River Watershed; Liz Kaufenberg, Effluent Limits Unit, Environmental Analysis and Outcomes Division; 7/1/2015). It was determined that the River Eutrophication Standards are not being violated and that there is no reasonable potential that the discharge will cause or contribute to a violation. EPA agrees with the analysis and no limits have been included in the permit. Also, a recent load duration curve (Ogema and Bejou_2003-2020) indicates that under low flow conditions when point sources are dominant, the Eutrophication Standard should be met under current conditions. Monitoring is still required as the information will be used with the Phosphorus Management Plan required below.

The permittee is also required to implement and update as necessary its Phosphorus Management Plan (PMP). While the PMP does not require specific reductions at this time, the EPA strongly encourages you to identify and eliminate/reduce sources of phosphorus to, and improve phosphorus management within, your wastewater treatment facility.

Nitrogen

Nitrogen is a pollutant that can negatively impact the quality of Minnesota's water resources, including water used for drinking. Studies have shown that nitrogen in lakes and streams has a toxic effect on aquatic life such as fish. Like phosphorus, nitrogen is a nutrient that promotes algae and aquatic plant growth often resulting in decreased water clarity and oxygen levels. In 2014 the MPCA completed a Statewide Nutrient Reduction Strategy (http://www.pca.state.mn.us/zihy1146) which identifies goals and milestones for nitrogen reductions for both point and non-point nitrogen sources within Minnesota. To gain a better understanding of the current nitrogen concentrations and loadings received by and discharged from your facility additional influent and effluent nitrogen monitoring has been added to the permit. The permit includes influent and effluent monitoring for Ammonia Nitrogen, Nitrite plus Nitrate-Nitrogen, Total Kjeldahl Nitrogen, and Total Nitrogen at a frequency of twice per year for the five-year term of the permit. There is no nitrogen limit in the permit.

Asset Management - Operation & Maintenance Plan

Regulations regarding proper operation and maintenance are found at 40 CFR § 122.41(e). These regulations require, "that the permittee shall at all times operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of the permit." The treatment plant and the collection system are included in the definition of "facilities and systems of treatment and control" and are therefore subject to the proper operation and maintenance requirements of 40 CFR § 122.41(e).

Similarly, a permittee has a "duty to mitigate" pursuant to 40 CFR §122.41(d), which requires the permittee to "take all reasonable steps to minimize or prevent any discharge in violation of the permit which has a reasonable likelihood of adversely affecting human health or the environment."

The draft permit requirements are the first steps of an asset management program which contains goals of effective performance, adequate funding, adequate operator staffing and training. Asset management is a planning process that ensures that you get the most value from each of your assets and have the financial resources to rehabilitate and replace them when necessary, and typically includes five core elements which identify: 1) the current state of the asset; 2) the desired level of service (e.g., per the permit, or for the customer); 3) the most critical asset(s) to sustain performance; 4) the best life cycle cost; and 5) the long term funding strategy to sustain service and performance.

EPA believes that requiring a certified wastewater operator and adequate staffing is also essential to ensure that the treatment facilities will be properly operated and maintained. Mapping the collection system with the service area will help the operator better identify the assets that he/she is responsible for and consider the resources needed to properly operate and maintain them. This will help in the development of a budget and a user rate structure that is necessary to sustain the operation. The development and implementation of a proactive preventive maintenance program is one reasonable step that the permittee can take to minimize or prevent a discharge in violation of the permit.

Special Conditions

- The permit requires the continued implementation of an Operation & Maintenance Plan. The plan covers the use of a certified operator (at least Minnesota Class D) to oversee the facility, having adequate staff to help ensure compliance with the permit, mapping the treatment system, developing a preventive maintenance program and other items.
- O Dikes must be maintained and vegetation cut.
- o Implement and update a Phosphorus Management Plan.
- The permit contains Industrial Waste Pretreatment Program requirements in accordance with 40 CFR Parts 122 and 403.
- Compliance with 40 CFR Part 503 (sludge use and disposal regulations). These requirements were developed using the Part 503 Implementation Guidance for sludge and 40 CFR Parts 122, 501, and 503. It is not expected that any sludge will be used or disposed of during this permit term. EPA is to be contacted if sewage sludge is to be removed from the pond system.

Significant Changes from the Previous Permit

The draft permit contains the following changes from the last issued permit:

- 1. Changes to EPA Region 5 mailing addresses have been made throughout the permit.
- 2. The 'Summary of Regular Reporting' has been updated. (Page 2)
- 3. The Reporting requirement has been changed to require electronic submittal of DMRs. (Part I.E.2)
- 4. Additional requirements related to Asset Management have been added. (Part I.E.5)
- 5. Updated Phosphorus Management Plan requirements. (Part I.E.6)
- 6. The "Standard Conditions" have been revised (Part II).

Permit No. MN-0064688-5 Page - 7

The permit is based on NPDES applications received on March 13, 2020 and additional application information dated June 5, 2020 (complete application) and additional documents found in the administrative record.

This permit will be effective for approximately five years from the date of issuance as allowed by regulation.

Written By: John Colletti

U.S. EPA, Region 5, WP-16J 77 West Jackson Blvd. Chicago, IL 60604 (312) 886-6106 July 2020