

# **Session 3: PFAS Treatment in Drinking Water and Wastewater – State of the Science**

Thomas Speth, PhD, PE  
US EPA Office of Research and Development

**PFAS Science Webinars for EPA Region 1 and State & Tribal Partners**

**September 16, 2020**

## Drinking Water

- Overview
- Treatment
- Cost
- Residual streams

## Wastewater

- Overview
- Treatment (*Residual streams and other materials to be covered on Sept. 23*)





# EPA's PFAS Drinking Water Research

**Problem:** Utilities lack treatment technology cost data for PFAS removal

**Actions:**

- Gather performance and cost data from available sources (DOD, utilities, industry, etc.)
- Conduct EPA research on performance of treatment technologies including home treatment systems
- Update [EPA's Treatability Database](#), [Treatment Models and Unit Cost Models](#)
- Connect EPA's Treatability Database to EPA's Unit Cost Models for ease of operation
- Model performance and cost, and then extrapolate to other scenarios
- Address treatment impact on corrosion
- Evaluate reactivation and incineration of spent granular activated carbon and incineration of spent ion exchange resins

**Impact:** *Enable utilities to make informed decisions about cost-effective treatment strategies for removing PFAS from drinking water*

## Model Scenarios

- Variable source waters
- Variable PFAS concentrations in source water
- Alternate treatment goals
- Changing production rates
- Document secondary benefits
- Different reactivation/disposal options



# Suite of Tools

## To provide tools to accurately predict the performance and cost of treating PFAS in drinking waters

### Treatability Database

United States Environmental Protection Agency

Environmental Topics    Laws & Regulations    About EPA    Search EPA.gov

Related Topics: [Water Research](#)    CONTACT US    SHARE         

## Drinking Water Treatability Database (TDB)

*Provides information on the control of contaminants*

EPA's [Drinking Water Treatability Database \(TDB\)](#) is an easy to use tool that provides referenced information on the control of contaminants in drinking water. It was designed for use by utilities, first responders to spills or emergencies, consultants and technical assistance providers, treatment process designers, and researchers.

Information in the TDB is gathered from thousands of literature sources and assembled on one site. Information is available for over 70 regulated and unregulated contaminants and more than 30 treatment processes.

[Navigating the TDB](#)    [Capabilities](#)    [Future Updates](#)    [Support](#)

Quick Start

- [Find a Contaminant](#)
- [Find a Treatment Process](#)

### Cost Models

United States Environmental Protection Agency

Environmental Topics    Laws & Regulations    About EPA    Search EPA.gov

Related Topics: [Safe Drinking Water Act](#)    CONTACT US    SHARE         

## Drinking Water Treatment Technology Unit Cost Models and Overview of Technologies

### Drinking Water Treatment Technology Unit Cost Models

and executive orders require EPA to estimate compliance costs for new drinking water standards. The three major components of these costs are:

nt

ng

erative costs

Technologies remove or destroy pollutants (such as arsenic, disinfection byproducts, and waterborne pathogens).

treatment costs, EPA developed several engineering models using a bottom-up approach known as work breakdown structure (WBS) models:

### Performance Models

United States Environmental Protection Agency

Environmental Topics    Laws & Regulations    About EPA    Search EPA.gov

Related Topics: [Water Research](#)    CONTACT US    SHARE         

## Environmental Technologies Design Option Tool (ETDOT)

*Adsorption treatment modeling for contaminant removal from drinking water and wastewater*

The Environmental Technologies Design Option Tool (ETDOT) is a suite of software models that provides engineers with the capability to evaluate and design systems that use granular activated carbon or ion exchange resins for the removal of contaminants, including PFAS, from drinking water and wastewater.

Access ETDOT

Access the ETDOT software, manuals, and more at [ETDOT GitHub site](#).    [EXIT](#)

[Suite of Models](#)    [Compatibility](#)    [Applications](#)    [Related EPA Resources](#)

### Suite of Models

ETDOT was developed by National Center for Clean Industrial and Treatment Technologies at Michigan Technological University (MTU). In 2019, EPA signed an agreement with MTU to make this suite of adsorption models available to the public at no cost.



# Suite of Tools

## To provide tools to accurately predict the performance and cost of treating PFAS in drinking waters

### Treatability Database

The screenshot shows the EPA website's navigation bar with 'Environmental Topics', 'Laws & Regulations', and 'About EPA'. Below the search bar, 'Related Topics: Water Research' is displayed. The main heading is 'Drinking Water Treatability Database (TDB)'. A sub-heading reads 'Provides information on the control of contaminants'. A 'Quick Start' section lists 'Find a Contaminant' and 'Find a Treatment Process'. A description states: 'EPA's Drinking Water Treatability Database (TDB) is an easy to use tool that provides referenced information on the control of contaminants in drinking water. It was designed for use by utilities, first responders to spills or emergencies, consultants and technical assistance providers, treatment process designers, and researchers. Information in the TDB is gathered from thousands of literature sources and assembled on one site. Information is available for over 70 regulated and unregulated contaminants and more than 30 treatment processes.' Navigation buttons include 'Navigating the TDB', 'Capabilities', 'Future Updates', and 'Support'.

### Cost Models

The screenshot shows the EPA website's navigation bar. Below the search bar, 'Related Topics: Safe Drinking Water Act' is displayed. The main heading is 'Drinking Water Treatment Technology Unit Cost Models and Overview of Technologies'. A sub-heading reads 'Drinking Water Treatment Technology Unit Cost Models'. A description states: '...and executive orders require EPA to estimate compliance costs for new drinking water standards. The three major components of these costs are: ...nt ...ng ...ative costs ...chnologies remove or destroy pollutants (such as arsenic, disinfection byproducts, and waterborne pathogens). ...reatment costs, EPA developed several engineering models using a bottom-up approach known as work breakdown structure (WBS) models: ...'

### Performance Models

The screenshot shows the EPA website's navigation bar. Below the search bar, 'Related Topics: Water Research' is displayed. The main heading is 'Environmental Technologies Design Option Tool (ETDOT)'. A sub-heading reads 'Adsorption treatment modeling for contaminant removal from drinking water and wastewater'. A description states: 'The Environmental Technologies Design Option Tool (ETDOT) is a suite of software models that provides engineers with the capability to evaluate and design systems that use granular activated carbon or ion exchange resins for the removal of contaminants, including PFAS, from drinking water and wastewater.' A 'Quick Start' section lists 'Find a Contaminant' and 'Find a Treatment Process'. A 'Suite of Models' section includes 'Compatibility', 'Applications', and 'Related EPA Resources'. A button labeled 'Access ETDOT' is present, with a sub-button 'Access the ETDOT software, manuals, and more at ETDOT GitHub site. EXIT'.

### Suite of Models

ETDOT was developed by National Center for Clean Industrial and Treatment Technologies at Michigan Technological University (MTU). In 2019, EPA signed an agreement with MTU to make this suite of adsorption models available to the public at no cost.



# Treatment Information

## Publicly Available Drinking Water Treatability Database

Interactive literature review database that contains 123 regulated and unregulated contaminants and covers 35 treatment processes commonly employed or known to be effective (thousands of sources assembled on one site)

### Currently available:

PFOA, PFOS, PFTriA, PFDoA, PFUnA, PFDA, PFNA, PFHpA, PFHxA, PFPeA, PFBA, PFDS, PFHpS, PFHxS, PFBA, PFBS, PFOSA, FtS 8:2, FtS 6:2, N-EtFOSAA, N-MeFOSAA and GenX

**Recently updated!**

*Contains treatment information to be used in performance or cost models*



[Access EPA's Drinking Water Treatability Database.](#)



# Treatability Database

## Agency Landing Page

The screenshot shows the EPA Agency Landing Page for the Drinking Water Treatability Database (TDB). The page features the EPA logo and navigation links for Environmental Topics, Laws & Regulations, and About EPA. A search bar is present. Below the navigation, there is a 'Related Topics' section for Water Research and social media sharing options. The main heading is 'Drinking Water Treatability Database (TDB)' with the subtitle 'Information on treatment processes for controlling contaminants'. A paragraph describes the TDB as an easy-to-use tool for referenced information on contaminant control. A 'NEW' badge indicates that information is now available for 35 treatment processes and 123 regulated and unregulated contaminants, including 26 PFAS chemicals. A section titled 'Overview and Search Capabilities' includes an image of a faucet and text stating that treatment and contaminant information is gathered from thousands of literature sources. A 'On this Page' sidebar lists links for Overview and Search Capabilities, Applications, Platform and Compatibility, and Future Updates and Support. A blue button labeled 'Access the TDB' is circled in black, with an orange arrow pointing towards the Database Homepage.

## Database Homepage

The screenshot shows the EPA Database Homepage for the Drinking Water Treatability Database (TDB). The page features the EPA logo and a search bar. The navigation menu includes Environmental Topics, Laws & Regulations, and About EPA. Below the navigation, there is a secondary menu with links for Home, About the TDB, Contact Us, Find Contaminant, Find Treatment Process, Help, and Quick Links. The 'Find Contaminant' and 'Find Treatment Process' links are circled in black. The main heading is 'Welcome to the Drinking Water Treatability Database' above a large image of water splashing.

[Access EPA's Drinking Water Treatability Database.](#)



# PFAS Treatment

## Per- and Polyfluoroalkyl Substances

### Informational Links

### Contaminant Navigation

Overview

Treatment Processes

Properties

Fate and Transport

References

Overview

#### CAS Number:

**Synonyms:**  
Heptafluoropropyl 1,2,2,2-tetrafluoroethyl ether (E1),2,3,3,3-tetrafluoro-2-(heptafluoropropoxy)propanoate (FRD-902),2,3,3,3-tetrafluoro-2-(heptafluoropropoxy)propanoic acid (FRD-903),Ammonium perfluoro-2-methyl-3-oxahexanoate (GenX),Heptadecafluorononanoic acid,Heptafluorobutyric acid,Nonadecafluorocapric acid,Nonadecafluorodecanoic acid,Pefluorobutane sulfonate,Perfluorobutyric acid,Perfluorocapric acid,Perfluorohexanesulfonic acid potassium salt,Potassium tridecafluoro-1-hexanesulfonate,Tridecafluorohexane-1-sulfonic acid potassium salt

**Contaminant Type:** Chemical

**Description:**  
Per- and polyfluoroalkyl substances (PFASs) are fluorinated aliphatic substances with unique properties, such as being both hydrophobic, lipophobic, and extremely stable due to the strength of the C-F bond [2539]. Their properties have led to their extensive use as surface active agents in products like stain repellants and fire-fighting foams [2527, 2539]. The two most frequently studied PFASs, perfluorooctane sulphonate (PFOS) and perfluorooctanoic acid (PFOA), have their own, separate entries in this treatability database. Both PFOS and PFOA are compounds with eight carbon atoms. This group entry covers

## Per- and Polyfluoroalkyl Substances

### Informational Links

### Contaminant Navigation

Overview

Treatment Processes

Properties

Fate and Transport

References

Treatment Processes

The following processes were found to be effective for the removal of PFASs: granular activated carbon (GAC) (up to > 98 percent), membrane separation (up to > 99 percent), and ion exchange (up to > 99 percent). These results cover the removal of specific PFASs including PFTriA, PFDoA, PFUnA, PFDA, PFNA, PFHpA, PFHxA, PFPeA, PFPeS, PFDS, PFHpS, PFHxS, PFBA, PFBS, PFPrS, PFOSA, PFMOAA, PFO3OA, PFO2HxA, FtS 8:2, FtS 6:2, N-EtFOSAA, N-MeFOSAA, and GenX. For results on the removal of PFOS and PFOA, see the separate treatability database entries for those specific contaminants.

Studies were identified evaluating the following treatment technologies for the removal of PFASs:

#### **Adsorptive Media**

A bench-scale study conducted batch tests of adsorption using magnetic nanoparticles with different polymer coatings. In ultrapure water, the best performing of these achieved high removals of long chain and sulfonated PFASs (e.g., >90 percent ...

[See more](#)

#### **Aeration and Air Stripping**

At a full-scale site, packed tower aeration was not effective for removing PFASs [2441].



# PFAS Treatment: Activated Carbon

## Matrix of conditions and results from treatment references that can be downloaded into a spreadsheet

Ref #	Author	Year	Log or Percent Removal	Removal Type	Contaminant Influent	Contaminant Effluent	Contaminant Units	Contaminant	Scale	Design Flow	Water	Location Studied	GAC Type	Manufacturer	Product Name
2441	Dickenson,	2016	-10.5 to 13.7#	Percent	4.4 to 5.1#	5.7 to 6.3#	ng/L	PFHpA	F	5	SW	New Jersey	B	Calgon	F300
2441	Dickenson,	2016	-11 to 5#	Percent	3.6 to 5.8#	4.0 to 5.5#	ng/L	PFHxS	F	5	SW	New Jersey	B	Calgon	F300
2441	Dickenson,	2016	-13 to 6#	Percent	1.8 to 2.4#	1.7 to 2.7#	ng/L	PFNA	F	5	SW	New Jersey	B	Calgon	F300
2441	Dickenson,	2016	-19 to 10#	Percent	6.8 to 7.3#	6.1 to 8.7#	ng/L	PFHxA	F	5	SW	New Jersey	B	Calgon	F300
2441	Dickenson,	2016	-26#	Percent	<5.0#	6.3#	ng/L	PFBA	F	5	SW	New Jersey	B	Calgon	F300
2441	Dickenson,	2016	-34 to 8#	Percent	0.59 to 0.97#	0.54 to 1.3#	ng/L	PFDA	F	5	SW	New Jersey	B	Calgon	F300
2441	Dickenson,	2016	-66 to 70#	Percent	1.23 to 1.81#	0.537 to 2.48#	ng/L	PFBA	F	0.5472 to	GW	Minnesota	B	Calgon	F600
2441	Dickenson,	2016	0 to 19#	Percent	<0.05 to 0.085	<0.05 to 0.069#	ng/L	PFPeA	F	0.5472 to	GW	Minnesota	B	Calgon	F600
2441	Dickenson,	2016	0 to 76#	Percent	<0.05 to 0.210	<0.05#	ng/L	PFHxS	F	0.5472 to	GW	Minnesota	B	Calgon	F600
2441	Dickenson,	2016	33#	Percent	15#	10#	ng/L	PFBA	F	5#	SW	Colorado	B	Norit	GAC 300
2441	Dickenson,	2016	46 to 60#	Percent	0.127 to 0.192	<0.05 to 0.1023	ng/L	PFHxA	F	0.5472 to	GW	Minnesota	B	Calgon	F600
2441	Dickenson,	2016	5 to 6#	Percent	2.1 to 3.6#	2.0 to 3.4#	ng/L	PFBS	F	5	SW	New Jersey	B	Calgon	F300
2441	Dickenson,	2016	7.2 to 12.7#	Percent	4.8 to 5.5#	6.4 to 6.9#	ng/L	PFPeA	F	5	SW	New Jersey	B	Calgon	F300
2441	Dickenson,	2016	74#	Percent	17#	4.4#	ng/L	PFPeA	F	5#	SW	Colorado	B	Norit	GAC 300
2441	Dickenson,	2016	91#	Percent	11#	0.97#	ng/L	PFNA	F	5#	SW	Colorado	B	Norit	GAC 300
2441	Dickenson,	2016	>89#	Percent	4.5#	<0.50#	ng/L	PFHpA	F	5#	SW	Colorado	B	Norit	GAC 300
2441	Dickenson,	2016	>96#	Percent	5.8#	<0.25#	ng/L	PFHxS	F	5#	SW	Colorado	B	Norit	GAC 300
2441	Dickenson,	2016	>96#	Percent	6.4#	<0.25#	ng/L	PFBS	F	5#	SW	Colorado	B	Norit	GAC 300
2505	Cummings,	2015	>72 to >93#	Percent	18 to 72	<5	ng/L	PFNA	F		SW	Logan System Birch	B	Calgon	F-400

## Ineffective Treatments

- Conventional Treatment
- Low Pressure Membranes
- Biological Treatment (including slow sand filtration)
- Disinfection
- Oxidation
- Advanced Oxidation

### **PAC Dose to Achieve**

50% Removal	16 mg/l
90% Removal	>50 mg/L

*Dudley et al., 2015*

## Effective Treatments

- Anion Exchange Resin (IEX)
- High Pressure Membranes
- Powdered Activated Carbon (PAC)
- Granular Activated Carbon (GAC)
  - Extended Run Time
  - Designed for PFAS Removal

### Percent Removal

- |              |  |
|--------------|--|
| 90 to 99     | - Effective                              |
| 93 to 99     | - Effective                              |
| 10 to 97     | - Effective for only select applications |
| 0 to 26      | - Ineffective                            |
| > 89 to > 98 | - Effective                              |




# Facility Evaluations

**Project:** Evaluation of chemicals of emerging concern including PFAS

**Actions:** Numerous sources evaluated including drinking water facilities

**Results:** Results confirm previous conclusions that advance technologies are needed, and they must be adequately designed





The screenshot shows the EPA website header with the logo and navigation menu. The main content area features a large title and a list of related topics. The text below the title describes the purpose of the models and lists the components of compliance costs.

**EPA** United States Environmental Protection Agency

Environmental Topics    Laws & Regulations    About EPA    Search EPA.gov

Related Topics: [Safe Drinking Water Act](#)    CONTACT US    SHARE      

## Drinking Water Treatment Technology Unit Cost Models and Overview of Technologies

### Drinking Water Treatment Technology Unit Cost Models

Federal laws and executive orders require EPA to estimate compliance costs for new drinking water standards. The three major components of compliance costs are:

- Treatment
- Monitoring
- Administrative costs

Treatment technologies remove or destroy pollutants (such as arsenic, disinfection byproducts, and waterborne pathogens).

To estimate treatment costs, EPA developed several engineering models using a bottom-up approach known as work breakdown structure (WBS). The WBS models:

[Access the Drinking Water Treatment Unit Cost Models and Overview of Technology webpage](#) or search EPA WBS.

# Various Models are Available

**Adsorptive media**

**Anion exchange**

**Biological treatment**

**Cation exchange**

**GAC**

**Greensand filtration**

**Microfiltration / ultrafiltration**

**Multi-stage bubble aeration**



**Non-treatment**

**Packed tower aeration**

**Point of Use (POU)/**

**Point of Entry (POE)\***

**Reverse Osmosis / Nanofiltration**


**UV disinfection**

**UV advanced oxidation**

\*POU/POE temporarily taken off web. Please contact [Rajiv Khera](#)



# Costs for PFAS Treatment: One GAC Example




Costs can be generated for various sizes, contaminants, and even POU scenarios

## Primary Assumptions:

- Two vessels in series
- 20 min Empty Bed Contact Time (EBCT) Total
- Bed Volumes Fed
  - 1,1-DCA = 5,560 (7.5 min EBCT)
  - Shorter Chain PFCA = 4,700
  - Gen-X = 7,100
  - Shorter Chain PFS = 11,400
  - PFOA = 31,000
  - PFOS = 45,000
- 7% Discount rate
- Mid-level cost



# Costs for PFAS Treatment: One IEX Example



Costs can be generated for various sizes, contaminants, and even POU scenarios

### Primary Assumptions:

- Two vessels in series
- 3 min EBCT Total
- Bed Volumes Fed:
  - Shorter Chain PFCA = 3,300
  - Gen-X = 47,600
  - Shorter Chain PFS = 34,125
  - PFOA = 112,500
  - PFOS = 191,100
- 7% Discount rate
- Mid-level cost

- As-built costs:
  - Installed equipment cost
  - System engineering and other indirect cost
  - Annual operating cost
- The more detail, the better:
  - Detailed breakdown of cost by line item
  - Total cost with list of categories included, for example:
    - “Equipment includes vessels, piping, valves, instrumentation, concrete pad, buildings”
    - “Indirect includes engineering, permitting, pilot testing, site work, mobilization”
    - “Operating cost includes media replacement, labor, electricity”
  - Total only
- Associated flow rates, vessel sizes, materials of construction for major components (e.g., stainless steel, fiberglass)



# Performance Model Demonstration

## To provide tools to accurately predict the performance and cost of treating PFAS in drinking waters

### Treatability Database

The screenshot shows the EPA website's navigation bar with 'Environmental Topics', 'Laws & Regulations', and 'About EPA'. Below the search bar, it lists 'Related Topics: Water Research'. The main heading is 'Drinking Water Treatability Database (TDB)'. A sub-heading reads 'Provides information on the control of contaminants'. A 'Quick Start' section includes links for 'Find a Contaminant' and 'Find a Treatment Process'. A descriptive paragraph states: 'EPA's Drinking Water Treatability Database (TDB) is an easy to use tool that provides referenced information on the control of contaminants in drinking water. It was designed for use by utilities, first responders to spills or emergencies, consultants and technical assistance providers, treatment process designers, and researchers. Information in the TDB is gathered from thousands of literature sources and assembled on one site. Information is available for over 70 regulated and unregulated contaminants and more than 30 treatment processes.' At the bottom, there are buttons for 'Navigating the TDB', 'Capabilities', 'Future Updates', and 'Support'.

### Cost Models

The screenshot shows the EPA website's navigation bar. Below the search bar, it lists 'Related Topics: Safe Drinking Water Act'. The main heading is 'Drinking Water Treatment Technology Unit Cost Models and Overview of Technologies'. A sub-heading reads 'Drinking Water Treatment Technology Unit Cost Models'. A paragraph states: '...and executive orders require EPA to estimate compliance costs for new drinking water standards. The three major components of these costs are: ...'. Another paragraph mentions: '...technologies remove or destroy pollutants (such as arsenic, disinfection byproducts, and waterborne pathogens). ...'. A final paragraph states: '...treatment costs, EPA developed several engineering models using a bottom-up approach known as work breakdown structure (WBS) models: ...'.

### Performance Models

The screenshot shows the EPA website's navigation bar. Below the search bar, it lists 'Related Topics: Water Research'. The main heading is 'Environmental Technologies Design Option Tool (ETDOT)'. A sub-heading reads 'Adsorption treatment modeling for contaminant removal from drinking water and wastewater'. A paragraph states: 'The Environmental Technologies Design Option Tool (ETDOT) is a suite of software models that provides engineers with the capability to evaluate and design systems that use granular activated carbon or ion exchange resins for the removal of contaminants, including PFAS, from drinking water and wastewater.' A green button labeled 'Access ETDOT' is present. Below it, a text box says: 'Access the ETDOT software, manuals, and more at [ETDOT GitHub site](#). EXIT'. At the bottom, there are buttons for 'Suite of Models', 'Compatibility', 'Applications', and 'Related EPA Resources'. The section is titled 'Suite of Models'. A paragraph at the bottom states: 'ETDOT was developed by National Center for Clean Industrial and Treatment Technologies at Michigan Technological University (MTU). In 2019, EPA signed an agreement with MTU to make this suite of adsorption models available to the public at no cost.'



# Environmental Technologies Design Option Tool (ETDOT)


ETDOT is a series of treatment models, data sets, and parameter estimation tools developed by National Center for Clean Industrial and Treatment Technologies at Michigan Technological University (MTU)

- The models were sold as a package for many years
- In 2019, EPA signed an agreement with MTU to make this suite of water and air treatment models available to the public at no cost

## **Expected interested users:**

- State primacy personnel interested in evaluating data sets
- Water utilities with experience in running models
- Consulting engineers
- University academicians

**Access the ETDOT software, manuals  
and more at the [ETDOT GitHub site](#).**




The screenshot shows the EPA website page for the Environmental Technologies Design Option Tool (ETDOT). The page features the EPA logo, navigation tabs for Environmental Topics, Laws & Regulations, and About EPA, and a search bar. Below the navigation is a 'Related Topics' section with 'Water Research' highlighted. The main heading is 'Environmental Technologies Design Option Tool (ETDOT)'. A descriptive paragraph follows, explaining that ETDOT is a suite of software models for evaluating and designing systems for contaminant removal. Below the text are four buttons: 'Suite of Models', 'Compatibility', 'Applications', and 'Related EPA Resources'. A green callout box with the text 'Access ETDOT' is circled in red, and an arrow points from the text 'GitHub Site' to it. The callout box contains the text 'Access the ETDOT software, manuals, and more at [ETDOT GitHub site](#). EXIT'.

GitHub Site

[Access the Environmental Technologies Design Option Tool \(ETDOT\)](#) or search EPA ETDOT.


## Models available at the GitHub site:

- Adsorption Design Software for Windows (AdDesignS) *Version 1.0*
- Advanced Oxidation Process Software (AdOx) *Version 1.0.2*
- Aeration System Analysis Program (ASAP) *Version 1.0*
- Biofilter Design Software *Version 1.0.27*
- Continuous Flow Pore Surface Diffusion Model for Modeling Powdered Activated Carbon Adsorption *Version 1.0*
- Dye Study Program (DyeStudy) *Version 1.0.0*
- Predictive Software for the Fate of Volatile Organics in Municipal Wastewater Treatment Plants (FaVOr) *Version 1.0.11*
- Ion Exchange Design Software (IonExDesign) *Version 1.0.0*
- Software to Estimate Physical Properties (StEPP) *Version 1.0*




*The engines are written in FORTRAN with a Visual Basic front end*


## Example: GAC Model



The models range from simple to complex



## Modeling Pilot-/Full-scale Data



Allows for predicting performance for other scenarios

- Other designs: number of contactors, contactor Empty Bed Contact Time (EBCT), different treatment goals, changing concentrations of PFAS or background constituents, changing demand, lead/lag operation, etc.

Working with EPA's Office of Ground Water and Drinking Water and the US Air Force on drinking water and remediation cost models

- Allows for comparison within and across technologies by cost


*Treatment and cost models will soon be made available to the public at no charge on EPA's website.*

## Treatability Database

- Further update treatability database with new references

## Performance Models

- Update Graphical User Interface to work with Windows 10
- Provide Python code for pore surface diffusion model (PSDM GAC) to automate the optimization routines for:
  - Specific throughput and carbon use rate calculations for multiple scenarios
  - Automated fitting of parameters
  - Automated optimal bed configuration
  - Automated optimal Empty Bed Contact Time (EBCT) selection
  - Automated evaluation of bed replacement frequency
  - Evaluation of multiple feed conditions
  - Evaluation of multiple flow conditions
  - Automated fitting and predicting lead/lag operations



## Performance Models *(continued)*


- Provide code for ion exchange models for
  - Include competition (e.g., inorganic ions and PFAS)
  - Continuous flow (columns) and batch (isotherm and kinetics)
  - Gel (HSDM) and macro porous (PSDM) resins
  - with automation features

## Cost Models

- Further updates to the cost models


## Combined Models

- Further merge Treatability Database, performance models and cost models
- Further merge the Treatability Database with [EPA's CompTox Chemicals Dashboard](#)




For the treatment/cost models housed at EPA...

- Provide tools and approaches to accurately predict the performance and cost of treating PFAS in waters
- [Environmental Technologies Design Option Tool Models](#) or search EPA ETDOT
- [Drinking Water Treatability Database](#) or search EPA TDB
- [Drinking Water Treatment Cost Models](#) or search EPA WBS



The screenshot shows the EPA website page for the Environmental Technologies Design Option Tool (ETDOT). The page features the EPA logo, navigation tabs for Environmental Topics, Laws & Regulations, and About EPA. A search bar is present. The main heading is "Environmental Technologies Design Option Tool (ETDOT)". Below the heading, there is a brief description of the tool and a prominent green button labeled "Access ETDOT". A secondary box below the button says "Access the ETDOT software, manuals, and more at ETDOT\_Chris2018\_0318.pdf". There are also tabs for "Suite of Models", "Compatibility", "Applications", and "Related EPA Resources". A "Suite of Models" section follows, mentioning its development by the National Center for Clean Industrial and Treatment Technologies at Michigan Technological University (MTU) in 2019.



The screenshot shows the EPA website page for the Drinking Water Treatability Database (TDB). It includes the EPA logo and navigation tabs. The main heading is "Drinking Water Treatability Database (TDB)". The text describes the database as a tool for controlling contaminants in drinking water, designed for use by utilities, emergency responders, and consultants. A "Quick Start" section is highlighted with a green box, containing links for "Find a Contaminant" and "Find a Treatment Process". There is also an image of water splashing. Navigation tabs at the bottom include "Navigating the TDB", "Capabilities", "Future Updates", and "Support".



The screenshot shows the EPA website page for "Drinking Water Treatment Technology Unit Cost Models and Overview of Technologies". It features the EPA logo and navigation tabs. The main heading is "Drinking Water Treatment Technology Unit Cost Models and Overview of Technologies". Below the heading, there is a sub-heading "Drinking Water Treatment Technology Unit Cost Models". The text explains that federal laws and executive orders require EPA to estimate compliance costs for new drinking water standards. A list of cost components is provided: Treatment, Monitoring, and Administrative costs. A final paragraph states that treatment technologies remove or destroy pollutants and that EPA developed several engineering models using a bottom-up approach known as work breakdown structure (WBS).

**Problem:** There are many sources of materials that may need to be thermally treated:

- Manufacturing wastes
- Wastewater sludges
- Municipal waste
- Obsolete flame retardants
- *Spent water treatment sorbents – in conjunction with reactivation*

*What minimum conditions (temperature, time) are needed to adequately destroy PFAS and what are the products of incomplete combustion?*

**Action:** Conduct bench- pilot- and full-scale incineration studies and modeling to evaluate:

- Impact of source material
- Impact of temperature on degree of destruction
- Impact of calcium
- PFAS releases from incineration systems

## Needs

- Destruction and removal efficiency? Can the ash be landfilled? Can the GAC be reused?
- Release of off gas (incineration, pollution control devices)?
- Mass balance closure to determine the fate of the contaminants?

## Chemistry

- What PFAS to analyze for? What sampling protocols?
- Analytical protocols for air, solid and liquid samples
- Effectiveness of conservative tracers?

## Source Material

- Do spent GAC and IX have different considerations?
- Co-treated materials, calcium and other additives?
- Size and chemical makeup

## Design and Operating Conditions

- Reactor type (temperature, residence time)
- Reaction zone (flow, movement of materials and gases)



# Extramural Project (Univ. of North Dakota)

## Thermal Stability and Decomposition of Perfluoroalkyl Substances on Spent Granular Activated Carbon

Feng Xiao,\* Pavankumar Challa Sasi, Bin Yao, Alena Kubátová, Svetlana A. Golovko, Mikhail Y. Golovko, and Dana Soli  
Environ. Sci. Technol. Lett. 2020, 7, 343–350 - USEPA ORD Science to Achieve Results (STAR) Program (RD83966; F.X.)

### Objectives

- Improve our understanding of the thermal stability of PFAS
- Investigate their decomposition mechanisms on spent GAC during thermal reactivation

### Design

- 7 perfluoroalkyl carboxylic acids (PFCAs), 3 perfluoroalkyl sulfonic acids (PFSAs), and 1 perfluoroalkyl ether carboxylic acid (PFECA) in different atmospheres (N<sub>2</sub>, O<sub>2</sub>, CO<sub>2</sub> and air)

### Bench Scale Results

- Decomposition of PFCAs such as PFOA on GAC was initiated at temperatures as low as 200 °C
- PFSAs such as PFOS, on the other hand, required a much higher temperature (≥450 °C) to decompose
- Volatile organofluorine species were the main thermal decomposition product of PFOA and PFOS at ≤600 °C
- Efficient decomposition (>99.9%) of PFOA and PFOS on GAC occurred at 700 °C or higher, accompanied by high mineralization of fluoride ions (>80%)

## Thermal Reactivation of Spent GAC from PFAS Remediation Sites

Detlef Knappe, S. James Ellen: North Carolina State University, SERDP Proposal (with EPA cooperation)

**Objective:** To identify conditions that effectively mineralize PFAS during the thermal reactivation of PFAS-laden GAC

**Design:** To identify the roles of 1) reactivation temperature, 2) reactivation time, 3) calcium, and 4) pretreatment with base on PFAS fate during thermal reactivation of GAC

### Questions to Resolve:

- What is the difference in behavior between the acid and salt forms of PFAS during thermal reactivation of GAC?
- What are the roles of calcium and base on the fate of PFAS during thermal reactivation of GAC?
- What are products of incomplete combustion (PICs) in air emissions and on the reactivated GAC?





# Emission Stack Testing of PFAS Residuals from Full-Scale GAC Reactivation Facilities

When DW treatment plant GAC is reactivated, the PFAS may be thermally destroyed or transformed into residual byproducts

- Spent GAC, reactivated GAC and scrubber water will be analyzed for PFAS
- Summa Canister, Modified Method 5 for Semi-Volatile Organics and PAHs and Modified Method 18 air samples will be collected and analyzed as follows:

Test Parameter	EPA Method
Carbon dioxide/Oxygen	U.S. EPA 3A
Volumetric flow rate, moisture	U.S. EPA 1, 2, 4
Hydrogen fluoride	U.S. EPA 26A
Speciated semivolatile organics	U.S. EPA 0010/8270D
Polar, volatile PFAS compounds	Modified U.S. EPA 18
Volatile organic compounds	U.S. EPA TO-15




Multiple Hearth Furnace for GAC Reactivation



Multiple Hearth Furnace Access Doors



Afterburner



**EPA is actively looking for partners for sampling of GAC reactivation facilities**

# Cement Kiln Incinerators

## Cement kilns are operated under different operating conditions

- Gas temperatures of up to  $\sim 2,000$  °C
- Gas residence times of up to 10 seconds
- Solid residence time of up to 30 minutes

PFAS in water




Simple & Cost Effective

PFAS-free water

PFAS loaded resin

Cement Kilns in the U.S. Source: US EPA

**Cement Kiln Incineration**  
1400°C to 2000°C





**Complete Destruction of PFAS**



Source: [Purolite presentation and case study](#), F. Boodoo et al.

# Incineration of Spent Ion Exchange Resin

- Anion exchange resins loaded with different PFAS compounds with or without calcium additives are placed in quartz crucibles and inserted into a preheated furnace
- Samples are incinerated (simulating a cement kiln) under constant air flow
- Samples are being collected and analyzed for calcium fluoride ( $\text{CaF}_2$ ) in incinerated ash and hydrogen fluoride (HF), tetrafluoromethane ( $\text{CF}_4$ ) and hexafluoroethane ( $\text{C}_2\text{F}_6$ ) in air emissions






00:00:00:00

# PFAS Fate and Transport for WWTPs & Biosolids


Wastewater Treatment Plants (WWTPs) may introduce PFAS into the environment through:

- Effluent discharge to surface water
- Land application of biosolids and disposal of residuals
- Air emissions




KEY A Atmospheric Deposition D Diffusion/Dispersion/Advection I Infiltration T Transformation of precursors (abiotic/biotic)

# US Publicly Owned Treatment Works (POTW) by daily average flow




# Wastewater Sludge Production in the US



## Problem: Survey of 50 wastewater treatment plant effluents show the presence of PFAS

- Greater than 80% WWTPS had measurable C4-10 PF carboxylates, PFBS, PFHS, PFOS
- PFHxA, PFOA and PFOS were predominant
- Median levels ~ 10–30 ng/L, although some plants were much higher
- Results shows temporal and spatial variability



50 Largest Plants (20% pop, 17% discharge)



# EPA's PFAS Wastewater Treatment Research

**Problem:** PFAS removal in wastewater plants is largely unknown

**Actions:**

- Analytical methods for the targeted compounds
- Bioassays to better understand if treatments are effective and to identify risks
- Evaluate air emissions from activated sludge and sludge treatment processes
- Evaluate conventional and advanced treatment processes for various size facilities
- Chemical and microbial transformation processes will also be evaluated in wastewater residuals/biosolids operations

**Impact:** *Enable entities to make informed decisions about wastewater treatment choices and residual handling*

## Residual Streams (to be covered Sept. 23)

- Wastewater residuals incineration
  - Multi hearth furnaces
  - Rotary kilns
  - Fluidized beds
- Biosolids formation
- Advanced technologies
- Landfill disposal
- Land application
- Plant uptake



# Wastewater Treatment: Conventional and Advanced

**Problem:** Data are needed for PFAS removal for conventional and advanced wastewater treatment processes

**Action:** Develop research to support:

- Treatment in conventional & advanced wastewater and biosolids treatment. Consider factors such as facility size, waste sources, treatment technologies, retention time, etc.
- Combinations of technologies
- Determination of where PFAS is coming from (e.g., industrial, landfills) and potential pretreatment technologies to address “sources” to wastewater plants
- Determination of fate & transport of PFAS in wastewater treatment: Chemical and biological transformations, and do shorter chain PFAS tend to end up in effluents than in biosolids?



## Thomas Speth, PhD, PE

Associate Director

Center for Environmental Solutions and Emergency Response  
US EPA Office of Research and Development

[Speth.Thomas@epa.gov](mailto:Speth.Thomas@epa.gov)

513-569-7208

### EPA Team:

Carolyn Acheson ([Acheson.Carolyn@epa.gov](mailto:Acheson.Carolyn@epa.gov))

Marc Mills ([Mills.Marc@epa.gov](mailto:Mills.Marc@epa.gov))

Craig Patterson ([Patterson.Craig@epa.gov](mailto:Patterson.Craig@epa.gov))

Jonathan Pressman ([Pressman.Jonathan@epa.gov](mailto:Pressman.Jonathan@epa.gov))

*The views expressed in this presentation are those of the individual author and do not necessarily reflect the views and policies of the US EPA.*

