

NPDES PERMIT

issued to

Permittee:

City of Bridgeport
999 Broad Street
Bridgeport, Connecticut 06604

Location Address:

Bridgeport East Side WPCF
695 Seaview Avenue
Bridgeport, Connecticut 06607

Permit ID: CT0101010

Design Flow Rate: 10.0 MGD

Effective Date:

Receiving Stream: Bridgeport Harbor

Permit Expires:

SECTION 1: GENERAL PROVISIONS

- (A) This permit is reissued in accordance with Section 22a-430 of Chapter 446k, Connecticut General Statutes ("CGS"), and Regulations of Connecticut State Agencies ("RCSA") adopted thereunder, as amended, and Section 402(b) of the Clean Water Act, as amended, 33 USC 1251, et. seq., and pursuant to an approval dated September 26, 1973, by the Administrator of the United States Environmental Protection Agency for the State of Connecticut to administer a N.P.D.E.S. permit program.
- (B) The City of Bridgeport, ("Permittee"), shall comply with all conditions of this permit including the following sections of the RCSA which have been adopted pursuant to Section 22a-430 of the CGS and are hereby incorporated into this permit. **Your attention is especially drawn to the notification requirements of subsection (i)(2), (i)(3), (j)(1), (j)(6), (j)(8), (j)(9)(C), (j)(10)(C), (j)(11)(C), (D), (E), and (F), (k)(3) and (4) and (l)(2) of Section 22a-430-3.** To the extent this permit imposes conditions more stringent than those found in the regulations, this permit shall apply.

Section 22a-430-3 General Conditions

- (a) Definitions
- (b) General
- (c) Inspection and Entry
- (d) Effect of a Permit
- (e) Duty to Comply
- (f) Proper Operation and Maintenance
- (g) Sludge Disposal
- (h) Duty to Mitigate
- (i) Facility Modifications; Notification
- (j) Monitoring, Records and Reporting Requirements
- (k) Bypass
- (l) Conditions Applicable to POTWs
- (m) Effluent Limitation Violations
- (n) Enforcement
- (o) Resource Conservation
- (p) Spill Prevention and Control
- (q) Instrumentation, Alarms, Flow Recorders
- (r) Equalization

Section 22a-430-4 Procedures and Criteria

- (a) Duty to Apply
- (b) Duty to Reapply
- (c) Application Requirements
- (d) Preliminary Review
- (e) Tentative Determination
- (f) Draft Permits, Fact Sheets
- (g) Public Notice, Notice of Hearing

- (h) Public Comments
- (i) Final Determination
- (j) Public Hearings
- (k) Submission of Plans and Specifications. Approval.
- (l) Establishing Effluent Limitations and Conditions
- (m) Case-by-Case Determinations
- (n) Permit Issuance or Renewal
- (o) Permit or Application Transfer
- (p) Permit Revocation, Denial or Modification
- (q) Variances
- (r) Secondary Treatment Requirements
- (s) Treatment Requirements
- (t) Discharges to POTWs - Prohibitions

- (C) Violations of any of the terms, conditions, or limitations contained in this permit may subject the Permittee to enforcement action including, but not limited to, seeking penalties, injunctions and/or forfeitures pursuant to applicable sections of the CGS and RCSA.
- (D) Any false statement in any information submitted pursuant to this Section of the permit may be punishable as a criminal offense under Section 22a-438 or 22a-131a of the CGS or in accordance with Section 22a-6, under Section 53a-157b of the CGS.
- (E) The Permittee shall comply with Section 22a-416-1 through Section 22a-416-10 of the RCSA concerning operator certification.
- (F) No provision of this permit and no action or inaction by the Commissioner shall be construed to constitute an assurance by the Commissioner that the actions taken by the Permittee pursuant to this permit will result in compliance or prevent or abate pollution.
- (G) Nothing in this permit shall relieve the Permittee of other obligations under applicable federal, state and local law.
- (H) An annual fee shall be paid for each year this permit is in effect as set forth in Section 22a-430-7 of the RCSA. As of October 1, 2009, the annual fee is \$3,005.00
- (I) The Permittee's discharge(s) shall not violate the Interstate Environmental Commission (IEC) Water Quality Regulations promulgated pursuant to the authority conferred upon the IEC by the Tri-State Compact (CGS 22a-294 et seq.) as defined in Attachment 1 Table A, remark E..
- (J) This permitted discharge is consistent with the applicable goals and policies of the Connecticut Coastal Management Act (Section 22a-92 of the CGS).

SECTION 2: DEFINITIONS

- (A) The definitions of the terms used in this permit shall be the same as the definitions contained in Section 22a-423 of the CGS and Section 22a-430-3(a) and 22a-430-6 of the RCSA, except for "Composite" and "No Observable Acute Effect Level (NOAEL)" which are redefined below.
- (B) In addition to the above, the following definitions shall apply to this permit:

"-----" in the limits column on the monitoring tables in Attachment 1 means a limit is not specified but a value must be reported on the DMR, MOR, and/or the ATMR.

"**Annual**" in the context of any sampling frequency, shall mean the sample must be collected in the month of June.

"**Average Monthly Limit**" means the maximum allowable "Average Monthly Concentration" as defined in Section 22a-430-3(a) of the RCSA when expressed as a concentration (e.g. mg/l); otherwise, it means "Average Monthly Discharge Limitation" as defined in Section 22a-430-3(a) of the RCSA.

"**Bi-Monthly**" in the context of any sampling frequency, shall mean once every two months including the months of January, March, May, July, September, and November.

"**Bi-Weekly**" in the context of any sampling frequency, shall mean once every two weeks.

"**Composite**" or "(C)" means a sample consisting of a minimum of eight aliquot samples collected at equal intervals of no less than 30 minutes and no more than 60 minutes and combined proportionally to flow over the sampling period provided that during the sampling period the peak hourly flow is experienced.

"**Critical Test Concentration**" or "**(CTC)**" means the specified effluent dilution at which the Permittee is to conduct a single-concentration Aquatic Toxicity Test.

"**Daily Composite**" or "**(DC)**" means a composite sample taken over a full operating day consisting of grab samples collected at equal intervals of no more than sixty (60) minutes and combined proportionally to flow; or, a composite sample continuously collected over a full operating day proportionally to flow.

"**Daily Concentration**" means the concentration of a substance as measured in a daily composite sample, or, arithmetic average of all grab sample results defining a grab sample average.

"**Daily Quantity**" means the quantity of waste discharged during an operating day.

"**Geometric Mean**" is the " n "th root of the product of " n " observations.

"**Infiltration**" means water other than wastewater that enters a sewer system (including sewer system and foundation drains) from the ground through such means as defective pipes, pipe joints, connections, or manholes. Infiltration does not include, and is distinguished from, inflow.

"**Inflow**" means water other than wastewater that enters a sewer system (including sewer service connections) from sources such as, but not limited to, roof leaders, cellar drains, yard drains, area drains, drains from springs and swampy areas, cross connections between storm sewers and sanitary sewers, catch basins, cooling towers, storm waters, surface runoff, street wash waters, or drainage. Inflow does not include, and is distinguished from, infiltration.

"**Instantaneous Limit**" means the highest allowable concentration of a substance as measured by a grab sample, or the highest allowable measurement of a parameter as obtained through instantaneous monitoring.

"**In-stream Waste Concentration**" or "**(IWC)**" means the concentration of a discharge in the receiving water after mixing has occurred in the allocated zone of influence.

"**MGD**" means million gallons per day.

"**Maximum Daily Limit**" means the maximum allowable "Daily Concentration" (defined above) when expressed as a concentration (e.g. mg/l), otherwise, it means the maximum allowable "Daily Quantity" as defined above, unless it is expressed as a flow quantity. If expressed as a flow quantity, it means "Maximum Daily Flow" as defined in Section 22a-430-3(a) of the RCSA.

"**NA**" as a Monitoring Table abbreviation means "not applicable".

"**NR**" as a Monitoring Table abbreviation means "not required".

"**No Observable Acute Effect Level**" or "**(NOAEL)**" means any concentration equal to or less than the critical test concentration in a single concentration (pass/fail) toxicity test, conducted pursuant to Section 22a-430-3(j)(7)(A)(i) of the RCSA, demonstrating 90% or greater survival of test organisms at the CTC.

"**Quarterly**" in the context of any sampling frequency, shall mean sampling is required in the months of March, June, September and December.

"**Range During Sampling**" or "**(RDS)**" as a sample type means the maximum and minimum of all values recorded as a result of analyzing each grab sample of; 1) a Composite Sample, or, 2) a Grab Sample Average. For those Permittee with pH meters that provide continuous monitoring and recording, Range During Sampling means the maximum and minimum readings recorded with the continuous monitoring device during the Composite or Grab Sample Average sample collection.

"**Range During Month**" or "**(RDM)**" as a sample type means the lowest and the highest values of all of the monitoring data for the reporting month.

"**Sanitary Sewage**" means wastewaters from residential, commercial and industrial sources introduced by direct connection to the sewerage collection system tributary to the treatment works including non-excessive inflow/infiltration sources.

"**Twice per Month**" in the context of any sampling frequency, mean two samples per calendar month collected no less than 12 days apart.

"**ug/l**" means micrograms per liter

"**Work Day**" in the context of a sampling frequency means, Monday through Friday excluding holidays.

"**Zone of Influence**" means the spatial area or volume of receiving water flow within which some degradation of water quality or use impairment is anticipated to occur as a result of a discharge.

SECTION 3: COMMISSIONER'S DECISION

- (A) The Commissioner of Energy and Environmental Protection ("Commissioner") has issued a final decision and continuance of the existing system to treat the discharge will protect the waters of the state from pollution. The Commissioner's decision is based on application #202006182 for permit reissuance received on May 11, 2020, and the administrative record established in the processing of that application.
- (B) The Commissioner hereby authorizes the Permittee to discharge in accordance with the provisions of this permit, the above referenced application, and all approvals issued by the Commissioner or his authorized agent for the discharges and/or activities authorized by, or associated with, this permit.
- (C) The Commissioner reserves the right to make appropriate revisions to the permit, if required after Public Notice, in order to establish any appropriate effluent limitations, schedules of compliance, or other provisions which may be authorized under the Federal Clean Water Act or the CGS or regulations adopted thereunder, as amended. The permit as modified or renewed under this paragraph may also contain any other requirements of the Federal Clean Water Act or CGS or regulations adopted thereunder which are then applicable.

SECTION 4: GENERAL LIMITATIONS AND OTHER CONDITIONS

- (A) The Permittee shall not accept any new sources of non-domestic wastewater conveyed to its POTW through its sanitary sewerage system or by any means other than its sanitary sewerage system unless the generator of such wastewater; (a) is authorized by a permit issued by the Commissioner under Section 22a-430 CGS (individual permit), or (b) is authorized under Section 22a-430b (general permit), or (c) has been issued an emergency or temporary authorization by the Commissioner under Section 22a-6k. All such non-domestic wastewaters shall be processed by the POTW via receiving facilities at a location and in a manner prescribed by the Permittee which are designed to contain and control any unplanned releases.
- (B) No new discharge of domestic sewage from a single source to the POTW in excess of 50,000 gallons per day shall be allowed by the Permittee until the Permittee has notified in writing the Connecticut Department of Energy and Environmental Protection, Bureau of Water Protection and Land Reuse, Water Planning and Management Division, Municipal Wastewater Section, 79 Elm Street, Hartford, CT 06106-5127 of said new discharge.
- (C) The Permittee shall maintain a system of user charges based on actual use sufficient to operate and maintain the POTW (including the collection system) and replace critical components.
- (D) The Permittee shall maintain a sewer use ordinance that is consistent with the most current Model Sewer Ordinance for Connecticut Municipalities prepared by the Department of Energy and Environmental Protection. The Commissioner of Energy and Environmental Protection alone may authorize certain discharges which may not conform to the Model Sewer Ordinance.
- (E) Outside of the Zone of Influence assigned to this discharge, this discharge shall not contain:
 - (1) sludge deposits, solid refuse, floating solids, oils and grease, or scum except as may result from a discharge from a wastewater treatment facility providing appropriate treatment and none exceeding levels necessary to protect and maintain all designated uses;
 - (2) color resulting in obvious discoloration of the surface water;
 - (3) suspended and settleable solids in concentrations or combinations which would impair the designated uses; be aesthetically objectionable; significantly alter the physical or chemical composition of bottom sediments; and/or adversely impact organisms living in or on the bottom sediment;
 - (4) silt or sand deposits other than of natural origin;
 - (5) turbidity other than that of natural origin except as may result discharge from a wastewater treatment facility providing appropriate treatment, provided all reasonable controls are used to control turbidity and none exceeding levels necessary to protect and maintain all designated uses; or
 - (6) odor that would impair the designated uses specifically assigned to this Classification pursuant to the Connecticut Water Quality Standards Regulations (RCSA §§ 22a-426-1—22a-426-9).

- (F) No discharge from the permitted facility shall cause acute or chronic toxicity in the receiving water body beyond any Zone Of Influence (ZOI) specifically allocated to that discharge in this permit.
- (G) The Permittee shall maintain an alternate power source adequate to provide full operation of all pump stations in the sewerage collection system and to provide a minimum of primary treatment and disinfection at the water pollution control facility to insure that no discharge of untreated wastewater will occur during a failure of a primary power source.
- (H) The average monthly effluent concentration shall not exceed 15% of the average monthly influent concentration for BOD₅ and Total Suspended Solids for all daily composite samples taken in any calendar month.
- (I) Any new or increased amount of sanitary sewage discharge to the sewer system is prohibited where it will cause a dry weather overflow or exacerbate an existing dry weather overflow.
- (J) Sludge Conditions
 - (1) The Permittee shall comply with all existing federal and state laws and regulations that apply to sewage sludge use and disposal practices, including but not limited to 40 CFR Part 503.
 - (2) If an applicable management practice or numerical limitation for pollutants in sewage sludge more stringent than existing federal and state regulations is promulgated under Section 405(d) of the Clean Water Act (CWA), this permit shall be modified or revoked and reissued to conform to the promulgated regulations.
 - (3) The Permittee shall give prior notice to the Commissioner of any change(s) planned in the Permittee' sludge use or disposal practice. A change in the Permittee' sludge use or disposal practice may be a cause for modification of the permit.
 - (4) Testing for inorganic pollutants shall follow "Test Methods for Evaluating Solid Waste, Physical/Chemical Methods", EPA Publication SW-846 as updated and/or revised.
- (K) This permit becomes effective on the 1st day of the month following the date of signature of the Commissioner or designee.
- (L) When the arithmetic mean of the average daily flow from the POTW for the previous 180 days exceeds 90% of the design flow rate, the Permittee shall develop and submit within one (1) year from the date such threshold was exceeded, for the review and approval of the Commissioner, a plan to accommodate future increases in flow to the plant. This plan shall include a schedule for completing any recommended improvements and a plan for financing the improvements.
- (M) When the arithmetic mean of the average daily BOD₅ or TSS loading into the POTW for the previous 180 days exceeds 90% of the design load rate, the Permittee shall develop and submit for the review and approval of the Commissioner within one (1) year from the date such threshold was exceeded, a plan to accommodate future increases in load to the plant. This plan shall include a schedule for completing any recommended improvements and a plan for financing the improvements.
- (N) On or before July 31st of each calendar year the main flow meter shall be calibrated by an independent contractor in accordance with the manufacturer's specifications. The actual record of the calibration shall be retained onsite and, upon request, the Permittee shall submit to the Commissioner a copy of that record.
- (O) The Permittee shall operate and maintain all processes as installed in accordance with the approved plans and specifications and as outlined in the associated operation and maintenance manual. This includes but is not limited to all preliminary treatment processes, primary treatment processes, recycle pumping processes, anaerobic treatment processes, anoxic treatment processes, aerobic treatment processes, flocculation processes, effluent filtration processes or any other processes necessary for the optimal removal of pollutants. The Permittee shall not bypass or fail to operate any of the aforementioned processes without the written approval of the Commissioner.
- (P) The Permittee is hereby authorized to accept septage at the treatment facility; or other locations as approved by the Commissioner.
- (Q) The temperature of any discharge shall not increase the temperature of the receiving stream above 83°F, or, in any case, raise the temperature of the receiving stream by more than 4°F beyond the permitted zone of influence. The incremental temperature increase in coastal and marine waters is limited to 1.5°F during the period including July, August and September.

SECTION 5: SPECIFIC EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

- (A) The discharge(s) shall not exceed and shall otherwise conform to the specific terms and conditions listed in this permit. The discharge is restricted by, and shall be monitored in accordance with Tables A through G incorporated in this permit as Attachment 1.

- (B) The Permittee shall monitor the performance of the treatment process in accordance with the Monthly Operating Report (MOR) incorporated in this permit as Attachment 2.

SECTION 6: SAMPLE COLLECTION, HANDLING and ANALYTICAL TECHNIQUES

(A) Chemical Analysis

- (1) Chemical analyses to determine compliance with effluent limits and conditions established in this permit shall be performed using the methods approved pursuant to the Code of Federal Regulations, Part 136 of Title 40 (40 CFR 136) unless an alternative method has been approved in writing pursuant to 40 CFR 136.4 or as provided in Section 22a-430-3(j)(7) of the RCSA. Chemicals which do not have methods of analysis defined in 40 CFR 136 or the RCSA shall be analyzed in accordance with methods specified in this permit.
- (2) All metals analyses identified in this permit shall refer to analyses for Total Recoverable Metal, as defined in 40 CFR 136 unless otherwise specified.
- (3) Grab samples shall be taken during the period of the day when the peak hourly flow is normally experienced.
- (4) Samples collected for bacteriological examination shall be collected between the hours of 11 a.m. and 3 p.m. or at that time of day when the peak hourly flow is normally experienced. **A chlorine residual sample must be taken at the same time and the results recorded.**
- (5) The Minimum Levels specified below represent the concentrations at which quantification must be achieved and verified during the chemical analyses for the parameters identified in Attachment 1, Tables A and C. Analyses for these parameters must include check standards within ten percent of the specified Minimum Level or calibration points equal to or less than the specified Minimum Level.

<u>Parameter</u>	<u>Minimum Level</u>
Aluminum	0.050 mg/l
Antimony, Total	0.010 mg/l
Arsenic, Total	0.005 mg/l
Beryllium, Total	0.001 mg/l
Cadmium, Total	0.0005 mg/l
Chlorine, Total Residual	0.050 mg/l
Chromium, Total	0.005 mg/l
Chromium, Total Hexavalent	0.010 mg/l
Copper, Total	0.005 mg/l
Cyanide, Total	0.010 mg/l
Iron, Total	0.040 mg/l
Lead, Total	0.005 mg/l
Mercury, Total	0.0002 mg/l
Nickel, Total	0.005 mg/l
Phosphorus, Total	0.10 mg/l
Selenium, Total	0.005 mg/l
Silver, Total	0.002 mg/l
Thallium, Total	0.005 mg/l
Zinc, Total	0.020 mg/l

- (6) The value of each parameter for which monitoring is required under this permit shall be reported to the maximum level of accuracy and precision possible consistent with the requirements of this Section of the permit.
- (7) Effluent analyses for which quantification was verified during the analysis at or below the minimum levels specified in this Section and which indicate that a parameter was not detected shall be reported as "less than x" where 'x' is the numerical value equivalent to the analytical method detection limit for that analysis.
- (8) Results of effluent analyses which indicate that a parameter was not present at a concentration greater than or equal to the Minimum Level specified for that analysis shall be considered equivalent to zero (0.0) for purposes of determining compliance with effluent limitations or conditions specified in this permit.

(B) Acute Aquatic Toxicity Test

- (1) Samples for monitoring of Acute Aquatic Toxicity shall be collected and handled as prescribed in "Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms" (EPA-821-R-02-012).

- (a) Composite samples shall be chilled as they are collected. Grab samples shall be chilled immediately following collection. Samples shall be held at 0 - 6°C until Acute Aquatic Toxicity testing is initiated.
 - (b) Effluent samples shall not be dechlorinated, filtered, or, modified in any way, prior to testing for Acute Aquatic Toxicity unless specifically approved in writing by the Commissioner for monitoring at this facility. Facilities with effluent dechlorination and/or filtration designed as part of the treatment process are not required to obtain approval from the Commissioner.
 - (c) Samples shall be taken after dechlorination for Acute Aquatic Toxicity unless otherwise approved in writing by the Commissioner for monitoring at this facility
 - (d) Chemical analyses of the parameters identified in Attachment 1, Table C shall be conducted on an aliquot of the same sample tested for Acute Aquatic Toxicity.
 - (i) At a minimum, pH, salinity, total alkalinity, total hardness, and total residual chlorine shall be measured in the effluent sample and, during Acute Aquatic Toxicity tests, in the highest concentration of the test and in the dilution (control) water at the beginning of the test and at test termination. If total residual chlorine is not detected at test initiation, it does not need to be measured at test termination. Dissolved oxygen, pH, and temperature shall be measured in the control and all test concentrations at the beginning of the test, daily thereafter, and at test termination. Salinity shall be measured in each test concentration at the beginning of the test and at test termination.
 - (e) Tests for Acute Aquatic Toxicity shall be initiated within 36 hours of sample collection.
- (2) Monitoring for Acute Aquatic Toxicity to determine compliance with the permit condition on Acute Aquatic Toxicity (invertebrate) shall be conducted for 48 hours utilizing neonatal (less than 24 hours old) *Daphnia pulex*.
 - (3) Monitoring for Acute Aquatic Toxicity to determine compliance with the permit condition on Acute Aquatic Toxicity (vertebrate) shall be conducted for 48 hours utilizing larval (1 to 14-day old with no more than 24 hours range in age) *Pimephales promelas*.
 - (4) Tests for Acute Aquatic Toxicity shall be conducted as prescribed for static non-renewal acute tests in "Methods for measuring the Acute Aquatic Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms" (EPA/821-R-02-012), except as specified below.
 - (a) For Acute Aquatic Toxicity limits, and for monitoring only conditions, expressed as a NOAEL value, Pass/Fail (single concentration) tests shall be conducted at a specified Critical Test Concentration (CTC) equal to the Aquatic Toxicity limit, (100% in the case of monitoring only conditions), as prescribed in Section 22a-430-3(j)(7)(A)(i) of the RCSA.
 - (b) Organisms shall not be fed during the tests.
 - (c) Synthetic freshwater prepared with deionized water adjusted to a hardness of 50±5 mg/L as CaCO₃ shall be used as dilution water in the tests.
 - (d) Copper nitrate shall be used as the reference toxicant.
 - (5) For monitoring only conditions, toxicity shall be demonstrated when the results of a valid pass/fail Acute Aquatic Toxicity indicates less than 90% survival in the effluent at the CTC (100%).

SECTION 7: RECORDING AND REPORTING REQUIREMENTS

- (A) The Permittee and/or the Signatory Authority shall continue to report the results of chemical analyses and any aquatic toxicity test required above in Section 5 and the referenced Attachment 1 by electronic submission of DMRs under this permit to the Department using NetDMR in satisfaction of the DMR submission requirement of this permit. The report shall include a detailed explanation of any violations of the limitations specified. DMRs shall be submitted electronically to the Department no later than the 15th day of the month following the month in which samples are collected.
 - (1) For composite samples, from other than automatic samplers, the instantaneous flow and the time of each aliquot sample collection shall be recorded and maintained at the POTW.
- (B) Complete and accurate test data, including percent survival of test organisms in each replicate test chamber, LC₅₀ values and 95% confidence intervals for definitive test protocols, and all supporting chemical/physical measurements performed in association with any aquatic toxicity test, shall be entered on the Aquatic Toxicity Monitoring Report form (ATMR) and sent to the Bureau of Water Protection and Land Reuse at

the address specified below by the 15th day of the month following the month in which samples are collected:

ATTN: Municipal Wastewater Monitoring Coordinator
Connecticut Department of Energy and Environmental Protection
Bureau of Water Protection and Land Reuse
Water Planning and Management Division
79 Elm Street
Hartford, Connecticut 06106-5127

- (C) The results of the process monitoring required above in Section 5 shall be entered on the Monthly Operating Report (MOR) form, included herein as Attachment 2, and reported to the Bureau of Water Protection and Land Reuse. The MOR report shall also be accompanied by a detailed explanation of any violations of the limitations specified. The MOR must be received at the address specified above in Section 7 (B) of this permit by the 15th day of the month following the month in which the data and samples are collected.

SECTION 8: RECORDING AND REPORTING OF VIOLATIONS, ADDITIONAL TESTING REQUIREMENTS, BYPASSES, MECHANICAL FAILURES, AND MONITORING EQUIPMENT FAILURES

- (A) If any Acute Aquatic Toxicity sample analysis indicates toxicity, or that the test was invalid, an additional sample of the effluent shall be collected and tested for Acute Aquatic Toxicity and associated chemical parameters, as described above in Section 5 and Section 6, and the results reported to the Bureau of Water Protection and Land Reuse (Attn: Aquatic Toxicity) via the ATMR form (see Section 7 (B)) within thirty (30) days of the previous test. These test results shall also be reported on the next month's DMR report pursuant to Section 7 (A). The results of all toxicity tests and associated chemical parameters, valid and invalid, shall be reported.
- (B) If any two consecutive Acute Aquatic Toxicity test results or any three Acute Aquatic Toxicity test results in a twelve month period indicates toxicity, the Permittee shall immediately take all reasonable steps to eliminate toxicity wherever possible and shall submit a report, to the Bureau of Water Protection and Land Reuse (Attn: Aquatic Toxicity), for the review and written approval of the Commissioner in accordance with Section 22a-430-3(j)(10)(c) of the RCSA describing proposed steps to eliminate the toxic impact of the discharge on the receiving water body. Such a report shall include a proposed time schedule to accomplish toxicity reduction and the Permittee shall comply with any schedule approved by the Commissioner.
- (C) Sewage Right-to-Know Bypass Reporting
- (1) Section 22a-430-3(k) of the RCSA shall apply in all instances of bypass including a bypass of the treatment plant or a component of the sewage collection system planned during required maintenance. The Department of Energy and Environmental Protection, Bureau of Water Protection and Land Reuse, Water Planning and Management Division, Municipal Wastewater, the Department of Public Health, Water Supply Section and Recreation Section, and the local Director of Health shall be notified **within two (2) hours** of the Permittee learning of the event via online reporting in a format approved by the Commissioner. A final incident report shall be submitted to the Department of Energy and Environmental Protection, Bureau of Water Protection and Land Reuse, Water Planning and Management Division, Municipal Wastewater **within five (5) days** of the Permittee learning of each occurrence of a discharge or bypass of untreated or partially treated sewage via online reporting in a format approved by the Commissioner.
- If the online reporting system is nonfunctional for either bypass reporting requirement noted above, then the Permittee shall notify DEEP via telephone during normal business hours (8:30 a.m. to 4:30 p.m. Monday through Friday) at (860) 424-3704 or after hours to the DEEP Emergency Response Unit at (860) 424-3338 and the Department of Public Health at (860) 509-8000 with the final incident report being submitted online.
- (2) The Permittee must notify the Department of Agriculture/Aquaculture Bureau **within two (2) hours** of the Permittee learning of the event by telephone at (203) 209-4023 of each occurrence of an emergency diversion or by-pass of untreated or partially treated sewage or the failure of any major component of the treatment facilities which the Permittee may have reason to believe would result in an effluent violation. Notification must be made during evening, weekend and holiday hours in addition to regular business hours.
- (D) Section 22a-430-3(j) 11 (D) of the RCSA shall apply in the event of any noncompliance with a maximum daily limit and/or any noncompliance that is greater than two times any permit limit. The Permittee shall notify the Department of Energy and Environmental Protection, Bureau of Water Protection and Land Reuse, Water Planning and Management Division, Municipal Wastewater Section in the same manner as in paragraph C (1) of this Section. If the online reporting system is nonfunctional and the noncompliance occurs outside normal working hours (8:30 a.m. to 4:30 p.m. Monday through Friday) the Permittee may wait to make the verbal report no later than 10:30 am of the next business day after learning of the noncompliance.
- (E) Section 22a-430-3(j) 8 of the RCSA shall apply in all instances of monitoring equipment failures that prevent meeting the requirements in this permit. In the event of any such failure of the monitoring equipment including, but not limited to, loss of refrigeration for an auto-sampler or lab refrigerator or loss of flow proportion sampling ability, the Permittee shall notify the Department of Energy and Environmental

Protection, Bureau of Water Protection and Land Reuse, Water Planning and Management Division, Municipal Wastewater Section in the same manner as in paragraph C (1) of this Section. If the online reporting system is nonfunctional and the failure occurs outside normal working hours (8:30 a.m. to 4:30 p.m. Monday through Friday) the Permittee may wait to make the verbal report no later than 10:30 am of the next business day after learning of the failure.

- (F) In addition to the reporting requirements contained in Section 22a-430-3(i), (j), and (k) of the RCSA, the Permittee shall notify the Department of Energy and Environmental Protection, Bureau of Water Protection and Land Reuse, Water Planning and Management Division, Municipal Wastewater in the same manner as in paragraph C (1) of this Section concerning the failure of any major component of the treatment facilities which the Permittee may have reason to believe would result in an effluent violation.

SECTION 9: COMBINED SEWER OVERFLOW

- (A) The Permittee shall continue to implement Best Management Practices (BMPs) to reduce the impact of existing combined sewage overflow(s) (CSO or CSOs) on the receiving waters. Detailed records of BMP activities shall be kept.
- (1) The Permittee has identified **Lauren McBennett-Mappa** as operations and maintenance manager to be in responsible charge of the wastewater collection system and serve as the contact person for Department personnel regarding CSOs. **Within ten (10) days** after retaining anyone other than the identified individual, the Permittee shall notify the Commissioner in writing of the identity of any other appointed operations and maintenance manager.
 - (2) The Permittee shall use, to the maximum extent practicable, available sewerage system transportation capabilities for the conveyance of combined sewage to treatment facilities.
 - (3) The Permittee is authorized to discharge combined sewage flows from CSO outfalls listed in Attachment 3 in response to wet weather flow (i.e. rainfall or snowmelt conditions), when total available transportation, treatment and storage capabilities are exceeded. Dry weather discharges are prohibited. Any dry weather discharge from the CSO outfalls listed in Attachment 3 constitutes a bypass and is subject to the requirements of Section 8(C) of this permit.
 - (4) The locations of outfalls and regulators listed in Attachment 3 are based on Department records. Any information on the locations of any outfalls and regulators in addition to or in conflict with those listed in Attachment 3 shall be submitted to the Commissioner within thirty (30) days of the effective date of this permit or the date the Permittee becomes aware of such information, whichever is earlier.
 - (5) When the WWTF influent flows exceed 24 MGD, in response to wet weather flow (i.e. rainfall or snowmelt conditions), the Permittee is authorized to treat those flows above 24 MGD, chlorine disinfected primary treated combined sewer wastewater for discharge through outfall serial number 001-1.
 - (6) The discharge from any CSO, including outfall serial number 001-1, shall not contain septage or holding tank waste.
 - (7) Discharges from CSOs, including outfall serial number 001-1, shall not cause violations of State Water Quality Standards.
 - (8) The sewage system shall be inspected and maintained such that deposition of solids and/or other obstructions do not cause restrictions in flow resulting in CSOs and to ensure that dry weather discharges are not occurring.
 - (9) The Permittee shall reduce excessive infiltration/inflow to the sewer system.
 - (10) The Permittee shall review its existing Sewer Use Ordinance, to ensure the language required under Section 4(D) of this permit has been incorporated. A copy of ordinance shall be submitted for the Commissioner's review. At any such time as the ordinance is revised, a copy of the ordinance must be submitted, within sixty (60) days from the effective date of the revision date, for the Commissioner's review. The Sewer Use Ordinance shall:
 - (a) prohibit the construction of new combined sewers except in cases where repair or replacement of the existing system is approved in writing by the Commissioner, and
 - (b) prohibit the introduction of new inflow sources to the existing system.
 - (11) The Permittee shall complete monthly CSO inspection forms for all CSO structures/regulators, pumping stations and tidegates. Such forms shall also verify the existence of identification signs for all CSO outfall structures using the format below:

The signs shall be located at or near the combined sewer outfall structures so that they are easily readable by the public. These signs shall be a minimum of 12 x 18 inches in size, with white lettering against a green background, and shall contain the following information and image:

(PERMITTEE NAME)

WET WEATHER SEWAGE
DISCHARGE OUTFALL (discharge serial number)



Anyone observing a discharge from this outfall during dry weather conditions should call and report it to the Permittee at [____], and to the Department of Energy and Environmental Protection at (860) 424-3704 or 424-3338.

(B) CSO Monitoring Plan

Within 180 days of the effective date of this permit, the Permittee shall submit, for the Commissioner's review and approval, an updated plan to strategically monitor each combined sewer discharge at all CSOs within the sewer system with a permanent metering system. Such plan shall include an order of priority and a schedule to implement the monitoring plan within one year of DEEP's approval of such plan.

(C) Annual CSO Monitoring Report

Annually, on or before February 15th, the Permittee shall submit an Annual CSO Monitoring Report on a form and in a manner prescribed by the Commissioner, including the results of all monitoring from the previous calendar year for each combined sewer outfall including those treated CSO flows going to outfall serial number 001-1.

The Annual CSO Monitoring Report shall include the following information:

- (1) a list of open CSO outfalls in the system including name/designation, location, size of structure and their receiving waters;
- (2) a list of CSO structures in the system that were sealed in the last calendar year including name/designation, location, size of structure, their receiving waters, and the physical method used to seal that CSO as approved by the Commissioner;
- (3) the date, time, and duration of each precipitation event causing CSO discharges;
- (4) the date, time, duration, and estimation of volume for each discharge event for each CSO structure;
- (5) the date, time, duration, quality and volume for each discharge event for treated CSO flows to outfall serial number 001-1;
- (6) monthly CSO inspection forms for all CSO structures/regulators, pumping stations and tidegates, which also verify the existence of identification signs for all combined sewer outfall structures using the format required by Section 9(A)(11) above.
- (7) a list of Best Management Practices (BMPs) that have been used to reduce the impact of existing CSOs on the receiving waters; and
- (8) a summary of upcoming CSO mitigation efforts for the next 5 years.

- (D)** In the event that the Permittee becomes aware that it did not or may not comply, or did not or may not comply on time, with any requirement of this Section of the permit or of any document required hereunder, the Permittee shall immediately notify the Commissioner and shall take all reasonable steps to ensure that any noncompliance or delay is avoided or, if unavoidable, is minimized to the greatest extent possible. In so notifying the Commissioner, the Permittee shall state in writing the reasons for the noncompliance or delay and propose, for the review and written approval of the Commissioner, dates by which compliance will be achieved, and the Permittee shall comply with any dates which may be approved in writing by the Commissioner. Notification by the Permittee shall not excuse noncompliance or delay, and the Commissioner's approval of any compliance dates proposed shall not excuse noncompliance or delay unless specifically so stated by the Commissioner in writing.

(E) Any document, other than a DMR, ATMR or MOR required to be submitted to the Commissioner under this Section of the permit shall, unless otherwise specified in writing by the Commissioner, be directed to:

CSO Coordinator
Department of Energy and Environmental Protection
Bureau of Water Protection and Land Reuse
Water Planning and Management Division
Municipal Wastewater
79 Elm Street
Hartford, Connecticut 06106-5127

(F) Right-to-know Untreated CSO Discharge Reporting

(1) Initial CSO Discharge Report

The Permittee shall notify the Department of Energy and Environmental Protection, Bureau of Water Protection and Land Reuse, Water Planning and Management Division, Municipal Wastewater (DEEP) and the Department of Agriculture/Aquaculture Division (DoAg) **within two (2) hours** of the Permittee's discovery of an untreated combined sewer overflow via the online reporting system in a format approved by the Commissioner. If the online reporting system is unavailable, then the Permittee shall notify DEEP and DoAg via telephone during normal business hours (8:30 a.m. to 4:30 p.m. Monday through Friday) at (860) 424-3704 and (203) 874-0696, respectively, or after hours to DEEP Emergency Response Unit at (860) 424-3338 and DoAg at (203) 874-0696.

(2) Follow-Up Untreated CSO Discharge Written Report

A final incident report shall be submitted to the Department of Energy and Environmental Protection, Bureau of Water Protection and Land Reuse, Water Planning and Management Division, Municipal Wastewater via the online reporting system in a format approved by the Commissioner **within five (5) days** of the Permittee learning of each occurrence of a combined sewer overflow of untreated sewage.

This permit is hereby issued on

Graham J. Stevens
Bureau Chief
Bureau of Water Protection and Land Reuse

ATTACHMENT 1

Tables A through G

DRAFT

TABLE A

Discharge Serial Number (DSN): 001-1						Monitoring Location: 1				
Wastewater Description: Sanitary Sewage										
Monitoring Location Description: Final Effluent										
Allocated Zone of Influence (ZOI): 293.5 cfs						In-stream Waste Concentration (IWC): 5.95 %				
PARAMETER	Units	FLOW/TIME BASED MONITORING				INSTANTANEOUS MONITORING			REPORT FORM	Minimum Level Analysis See Section 6
		Average Monthly Limit	Maximum Daily Limit	Sample Freq.	Sample type	Instantaneous Limit or Required Range ³	Sample Freq.	Sample Type		
Alkalinity	mg/l	NA	NA	NR	NA	-----	Monthly	Grab	MOR	
Biochemical Oxygen Demand (5 day) ^{1, 5} (See remarks D and E below)	mg/l	30 mg/l	50 mg/l	3/week	Daily Composite	NA	NR	NA	DMR/MOR	
Carbonaceous BOD (5 day) ⁶	mg/l	-----	-----	Monthly	Daily Composite	NA	NR	NA	DMR/MOR	
Chlorine, Total Residual ⁵ (See remark A below)	mg/l	0.05 ⁴	0.10 ⁴	4/ Work Day	Grab	0.20	4/ Work Day	Grab	DMR/MOR	*
Fecal coliform ⁵ (See remark E below)	Colonies per100 ml	NA	NA	NR	NA	(See remark B below)	3/week	Grab	DMR/MOR	
Fecal coliform ⁵ (See remark E below)	Percent of samples exceeding 260 colonies per 100 ml	NA	NA	NR	NA	≤10	3/week	Grab	DMR/MOR	
Enterococci ⁵ (See remark C below)	Colonies per100 ml	NA	NA	NR	NA	500	3/week	Grab	DMR/MOR	
Flow	MGD	-----	-----	Continuous ²	Average Daily Flow	NA	NR	NA	DMR/MOR	
Nitrogen, Ammonia (total as N)	mg/l	NA	-----	Monthly	Daily Composite	NA	NR	NA	DMR/MOR	
Nitrogen, Nitrate (total as N)	mg/l	NA	-----	Monthly	Daily Composite	NA	NR	NA	MOR	
Nitrogen, Nitrite (total as N)	mg/l	NA	-----	Monthly	Daily Composite	NA	NR	NA	MOR	
Nitrogen, Total Kjeldahl	mg/l	NA	-----	Monthly	Daily Composite	NA	NR	NA	MOR	
Nitrogen, Total	mg/l	NA	-----	Monthly	Daily Composite	NA	NR	NA	MOR	
Nitrogen, Total	lbs/day	NA	-----	Monthly	Daily Composite	NA	NR	NA	MOR	
Oxygen, Dissolved	mg/l	NA	NA	NR	NA	-----	Work Day	Grab	MOR	
pH	S.U.	NA	NA	NR	NA	6 - 9	Work Day	Grab	DMR/MOR	

Phosphate, Ortho	mg/l	NA	-----	Monthly	Daily Composite	NA	NR	NA	MOR
Phosphorus, Total	mg/l	NA	-----	Monthly	Daily Composite	NA	NR	NA	DMR/MOR
Solids, Settleable	ml/l	NA	NA	NR	NA	-----	Work Day	Grab	MOR
Solids, Total Suspended ^{1, 5} (See remarks D and F below)	mg/l	30 mg/l	50 mg/l	3/week	Daily Composite	NA	NA	NA	DMR/MOR
Temperature	°F	NA	NA	NR	NA	-----	Work Day	Grab	MOR
Turbidity	NTU	NA	NA	NR	NA	-----	Work Day	Grab	MOR

TABLE A – CONDITIONS

Footnotes:

¹ The discharge shall not exceed an Average Monthly Limit of 30 mg/l or a Maximum Daily Limit of 50 mg/l. The Maximum Daily Limit of 50.0 mg/l for BOD₅ and 50.0 mg/l for Total Suspended Solids shall not apply during periods when the facility is treating dilute influent and influent flows exceed 24 MGD due to storm runoff collected by the Combined Sewer System. The Permittee shall report on the monthly Discharge Monitoring Reports and MORs when exceedance of the BOD₅ and/or the Total Suspended Solids limit(s) is due to storm induced flows.

² The Permittee shall record and report on the MOR the minimum, maximum and total flow for each day of discharge and the average daily flow for each sampling month. The Permittee shall report, on the discharge monitoring report, the average daily flow and maximum daily flow for each sampling month.

³ The instantaneous limits in this column are maximum limits.

⁴ The maximum daily concentration to be reported shall be determined by mathematically averaging the results of the four grab samples required above. The average monthly concentration shall be determined by mathematically averaging the results of the maximum daily concentrations required above.

⁵ When the influent flows exceed 24 MGD due to storm events, the Permittee may bypass secondary biological treatment only for those flows over 24 MGD. The bypassed flows over 24 MGD shall receive a minimum of primary treatment and disinfection. In addition to Table A requirements, during bypass events, the bypasses shall be sampled daily for the entirety of the event in accordance with Table A-1 below.

⁶ CBOD test to be performed on the same sample as the BOD test for comparative purposes.

Remarks:

(A) Chlorine disinfection shall be utilized year-round.

(B) The geometric mean of the Fecal coliform bacteria values for the effluent samples collected in a period of a calendar month shall not exceed 88 colonies per 100 milliliters.

(C) The geometric mean of the Enterococci bacteria values for the effluent samples collected in a period of a calendar month shall not exceed 35 colonies per 100 milliliters

(D) The Average Weekly Discharge Limitation for BOD₅ and Total Suspended Solids shall be 1.5 times the Average Monthly Limit listed above.

(E) In addition to the discharge limits included herein and with the exception of bypass events due to storm-induced flows exceeding 24 MGD, the following conditions shall apply:

- (i) Biochemical Oxygen Demand shall not exceed 50 mg/l on a 6 consecutive hour average.
- (ii) Total Suspended Solids content shall not exceed 50 mg/l on a 6 consecutive hour average.
- (iii) Fecal Coliform content shall not exceed:
 - (a) 800 colonies per 100 ml on a 6 consecutive hour geometric mean.
 - (b) No sample may contain more than 2,400 colonies per 100 ml.

TABLE A-1

Discharge Serial Number: 001-1 (B)			Monitoring Location: 8			
Wastewater Description: Final effluent during secondary treatment bypass events						
Monitoring Location Description: Final Effluent during secondary treatment bypass events						
PARAMETER	Units	FLOW/TIME BASED MONITORING			INSTANTANEOUS MONITORING	
		Sample Frequency	Sample Type	Sample Frequency	Sample Type	Reporting form
BOD (5 day)	mg/l	Daily/event ^{1, 3}	Daily Composite	NA	NA	DMR/MOR
Chlorine Residual (TRC) (May 1st through Sept. 30 th)	mg/l	NA	NA	Daily/event ^{1, 3}	Grab	DMR/MOR
Event Duration	Days, hours, minutes	Continuous ²	Time	NA	NA	DMR/MOR
Fecal Coliform	Colonies per 100 ml	NA	NA	Daily/event ^{1, 3}	Grab	DMR/MOR
Enterococci	Colonies per 100 ml	NA	NA	Daily/event ^{1, 3}	Grab	DMR/MOR
Flow	MGD	Continuous ²	Daily Flow	NA	NA	DMR/MOR
Solids, Total Suspended	mg/l	Daily/event ^{1, 3}	Daily Composite	NA	NA	DMR/MOR

TABLE A-1 - CONDITIONS

Footnotes:

¹ For overflow events exceeding one calendar day in duration, sampling shall be performed each day of the event according to the measurement frequency specified. For bypass events exceeding one (1) hour and less than 24 hours in duration, sampling shall be performed each day of the event according to the measurement frequency specified. If an overflow event exceeds 24 hours, the Permittee shall take daily composite samples for CBOD₅ and TSS, initiating samples at the start of the overflow event and each subsequent 24-hour period thereafter and terminating samples at the end of the overflow event. For example, for an overflow event that lasts for 54 hours, sampling would consist of 2, 24 hour composite samples and 1, 6 hour composite sample over the course of 3 days. Samples shall be flow proportional for BOD and TSS.

² When the facility is treating dilute influent due to storm runoff collected by the Combined Sewer System causing influent flows to exceed 24 MGD, the Permittee is authorized to allow flows above 24 MGD to bypass secondary treatment processes and be discharged as disinfected primary treated combined sewer wastewater.

³ During short duration overflow events (less than one hour in duration) or during intermittent overflow events (with no one overflow exceeding one hour), this sampling requirements of Table A-1 do not apply.

Remarks – Applicable to all parameters listed in Table A-1:

(a) Sampling data during permitted bypass events shall be excluded from the DMRs and shall be recorded on the MORs.

(b) The Permittee shall make reasonable efforts to maximize the amount of flow receiving final secondary treatment and complying with NPDES effluent limits described in Table A of the Permit.

(c) The reporting requirements of Section 8(C) of this permit do not apply for discharges during these bypass events.

(d) Total Residual Chlorine Limits are 0.2-1.5mg/l

(e) For any month with no overflow events, the Permittee shall enter on the DMR a No Data Indicator (“NODI”) code “9” for Discharge Serial Number 001-1 (B).

TABLE B

Discharge Serial Number (DSN): 001-1			Monitoring Location: K		
Wastewater Description: Sanitary Sewage					
Monitoring Location Description: Final Effluent					
Allocated Zone of Influence (ZOI): 293.5 cfs			In-stream Waste Concentration (IWC): 5.95 %		
PARAMETER	Units	FLOW/TIME BASED MONITORING			REPORT FORM
		Average Monthly Minimum	Sample Freq.	Sample type	
Biochemical Oxygen Demand (5 day) Percent Removal ^{1, 3}	% of Influent	85	3/week	Calculated ²	DMR
Solids, Total Suspended Percent Removal ^{1, 3}	% of Influent	85	3/week	Calculated ²	DMR

TABLE B – CONDITIONS

Footnotes:

¹ The discharge shall be less than or equal to 15% of the average monthly influent BOD₅ and Total Suspended Solids (Table E, Monitoring Location G). The 15% provision is waived during periods when the facility is treating dilute influent due to storm runoff collected by the Combined Sewer System causing influent flows to exceed 24 MGD. The Permittee shall state on the monthly Discharge Monitoring Reports and MORs when exceedance of the 15% provision is due to storm induced flows.

² Calculated based on the average monthly results described in Table A. Removal efficiency = $\frac{\text{Inf.BOD or TSS} - \text{Effluent BOD or TSS}}{\text{Inf.BOD or TSS}} \times 100$

³ When the influent flows exceed 24 MGD due to storm events, the Permittee may bypass secondary biological treatment. During bypass events, the removal efficiency for these parameters shall be sampled daily during the event. During short duration bypass events (less than one hour in duration) or during intermittent bypass events (with no one bypass exceeding one hour), this sampling requirement does not apply. For bypass events exceeding one hour and less than 24 hours in duration, sampling shall be performed each day of the event according to the measurement frequency specified. If a bypass event covers all or part of three calendar days, the Permittee shall take three daily composite samples for BOD₅ and TSS, initiating samples at the start of the bypass event and each subsequent calendar day and terminating samples at the end of the calendar day or at the end of the bypass event. Samples shall be flow proportional.

TABLE C

Discharge Serial Number (DSN): 001-1			Monitoring Location: T			
Wastewater Description: Sanitary Sewage						
Monitoring Location Description: Final Effluent						
Allocated Zone of Influence (ZOI): 293.5 cfs			In-stream Waste Concentration (IWC): 5.95 %			
PARAMETER	Units	Maximum Daily Limit	Sampling Frequency	Sample Type	Reporting form	Minimum Level Analysis See Section 6
Aluminum, Total	mg/l	-----	Quarterly	Daily Composite	ATMR/DMR	*
Antimony, Total	mg/l	-----	Quarterly	Daily Composite	ATMR/DMR	*
NOAEL Static 48Hr Acute D. Pulex ¹	% survival	-----	Quarterly	Daily Composite	ATMR/DMR	
NOAEL Static 48Hr Acute Pimephales ¹	% survival	-----	Quarterly	Daily Composite	ATMR/DMR	
Arsenic, Total	mg/l	-----	Quarterly	Daily Composite	ATMR/DMR	*
Beryllium, Total	mg/l	-----	Quarterly	Daily Composite	ATMR/DMR	*
BOD ₅	mg/l	-----	Quarterly	Daily Composite	ATMR/DMR	
Cadmium, Total	mg/l	-----	Quarterly	Daily Composite	ATMR/DMR	*
Chromium, Hexavalent	mg/l	-----	Quarterly	Daily Composite	ATMR/DMR	*
Chromium, Total	mg/l	-----	Quarterly	Daily Composite	ATMR/DMR	*
Chlorine, Total Residual	mg/l	-----	Quarterly	Daily Composite	ATMR/DMR	*
Copper, Total	mg/l	-----	Quarterly	Daily Composite	ATMR/DMR	*
Cyanide, Amenable	mg/l	-----	Quarterly	Daily Composite	ATMR/DMR	
Cyanide, Total	mg/l	-----	Quarterly	Daily Composite	ATMR/DMR	*
Iron, Total	mg/l	-----	Quarterly	Daily Composite	ATMR/DMR	*
Lead, Total	mg/l	-----	Quarterly	Daily Composite	ATMR/DMR	*
Mercury, Total	mg/l	-----	Quarterly	Daily Composite	ATMR/DMR	*
Nickel, Total	mg/l	-----	Quarterly	Daily Composite	ATMR/DMR	*
Nitrogen, Ammonia (total as N)	mg/l	-----	Quarterly	Daily Composite	ATMR/DMR	
Nitrogen, Nitrate, (total as N)	mg/l	-----	Quarterly	Daily Composite	ATMR/DMR	
Nitrogen, Nitrite, (total as N)	mg/l	-----	Quarterly	Daily Composite	ATMR/DMR	
Phenols, Total	mg/l	-----	Quarterly	Daily Composite	ATMR/DMR	
Phosphorus, Total	mg/l	-----	Quarterly	Daily Composite	ATMR/DMR	
Selenium, Total	mg/l	-----	Quarterly	Daily Composite	ATMR/DMR	*
Silver, Total	mg/l	-----	Quarterly	Daily Composite	ATMR/DMR	*
Suspended Solids, Total	mg/l	-----	Quarterly	Daily Composite	ATMR/DMR	
Thallium, Total	mg/l	-----	Quarterly	Daily Composite	ATMR/DMR	*
Zinc, Total	mg/l	-----	Quarterly	Daily Composite	ATMR/DMR	*
TABLE C - CONDITIONS						
¹ The results of the Toxicity Tests are recorded in % survival. The Permittee shall report % survival on the DMR based on criteria in Section 6(B) of this permit.						
ATMR – Aquatic Toxicity Monitoring Report						

TABLE D

Discharge Serial Number: 001-1		Monitoring Location: N		
Wastewater Description: Activated Sludge				
Monitoring Location Description: Each Aeration Unit				
PARAMETER	REPORTING FORMAT	INSTANTANEOUS MONITORING		REPORTING FORM
		Sample Frequency	Sample Type	
Oxygen, Dissolved	High & low for each Work Day	4/Work Day	Grab	MOR
Sludge Volume Index	Work Day	Work Day	Grab	MOR
Mixed Liquor Suspended Solids	Work Day	Work Day	Grab	MOR

TABLE E

Discharge Serial Number: 001-1			Monitoring Location: G				
Wastewater Description: Sanitary Sewage							
Monitoring Location Description: Influent							
PARAMETER	Units	DMR REPORTING FORMAT	FLOW/TIME BASED MONITORING		INSTANTANEOUS MONITORING		REPORTING FORM
			Sample Frequency	Sample Type	Sample Frequency	Sample Type	
Biochemical Oxygen Demand (5 day)	mg/l	Monthly average	3/week	Daily Composite	NA	NA	DMR/MOR
Nitrogen, Ammonia (total as N)	mg/l	NA	Monthly	Daily Composite	NA	NA	MOR
Nitrogen, Nitrate (total as N)	mg/l	NA	Monthly	Daily Composite	NA	NA	MOR
Nitrogen, Nitrite (total as N)	mg/l	NA	Monthly	Daily Composite	NA	NA	MOR
Nitrogen, Total Kjeldahl	mg/l	NA	Monthly	Daily Composite	NA	NA	MOR
Nitrogen, Total	mg/l	NA	Monthly	Daily Composite	NA	NA	MOR
Phosphate, Ortho	mg/l	NA	Monthly	Daily Composite	NA	NA	MOR
Phosphorus, Total	mg/l	NA	Monthly	Daily Composite	NA	NA	MOR
pH	S.U.	NA	NA	NA	Work Day	Grab	MOR
Solids, Total Suspended	mg/l	Monthly average	3/week	Daily Composite	NA	NA	DMR/MOR
Temperature	°F	NA	NA	NA	Work Day	Grab	MOR

TABLE F

Discharge Serial Number: 001-1				Monitoring Location: P			
Wastewater Description: Primary Effluent							
Monitoring Location Description: Primary Sedimentation Basin Effluent							
PARAMETER	Units	REPORTING FORMAT	TIME/FLOW BASED MONITORING		INSTANTANEOUS MONITORING		REPORTING FORM
			Sample Frequency	Sample Type	Sample Frequency	Sample type	
Alkalinity, Total	mg/l	NA	NA	NA	Monthly	Grab	MOR
Biochemical Oxygen Demand (5 day)	mg/l	Monthly average	Weekly	Composite	NA	NA	MOR
Nitrogen, Ammonia (total as N)	mg/l	NA	Monthly	Composite	NA	NA	MOR
Nitrogen, Nitrate (total as N)	mg/l	NA	Monthly	Composite	NA	NA	MOR
Nitrogen, Nitrite (total as N)	mg/l	NA	Monthly	Composite	NA	NA	MOR
Nitrogen, Total Kjeldahl	mg/l	NA	Monthly	Composite	NA	NA	MOR
Nitrogen, Total	mg/l	NA	Monthly	Composite	NA	NA	MOR
pH	S.U.	NA	NA	NA	Monthly	Grab	MOR
Solids, Total Suspended	mg/l	Monthly average	Weekly	Composite	NA	NA	MOR

TABLE G

Discharge Serial Number: 001-1		Monitoring Location: SL	
Wastewater Description: Thickened Sludge			
Monitoring Location Description: At sludge draw off			
PARAMETER	INSTANTANEOUS MONITORING		REPORTING FORM
	Units	Grab Sample Freq.	
Arsenic, Total	mg/kg	Bi-monthly	DMR
Beryllium, Total	mg/kg	Bi-monthly	DMR
Cadmium, Total	mg/kg	Bi-monthly	DMR
Chromium, Total	mg/kg	Bi-monthly	DMR
Copper, Total	mg/kg	Bi-monthly	DMR
Lead, Total	mg/kg	Bi-monthly	DMR
Mercury, Total	mg/kg	Bi-monthly	DMR
Nickel, Total	mg/kg	Bi-monthly	DMR
Nitrogen, Ammonia *	mg/kg	Bi-monthly	DMR*
Nitrogen, Nitrate (total as N) *	mg/kg	Bi-monthly	DMR*
Nitrogen, Organic *	mg/kg	Bi-monthly	DMR*
Nitrogen, Nitrite (total as N) *	mg/kg	Bi-monthly	DMR*
Nitrogen, Total *	mg/kg	Bi-monthly	DMR*
pH *	S.U.	Bi-monthly	DMR*
Polychlorinated Biphenyls	mg/kg	Bi-monthly	DMR
Solids, Fixed	%	Bi-monthly	DMR
Solids, Total	%	Bi-monthly	DMR
Solids, Volatile	%	Bi-monthly	DMR
Zinc, Total	mg/kg	Bi-monthly	DMR
<p>(*) required for composting or land application only Testing for inorganic pollutants shall follow "Test Methods for Evaluating Solid Waste, Physical/Chemical Methods", EPA Publication SW-846 as updated and/or revised.</p>			

ATTACHMENT 2
MONTHLY OPERATING REPORT FORM

DRAFT

ATTACHMENT 3

CSO REGULATORS AND DISCHARGE POINTS

City of Bridgeport East Side NPDES Permitted Regulators, as of August 2020
Permit ID: CT0101010

NPDES #	MNEUMONIC	LOCATION	RECEIVING WATER
153	WANN 153	Waterview & Ann Street	Yellow Mill Pond
22	CHUR 22	Church Street West of Waterview	Yellow Mill Pond
16	DEAC 16	Seaview & Deacon Street	Yellow Mill Pond
12	STRAT	Connecticut & Stratford	Yellow Mill Pond
6	BAYEL 6	Bay St & Mildner Dr	Johnson's Creek
18	BARN 18	Seaview & Barnum	Yellow Mill Pond

DATA TRACKING AND TECHNICAL FACT SHEET

PERMITTEE: City of Bridgeport

PERMIT, ADDRESS, AND FACILITY DATA

PERMIT #: CT0101010 APPLICATION #: 202006182 FACILITY ID. 015-002

<u>Mailing Address:</u> Street: 695 Seaview Avenue City: Bridgeport ST: CT Contact Name: Lauren Mappa, P.E. Phone No.: 203-332-5550	<u>Location Address:</u> Street: 695 Seaview Avenue City: Bridgeport ST: CT Zip: 06607 Contact Name: Lauren Mappa, P.E. Phone No.: 203-332-5550 DMR Contact Lauren.ncbennettmappa@bridgeportct.gov email address:
---	---

PERMIT INFORMATION

DURATION 5 YEAR X 10 YEAR ___ 30 YEAR ___

TYPE New ___ Reissuance X Modification ___

CATEGORIZATION POINT (X) NON-POINT () GIS #

NPDES (X) PRETREAT () GROUND WATER(UIC) () GROUND WATER (OTHER) ()

NPDES MAJOR(MA) X

NPDES SIGNIFICANT MINOR or PRETREAT SIU (SI) ___

NPDES or PRETREATMENT MINOR (MI) ___

COMPLIANCE SCHEDULE YES ___ NO X

POLLUTION PREVENTION ___ TREATMENT REQUIREMENT ___

WATER QUALITY REQUIREMENT ___ OTHER ___

OWNERSHIP CODE

Private ___ Federal ___ State ___ Municipal (town only) X Other public ___

DEEP STAFF ENGINEER Ann Straut

DATE DRAFTED: 18 May 2020

PERMIT FEES

Discharge Code	DSN Number	Annual Fee
111000e	001-1	\$3,005.00

APPLICATION FEE PAID on 7/15/2020

PROCESSING FEE PAID on 10/1/2020

ANNUAL FEE PAID on 10/14/2020

PUBLIC NOTICE

Date of Public Notice: _____

Date Permit Cleared Public Notice: _____

Date Public Notice Fees Paid: _____

FOR NPDES DISCHARGES

Drainage Basin Code: NA Water Quality Classification Goal: SB Segment: Bridgeport Harbor

NATURE OF BUSINESS GENERATING DISCHARGE

Municipal Sanitary Sewage Treatment

PROCESS AND TREATMENT DESCRIPTION (by DSN)

001-1: Screening, degritting, primary and secondary treatment with denitrification, chlorine disinfection and dechlorination.

RESOURCES USED TO DRAFT PERMIT

- Federal Effluent Limitation Guideline 40CFR 133* Secondary Treatment Category
- Performance Standards*
- Federal Development Document* *name of category*
- Department File Information*
- Connecticut Water Quality Standards*
- Anti-degradation Policy*
- Coastal Management Consistency Review Form*
- Other - Explain*

BASIS FOR LIMITATIONS, STANDARDS OR CONDITIONS

- Secondary Treatment (Section 22a-430-4(r) of the Regulations of Connecticut State Agencies)*
- Case-by-Case Determination (See Other Comments)*
- In order to meet in-stream water quality (See General Comments)*
- Anti-degradation policy*

GENERAL COMMENTS

The City of Bridgeport ("Permittee") operates a municipal water pollution control facility ("the facility") located at 695 Seaview Avenue, Bridgeport. The facility is designed to treat and discharge up to 10 million gallons a day of effluent into Bridgeport Harbor. The facility currently uses secondary treatment with denitrification and chlorine disinfection to treat effluent before being discharged. Pursuant to Conn. Gen. Stat. § 22a-430, the Department of Energy and Environmental Protection has issued the City of Bridgeport a permit for the discharge from this facility. The City of Bridgeport has submitted an application to renew its permit. The Department has made a tentative determination to approve The City of Bridgeport's application and has prepared a draft permit consistent with that determination.

The most significant change from the current permit is the removal of the copper limits based on a review of 5 years' worth of weekly copper data and the reasonable potential analysis showing a low statistical probability of exceeding such limits. Aluminum monitoring has been continued to be consistent with the most recent CT Water Quality Standards and Iron monitoring has been continued to be consistent with EPA's National Recommended Water Quality Criteria. CBOD monitoring has been included in the new permit as a monitoring-only parameter to be tested once per month. The CBOD data will be used by DEEP's water quality group to model water quality conditions in receiving streams. No limits are established since the water quality of the receiving water body is under evaluation and a TMDL has not been established.

SUMMARY OF COMMENTS RECEIVED DURING THE PUBLIC NOTICE PERIOD AND THE

DEPARTMENT'S RESPONSES

- The Department has received no written comments on the proposed action.*
- Staff has reviewed the written comments and responded to the comments, no significant permit changes have been made.*
- The Department has received and Staff has reviewed written comments on the proposed action and made significant changes as follows:*

SPECIFIC REQUIREMENTS OR REVISIONS

The Department reviewed the application for consistency with Connecticut's Water Quality Standards and determined that with the limits in the draft permit, including those discussed below, that the draft permit is consistent with maintenance and protection of water quality in accordance with the Tier I Anti-degradation Evaluation and Implementation Review provisions of such Standards.

The need for inclusion of water quality-based discharge limitations in this permit was evaluated consistent with Connecticut Water Quality Standards and criteria, pursuant to 40 CFR 122.44(d). Discharge monitoring data was evaluated for consistency with the available aquatic life criteria (acute and chronic) and human health (fish consumption only) criteria, considering the zone of influence allocated to the facility where appropriate. In addition to this review, the statistical procedures outlined in the EPA Technical Support Document for Water Quality-based Toxics Control (EPA/505/2-90-001) were employed to calculate the need for such limits. Comparison of the attached monitoring data and its inherent variability with the calculated water quality-based limits indicates a low statistical probability of exceeding such limits. Therefore, no water quality-based limits were included in the permit at this time.

WATER QUALITY LIMIT CALCULATIONS

See attached

OTHER COMMENTS:

A Public Scoping Meeting for this project was conducted on October 29, 2020 associated with the Facilities Planning for East Side and West Side Wastewater Treatment Plants. The City of Bridgeport owns and operates two wastewater treatment plants which are the subject of Administrative Order AOWRMU19001 issued by DEEP on March 1, 2019 requiring a facilities planning report to be submitted to DEEP on or before November 30, 2020. Based on previously submitted engineering reports, inspection reports and parameter testing results, a number of upgrades at both plants will be required by the Administrative Order for the treatment plants to treat to a level that protects human health and the environment. Both plants have exceeded their ability to function properly including a building that was deemed unfit for habitation that had to be demolished. The following items are being investigated during this facility planning stage: Liquid Stream Alternatives, Solids Processing Alternatives, Plant Consolidation, High Flow Management/Maximization of Flow to WWTP(s), Operability/ Construction Assessment, Resiliency to Storms, Flooding and Climate Change, Outfall Inspection, Improvements, and Necessary Change, SCADA Evaluation, and Odor Control Evaluation.

Consistent with the language in the existing permit, the proposed renewal continues to include language regarding compliance with the Interstate Environmental Commission (IEC) Water Quality Regulations promulgated pursuant to the authority conferred upon the IEC by the Tri-State Compact (CGS 22a-294 et seq.) for effluent limitations as follows:

- (i)** Biochemical Oxygen Demand shall not exceed 50 mg/l on a 6 consecutive hour average.
- (ii)** Total Suspended Solids content shall not exceed 50 mg/l on a 6 consecutive hour average.
- (iii)** Fecal Coliform content shall not exceed:
 - (a)** 800 colonies per 100 ml on a 6 consecutive hour geometric mean.
 - (b)** No sample may contain more than 2,400 colonies per 100 ml.

**Notice of Tentative Determination to Approve
NPDES Permit Renewal
Applicant: City of Bridgeport
Application No. 202006182
City/Town: Bridgeport**

The Commissioner of the Department of Energy and Environmental Protection (“DEEP”) hereby gives notice that a tentative determination has been reached to approve the following application.

Applicant’s Name and Address: City of Bridgeport, 999 Broad Street, Bridgeport, CT 06604

Contact Name and Phone No.: Lauren Mappa (203) 332-5550

Type of Permit and #: NPDES – CT0101010

Type of Facility: Domestic Wastewater Treatment

Facility Location: East Side WPCF, 695 Seaview Ave., Bridgeport, CT 06607

Facility design capacity: 10.0 million gallons per day

COMMISSIONER’S FINDINGS/REGULATORY CONDITIONS

The applicant has previously received a permit from the Department of Energy and Environmental Protection (“Department”) authorizing the discharge of up to an annual average daily design flow of 10.0 million gallons a day of secondary treated municipal wastewaters to the Bridgeport Harbor. The applicant has submitted an application to renew its existing permit. This renewal application is the subject of this notice.

THE DRAFT PERMIT

The Department has prepared a draft permit consistent with the tentative determination to approve City of Bridgeport’s renewal application. This draft is available on the public participation section of the Department’s website. In accordance with Sections 22a-430-4(l) and 22a-430-4(r) of the Regulations of Connecticut State Agencies (RCSA), the draft permit contains effluent limitations that meet Connecticut’s Water Quality Standards for the following: Biochemical Oxygen Demand (5 day), chlorine, enterococci, fecal coliform, flow, pH, and total suspended solids.

INFORMATION REQUESTS/PUBLIC COMMENT

This application has been assigned No. 202006182; please use this number when corresponding with DEEP regarding this application. Interested persons may obtain copies of the application from the applicant at the above address. Due to the ongoing Covid-19 virus pandemic, the Department of Energy and Environmental Protection located at 79 Elm Street, Hartford, CT is closed to the public until further notice. However, electronic copies of the application and supporting documentation can

be provided to interested persons via email. Any such requests for electronic documents may be directed to Ann Straut of the Municipal Wastewater Section at 860-424-3137 or ann.straut@ct.gov.

Before making a final decision on this application, the Commissioner shall consider written comments on the application from interested persons. Written comments on the application should be directed to Ann Straut via electronic mail to: ann.straut@ct.gov no later than thirty (30) days from the publication date of this notice. Written comments may also be submitted in paper form to the Department of Energy and Environmental Protection located at 79 Elm Street, Bureau of Water Protection and Land Reuse Hartford, CT. In this submittal please identify the name of the staff assigned to the application, the permit application number and your phone number and/or email address to facilitate responses to your comments. Due to the Covid -19 virus Pandemic and social distancing measures implemented by DEEP staff, there could be delays in the response to your comments. You may contact the staff person identified in this notice with any questions you may have.

PETITIONS FOR HEARING

The Commissioner may conduct a public hearing if the Commissioner determines that the public interest will best be served thereby, or shall hold a hearing upon receipt of a petition signed by at least twenty-five persons. Petitions for a hearing shall be submitted within thirty (30) days from the date of publication of this public notice and should include the application number noted above and also identify a contact person to receive notifications. Petitions should also identify a person who is authorized to engage in discussions regarding the application and, if resolution is reached, withdraw the petition. In order to facilitate the filing of requests for hearing during the COVID-19 emergency and consistent with the Department's Temporary Directive, the Office of Adjudications will accept electronically-filed petitions in addition to petitions submitted by mail. Petitions with required signatures may be filed by email to deep.adjudications@ct.gov or mailed to the DEEP Office of Adjudications, 79 Elm Street, Hartford, CT 06106. Within thirty (30) days of filing the petition, original petitions that were filed electronically must be also be mailed to the Office at the above-noted address. If the original petition exists only in electronic format or signatures were produced using a computer or typewriter, the petition must be submitted with a statement bearing the wet-ink signature of the petitioner that the petition is only available in that format and has been submitted to satisfy the requirement that an original petition be filed. If a hearing is held, timely notice of such hearing will be published in a newspaper of general circulation and posted on the DEEP website at www.ct.gov/deep. Additional information at www.ct.gov/deep/adjudications.

Dated: 1/12/2021



Jennifer L. Perry, P.E.
Director
Water Planning and Management Division
Bureau of Water Protection and Land Reuse

The Connecticut Department of Energy and Environmental Protection is an Affirmative Action/Equal Opportunity Employer that is committed to complying with the requirements of the Americans with Disabilities Act. Please contact Barbara Viadella or Cenit Mirabal, DEEP Office of

Diversity and Equity at (860) 418-5910 or by email @ deep.accommodations@ct.gov if you are requesting a communication aid or service, have limited proficiency in English, need some other type of accommodation, or if you wish to file an ADA or Title VI discrimination complaint. In order to facilitate efforts to provide an accommodation, please request all accommodations as soon as possible following notice of any agency hearing, meeting, program or event.