Advanced Refrigeration Systems

Maintaining CO₂ Secondary & Cascade Systems

Wayne Rosa
Energy & Maintenance Manager
Food Lion, LLC







Food Lion, LLC














Hilton Minneapolis, MN September 19-22, 2010 $E + sd^{2010}$

Energy & Store Development Conference



Advanced Refrigeration Systems

2118 Dinwiddie, VA: MT Glycol Secondary Loop System (R507)

2663 Montpelier, VA: LT CO₂ Secondary System (R507)

2659 Portsmouth, VA: MT Glycol Secondary Loop System (R507)

LT CO₂ Secondary System (R507)

2161 College Park, GA: CO₂ Cascade System (R507)

2157 Columbia, SC: CO₂ Cascade System (R407A)

2191 Conyers, GA: CO₂ Cascade System (R407A)

Opened July 28, 2010

Hilton Minneapolis, MN September 19-22, 2010





Refrigerant Reductions

<u>Refrigerant</u>	Refrigerant/CO ₂ Charge (lbs)
--------------------	--

2118: R507/Glycol 500/???

2663: R507/CO₂ 350/900

2659: MT R507/Gycol 800/???

LT R507/CO₂ 300/900

2161: R507/CO₂ 1800/2248

2157: R407A/CO₂ 900/1450

2191: R407A/CO₂ 1000/1800

Hilton Minneapolis, MN September 19-22, 2010





Refrigerant Reductions

	<u>Refrigerant</u>	ARS (Ibs)	DX System (lbs)	Red	<u>uction</u>
2118:	R507	500	1150	650	(57%)
2663 :	R507	350	885	535	(60%)
2659 :	MT R507 LT R507	800 300	1753 1367	953 1067	(54%) (78%)
2161 :	R507	1800	3100	1300	(42%)
2157 :	R407A	900	3100	2200	(71%)
2191 :	R407A	1000	3100	2100	(68%)







Refrigerant Reductions - Savings

	<u>Refrigerant</u>	ARS (Ibs)	DX System (lbs)	<u>Savings</u>
2118 :	R507	500	1150	\$4,388
2663 :	R507	350	885	\$3,612
2659 :	MT R507 LT R507	800 300	1753 1367	\$6,433 \$7,202
2161 :	R507	1800*	3100	\$8,775
2157:	R407A	900**	3100	\$13,860
2191 :	R407A	1000	3100	\$13,230

*Refrigerant reclaim

**Glycol Loop reclaim

Hilton Minneapolis, MN September 19-22, 2010





Leak Rates

- Primary Refrigerant Leak Rate: 0%
 - Total refrigerant use (rolling 1 year August 2010)
 - Last refrigerant add was July 30, 2009
 - 1.79% rolling 1 year (60 lbs.)
- CO₂ operating leak rate:

42.7%

- CO₂ loss thru actual system failure (Leak 2350 lbs)
- 2010 (rolling 1 year thru August): 11,609 lbs CO2 used
 - Power Failure
 - Water Cooled Condenser (Freezing)
 - Volumetric expansion in system (PRV)
- Component failures (Pressure Relief Valves)







Refrigeration Costs

Advanced Refrigeration Systems:

- Average Refrigeration Cost is 49% of chain average.*
- Refrigeration CPSW calculation (Metric)
- Low Leak Rates and Low Refrigerant use

Refrigeration Costs include (CPSW):

- Refrigerant (includes CO₂)
- Refrigeration Parts
- Refrigeration Labor





^{*}Year to date 2010

Key to Successful Implementation

Manufacturer Sponsored Training

- Factory visit
 - Training by Engineering Department (Theory)
 - Equipment Assembly (Chillers, pumps, heat exchangers)
 - Promote equipment familiarity
- On-site during installation
 - Pipe routing
 - Control wiring





Key to Successful Implementation

Who to include:

- Installing Refrigeration Contractor
- Refrigeration Technician (In-House)
- Back-up/Service Contractor
- Energy Specialist (Refrig. Commissioning)

Require Factory Start-up





Installation

- Construction Cost Neutral
 - Electric Defrost Added Cost
 - EEV Added Cost
 - Generator/Condensing Unit



Challenges

CO₂ Availability

- Lead Times at Supply House (Week Delivery)
- Not Common stocking item at Supply House
- Build Relationship with Supply House
- Maintain Rack Capacity on Site

Proper Service Tools

- CO₂ Leak Detectors
- Heavy Duty Hoses for charging system
- Adaptors for CO₂ cylinders for system charging





Thank You

Questions?





