

SWTR Daily Reporting Sheet for UV Systems (<40 gpm)

MONTH _____
 YEAR _____

PWS ID # _____
 PWS NAME _____

UV validated dosage = _____
 Maximum flow rate allowed (gpm) = _____
 If Water Plant is Not Operating indicate "PO"

Date	Lamp Status (Safe (ON) - Alarm (Fail))	UV Intensity (Safe (OK) - Low (Fail))	Describe any maintenance or lamp change-outs
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			
25			
26			
27			
28			
29			
30			
31			

System cannot provide off-spec water more than 1 day/month (more than 5%). Off-spec occurs if you are serving inadequately treated water: Lamp is in failure alarm, UV intensity too low, UV unit off or bypassed, or flow rate >max gpm rated for the unit.