



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION IX
75 Hawthorne Street
San Francisco, CA 94105-3901

Apr 20, 2004

CERTIFIED MAIL 7000 0520 0021 6108 9816
RETURN RECEIPT REQUESTED

In Reply Refer To: CWA-308-9-04-002

Diane Tullos, Compliance Manager
Calpine, Greenleaf Unit 2
845 North Walton Avenue
Yuba City, California 95993

Subject: Request for Information and Self-Monitoring Order Under Section 308 of the Clean Water Act Concerning Greenleaf Unit 2.

Dear Ms. Tullos:

This Order is in response to our inspection of Greenleaf Unit 2 in which we found the discharge to be uncontrolled in nature for pH and the sampling to be unrepresentative of the various contributing waste streams. The key dates are as follows:

| KEY DATES | REQUEST FOR INFORMATION AND SELF-MONITORING ORDER CWA-308-9-04-002 |
|-----------|--|
| 05/28/04 | 1. Submit written responses to the February 29, 2004 inspection report. |
| 06/01/04 | 3. Begin one-year of wastewater self-monitoring under this Order. Monthly sampling for aluminum, copper, iron, molybdenum, zinc, total dissolved solids, and specific conductivity. Monthly summaries of pH and discharge flow rate. |
| 08/28/04 | 2. Submit a report that identifies each contributing waste stream to the sewer. 3. Part 3(d) One-time sampling of each contributing waste stream. |
| 05/31/05 | End self-monitoring under this Administrative Order. |
| * * * | Self-monitoring reports are due on the 28th day of each month for the samples collected during the previous calendar month. |

Under Section 308(a) of the Clean Water Act ("the Act") as amended [33 U.S.C. Section 1318(a)], the Administrator of EPA is authorized to require persons subject to the Act to furnish information, conduct monitoring, provide entry to the Administrator or authorized representatives and make reports as may be necessary to carry out the objectives of the Act. This authority has been duly delegated to the Chief of the Clean Water Act Compliance Office of Region 9.

Calpine is required to submit information and self-monitor as set forth as follows in items 1-14.

Compliance Determination

1. By **MAY 28, 2004**, Calpine shall submit a response to each of the numbered Sections 2.0 through 5.0 of the February 29, 2004 EPA inspection report.
2. By **AUGUST 28, 2004**, Calpine shall submit a report of sewer discharge that identifies each contributing waste stream by source of wastewater discharge, type of wastewater (ie. blowdown, wash water, condensate, etc.), operational schedule of wastewater discharge, and discharge volume or flow rate.

Self-Monitoring Requirements

3. From **JUNE 1, 2004 THROUGH MAY 31, 2005**, Calpine shall self-monitor the wastewater discharges from Greenleaf Unit 2 to the sewers from the sampling shack at the compliance point designated in this Order as IWD-LOC1 in accordance with the following sampling schedule:
 - a. **ONCE EVERY MONTH**, Calpine shall self-monitor for aluminum, copper, iron, molybdenum, zinc, total dissolved solids, and specific conductivity;
 - b. **ONCE EVERY MONTH**, Calpine shall summarize the continuous pH meter strip charts to reflect the following:
 - i. The number of minutes each day in which the pH is below 2.0;
 - ii. The number of minutes each day in which the pH is below 5.0;
 - iii. The number of minutes each day in which the pH is below 6.5;
 - iv. The number of minutes each day in which the pH is above 9.5;
 - v. The number of minutes each day in which the pH is above 12.5.
 - c. **ONCE EVERY MONTH**, Calpine shall report the discharge flow rate for each day.
 - d. **ONCE PRIOR TO AUGUST 28, 2004**, Calpine shall self-monitor each of the contributing waste streams (as identified under the requirements of item 2 above) for aluminum, copper, iron, molybdenum, zinc, total dissolved solids, specific conductivity, and pH.

4. Calpine shall self-monitor and analyze using the sampling protocols and EPA approved analytical methods (or equivalent) to achieve the listed detection limits indicated below:

| Parameters and Pollutants | Sampling Method Protocols | | Detection Limits |
|------------------------------|---------------------------|------------------|---------------------|
| | @ Sources | @ Sampling Shack | |
| flow rate | estimates | meter readings | - |
| aluminum | grab | 24-hr composite | 10 ug/l |
| copper | grab | 24-hr composite | 10 ug/l |
| iron | grab | 24-hr composite | 10 ug/l |
| molybdenum | grab | 24-hr composite | 10 ug/l |
| zinc | grab | 24-hr composite | 10 ug/l |
| pH | field grab | continuous | 0.1 s.u. |
| total dissolved solids | grab | 24-hr composite | 5 mg/l |
| specific conductivity | grab | 24-hr composite | - |

5. The sewer sampling of the discharges required in item 3(a) of this Order shall be representative of the overall discharge to the Yuba City sewers at the compliance sampling point IWD-LOC1, unless EPA approves a new sample point or points.

Submissions

6. By the **TWENTY-EIGHTH (28th) DAY OF EACH MONTH**, Calpine shall submit all self-monitoring results for the previous month. The first monthly report is due on July 28, 2004 for the June 2004 self-monitoring. The 12th-and-last monthly report is due on June 28, 2005 for the May 2005 self-monitoring.
7. For each sample, Calpine shall record the sample results, the EPA analytical methods used, the date, time and location of sampling, the type of sampling (ie. 24-hour composite or grab), and the name of the laboratory used.
8. All reports submitted pursuant to this Order shall be signed by a principal executive officer of Calpine and shall include the following statement:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, I certify that the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I certify that all wastewater samples analyzed and reported herein are representative of the ordinary process wastewater flow from this facility. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

9. All submissions shall be mailed to the following addresses:

U.S. ENVIRONMENTAL PROTECTION AGENCY

75 Hawthorne Street
San Francisco, California 94105
Attn: Greg V. Arthur (WTR-7)

REGIONAL WATER QUALITY CONTROL BOARD

11020 Sun Center Driver, No. 200
Rancho Cordova, California 95670
Attn: Melissa Hall

CITY OF YUBA CITY

302 Burns Drive
Yuba City, California 95991
Attn: Mike Paulucci

Standard Provisions

10. This letter is not and shall not be interpreted to be a National Pollutant Discharge Elimination System permit under Section 402 of the Act [33 U.S.C. Section 1342], nor a local industrial user permit under 40 CFR Part 403.8(f)(iii). In addition, this letter shall not in any way extinguish, waive, satisfy, or otherwise affect Calpine's obligation to comply with the Act or its regulations, as well as any other Federal, State or local law, including the sewer use ordinance for the City of Yuba City.
11. Failure to comply with this letter constitutes a violation of the Clean Water Act, for which Calpine could be liable for civil or criminal penalties, as provided in Section 309 of the Act, [33 U.S.C. Section 1319].
12. EPA has promulgated regulations to protect the confidentiality of the business information it receives. These regulations are set forth in 40 CFR Part 2, Subpart B and in the Federal Register at 41 F.R. 36902 (September 1, 1976) and 43 F.R. 40000 (September 8, 1978). A claim of business confidentiality may be asserted in the manner specified by 40 CFR Section 2.203(b) for part or all of the information requested. EPA will disclose business information covered by such a claim only as authorized under 40 CFR Part 2, Subpart B. If no claim accompanies the business information at the time EPA receives it, EPA may make it available to the public without further notice. Calpine may not withhold from EPA any information on the grounds that it is confidential.
13. This request for information is not subject to review by the Office of Management and Budget (AOMB@) under the Paperwork Reduction Act because it is not an Ainformation collection request@ within the meaning of 44 U.S.C. ' ' 3502(3), 3507, 3512, and

3518(c)(1) (see also, 5 C.F.R. ' ' 1320.3(c), 1320.4, and 1320.6(a)). Furthermore, it is exempt from OMB review under the Paperwork Reduction Act because it is directed to fewer than ten persons [see, 44 U.S.C. ' 3502(4) & (11); 5 C.F.R. ' ' 1320.4 and 1320.6(a)].

14. This Order takes effect upon signature.

If you have any questions regarding this matter, please contact Greg V. Arthur of my staff at (415) 972-3504 or at arthur.greg@epa.gov.

Sincerely,

Original signed by:
Kathi Moore

Kathi Moore
Chief, Office of CWA Compliance

cc: Mike Paulucci, Yuba City
Melissa Hall, RWQCB-Sacramento