

IN THE UNITED STATES DISTRICT COURT
FOR THE SOUTHERN DISTRICT OF MISSISSIPPI
(Jackson Division)

UNITED STATES OF AMERICA and,)
the STATE OF MISSISSIPPI,)

Plaintiffs,)

v.)

THE CITY OF JACKSON, MISSISSIPPI,)

Defendant.)
_____)

Case: No. 3:12-cv-790 TSL-MTP

CONSENT DECREE

TABLE OF CONTENTS

I. JURISDICTION AND VENUE	7
II. APPLICABILITY	8
III. OBJECTIVES	9
IV. DEFINITIONS.....	9
V. REVIEW OF DELIVERABLES/CERTIFICATION OF DELIVERABLES ...	16
VI. COMPLIANCE REQUIREMENTS	18
VII. CIVIL PENALTY.....	70
VIII. SUPPLEMENTAL ENVIRONMENTAL PROJECT.....	72
IX. REPORTING REQUIREMENTS.....	75
X. STIPULATED PENALTIES.....	78
XI. FORCE MAJEURE.....	84
XII. DISPUTE RESOLUTION.....	86
XIII. RIGHT OF ENTRY AND INFORMATION COLLECTION AND RETENTION	89
XIV. EFFECT OF SETTLEMENT/RESERVATION OF RIGHTS.	91
XV. COSTS.....	93
XVI. NOTICES.....	93
XVII. EFFECTIVE DATE.....	95
XVIII. RETENTION OF JURISDICTION.....	95
XIX. MODIFICATION.....	95
XX. TERMINATION.....	96

XXI. PUBLIC PARTICIPATION..... 97

XXII. SIGNATORIES/SERVICE..... 97

XXIII. INTEGRATION..... 98

XXIV. FINAL JUDGMENT.....98

XXV. APPENDICES.....98

WHEREAS, Plaintiff, the United States of America (“United States”), by the authority of the Attorney General of the United States and through its undersigned counsel, acting at the request and on behalf of the United States Environmental Protection Agency (“EPA”), filed a Complaint (“Complaint”) concurrently with the lodging of this Consent Decree alleging that Defendant, the City of Jackson, Mississippi (the “City”), has violated and continues to violate Sections 301 of the Clean Water Act, 33 U.S.C. § 1311 (“CWA”), and terms and conditions of its National Pollutant Discharge Elimination System (“NPDES”) permits issued under Section 402 of the CWA, 33 U.S.C. § 1342;

WHEREAS, Plaintiff, the State of Mississippi (the “State”), acting through the Mississippi Commission on Environmental Quality and the Mississippi Department of Environmental Quality (collectively, “MDEQ”), joined in the Complaint and seeks injunctive relief and civil penalties for the City’s alleged violations of the Mississippi Air and Water Pollution Control Law, Miss. Code Ann. § 49-17-1 *et seq.*;

WHEREAS, the State is also a Plaintiff in this action and is joined as a party under Section 309(e) of the CWA, 33 U.S.C. § 1319(e), which requires the state in which a municipality is located to be joined as a party whenever the municipality is a party to a civil action brought by the United States under Section 309 of the CWA;

WHEREAS, MDEQ has been authorized by EPA to administer the NPDES program pursuant to Section 402(b) of the CWA, 33 U.S.C. § 1342(b);

WHEREAS, the City is a “municipality” pursuant to Section 502 of the CWA, 33 U.S.C. § 1362;

WHEREAS, the City's Wastewater Collection and Transmission System ("WCTS") transports wastewater to three (3) publicly owned wastewater treatment plants ("WWTPs"): the Savanna Street Wastewater Treatment Plant ("Savanna Street WWTP"), the Trahon/Big Creek Wastewater Treatment Plant ("Trahon WWTP"), and the Presidential Hills Wastewater Treatment Plant ("Presidential Hills WWTP"), which are operated by the City pursuant to NPDES permit numbers MS0024295, MS0044059 and MS0030295, respectively ("NPDES Permits");

WHEREAS, EPA and MDEQ have determined, based upon information provided by the City, that the City has had at least 2,300 unauthorized Sanitary Sewer Overflows ("SSOs") in the past five (5) years;

WHEREAS, EPA and MDEQ have determined that the City has experienced a number of Prohibited Bypasses, in which the Savanna Street WWTP has discharged wastewater without required primary and/or Secondary Treatment into the Pearl River, a water of the United States;

WHEREAS, the City has reported to MDEQ a number of violations of the effluent limitations in the NPDES Permits;

WHEREAS, EPA and MDEQ have determined that the City had no effective system of SSO reporting or record-keeping, and has thus failed to comply with the reporting requirements of its NPDES Permits;

WHEREAS, the United States and the State contend that these SSOs, Prohibited Bypasses, effluent limit exceedances, and reporting failures are violations of the CWA, Miss. Code Ann. § 49-17-29, and the City's NPDES Permits;

WHEREAS, on September 10, 2010, MDEQ and the City entered into an Agreed Order, as amended on October 11, 2010 and again amended on September 29, 2011, a copy of which is attached hereto as Appendix A, that includes requirements for the City to address certain violations and other specific environmental issues at the Savanna WWTP and pay a civil penalty of \$240,000 (the “MDEQ Agreed Order I”);

WHEREAS, on August 23, 2011, MDEQ and the City entered into an Agreed Order, a copy of which is attached hereto as Appendix B, that requires the City to address certain violations and other specific environmental issues at the Presidential Hills WWTP and pay a civil penalty of \$22,500 (the “MDEQ Agreed Order II”);

WHEREAS, on May 4, 2012, MDEQ issued to the City a revised NPDES Permit for the Savanna Street WWTP that includes more stringent effluent limits for the nutrients Nitrogen (Total) and Phosphorous (Total), and more stringent effluent limits for parameters Ammonia Nitrogen (Nov-Oct); Flow (Nov-Apr); Oxygen Demand, Carbonaceous (Nov-Oct); Solids (Total Suspended) Effluent (Nov-Apr); % Effect Static Renewal 7-Day Chronic Ceriodaphnia, Effluent (Jan-Dec); and % Effect Static Renewal 7-Day Chronic Pimephales, Effluent (Jan-Dec);

WHEREAS, the City contends that it is not currently able to meet the new effluent limits for these nutrients;

WHEREAS, this Consent Decree requires the City to develop, submit, finalize, and implement plans for the continued improvement of its WCTS and WWTPs; to eliminate SSOs, effluent limit violations (including any violations of the new effluent limits for nutrients), and reporting violations; and to minimize Prohibited Bypasses;

WHEREAS, the Parties to this Consent Decree have negotiated in good faith and have reached a settlement of the issues raised in the Complaint;

WHEREAS, the City's agreement to this Consent Decree is not an admission of liability, except for the City's consent to jurisdiction and venue as provided in Section I of this Consent Decree, nor is it an adjudication or admission of any law or fact;

WHEREAS, the Parties recognize, and the Court by entering this Consent Decree finds, that this Consent Decree has been negotiated by the Parties in good faith and will avoid litigation between the Parties and that this Consent Decree is fair, reasonable, and in the public interest.

NOW THEREFORE, with the consent of the Parties, it is hereby ORDERED, ADJUDGED and DECREED as follows:

I. JURISDICTION AND VENUE

1. This Court has jurisdiction over the subject matter of this action, pursuant to 28 U.S.C. §§ 1331, 1345, and 1355, and Section 309(b) of the CWA, 33 U.S.C. § 1319(b), and over the Parties. This Court has supplemental jurisdiction over the state law claims asserted by the State pursuant to 28 U.S.C. § 1367. Venue is proper in the Southern District of Mississippi pursuant to Section 309(b) of the CWA, 33 U.S.C. § 1319(b), and 28 U.S.C. §§ 1391(b) and 1395(a), because the violations alleged in the Complaint are alleged to have occurred in this judicial district. For purposes of this Decree, or any action to enforce this Consent Decree, the City consents to the Court's jurisdiction over this Consent Decree and any such action and over the City and consents to venue in this judicial district.

2. For purposes of this Consent Decree, the City agrees that the Complaint states claims upon which relief may be granted pursuant to Sections 309(b) of the CWA, 33 U.S.C. § 1319(b), and Miss. Code Ann. § 49-17-29 and § 49-17-43.

II. APPLICABILITY

3. The obligations of this Consent Decree apply to and are binding upon the United States, the State, and upon the City and any successors, assigns, or other entities or persons otherwise bound by law.

4. No transfer of ownership or operation of the Sewer System, whether in compliance with the procedures of this Paragraph or otherwise, shall relieve the City of its obligation to ensure that the terms of this Consent Decree are implemented. At least thirty (30) Days prior to such transfer, the City shall provide a copy of this Consent Decree to the proposed transferee and shall simultaneously provide written notice of the prospective transfer, together with a copy of the proposed written agreement, to EPA Region IV, the United States Department of Justice and MDEQ, in accordance with Section XVI of this Consent Decree (Notices). The City shall require, as a condition of any sale or transfer, that the purchaser or transferee agrees in writing to be bound by this Consent Decree and submit to the jurisdiction of the Court for its enforcement. Any attempt to transfer ownership or operation of the Sewer System without complying with this Paragraph constitutes a violation of this Consent Decree.

5. The City shall provide a copy of this Consent Decree to all officers, employees, and agents whose duties might reasonably include compliance with any provision of this Consent Decree, as well as to any contractor retained to perform work required under this Consent

Decree. The City shall condition any such contract upon performance of the work in conformity with the terms of this Consent Decree.

6. In any action to enforce this Consent Decree, the City shall not raise as a defense the failure by any of its officers, directors, employees, agents, or contractors to take any actions necessary to comply with the provisions of this Consent Decree.

III. OBJECTIVES

7. All plans, measures, reports, construction, maintenance, operational requirements, and other obligations in this Consent Decree or resulting from the activities required by this Consent Decree shall have the objective of causing the City to achieve and maintain full compliance with the CWA, the Mississippi Air and Water Pollution Control Law, and the NPDES Permits, including the elimination of all Sanitary Sewer Overflows.

IV. DEFINITIONS

8. Terms used in this Consent Decree that are defined in the CWA or in regulations promulgated pursuant to the CWA (including, without limitation, those terms defined in Section 502 of the CWA, 33 U.S.C § 1362, and at 40 C.F.R. § 122.2) shall have the meanings assigned to them in the CWA, 33 U.S.C. §§ 1251 *et seq.*, and regulations promulgated under the CWA, unless otherwise provided in this Consent Decree. Whenever the terms set forth below are used in this Consent Decree, the following definitions shall apply:

(a) “Building Backup” shall mean a wastewater release or backup into a building that is caused by blockages, flow conditions, or other malfunctions in the Wastewater Collection and Transmission System. A wastewater backup or release that is caused by blockages, flow conditions, or other malfunctions of a Private Lateral is not a Building Backup.

(b) “Calendar Quarter” shall mean the three (3)-month periods ending on March 31, June 30, September 30, and December 31.

(c) “Calendar Year” shall mean the twelve (12)-month period starting on January 1 and ending on December 31.

(d) “Certification” or “certify” when used in this Consent Decree shall require the City to comply with Paragraph 16 of this Consent Decree.

(e) “The City” or “Defendant” shall mean the City of Jackson, Mississippi, a municipal corporation, including all of its departments, agencies, instrumentalities such as the Public Works Department, and any successor thereto.

(f) “CMOM” or “Capacity, Management, Operations, and Maintenance” shall mean a program of accepted industry practices to properly manage, operate and maintain sanitary wastewater collection, transmission and treatment systems, investigate capacity-constrained areas of these systems, and respond to SSO events.

(g) “Complaint” shall mean the complaint filed by the United States and the State in this action.

(h) “Consent Decree” or “Decree” shall mean this Decree and all appendices attached hereto listed in Section XXV. In the event of a conflict between this document and any appendix, this document shall control.

(i) “CWA” shall mean the Clean Water Act, as amended, 33 U.S.C. §§ 1251, *et seq.*

(j) “Date of Entry” shall mean the date on which this Consent Decree is entered by the United States District Court for the Southern District of Mississippi.

(k) “Date of Lodging” shall mean the date this Consent Decree is filed for lodging with the Clerk of the Court for the United States District Court for the Southern District of Mississippi.

(l) “Day” shall mean a calendar day unless expressly stated to be a business day. In computing any period of time under this Consent Decree, where the last day would fall on a Saturday, Sunday, or federal holiday, the period shall run until the close of business of the next business day.

(m) “Deliverable” shall mean any written document required to be prepared and/or submitted by or on behalf of the City pursuant to this Consent Decree.

(n) “DOJ” shall mean the United States Department of Justice and any of its successor departments or agencies.

(o) “EPA” shall mean the United States Environmental Protection Agency and any of its successor departments or agencies.

(p) “Excessive Inflow/Infiltration” or “Excessive I/I” shall have the meaning provided in 40 C.F.R. § 35.2005(b)(16).

(q) “Force Main” shall mean any pipe that receives and conveys, under pressure, wastewater from the discharge side of a pump. A Force Main is intended to convey wastewater under pressure.

(r) “Gravity Sewer Line” or “Gravity Sewer” shall mean a pipe that receives, contains and conveys wastewater not normally under pressure, but is intended to flow unassisted under the influence of gravity.

(s) “Infiltration” as defined by 40 C.F.R. § 35.2005(b)(20) shall mean water other than wastewater that enters the WCTS (including sewer service connections and foundation drains) from the ground through such means as defective pipes, pipe joints, connections, or manholes.

(t) “Inflow” as defined by 40 C.F.R. § 35.2005(b)(21) shall mean water other than wastewater that enters the WCTS (including sewer service connections) from sources such as, but not limited to, roof leaders, cellar drains, yard drains, area drains, drains from springs and swampy areas, manhole covers, cross connections between storm sewers and sanitary sewers, catch basins, cooling towers, storm water, surface runoff, street wash waters, or drainage.

(u) “I/I” shall mean the total quantity of water from inflow, infiltration, and rainfall induced inflow and infiltration without distinguishing the source.

(v) “Major Gravity Line” shall mean any of the following:

(i) all Gravity Sewer Lines that are twelve (12) inches in diameter or larger;

(ii) all Gravity Sewer Lines that convey wastewater from one pumping station service area to another pumping station service area; and

(iii) all Gravity Sewer Lines that have caused or contributed, or that the City knows will likely cause or contribute to capacity-related SSOs.

(w) “MDEQ” shall mean the Mississippi Department of Environmental Quality and any of its successor departments or agencies of the State.

(x) “NPDES” shall mean the National Pollutant Discharge Elimination System authorized under Section 402 of the CWA, 33 U.S.C. § 1342.

(y) “NPDES Permits” shall mean NPDES permit No. MS0024295 issued to the City pursuant to Section 402 of the Clean Water Act, 33 U.S.C. § 1342, for the Savanna Street WWTP; NPDES permit No MS0044059 issued to the City pursuant to Section 402 of the Clean Water Act, 33 U.S.C. § 1342, for the Trahon/Big Creek WWTP; NPDES permit No. MS0030295 issued to the City pursuant to Section 402 of the Clean Water Act, 33 U.S.C. § 1342, for the Presidential Hills WWTP; and any future extended, modified, or reissued permits.

(z) “Paragraph” shall mean a portion of this Consent Decree identified by an Arabic numeral.

(aa) “Parties” shall mean the United States of America on behalf of EPA, the State on behalf of MDEQ, and the City.

(bb) “Plaintiffs” shall mean the United States of America on behalf of EPA and the State of Mississippi on behalf of MDEQ.

(cc) “Private Lateral” shall mean that portion of a sanitary sewer conveyance pipe that extends from the wastewater main to the single-family, multi-family, apartment, or other dwelling unit or commercial or industrial structure to which wastewater service is or has been provided.

(dd) “Prohibited Bypass” shall mean the intentional diversion of waste streams from any portion of a treatment facility which is prohibited pursuant to the terms set forth at 40 C.F.R. § 122.41(m).

(ee) “Public Document Repository” or “PDR” shall mean the City of Jackson’s Eudora Welty Library, located at 300 N. State Street, Jackson, Mississippi 39201, and the City’s website, <http://www.jacksonms.gov/home/index.php>.

(ff) “Publicly Owned Treatment Works” or “POTW” shall mean a publicly owned treatment works or POTW as defined in 40 C.F.R. § 403.3(q), and includes the WCTS and the WWTPs as defined in this Consent Decree.

(gg) “Pump Station” shall mean facilities comprised of pumps which lift wastewater to a higher hydraulic elevation, including all related electrical, mechanical, and structural systems necessary to the operation of that pump station.

(hh) “Sanitary Sewer Overflow” or “SSO” shall mean any discharge of wastewater to waters of the United States or the State from the City’s Sewer System through a point source not specified in any NPDES permit, as well as any overflow, spill, or release of wastewater to public or private property from the Sewer System that may not have reached waters of the United States or the State, including all Building Backups.

(ii) “Secondary Treatment” is a biological wastewater treatment technology required by the Clean Water Act for discharges from Publicly Owned Treatment Works, as that term is defined at 40 C.F.R. § 403.3(q). The minimum level of effluent quality attainable through the application of Secondary Treatment is established in 40 C.F.R. § 133.102 in terms of the parameters for 5-day biochemical oxygen demand (“BOD₅”) concentration and percent removal, total suspended solids (“TSS”) concentration and percent removal, and pH.

(jj) “Section” shall mean a portion of this Consent Decree identified by a Roman numeral.

(kk) “Sewershed” shall mean the subdivisions of the City’s WCTS containing sewers that are primarily hydraulically linked as identified on Appendix C, attached hereto and incorporated herein.

(ll) “Sewer System” shall mean the WCTS and the WWTPs.

(mm) “State” shall mean the State of Mississippi including all of its departments, agencies, and instrumentalities.

(nn) “Timely” when applied to the submittal of a Deliverable shall mean submitted no later than the deadline established in this Consent Decree (or in a document approved pursuant to this Consent Decree) and containing all of the elements pertaining to the submittal as set forth in this Consent Decree (or in a document approved pursuant to this Consent Decree). “Timely,” when applied to the implementation of any Work shall mean implemented no later than the deadline established in this Consent Decree (or in a document approved pursuant to this Consent Decree) and in accordance with the elements pertaining to such Work as set forth in this Consent Decree (or in a document approved pursuant to this Consent Decree).

(oo) “United States” shall mean the United States of America, acting on behalf of EPA, including its departments, agencies, and instrumentalities.

(pp) “Wastewater Collection and Transmission System” or “WCTS” shall mean the municipal wastewater collection, retention and transmission system, including all pipes, Force Mains, Gravity Sewer Lines, Pump Stations, pumps, manholes, and appurtenances thereto, which are owned or operated by the City.

(qq) “Wastewater Treatment Plant” or “WWTP” shall mean devices or systems used in the storage, treatment, recycling, and reclamation of municipal wastewater. For purposes of this Consent Decree, this definition shall include all facilities owned, managed, operated, and maintained by the City, including but not limited to the following treatment facilities: the Savanna Street WWTP located at 3810 I-55 South & Savanna Street, Jackson, MS 39121; the

Trahon/Big Creek WWTP located at One Apache Dr., Landfill Road, Byram, Mississippi; the Presidential Hills WWTP located at Franklin D. Roosevelt Dr. W, Jackson, Mississippi; and all components of such sewage treatment plants.

(rr) “Work” shall mean all activities the City is required to perform under this Consent Decree.

V. REVIEW OF DELIVERABLES/CERTIFICATION OF DELIVERABLES

9. Public Document Repository. Within seven (7) Days after a Deliverable is submitted to EPA, the City shall place a copy in the PDR along with a one (1)-page instruction flyer containing a brief synopsis of the Deliverable and instructions on how to navigate to the City’s website. Within seven (7) Days after EPA’s approval, approval contingent upon conditions, or modification by EPA, the City shall place a copy of such version of the Deliverable in the PDR. This copy shall replace all previous copies of that Deliverable in the PDR and shall remain in the PDR along with all comments until termination of this Consent Decree. In addition, the City shall maintain in the PDR a listing of all Deliverables.

10. Copy to MDEQ. The City shall provide a copy of any Deliverable to MDEQ at the same time such Deliverable is due to EPA.

11. EPA Action on Deliverables. After review of any Deliverable that is required to be submitted pursuant to this Consent Decree, EPA, after consultation with MDEQ, shall in writing:

- (a) approve the submission;
- (b) approve the submission upon specified conditions;
- (c) approve part of the submission and disapprove the remainder; or

(d) disapprove the submission.

12. Approved Deliverables. If a Deliverable is approved by EPA pursuant to Paragraph 11.(a), the City shall take all actions required by the Deliverable in accordance with the schedules and requirements of the Deliverable as approved. If the Deliverable is conditionally approved or approved only in part, pursuant to Paragraph 11.(b) or (c), the City shall, upon written direction from EPA, after consultation with MDEQ, take all actions required by the approved plan, report, or other item that EPA, after consultation with MDEQ, determines are technically severable from any disapproved portions, subject to the City's right to dispute only the specified conditions or the disapproved portions, under Section XII of this Consent Decree (Dispute Resolution). Following EPA approval of any Deliverable or portion thereof, such Deliverable or portion thereof so approved shall be incorporated into and become enforceable under this Consent Decree.

13. Disapproved Deliverables. If the Deliverable is disapproved in whole or in part pursuant to Paragraph 11.(c) or (d), the City shall, within thirty (30) Days or such other time as EPA and the City agree to in writing, correct all deficiencies and resubmit to EPA the Deliverable, or disapproved portion thereof, for approval, in accordance with Paragraphs 11 and 12. If the resubmission is approved in whole or in part, the City shall proceed in accordance with Paragraph 12.

14. Stipulated Penalties Accruing. Any stipulated penalties applicable to the original Deliverable, as provided in Section X of this Decree, shall accrue during the thirty (30)-Day period or other specified period, but shall not be payable unless the resubmitted Deliverable is untimely or is disapproved in whole or in part; provided that, if the original submission was so

deficient as to constitute a material breach of the City's obligations under this Decree, the stipulated penalties applicable to the original submission may be due and payable notwithstanding any subsequent resubmission.

15. Resubmitted Deliverable. If a resubmitted Deliverable, or portion thereof, is disapproved in whole or in part, EPA, after consultation with MDEQ, may again require the City to correct any deficiencies, in accordance with preceding Paragraph 13, or may itself correct any deficiencies, subject to the City's right to invoke Dispute Resolution and the right of EPA to seek stipulated penalties as provided in preceding Paragraph 14. Upon EPA's correction of any deficiencies, such resubmitted plan, report, or other item, or portion thereof will be incorporated into and become enforceable under this Consent Decree and shall be implemented by the City according to the approved schedule subject to the City's right to invoke Dispute Resolution.

16. Certification. In all Deliverables, notices, documents or reports submitted to the United States and State pursuant to this Consent Decree, the City shall, by a senior City management official, sign and certify such notices, documents and reports as follows:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

VI. COMPLIANCE REQUIREMENTS

A. Summary of the Sewer System Remedial Actions

17. The remedial actions for the City's Sewer System consist of a phased approach for the evaluation and rehabilitation of the City's WCTS (Section VI.B); the development and

implementation of a Comprehensive Performance Evaluation (“CPE”) and Composite Correction Program (“CCP”) for the Savanna Street WWTP (Section VI.C); the development and implementation of programs to insure proper Capacity, Management, Operations and Maintenance of the Sewer System (“CMOM”) (Section VI.D); and the implementation of certain work set forth in MDEQ Agreed Orders I and II (Section VI.E).

18. The evaluation and rehabilitation of the WCTS consist of a multi-phased program which will result in a prioritized analysis and evaluation of the City’s WCTS, the identification of deficiencies, and the correction of deficiencies. The City shall first develop and implement a West Bank Interceptor Work Plan and a West Bank Interceptor Rehabilitation Plan pursuant to which the City will conduct sewage flow monitoring and inspection of the West Bank Interceptor to identify and remediate any structural deficiencies in the West Bank Interceptor. The City shall also develop and implement a Prioritization Work Plan and a Prioritization Report pursuant to which the City will estimate the severity of I/I within each Sewershed comprising the WCTS; map the Sewer System; assess the capacity of the WCTS; and establish Sewershed priorities for further evaluation and rehabilitation. The City shall also develop and implement a Sewershed Evaluation Plan that will outline how Sewersheds or groups of Sewersheds will be assessed in phases pursuant to the approved schedules set forth in the Prioritization Report. These evaluations will determine the extent of rehabilitative needs and corrective actions the City shall perform in the WCTS pursuant to an Evaluation Report/Rehabilitation Plan to meet the objectives of this Consent Decree. Such rehabilitative needs and corrective actions shall be completed for the Sewersheds or groups of Sewersheds in accordance with an approved schedule as set forth in the Evaluation Report/Rehabilitation Plan for that Sewershed or groups of

Sewersheds, provided, however, that all such rehabilitative needs and corrective actions shall be completed on or before two hundred seven (207) months after the Date of Entry of this Consent Decree.

19. The CPE consists of an in-depth diagnostic evaluation of the capacity and operation of the Savanna Street WWTP and its ability to comply with the NPDES Permit including eliminating Prohibited Bypasses. Based on this evaluation, the CCP shall identify rehabilitative needs and corrective actions to address problems identified in the CPE which shall be completed on or before sixty (60) months after EPA's approval of the CCP.

20. The CMOM programs that the City will develop and implement include the following: Training Program; Capacity Assurance Program; Sewer Overflow Response Plan; Inter-Jurisdictional Agreement Program; Private Lateral Program; Water Quality Monitoring Program; Pump Station Operations Program; Fats, Oils and Grease Control Program; Pump Station Preventive Maintenance Program; Gravity Line Preventive Maintenance Program; WWTP Operations and Maintenance Program; and Financing and Cost Analysis Program.

21. Specific references must be cited for proposed procedures, techniques, and design criteria to be used in evaluating the City's Sewer System. The I/I evaluations and WCTS evaluations and rehabilitation shall be consistent with EPA's Handbook: *Sewer System Infrastructure Analysis and Rehabilitation*, EPA/625/6-91/030, October 1991; Water Environment Federation's *Manual of Practice FD-6, Existing Sewer Evaluation & Rehabilitation*, 1994; and the most current edition of MDEQ's *Guidance for the Design of Publicly Owned Wastewater Facilities*. The CPE and CCP shall be consistent with the following publications: *Improving POTW Performance Using the Composite Correction Approach*, EPA

CERI, October 1984; *Retrofitting POTWs*, EPA CERI, July 1989; and the most current edition of MDEQ's *Guidance for the Design of Publicly Owned Wastewater Facilities*. The Pump Stations evaluations shall be consistent with the "Pumping Systems" chapter of the most current version of Water Environment Federation's *Manual of Practice FD-4, Design of Wastewater and Stormwater Pumping Stations*.

B. Phased Approach for WCTS Evaluation and Rehabilitation

22. West Bank Interceptor Work Plan. Within five (5) months after the Date of Entry of this Consent Decree, the City shall submit to EPA for review and approval a West Bank Interceptor Work Plan. Upon approval by EPA, the City shall implement the West Bank Interceptor Work Plan. The West Bank Interceptor Work Plan shall include, at a minimum, the following:

(a) The proposed locations selected, and proposed methodologies and criteria that the City will implement and use, to conduct sewage flow monitoring and inspection of the West Bank Interceptor to identify and analyze structural deficiencies in the West Bank Interceptor.

(b) The methodologies and procedures the City will implement for monitoring and determining the total dry weather and wet weather (peak) flow rate in the West Bank Interceptor in order to estimate the severity of I/I in the West Bank Interceptor.

(c) The methodologies and procedures the City will implement for evaluating and assessing the West Bank Interceptor to enable the City, in the West Bank Interceptor Rehabilitation Plan set forth below, to identify any deficiencies therein and a specific list of proposed remedial measures to correct such deficiencies. The proposed remedial measures shall

be performed in two (2) phases. The first phase of such remedial measures shall include cleaning of debris accumulated in the West Bank Interceptor and repairs throughout the length of the West Bank Interceptor that have been evaluated as being necessary to prevent imminent structural failure or have been evaluated as necessary to correct a major structural defect, including sources of Excessive I/I. The first phase shall also include total rehabilitation of at least 20% of the total length of the West Bank Interceptor, or a lesser amount as approved by EPA based upon justification by the City in the West Bank Interceptor Work Plan. Examples of these repairs include, but are not limited to, point repairs, manhole repairs, and replacement of sections of sewer pipe or pipe lining of critical segments. The second phase of such remedial measures shall include rehabilitation of those segments throughout the length of the West Bank Interceptor that include long-term repairs necessary for proper "Asset Management" and/or addressing sources of non-Excessive I/I. Examples of these repairs include, but are not limited to, manhole repairs, sewer pipe lining, and replacement or construction of new gravity sewer pipe segments. Asset Management is a continuous process that guides the acquisition, use, and disposal of infrastructure assets to optimize service delivery and minimize costs over the asset's entire life.

23. West Bank Interceptor Rehabilitation Plan. Within twenty-two (22) months after EPA approval of the West Bank Interceptor Work Plan, the City shall submit to EPA for review and approval a West Bank Interceptor Rehabilitation Plan setting forth the results and conclusions from the implementation of the West Bank Interceptor Work Plan. Upon approval by EPA, the City shall implement the West Bank Interceptor Rehabilitation Plan. The West Bank Interceptor Rehabilitation Plan shall include, at a minimum, the following:

(a) The results of flow monitoring conducted pursuant to the West Bank Interceptor Work Plan and estimates of the severity of I/I within the West Bank Interceptor.

(b) Proposed remedial measures to be conducted in two (2) phases, as more particularly described in Paragraph 22.(c) above, to correct any identified deficiencies. Any such proposal for remedial measures for the West Bank Interceptor shall include a detailed work plan for the implementation of such measures within each phase including beginning and completion dates and a date for the submittal to EPA of a West Bank Interceptor Final Report upon completion of the remedial measures in each phase detailing the activities taken; provided, however, that such remedial measures for phase I shall be completed within seventy-two (72) months after EPA approval of the West Bank Interceptor Rehabilitation Plan and that such remedial measures for phase II shall be completed within one hundred seventy-four (174) months after EPA approval of the West Bank Interceptor Rehabilitation Plan.

24. Prioritization Work Plan. Within seven (7) months after the Date of Entry of this Consent Decree, the City shall submit to EPA for review and approval a Prioritization Work Plan which shall set forth the proposed locations selected, and proposed methodologies and criteria that the City will implement and use, to identify the severity of I/I within the WCTS, to map the Sewer System, to assess the capacity of WCTS, and to establish Sewershed priorities for further evaluation and rehabilitation of the WCTS pursuant to the Sewershed Evaluation Plan and Evaluation Report/Rehabilitation Plan as set forth in Paragraphs 26 and 27 below. Upon approval by EPA, the City shall implement the Prioritization Work Plan. The Prioritization Work Plan shall include, at a minimum, the following:

(a) The methodologies and procedures the City will implement to estimate the severity of I/I within each Sewershed.

(b) The methodologies and procedures the City will implement for the development of a computerized digital mapping system for each Sewershed that shall include, and have the ability to display, the West Bank Interceptor, all Gravity Sewer Lines, Force Mains, Pump Stations, manholes, inverts, siphons, WWTP locations, diversion valves, outfall locations, and all other appurtenances relating to the City's Sewer System. The mapping system does not need to include Private Laterals. The mapping system shall have the capability to store, update, and display information in a manner that will aid City personnel in the development and implementation of a Hydraulic Model, the Sanitary Sewer Evaluation Survey and the proper operation and maintenance of the Sewer System.

(c) The methodologies and procedures the City will implement for assessing the capacity of the WCTS including the West Bank Interceptor, all Pump Stations, all Major Sewer Gravity Lines, all Force Mains and siphons and their respective related appurtenances, all known SSO locations, and any other portions of each Sewershed. The capacity assessment shall include the WCTS that must be assessed so as to allow a technically-sound evaluation of the causes of SSOs and Prohibited Bypasses at the WWTPs. The capacity assessment shall specifically identify, at a minimum, the hydraulic capacities of the WCTS, and compare those capacities to existing and future projected average and peak flows in dry and wet weather. This assessment shall identify those portions of the WCTS that are expected to cause or contribute to SSOs and/or Prohibited Bypasses at the WWTPs under existing and future projected average and peak flows in dry and wet weather, and the degree to which those portions experience or cause,

under current or projected future conditions, SSOs and/or Prohibited Bypasses at the WWTPs. As part of the capacity assessment, the City shall use the information it is required to develop pursuant to Section VI.B to assess existing and future projected capacity of the WCTS and the ability of the WCTS to transmit peak flows experienced by and predicted for the WCTS.

(d) The methodologies and procedures the City will implement to develop a computerized Hydraulic Model of the WCTS within each Sewershed using a hydraulic modeling software package. The City shall use the Hydraulic Model in the assessment of the hydraulic capacity of the WCTS in that Sewershed and in the identification of appropriate rehabilitative and corrective actions to address all capacity and condition limitations identified in that Sewershed's WCTS. The City shall develop the Hydraulic Model to provide a detailed understanding of the response of the WCTS to wet weather events and an evaluation of the impacts of proposed remedial measures and removal of I/I flow.

The City shall configure the Hydraulic Model to accurately represent the City's WCTS, in accordance with currently accepted engineering practice. The City may model its WCTS in different levels of detail, as necessary to identify the causes of all known SSOs and to assess proposed remedial measures with the goal of eliminating those SSOs. The City's Hydraulic Model shall include at a minimum the West Bank Interceptor, all Major Gravity Lines and associated manholes, and all Pump Stations and associated Force Mains.

The City shall configure the Hydraulic Model using adequate, accurate, and sufficiently current physical data (e.g., invert and ground elevations, pipe diameters, slopes, pipe run lengths, Manning roughness factors, manhole sizes and configurations, Pump Station performance

factors) for its WCTS. In particular, the City shall field verify the physical data to allow calibration and verification of the model.

The City shall calibrate and verify the Hydraulic Model using appropriate rainfall data, actual hydrographs, and WCTS flow data. The City shall use at least three (3) separate data sets each for calibration and verification. As part of the calibration process, the City shall either use existing sensitivity analyses for the selected model, or carry out its own sensitivity analyses, such that calibration effectiveness is maximized.

The Hydraulic Model shall, at a minimum, include:

- (i) a description of the Hydraulic Model that includes the criteria set forth above;
- (ii) specific attributes, characteristics, and limitations of the Hydraulic Model;
- (iii) identification of all input parameters, constants, assumed values, and expected outputs;
- (iv) digitized map(s) and schematics that identify and characterize the portions (including the specific Gravity Sewer Lines) of the WCTS that shall be included in the Hydraulic Model;
- (v) identification of input data to be used;
- (vi) configuration of the Hydraulic Model;
- (vii) procedures and protocols for performance of sensitivity analyses (*i.e.*, how the Hydraulic Model responds to changes in input parameters and variables including the use of various design storms of varying durations and intensities);

(viii) procedures for calibrating the Hydraulic Model to account for values representative of the WCTS and WWTPs using actual system and WWTP data (*e.g.*, flow data); and

(ix) procedures to verify the Hydraulic Model's performance using additional, independent actual Sewer System data (*e.g.*, flow data).

(e) The methodology and criteria for prioritizing Sewersheds or groups of Sewersheds in order to conduct the phased evaluation and rehabilitation of the WCTS in each Sewershed as required by this Consent Decree. The criteria for prioritizing Sewersheds shall include, at a minimum, the following:

- (i) the severity of the estimated I/I in the Sewersheds;
- (ii) the frequency, volume and location of SSOs in the Sewersheds;
- (iii) the relative potential impact of SSOs in the Sewersheds to human health and the environment;
- (iv) the average age of Gravity Sewer Lines within each Sewershed;
- (v) the pipe material used within each Sewershed; and
- (vi) any ongoing rehabilitation or corrective action work in the Sewersheds including detailed information on the current status and completion dates for such work.

(f) The methodologies, procedures and criteria for developing proposed schedules for implementing and completing the evaluation and rehabilitation of the WCTS in each Sewershed or groups of Sewersheds as required by this Consent Decree.

25. Prioritization Report. Within thirty-two (32) months after EPA approval of the Prioritization Work Plan, the City shall submit to EPA for review and approval a Prioritization Report setting forth the results and conclusions from the implementation of the Prioritization Work Plan. The Prioritization Report shall include, at a minimum, the following:

(a) The results of flow monitoring conducted pursuant to the Prioritization Work Plan and estimates of the severity of I/I within each Sewershed.

(b) The computerized digital map of the Sewer System.

(c) The results of the capacity assessment of the WCTS.

(d) The results of the Hydraulic Model.

(e) The results of applying to each Sewershed the prioritization criteria approved in the Prioritization Work Plan.

(f) An organization of the Sewersheds into three (3) Sewer Groups, based upon the severity of I/I, and other criteria set forth in Paragraph 24(e), with the most severe being prioritized into Sewer Group 1. In addition, the Sewersheds in Group 1 shall contain at a minimum at least 30% of the estimate of total I/I within all the Sewersheds, and the Sewersheds in Group 2 shall contain at a minimum at least 40% of the estimate of total I/I within all the Sewersheds. The Prioritization Report shall also include a schedule for the Sewersheds in the Sewer Groups to be evaluated in accordance with the Sewershed Evaluation Plan as set forth in Paragraph 26 below, including beginning and completion dates; provided, however, that such schedule shall provide for all Sewersheds in Group 1 to be evaluated within sixty-three (63) months after the Date of Entry of this Consent Decree and all Sewersheds in Group 2 be

evaluated within one hundred forty-one (141) months after the Date of Entry of this Consent Decree.

Upon approval by EPA of the Prioritization Report, the City shall evaluate the Sewersheds in accordance with the Sewershed Evaluation Plan as approved by EPA in accordance with Paragraph 26 below and the prioritized schedule for the Sewersheds as set forth in the approved Prioritization Report.

26. Sewershed Evaluation Plan. Within twelve (12) months after the Date of Entry of this Consent Decree, the City shall submit to EPA for review and approval a Sewershed Evaluation Plan that the City will implement for the Sewersheds in Sewer Groups 1 and 2 pursuant to the schedule set forth in the approved Prioritization Report. The Sewershed Evaluation Plan shall provide for the City to evaluate the WCTS within the Sewersheds in order to support the development of the Evaluation Report/Rehabilitation Plan for the Sewershed, as provided in Paragraph 27 below, and the identification of rehabilitative and corrective actions to meet the objectives of this Consent Decree. The City's evaluation of the Sewersheds shall include (and the Sewershed Evaluation Plan shall describe) at minimum the following requirements:

(a) Sanitary Sewer Evaluation Survey. The Sewershed Evaluation Plan shall provide for the City to characterize and address the structural integrity of the WCTS and to identify means to improve WCTS capacity and eliminate SSOs and Prohibited Bypasses at the WWTPs, including the identification and reduction of I/I, by conducting a Sanitary Sewer Evaluation Survey for the Sewershed. The Sanitary Sewer Evaluation Survey component of the Sewershed Evaluation Plan shall include, at a minimum, the following:

(i) the criteria that the City will use for establishing the location of flow and rainfall monitoring equipment installation for the Sewershed evaluations, and for determining whether the City will install the flow and rainfall monitoring equipment either permanently or temporarily, in order to adequately characterize flow in the Sewershed;

(ii) a map showing the location of each permanent and temporary flow and rainfall monitoring site established in the WCTS;

(iii) a description of the data management system that will organize, analyze, and report flow and rainfall data collected from the WCTS;

(iv) a description of the quality assurance and quality control program the City will follow to ensure the accuracy and reliability of flow and rainfall data collected from the WCTS;

(v) procedures to identify and evaluate I/I in the Sewersheds (including, without limitation, Private Laterals);

(vi) dry weather monitoring to characterize base flows and wet weather monitoring following events of sufficient duration and intensity to characterize peak flows;

(vii) techniques for reducing Infiltration;

(viii) a program to eliminate sources of Inflow (including legal mechanisms and enforcement programs);

(ix) a program to identify and eliminate cross connections between the WCTS and the City's municipal separate storm sewer system;

(x) methodologies to evaluate the success of items (v) through (ix) above;

(xi) a review of the legal authority in the current sewer use ordinance to require that the owner of an illegal stormwater connection to the WCTS take all appropriate steps necessary to eliminate the connection;

(xii) if the review of the legal authority indicates a need to amend the legal authority in order to assume better control over illegal stormwater connections to the WCTS, the Plan shall include the proposed revisions to the ordinance with a schedule for proposing the draft ordinance to the City Council for adoption;

(xiii) decision-making criteria, procedures, and protocols for prioritization of the evaluation and rehabilitation of Gravity Sewer Lines and associated manholes;

(xiv) decision-making criteria, procedures, and protocols to determine the need for, and the conduct of, internal condition inspection of Gravity Sewer Lines and associated manholes;

(xv) decision-making criteria, procedures, and protocols to determine the need for, and the conduct of, grouting in Gravity Sewer Lines and associated manholes (e.g., leakage rate for application of grout);

(xvi) decision-making criteria, procedures, and protocols used to determine the need for, and the conduct of, smoke testing;

(xvii) decision-making criteria, procedures, and protocols used to determine the need for, and the conduct of, dye testing;

(xviii) decision-making criteria, procedures, and protocols used to determine the need for, and the conduct of, point repair(s), slip lining or line replacement;

(xix) decision-making criteria, procedures, and protocols to determine whether I/I from a Private Lateral is excessive and needs to be addressed;

(xx) decision-making criteria, procedures, and protocols to determine the need for, and the conduct of, flow isolation of Gravity Sewer Lines and associated manholes;

(xxi) guidelines for conducting a cost-effectiveness analysis to consider the rehabilitation costs for I/I sources and rainfall-induced I/I source eliminations versus the costs of transportation, storage, and treatment; and

(xxii) documentation of the basis and criteria for rehabilitation, transportation, storage, and treatment costs.

(b) Pump Station Evaluations. The Sewershed Evaluation Plan shall provide for the City to evaluate the design capacity, current effective capacity, equipment condition, and operational redundancy in its Pump Stations in the Sewersheds. This evaluation shall include, at a minimum, the following criteria:

(i) adequacy of station capacity;

(ii) critical response time, defined as the time interval between activation of the high wet well level alarm and the first SSO, under peak flow conditions;

(iii) adequacy of station condition, based upon both physical inspection and any available operating and mechanical failure history during at least the past five (5) years preceding the lodging date of the Consent Decree;

(iv) adequacy of station design and equipment, including redundancy of pumps and electrical power supply (including whether emergency or back-up power is available

on a portable or fixed basis), and other equipment installed, based upon the most current edition of MDEQ's *Guidance for the Design of Publicly Owned Wastewater Facilities*; and

(v) the ability of maintenance personnel to take corrective action within the critical response time calculated for each Pump Station.

27. Evaluation Report/Rehabilitation Plan. Within three (3) months after completion of the WCTS evaluation within a Sewershed pursuant to the Sewershed Evaluation Plan, the City shall submit to EPA for review and approval an Evaluation Report/Rehabilitation Plan setting forth the results of the Sewershed Evaluation Plan for that Sewershed, proposed rehabilitative and corrective actions and schedules in order to meet objectives of this Consent Decree. Upon approval by EPA, the City shall implement the remedial measures in the approved Rehabilitation Plan portion of this submittal in accordance with the schedule contained therein.

(a) The Evaluation Report portion of this submittal shall include, at a minimum, the following:

(i) a thorough analysis of historical and current flow monitoring, inspection, rainfall and other data, including data collected during the evaluation of the Sewershed;

(ii) identification of areas with Excessive I/I, such that these conditions are causing and/or contributing to SSOs and/or Prohibited Bypasses at the WWTPs;

(iii) identification of sources of I/I within the Sewershed, if identifiable, by manhole/line segment, street address, type (Infiltration or Inflow), source (*e.g.*, "wall leakage"), and estimated flow from the source;

(iv) identification of cross-connections between the WCTS and the City's municipal separate storm sewer system;

(v) identification and quantification of SSOs, including all potential SSOs identified pursuant to implementation of the Prioritization Work Plan and the Sewershed Evaluation Plan;

(vi) a summary of activities undertaken to configure the Hydraulic Model for each Sewershed and certification that the Hydraulic Model is capable of performing those functions identified in Paragraph 24.(d);

(vii) a summary of activities undertaken to calibrate the Hydraulic Model and certification that the Hydraulic Model has been calibrated (including the performance of sensitivity analyses) and verified in accordance with the Prioritization Work Plan using actual system data (e.g., flow data) from permanent and temporary sewage flow monitoring points in the WCTS (this certification shall include a description of the methodology, data collected, and results of the Hydraulic Model calibrations and verifications);

(viii) identification of portions of the WCTS within the Sewershed in which physical degradation is causing or contributing to SSOs;

(ix) results of average and peak daily dry and wet weather flow measurements;

(x) a determination of maximum Infiltration rate during periods of high ground water (in gpd/inch diameter-mile);

(xi) a determination of maximum hourly Inflow rate during wet weather for various storm durations and intensities (in gpd/inch diameter-mile);

(xii) a determination of peaking factors for each Sewershed (the ratio of measured peak flow to average dry weather flow as measured through the duration of the evaluation);

(xiii) a summary of flow monitoring activities, to include, at a minimum, a map showing the delineation of the Sewershed, location and type of each flow meter, problems encountered and deviations from the Prioritization Work Plan and Sewershed Evaluation Plan, and a description of flow monitor calibration activities, including any scatter graphs and calibration and verification graphs;

(xiv) a summary of field investigative activities performed to include, at a minimum: type of activity; number of activities performed (*e.g.*, “100 out of 500 manholes inspected in Sewershed XX”), observations made under each activity (inspection procedure), and summaries of the results;

(xv) a summary of the structural defects identified in the WCTS to include, at a minimum: number of each type of defect by line segment, manhole number or street address, and estimates of peak flow or impact on WCTS capacity (as appropriate) from defects in each line segment, based on a consistently applied set of stated criteria as set forth in the Sewershed Evaluation Plan;

(xvi) a summary of the technical approach utilized in carrying out the capacity assessment analyses;

(xvii) a detailed description of any deviations from the capacity assessment portion of the Prioritization Work Plan, including a discussion of the reasons for such deviation;

(xviii) identification of all portions of the WCTS within the Sewershed with insufficient capacity as identified by the Hydraulic Model of a Major Gravity Line, Pump Station or other structure to convey peak flows without experiencing surcharge sufficient to cause an SSO under either predicted peak flows or predicted average conditions or both;

(xix) a description of future projected flows;

(xx) information on the predicted (e.g. Manning equation) and actual peak flow capacity of all Major Gravity Lines (by segment), all Force Mains, siphons, and Pump Stations;

(xxi) summaries of the number and footage of sewer segments surcharged, and the number of structures at which an SSO might be expected to occur under each condition investigated;

(xxii) mapping for each condition investigated, illustrating each pipe segment operating in surcharge, and each manhole or structure at which an SSO might be expected to occur;

(xxiii) information regarding the Pump Station evaluation as required by Paragraph 26.(b) above;

(xxiv) the results of the capacity assessment as required by the Prioritization Work Plan; and

(xxv) a summary of any capital projects implemented since commencement of the Sewershed Evaluation Plan.

(b) The Rehabilitation Plan portion of this submittal shall include, at a minimum, the following:

(i) identification of specific measures and schedules that, when implemented, will result in adequate capacity in the WCTS within that Sewershed to collect, convey and treat anticipated peak flows, without SSOs or Prohibited Bypasses at the WWTPs;

(ii) identification of the degree to which sources of Excessive I/I shall be removed, and the degree to which Excessive I/I removal is expected to alleviate capacity constraints, and propose specific remedial measures and schedules that will address those capacity limitations not expected to be addressed by Excessive I/I removal (anticipated I/I removal rates used in the development of the Rehabilitation Plan shall reflect current industry practice);

(iii) identification of specific remedial measures and schedules to address capacity limitations that may also include increases in Pump Station and sewer line capacity, construction of storage or equalization basin facilities, or increases in WWTP capacity;

(iv) identification of all measures and schedules necessary to eliminate all cross-connections between the WCTS and the City's municipal separate storm sewer system;

(v) identification of all measures and schedules necessary to eliminate all SSOs caused by physical degradation of sewers, inadequate Pump Station capacities, or inadequate Pump Station reliability;

(vi) prioritized schedules for remedial measures based upon relative likely human health and environmental impact risks, SSO frequencies, and SSO volumes;

(vii) a description of the methodology used to apply the prioritization factors in Paragraph 27.(b)(vi) above;

(viii) estimated capital, operations and maintenance, and present value costs for each identified remedial measure in consistent, year-specific dollars;

(ix) an expeditious schedule such that design, construction, and placement in service of all proposed measures for Sewersheds in Group 1 shall be completed within one hundred twenty-nine (129) months after the Date of Entry of this Consent Decree and for Sewersheds in Group 2 completed within two hundred seven (207) months after the Date of Entry of this Consent Decree; and

(x) identification of the dates for preliminary design, complete design, complete permitting, contract award, construction commencement, and construction completion dates for each measure proposed.

28. Rehabilitation Report for each Sewershed. Within three (3) months after completion of all remedial measures set forth in a Rehabilitation Plan for a Sewershed, the City shall submit to EPA for review and approval a Rehabilitation Report summarizing the implementation of the Rehabilitation Plan for that Sewershed. Such summary shall include, at a minimum, the following:

(a) Identification of specific measures taken to achieve, and an analysis of whether such measures resulted in, adequate capacity in the WCTS within that Sewershed to collect and convey and treat anticipated peak flows, without SSOs or Prohibited Bypasses at the WWTPs.

(b) An analysis of the degree to which sources of Excessive I/I were removed, and the degree to which Excessive I/I removal alleviated capacity constraints.

(c) Identification of all measures taken to eliminate, and an analysis of whether such measures resulted in the elimination of, all cross-connections and SSOs caused by physical degradation of sewers, inadequate Pump Station capacities, or inadequate Pump Station reliability.

C. Comprehensive Performance Evaluation (“CPE”) and Composite Correction Program (“CCP”) for the Savanna Street WWTP

29. CPE. Within fifteen (15) months after the Date of Entry of this Consent Decree, the City shall submit to EPA for review and approval a CPE for the Savanna Street WWTP. The CPE shall be consistent with the EPA publications *Improving POTW Performance Using the Composite Correction Approach*, EPA CERI, October 1984, and *Retrofitting POTWs*, EPA CERI, July 1989, and the most current edition of MDEQ’s *Guidance for the Design of Publicly Owned Wastewater Facilities*. The purpose of the CPE is to identify flow and/or loading rate restricted treatment process unit(s) at the Savanna Street WWTP. Upon approval by EPA, the City shall implement the CPE in accordance with the schedule contained therein. The CPE shall include, at a minimum, the following:

(a) An in-depth diagnostic evaluation of the capacity and operation of the Savanna Street WWTP and its ability to provide Secondary Treatment to all dry and wet weather flow and otherwise meet all terms of the NPDES Permit.

(b) An evaluation of the major individual unit processes, identification of all performance-limiting factors, prioritization of performance-limiting factors, and a comprehensive assessment of the ability to improve performance with a CCP.

(c) Identification of whether the design requirements for the Savanna Street WWTP are consistent with the most current edition of MDEQ's *Guidance for the Design of Publicly Owned Wastewater Facilities*.

(d) Identification of design flow capacity requirements for the Savanna Street WWTP to adequately treat 100% of the peak annual dry weather flow, including providing Secondary Treatment without experiencing a Prohibited Bypass.

(e) Identification of design capacity requirements to adequately treat 100% of the peak wet weather flow, including providing Secondary Treatment for all flows without experiencing a Prohibited Bypass. The CPE may include estimated wet weather flow anticipated after performance of I/I reduction efforts identified in the Rehabilitation Plans for the WCTS and after sludge/solids removal at the Savanna Street WWTP.

(f) Identification of design requirements necessary to treat sewage to the level established by the most current MDEQ effluent permit requirements, including to the extent feasible any planned TMDLs to be implemented by MDEQ.

(g) A schedule and procedures that the City will use to prepare a Composite Correction Plan ("CCP"), as set forth below, based on the results of the CPE.

(h) Use of flow modeling and other appropriate techniques to evaluate Savanna Street WWTP capacity and operation, taking into account the net (cumulative) increase or decrease to the existing volume of wastewater introduced to the Savanna Street WWTP as a result of the City's actual and anticipated increases in flow from the authorization of new sewer service connections and/or from existing sewer service connections pursuant to Paragraph 33,

and the reduction of I/I into the WCTS as a result of any remedial measures taken pursuant to Section VI.B of this Consent Decree.

(i) A schedule for submission of the CCP as set forth below; provided, however, that for submission of the CCP, such schedule shall not exceed twelve (12) months after EPA's approval of the CPE.

30. CCP. Pursuant to the schedule set forth in the approved CPE, the City shall submit to EPA for review and approval a CCP as described below. The purpose of the CCP is to identify rehabilitation and/or upgrades to the Savanna Street WWTP to address the problems identified in the CPE as more particularly described below. To the extent applicable, the CCP shall be consistent with the EPA publications *Improving POTW Performance Using the Composite Correction Approach*, EPA CERI, October 1984, and *Retrofitting POTWs*, EPA CERI, July 1989; and the most current edition of MDEQ's *Guidance for the Design of Publicly Owned Wastewater Facilities*. Upon approval by EPA, the City shall implement the remedial measures in the approved CCP in accordance with the expeditious schedules contained therein.

The CCP shall include, at a minimum, the identification of specific Type 1, Type 2 and Type 3 remedial measures, as such terms are used in the above-referenced EPA publications and as further clarified below. Type 1 and Type 2 remedial measures shall include, minor process changes, minor equipment additions or enhancements, or flow configuration changes to meet NPDES Permit effluent limits and to maximize Secondary Treatment of peak wet weather flow through the Savanna Street WWTP. For purposes of this Paragraph 30, Type 3 remedial measures shall include any capital improvements, including, without limitation, the addition of a clarifier of equal size to the existing clarifiers at the Savanna Street WWTP and Biological

Nutrient Removal (“BNR”), necessary for the Savanna Street WWTP to meet the May 4, 2012 NPDES Permit effluent limits including nutrient limits. The CCP shall also include expeditious schedules for the implementation of such measures; provided, however, that all Type 1 and Type 2 measures shall be completed within twenty-four (24) months after EPA’s approval of the CCP and all Type 3 measures shall be completed within sixty (60) months after EPA’s approval of the CCP.

D. Capacity, Management, Operations and Maintenance Programs

31. The City shall develop and implement the Capacity, Management, Operations and Maintenance (“CMOM”) programs as provided below. All CMOM programs shall be developed in accordance with EPA Region IV guidance, as set forth in the CDROM disk attached hereto as Appendix D. The City shall ensure that each CMOM program has a written, defined purpose; a written, defined goal; is documented in writing with specific detail; is implemented by trained personnel; has established performance measures; and has written procedures for periodic review. The Parties recognize that the City may need or want to revise the CMOM Programs set forth below during the term of this Consent Decree. Such revisions shall not be considered modifications to the Consent Decree for purposes of Section XIX (Modification). The City must obtain EPA's prior written approval of any revision to the substance of any CMOM Program required by this Consent Decree and shall place copies of any such revised Program in the PDR in accordance with the provisions of Section V. The City may revise the form of any CMOM Program required by this Consent Decree without EPA’s approval and shall provide a copy of any revised Program to EPA and MDEQ, and place a copy of any such revised Program in the PDR within seven (7) Days after making such revision.

32. Training Program. Within twelve (12) months after the Date of Entry of this Consent Decree, the City shall submit to EPA for review and approval a Training Program, including a schedule for full implementation of the program not to exceed twelve (12) months after its approval by EPA. The Training Program shall include, at a minimum, the following:

(a) Technical Training. The technical training component shall include, at a minimum, the following:

(i) employee technical training and refresher technical training requirements (curriculum) that ensure that each City employee has a level of knowledge, commensurate with duties, of the overall functions of the City's infrastructure;

(ii) a description of outside technical training and networking opportunities, such as conferences and seminars, that are made available to City employees;

(iii) a description of the extent to which employee certification, at the State or at the City level, is required as a basis for obtaining or maintaining a position;

(iv) records of technical training, including on-the-job training, which shall be maintained in an information management system and shall describe the degree to which completed technical training and on-the-job training is tied to promotion and pay; and

(v) a description of the technical training required before an employee can undertake specific work assignments or tasks.

(b) Skills Training. The skills training component shall include, at a minimum, the following:

(i) employee skills training and refresher skills training requirements (curriculum) that ensure that each City employee has a level of knowledge, commensurate with

duties, of the specific equipment to be used and the procedures to be followed in carrying out duties;

(ii) a description of outside skills training opportunities, such as manufacturers' training, that are made available to employees;

(iii) a description of the extent to which employee certification, at the State or at the City level, is required as a basis for obtaining or maintaining a position;

(iv) records of skills training, including on-the-job training, which shall be maintained in an information management system) and shall describe the degree to which completed skills training and on-the-job training is tied to promotion and pay; and

(v) a description of the skills and on-the-job training required before an employee can undertake specific work assignments or tasks.

(c) Safety Training. The safety training component shall include, at a minimum, the following:

(i) employee safety training and refresher safety training requirements (curriculum) that ensure that each City employee has level of knowledge regarding on-the-job safety that is commensurate with the employee's equipment and work environment;

(ii) a description of the extent to which employee safety certification at the State or at the City level is required as a basis for obtaining or maintaining a position;

(iii) records of safety training, including on-the-job training, which shall be maintained in an information management system and shall describe the degree to which completed safety training and on-the-job training is tied to promotion and pay; and

(iv) a description of the safety training required before an employee can undertake specific work assignments or tasks.

33. Capacity Assurance Program. Within fifty-four (54) months after the Date of Entry of this Consent Decree, the City shall submit to EPA for review and approval a Capacity Assurance Program ("CAP"), including a schedule for full implementation of the program not to exceed twelve (12) months after EPA approval of the CAP. Pursuant to the capacity assessment performed in accordance with Paragraph 24.(c) above, the CAP shall identify each Sewershed or part of a Sewershed with insufficient capacity under either peak wet weather, or average conditions, or both. It shall also analyze all portions of the WCTS that hydraulically impact all known SSOs and all components of a WWTP that may contribute to violations of the NPDES Permits. The CAP shall assess peak flow capacity of the West Bank Interceptor, all Pump Stations, all Major Sewer Gravity Lines, all Force Mains and siphons and their respective related appurtenances, all known SSO locations, and any other portions of the WCTS that must be assessed so as to allow a technically-sound evaluation of the causes of SSOs and Prohibited Bypasses at the WWTPs for existing and proposed flows. The CAP shall enable the City to authorize new sewer service connections, or increases in flow from existing sewer service connections, only after the City certifies that the analysis procedures contained in the approved CAP have been used and that the City has determined, based on those procedures, that there is Adequate Treatment Capacity, Adequate Transmission Capacity, and Adequate Collection Capacity as set forth below. The Capacity Assurance Program shall include, at a minimum, the following:

(a) The technical information, methodology, and analytical techniques, including the model or software, to be used by the City to calculate collection, transmission, and treatment capacity.

(b) The means by which the City will integrate its certification of Adequate Treatment Capacity, Adequate Transmission Capacity, and Adequate Collection Capacity with the issuance of building permits by the City and the City's acquisition of new or existing sewers from other owners.

(c) The means by which the City will integrate its certification of Adequate Treatment Capacity, Adequate Transmission Capacity, and Adequate Collection Capacity with the requirements of Mississippi Commission on Environmental Quality Regulation WPC-1, Section I.C.1.(b) and Sections VI.B.2 and VI.B.4., regarding the certification of capacity for the construction of new sewer lines that provide new flow into the City's Sewer System.

(d) The technical information, methodology, and analytical techniques, including the model or software, to be used by the City to calculate the net (cumulative) increase or decrease in volume of wastewater introduced to the WCTS as a result of the City's authorization of new sewer service connections and increases in flow from existing connections and the completion of: (i) specific projects that add or restore collection or transmission capacity to the WCTS or add or restore Secondary Treatment capacity at a WWTP ("Capacity Enhancing Projects"), (ii) specific projects that reduce peak flow through removal of I/I ("I/I Projects"), and (iii) permanent removal of sewer connections ("Removal of Connections").

(e) An Information Management System capable of tracking the accumulation of banked credits, earned pursuant to Paragraph 33.(i) below, from completion of Capacity

Enhancing Projects, I/I Projects and Removal of Connections; the capacity-limited portion of the Sewershed in which those credits were earned; and the expenditure of such credits on future increases in flow from new or existing sewer service connections in that capacity-limited portion of the Sewershed.

(f) All evaluation protocols to be used to calculate collection, transmission, and treatment capacity including, but not limited to, standard design flow rate rules of thumb regarding pipe roughness, manhole head losses, as-built drawing accuracy (distance and slope), water use (gallons per capita per day), projected flow impact calculation techniques, and metering of related existing peak flows (flows metered in support of analysis and/or manual observation of existing peak flows). The City may identify sewer line segments which have been specifically designed and constructed to operate under surcharge conditions (e.g., with welded or bolted joints) and identify the level of surcharge for those segments.

(g) Capacity Certifications. Except as provided in Paragraphs 33.(h), (i), (j) and (k) below, after twelve (12) months of EPA's approval of the CAP, the City shall authorize a new sewer service connection, or additional flow from an existing sewer service connection, only after it certifies that the analysis procedures contained in the approved CAP have been used and that the City has determined, based on those procedures, that there is Adequate Treatment Capacity, Adequate Transmission Capacity, and Adequate Collection Capacity as defined below:

(i) Treatment Capacity Certifications. The City's certification of "Adequate Treatment Capacity" shall confirm that, at the time the WWTP receives the flow from a proposed sewer service connection(s) or increased flow from an existing sewer service connection(s), when combined with the flow predicted to occur from all other authorized sewer

service connections (including those which have not begun to discharge into the WCTS), the WWTP will not be in “non-compliance” for quarterly reporting as defined in 40 C.F.R. Part 123.45, Appendix A. In addition, the City’s certification of “Adequate Treatment Capacity” shall confirm that the new or increased flow to the WWTP will not result in a Prohibited Bypass.

(ii) Transmission Capacity Certifications. The City’s certification of “Adequate Transmission Capacity” shall confirm that each Pump Station, through which the proposed additional flow from new or existing sewer service connections would pass to the WWTP receiving such flow, has the capacity to transmit, with its largest pump out of service, the existing one (1) hour peak flow passing through the Pump Station, plus the addition to the existing one (1) hour peak flow predicted to occur from the proposed connection, plus the addition to the existing one (1) hour peak flow predicted to occur from all other authorized sewer service connections which have not begun to discharge into the WCTS.

(iii) Collection Capacity Certifications. The City’s certification of “Adequate Collection Capacity” shall confirm that each Major Gravity Line, through which the proposed additional flow from new or existing connections would pass, has the capacity to carry the existing one (1) hour peak flow passing through the Major Gravity Line, plus the addition to the existing one (1) hour peak flow from the proposed connection, plus the addition to the existing one (1) hour peak flow predicted to occur from all other authorized sewer service connections which have not begun to discharge into the WCTS without causing a Surcharge Condition.

(iv) Definition of “One (1) Hour Peak Flow” and “Surcharge Condition”. The terms set forth below are defined herein only for purposes of implementation of the CAP.

The City agrees that it shall not use these definitions for purposes of establishing any design criteria for the implementation of rehabilitation measures to the Sewer System. The term “one (1) hour peak flow” shall mean the greatest flow in a sewer averaged over a sixty (60) minute period at a specific location expected to occur as a result of a representative 2 year-24 hour storm event. Except for the West Bank Interceptor as set forth below, the term “Surcharge Condition” shall mean the condition that exists when the supply of wastewater resulting from the one (1) hour peak flow is greater than the capacity of the pipes to carry it and the surface of the wastewater in manholes rises to an elevation greater than twenty-four (24) inches above the top of the pipe or within three (3) feet of the rim of the manhole, and the sewer is under pressure or head, rather than at atmospheric pressure, unless the City has, pursuant to Paragraph 33.(f) above, identified that pipe segment and manhole as designed to operate in that condition, in which case the identified level of surcharge will be used. For the West Bank Interceptor, the term “Surcharge Condition” shall mean the condition that exists when the supply of wastewater resulting from the one (1) hour peak flow is greater than the capacity of the Interceptor to carry it and the surface of the wastewater rises to an elevation within three (3) feet of the rim of any manhole. The City agrees to not construct additional manholes for the West Bank Interceptor and to not increase the elevation of existing manholes except to ensure that the elevation is no higher than five (5) feet above the Base Flood elevation as that term is defined at 44 C.F.R. § 59.1.

(h) Minor Sewer Connections. For minor sewer service connections, the City may elect to perform a monthly capacity analysis for each Sewershed or part of a Sewershed by certifying that the Sewershed has adequate capacity, as defined above, to carry existing peak

flows and the additional flows generated by all such minor sewer service connections projected to be approved in the subsequent month. For any Sewershed or part of a Sewershed which can be so certified, the City may approve these projected minor sewer service connections without performing individual certifications for each connection. For the purposes of this paragraph only, a "minor sewer service connection" is a connection with an average flow not to exceed 2,500 gallons per day.

(i) Capacity for Treatment, Transmission, and Collection in Lieu of Certification. The City may authorize a new sewer service connection, or additional flow from an existing sewer service connection, even if it cannot satisfy the requirements of Paragraph 33.(g), provided the City certifies that all of the following provisions, where applicable, are satisfied:

(i) the City is in substantial compliance with this Consent Decree;

(ii) the sewer lines which will convey the proposed additional flow from new or existing sewer service connections have not experienced dry weather SSOs due to inadequate capacity within the previous twelve (12) Months; or, in the alternative, the causes of any dry weather SSOs due to inadequate capacity have been eliminated;

(iii) the City has identified the sewer line segment(s), Pump Station(s) and/or wastewater treatment systems that do not meet the conditions for certification of Adequate Treatment Capacity, Adequate Collection Capacity, and/or Adequate Transmission Capacity;

(iv) the City shall complete, prior to the time the proposed additional flow from new or existing sewer service connections is introduced into the WCTS, specific Capacity

Enhancing Projects, I/I Projects, and/or Removal of Connections which will add sewer capacity or reduce peak flows to the identified sewer line segment(s), Pump Station(s), and wastewater treatment system(s) in accordance with the factors set forth in Paragraphs 33.(i)(v) and (vi) below;

(v) where the City has undertaken specific Capacity Enhancing Projects that provide for additional off-line storage or additional Secondary Treatment capacity, and/or specific Removal of Connections to satisfy the requirements of Paragraph 33.(i)(iv) above, the estimated added capacity resulting from such projects must be equal to or greater than the estimated amount of any proposed additional flow;

(vi) where the City has undertaken specific I/I Projects or Capacity Enhancing Projects, other than those that provide for additional off-line storage or additional Secondary Treatment capacity, to satisfy the requirements of Paragraph 33.(i)(iv) above, the estimated reduction in peak flows or added capacity resulting from such projects must exceed the estimated amount of any proposed additional flow by a factor of 3:1;

(vii) commencing within twelve (12) months of EPA's approval of the CAP and annually thereafter, the City has performed a review of specific Capacity Enhancing Projects and I/I Projects undertaken to determine if actual added capacity and peak flow reductions are in line with what the City originally estimated for such projects; and the City has used the results of this review to adjust future estimates as necessary;

(viii) any new sewer service connection or increase in flow to an existing connection authorized prior to the completion of a necessary added capacity or peak flow reduction project as set forth above shall be conditioned upon completion of such project prior to

the time that the new sewer service connection or flow increase is introduced into the WCTS;
and

(ix) in implementing the provisions of this Paragraph 33.(i), the City may use a “banking credit system” for the sewer line segment(s), pump station(s), and/or wastewater treatment systems for which the City is not able to satisfy the conditions set forth in Paragraph 33.(g) above.

(j) Essential Services. Notwithstanding the above provisions, the City may authorize a new sewer service connection, or additional flow from an existing sewer service connection, even if it cannot certify that it has Adequate Transmission Capacity, Adequate Collection Capacity, and/or Adequate Treatment Capacity as defined above for health care facilities, public safety facilities, and public schools and, subject to EPA review and approval, for government facilities; and in those cases where a pollution or sanitary nuisance condition exists, as determined by the local county health department or its regulatory successor, as the result of a discharge of untreated wastewater from an on-site septic tank.

(k) Existing Illicit Connections. Notwithstanding the provisions above, the City may authorize a new sewer service connection, or additional flow from an existing sewer service connection, even if it cannot certify that it has Adequate Transmission Capacity and/or Adequate Collection Capacity and/or Adequate Treatment Capacity as defined above for any illicit connections or discharge of wastewater to the stormwater system or to waters of the State. For purposes of this subparagraph, the term “illicit connection” shall mean any connection resulting in a discharge to the municipal separate storm sewer system (“MS4”) that is not

composed entirely of storm water, except for discharges allowed under a NPDES permit or waters used for firefighting operations.

(l) Certifications. All certifications pursuant to this Paragraph 33 shall be made by a professional engineer registered in the State of Mississippi and shall be approved by a responsible party of the City as defined by 40 C.F.R. § 122.22(b). The City shall maintain all such certifications, and all data on which the certifications are based, in its offices for inspection by EPA and MDEQ. EPA and MDEQ may request, and the City shall provide, any and all documentation necessary to support any certification made by the City pursuant to this Paragraph 33, and make available, to the extent possible, individuals providing such certifications to meet with EPA and MDEQ.

34. Sewer Overflow Response Plan ("SORP"). The City submitted to MDEQ a SORP on September 28, 2011, pursuant to the MDEQ Agreed Order I. MDEQ approved the SORP on October 10, 2011. A copy of the SORP is attached hereto as Appendix E and hereby incorporated herein by reference. The City shall continue to implement the SORP as an enforceable obligation under this Consent Decree.

35. Inter-Jurisdictional Agreement Program. Within twenty-four (24) months after the Date of Entry of this Consent Decree, the City shall submit to EPA for review and approval an Inter-Jurisdictional Agreement Program for when the City reopens or renews existing agreements or enters into new agreements that cover the collection, conveyance, and treatment of sewage by the City from municipal satellite sewer systems and/or large volume sewer customers. The program shall delineate the minimum provisions to be set forth in these agreements with which the contracting municipality or large volume sewer customer must comply. Such

provisions shall include requirements on the contracting party to properly manage, operate, and maintain its sewage collection and conveyance systems including, without limitation, the management of FOG and the minimization of peak flows into the City's Sewer System by excluding, to the maximum reasonable extent, I/I. In addition, such provisions shall include requirements on the contracting party to ensure that any of its municipal satellite sewer systems and/or large volume sewer customers also properly manage, operate, and maintain their sewage collection and conveyance systems. The program shall also delineate provisions addressing the term or life of these agreements; mechanisms for appropriate modification of the agreements; and mechanisms for enforcement of the agreements (including a description of the legal support necessary to develop, oversee and enforce the agreements) which may include provisions permitting termination of the agreement and physical disconnection from the City's Sewer System within a reasonable time not exceeding two (2) years upon the failure of the contracting party to comply with its management, operations, and maintenance obligations.

The City represents that it currently has in place agreements covering the collection, conveyance, and treatment of sewage with all municipal satellite sewer systems that may or may not currently satisfy the requirements of the Inter-Jurisdictional Agreement Program as set forth above. The City represents that these existing agreements may expire or terminate before or after the Date of Entry of this Consent Decree. When any of these currently existing agreements expire or terminate, the City may, but shall not be required to, renew any such agreement or enter into a new agreement covering the collection, conveyance, and treatment of sewage from such other municipal satellite sewer system. In the event the City does reopen or renew such an

agreement or enters into any new agreement, each agreement shall be consistent with the requirements of this Inter-Jurisdictional Agreement Program.

36. Private Lateral Program. Within twenty-four (24) months after the Date of Entry of this Consent Decree, the City shall submit to EPA for review and approval Private Lateral Program, including a schedule for full implementation of the program not to exceed twelve (12) months after its approval by EPA. The Private Lateral Program shall include, at a minimum, the following:

(a) A legal review of the City's sewer use ordinance to ensure that the City has the authority to require customers to repair or replace Private Laterals that may contain defects and/or improper connections that:

(i) are potential sources of I/I to the WCTS that may cause or contribute to SSOs or other violations of the NPDES Permits;

(ii) allow for the possible exfiltration of wastewater onto or below the surface of the ground that could then enter the stormwater system; or

(iii) allow roots and/or debris to enter the WCTS through cracks, holes, or poorly sealed joints, thus restricting flow and increasing the likelihood of SSOs.

(b) If the legal review indicates a need to amend the legal authority in order to assume better control over problems with capacity on the Private Laterals, the Plan shall include the proposed revisions to the ordinance with a schedule for proposing the draft ordinance to the City Council for adoption.

(c) An enforcement response guide to address Private Laterals that contain defects and/or improper connections. The enforcement response guide shall:

(i) identify the process that the City will follow to require customers to repair or replace the identified Private Laterals;

(ii) set forth a series of graduated enforcement responses by the City, which may include termination of services, in the event a customer fails to repair or replace the identified Private Laterals;

(iii) describe the notice the City provides to customers to require repair or replacement of identified Private Laterals and the process a customer must follow in order to challenge the City's determination that repair or replacement is necessary or the City's enforcement response, such as termination of services; and

(iv) identify the process a customer must follow to request a waiver of any of the obligations to properly operate and maintain Private Laterals imposed by the City's sewer use ordinance and the process the City will use to consider granting and revoking such waivers.

(d) Establishment of technical and legal staffing to ensure effective implementation of the enforcement response guide.

(e) An information management system.

37. Water Quality Monitoring Program. Within twenty-four (24) months after the Date of Entry of this Consent Decree, the City shall submit to EPA for review and approval a Water Quality Monitoring Program, including a schedule for full implementation of the program not to exceed twelve (12) months after its approval by EPA. Water Quality Monitoring Program described below shall identify SSOs originating at sewer pipe creek crossings and other isolated or remote sewer locations adjacent or in proximity to waterways; locate the source or sources of

such SSOs; and assess the impact upon the environment and public health of such SSOs. The Water Quality Monitoring Program shall also include standard sampling and quality assurance procedures and an information management system. The Water Quality Monitoring Program is in addition to any other sampling required by the NPDES Permits. The Water Quality Monitoring Program shall include, at a minimum, the following:

(a) Routine Water Quality Monitoring Component. The City shall develop and implement a Routine Water Quality Monitoring component to detect SSOs originating at or in proximity to stream crossings or other isolated and remote sewer locations. This component shall provide for scheduled sampling during both dry and wet weather periods from a network of monitoring stations located in each of the City's Sewersheds. The Routine Water Quality Monitoring component shall propose the exact number and location of monitoring points depending upon drainage configuration and other factors, but in no event shall the number of monitoring points be less than twelve (12) monitoring points. The Routine Water Quality Monitoring component shall include a map of all sampling locations, and shall specify sampling frequency and sampling parameters, including pH, dissolved oxygen, and fecal coliform and/or *E. coli* bacteria. The City may elect to specify one or both of fecal coliform and *E. coli* bacteria as a sampling parameter.

(b) Investigative Water Quality Monitoring Component. The City shall develop and implement an Investigative Water Quality Monitoring component to determine whether the WCTS and/or any WWTP is a source of pollution identified as a result of complaints, routine water quality monitoring pursuant to Paragraph 37.(a) above, or by other means. This component shall specify the conditions under which the City will initiate an

investigation under this Paragraph 37.(b). The Investigative Water Quality Monitoring component shall include a requirement for development of a map of all actual sampling locations, and shall specify a protocol for determining sampling parameters to be used depending on the type of pollution identified or suspected. The Investigative Water Quality Monitoring component shall include the following:

(i) Dry Weather Monitoring. The purpose of dry weather monitoring shall be to detect chronic line leaks. Dry weather sampling shall be conducted for a definite period of time, e.g., one week ("Testing Period"). During the Testing Period, the City shall collect fecal coliform and/or *E. Coli* bacteria samples at least once a day at locations to be investigated.

(ii) Wet Weather Monitoring. The purpose of wet weather monitoring shall be to detect capacity problems. The wet weather sampling period shall be defined using rainfall and stream stage data or sewer flow data. During the sampling period, the City shall collect fecal coliform and/or *E. Coli* bacteria samples at least two (2) times a day at locations to be investigated.

(iii) Location of Source of Release. If necessary, the isolated stream segment shall be sampled at defined intervals to identify the source of the release. Fecal coliform and/or *E. Coli* bacteria samples shall be taken in each of the monitoring locations. After repair of the source, the City shall take additional samples to ensure that the repair has been successful.

(c) Spill Impact Water Quality Monitoring Component. The City shall develop and implement a Spill Impact Water Quality Monitoring component to assess any

impact upon public health and the environment of pollution resulting from SSOs, and to assist in assessing the need for any environmental and/or public health response. The City shall consult with EPA, MDEQ, and public health authorities during development and implementation of the Spill Impact Water Quality Monitoring component. As part of the Spill Impact Water Quality Monitoring component, the City shall develop protocols for mapping all actual sampling locations, for determining the frequency and duration of sampling (depending upon the potential impact of the spill on public health and the environment), and for sampling for pH, dissolved oxygen, and fecal coliform and/or *E. coli* bacteria. The sampling protocol shall include sampling upstream (control) and downstream of the spill. The sampling protocol also shall identify the circumstances under which the City shall sample for those Priority Pollutants known to be present in the wastewater of any Significant Industrial User that discharges into the portion of the WCTS upsewer of the SSO. The Water Quality Monitoring information management system shall contain a list of the Priority Pollutants, if any, in wastewater discharged by any Significant Industrial User to the WCTS, and the lines affected by any such discharge.

(d) Quality Assurance, Sampling, Data Analysis. The City shall use analytical procedures, sample containers, preservation techniques, and sample holding times that are specified in 40 C.F.R. Part 136. Upon request, the City shall allow split or duplicate samples to be taken by EPA, MDEQ, or their authorized representatives. In addition, EPA and MDEQ shall have the right to take any additional samples that EPA or MDEQ may deem necessary.

(e) Water Quality Reporting. The City shall report, pursuant to the requirements of Section IX (Reporting Requirements), the following information:

(i) the actions which have been taken under the Water Quality Monitoring Program during the previous Calendar Quarter, including the dates and times of all sampling;

(ii) a summary of all results of sampling during the previous Calendar Quarter; and

(iii) all actions including, but not limited to, data collection, which are scheduled for the next Calendar Quarter.

38. Pump Station Operations Programs. Within twelve (12) months after the Date of Entry of this Consent Decree, the City shall submit to EPA for review and approval Pump Station Operations Programs, including a schedule for full implementation of the programs not to exceed twelve (12) months after their approval by EPA. The Pump Station Operations Programs shall include, at a minimum, the following:

(a) Routine Pump Station Operations Program. The Routine Pump Station Operations Program shall be developed to ensure proper Pump Station operations that will necessitate prevention of Pump Station failure. This program shall include, at a minimum, the following:

(i) procedures for reading and recording information appropriate to each Pump Station including, as applicable, pump run-time meter readings, start counters, amperage readings, checking and resetting conditions, wet-well points, grease accumulations, and any other information that is necessary for the proper operation of a Pump Station;

(ii) development of standard inspection routes and schedules; and

(iii) provisions for needs determination, establishing priorities and scheduling, number of crews and personnel (including, where appropriate, contract crews), standard forms, records and performance measures, and an information management system.

(b) Emergency Pump Station Operations Program. The Emergency Pump Station Operations Program shall be developed to necessitate emergency operations in the event of Pump Station failure. This program shall provide guidance and ensure timely response to atypical situations in the WCTS through the use of written standard emergency operating procedures for each type of Pump Station and shall include, at a minimum, the following:

- (i) emergency contact information;
- (ii) location(s) of auxiliary power including portable or fixed emergency generators applicable to each Pump Station;
- (iii) location(s) of portable pumping equipment;
- (iv) guidance for initiating auxiliary power with portable or fixed generators;
- (v) guidance for installing portable pumps during high flow;
- (vi) applicable contingency plans; and
- (vii) standard forms, records and performance measures and an information management system.

39. Fats, Oils and Grease ("FOG") Control Program. Within twenty-four (24) months after the Date on Entry of this Consent Decree, the City shall submit to EPA for review and approval a FOG Control Program, including a schedule for full implementation of the

program not to exceed twelve (12) months after its approval by EPA. The FOG Control Program shall include, at a minimum, the following:

- (a) The legal authority to control the discharge of FOG into the WCTS, including the ability to implement a permit and enforcement program.
- (b) Specification of accepted devices to control the discharge of FOG into the WCTS.
- (c) Establishment of standards for the design and construction of FOG control devices including standards for capacity and accessibility, site map, design documents, and as-built drawings.
- (d) Establishment of FOG control device management, operations, and maintenance standards, or best management practices, that address onsite record keeping requirements, cleaning frequency, cleaning standards, use of additives, and ultimate disposal.
- (e) Establishment of construction inspection protocols, including scheduling, inspection report forms, and inspection record keeping requirements, to assure that FOG control devices are constructed in accordance with established design and construction standards.
- (f) Establishment of compliance inspection protocols, including scheduling, inspection report forms, and inspection record keeping requirements to assure that FOG control devices are being managed, operated, and maintained in accordance with the established management, operations, and maintenance standards or best management practices.
- (g) Establishment of a FOG disposal manifest system.
- (h) Establishment of an enforcement program, including specific enforcement mechanisms, to ensure compliance with the FOG Control Program.

(i) Establishment of a compliance assistance program to facilitate training of FOG generators and their employees.

(j) Establishment of a public education program directed at reducing the amount of FOG entering the WCTS from private residences.

(k) Establishment of staffing (technical and legal) and equipment requirements to ensure effective implementation of the FOG Control Program.

(l) A FOG characterization study that shall identify the sources of FOG causing problems in the WCTS and the best method or mechanism for addressing those sources.

(m) A list of current commercial establishment FOG generators including a description of their FOG generating processes and average daily discharge volume.

(n) Establishment of performance indicators to be used by the City to measure the effectiveness of the FOG Control Program.

40. Pump Station Preventive Maintenance Programs. Within twelve (12) months after the Date of Entry of this Consent Decree, the City shall submit to EPA for review and approval Pump Station Preventive Maintenance Programs, including a schedule for full implementation of the programs not to exceed twelve (12) months after their approval by EPA. The Pump Station Preventive Maintenance Programs shall include, at a minimum, the following:

(a) An electrical maintenance component which shall provide guidance to managers and field personnel responsible for electrical maintenance to ensure that preventive maintenance on Pump Station electrical components are performed on a routine basis. This component shall include meter calibration schedules for any meter used to record data collected at or from a Pump Station.

(b) A mechanical maintenance component that shall provide guidance to managers and field personnel responsible for mechanical maintenance to ensure that preventive maintenance on Pump Station mechanical components are performed on a routine basis.

(c) A physical maintenance component that shall provide guidance to managers and field personnel responsible for physical maintenance (pipes, walls, inverts, covers, etc.) to ensure that preventive maintenance on Pump Station physical components are performed on a routine basis.

(d) A Pump Station repair component that shall serve as a reactive maintenance system to repair Pump Stations that are currently in a state of disrepair but still cost-effective to service. This component shall provide for the identification, prioritization, scheduling, and repair of Pump Stations on a timely basis once a Pump Station has deteriorated beyond the scope of the preventive maintenance programs. This component shall include, at a minimum, the following:

- (i) guidance outlining when a Pump Station is to be placed in the Pump Station Repair Program;
- (ii) a prioritized inventory of Pump Stations in need of repair;
- (iii) an ongoing inventory of completed repairs;
- (iv) a work schedule for repairs; and
- (v) standard forms, records and performance measures, and an information management system.

41. Gravity Line Preventive Maintenance Program. Within fifteen (15) months after the Date of Entry of this Consent Decree, the City shall submit to EPA for review and approval a

Gravity Line Preventive Maintenance Program, including a schedule for full implementation of the program not to exceed twelve (12) months after its approval by EPA. The Gravity Line Preventive Maintenance Program shall include, at a minimum, the following:

(a) A preventive hydraulic cleaning component which shall include protocols for implementing routine hydraulic cleaning component of the preventive maintenance program for Gravity Sewer Lines. This component shall include provisions for needs determination, establishing priorities and scheduling, number of crews and personnel (including, where appropriate, contract crews), hydraulic cleaning equipment to be used, standard hydraulic cleaning maintenance procedures, standard forms, records and performance measures, and an information management.

(b) A preventive mechanical cleaning component which shall include protocols for implementing routine mechanical cleaning component of the preventive maintenance program for Gravity Sewer Lines. This component shall include provisions for needs determination, establishing priorities and scheduling, number of crews and personnel (including, where appropriate, contract crews), mechanical cleaning equipment to be used, standard mechanical cleaning maintenance procedures, standard forms, records and performance measures, and an information management system.

(c) A root control component which shall include protocols, methods, and approaches for implementing a root control component of the preventive maintenance program for Gravity Sewer Lines. This component shall include provisions for needs determination, establishing priorities and scheduling, number of crews and personnel (including, where appropriate, contract crews), root control methods and approaches, root control maintenance

procedures, standard forms, records and performance measures, and an information management system.

(d) A manhole preventive maintenance component which shall include protocols, methods, and approaches for implementing a routine inspection and maintenance component of the preventive maintenance program for Gravity Sewer Lines. This component shall include provisions for needs determination, establishing priorities and scheduling, number of crews and personnel (including, where appropriate, contract crews), inspection methods and approaches, standard maintenance procedures, standard forms, records and performance measures, and an information management system.

(e) A prioritized and expedited schedule for implementation of the Program for the West Bank Interceptor.

42. WWTP Operations and Maintenance Program. Within fifteen (15) months after the Date of Entry of this Consent Decree, the City shall submit to EPA for review and approval a WWTP Operations and Maintenance Program, including a schedule for full implementation of the program not to exceed twelve (12) months after its approval by EPA. The WWTP Operations and Maintenance Program shall include, at a minimum, the following:

(a) Equipment, Parts, and Material Inventory. The City shall inventory its WWTPs' operating equipment and materials and evaluate the impacts of the loss of use or failure of each major system component. The City shall develop an inventory control system which shall have the capability of tracking spare parts use and inventory, as well as generating inventory replenishment needs reports. The City's inventory control system shall also include the following elements:

(i) prioritization of WWTP components as critical, semi-critical, or non-critical which shall allow the City to focus its maintenance capabilities and spare parts inventories on the WWTP components and potential failures that would have the greatest impact on treatment capacity, Prohibited Bypassing, and NPDES Permit compliance;

(ii) identification of critical spare parts and materials, and procedures to ensure that these parts and materials are stored and maintained in inventory at the WWTP;

(iii) a list of where the remaining spare parts may be secured to enable the repair or replacement of such equipment in a minimum amount of time and to ensure proper operation of the WWTP; and

(iv) tracking of spare parts use and inventory, as well as generating inventory replenishment needs reports.

(b) Sludge Processing and Removal. Not inconsistent with the requirements of the MDEQ Agreed Order I, the maintenance program shall include sludge removal procedures, schedules, and standard practices for the WWTPs and from any storage lagoons, wet weather storage cells, equalization ponds, or any other wet weather storage facility that is, or is planned for use by, a WWTP.

(c) Preventive Maintenance. The City develop and implement a preventive maintenance system for the WWTPs to ensure that preventive and corrective maintenance is conducted and that equipment integral to proper operation and maintenance, treatment units, and tanks are maintained so as to achieve compliance with the NPDES permit. The preventive maintenance system shall include, at a minimum, the following:

(i) identification of equipment used in the treatment of wastewater liquids and biosolids;

(ii) identification of the standard procedures to conduct preventive maintenance of such WWTP equipment;

(iii) identification of the frequency and duration of preventive maintenance necessary to ensure that all WWTP equipment is maintained in such a way so as to achieve compliance with the NPDES permit;

(iv) identification of the training and education required for maintenance personnel to perform the standard preventive maintenance procedures;

(v) procedures for recognition of indicators that corrective maintenance on WWTP equipment is necessary;

(vi) procedures for the generation of work orders for preventive and corrective maintenance of WWTP equipment;

(vii) procedures for the generation of purchase orders associated with preventive and corrective maintenance of WWTP equipment;

(viii) examples of the types of reports and forms which will be used in implementing the preventive maintenance system;

(ix) a system for tracking preventive and corrective maintenance activities and histories including the generation of summary reports each month that identify major equipment failures occurring in the previous month and the end-of-month status of preventive and corrective maintenance work orders issued or outstanding in the previous month for equipment; and

(x) procedures to ensure that failures of equipment and/or loss of power supply during abnormal and emergency conditions are corrected in a timely fashion so as to limit the downtime of the facility or component.

43. Financing & Cost Analysis Program. Within eighteen (18) months after the Date of Entry of this Consent Decree, the City shall submit to EPA for review and approval a Financing and Cost Analysis Program. The Financing and Cost Analysis Program shall include, at a minimum, the following:

(a) A process (including a schedule of implementation) that regularly analyzes, projects, plans, and finances management, operating, and maintenance costs of its Sewer System, including those management, operating, and maintenance costs associated with labor and equipment needed to properly implement the CMOM programs required pursuant to this Consent Decree.

(b) A process (including a schedule of implementation) that regularly analyzes, projects, plans, and finances capital improvements to its Sewer System, including those capital improvements required pursuant to this Consent Decree. Capital improvement financing shall be planned using, at a minimum, a five (5)-year planning horizon followed by annual updates.

(c) A process, including a schedule of implementation, to ensure that life cycle cost analysis is incorporated into its operations cost analyses, maintenance cost analyses, and management cost analyses for all Sewer System equipment and infrastructure.

(d) A process, including a schedule of implementation, to establish its annual budget and set customer rates that assures that the budget and rates are based on the programs referenced in Paragraph 43.(a) through (c) above.

D. Work under MDEQ Orders Enforceable under this Consent Decree

44. As set forth in Section 2.D of the MDEQ Agreed Order I, the City has agreed to implement a Sludge and Solids Removal Plan that provides for the removal and proper disposal of excess, accumulated sludge/solids from the Savanna Street WWTP storm diversion cells. The Parties agree that the City shall implement the Sludge and Solids Removal Plan as an enforceable obligation under this Consent Decree. In addition, as set forth in Sections 2.B., C. and D. of the MDEQ Order II, the City has agreed to implement certain remedial measures to address NPDES permit effluent limitation violations at the Presidential Hills WWTP. The Parties agree that the City shall implement such remedial measures as an enforceable obligation under this Consent Decree.

VII. CIVIL PENALTY

45. The City shall pay the sum of \$437,916 as a civil penalty to be paid in four (4) installments of \$109,479. The first installment shall be due within thirty (30) Days after the Date of Entry of this Consent Decree. The second installment shall be due within seven (7) months after the Date of Entry of this Consent Decree, the third installment shall be due thirteen (13) months after the Date of Entry of this Consent Decree, and the fourth installment shall be due nineteen (19) months after the Date of Entry of this Consent Decree. The second, third and fourth installment payment of the civil penalty shall also include an additional sum for interest accrued on the unpaid portion of the principal amount calculated from the Date of Entry of this

Consent Decree until the date of the payment. The Financial Litigation Unit ("FLU") of the U.S. Attorney's Office for the Southern District of Mississippi, 500 One Jackson Place, 188 E. Capital Street, Jackson, Mississippi 39201 (601-955-4480), shall send to the City a calculation of the interest due for the second, third and fourth installment payment. The City may pay any installment payment prior to the due date, but must contact the FLU in advance for a determination regarding the amount of interest to be included with the payment. In the event any installment payment includes an overpayment, the amount of the overpayment shall be applied to the remaining principal.

46. The City shall pay to the United States sixty percent (60%) of each installment of the civil penalty plus any interest due by FedWire Electronic Funds Transfer ("EFT") to the U.S. Department of Justice in accordance with written instructions to be provided to the City by the FLU. At the time of payment, the City shall send a copy of the EFT authorization form and the EFT transaction record, together with a transmittal letter, which shall state that the payment is for the civil penalty owed pursuant to the Consent Decree in United States et al. v. City of Jackson, and shall reference the civil action number and DOJ case number 90-5-1-1-09841, to the United States in accordance with Section XVI of this Decree (Notices); by email to acctsreceivable.CINWD@epa.gov; and by mail to:

EPA Cincinnati Finance Office
26 Martin Luther King Drive
Cincinnati, Ohio 45268.

In the event that full cash payment of any installment to the United States is not made within the due date for such installment, the City shall also pay to the United States interest on the balance

due from the original due date to the date of payment, at the rate calculated pursuant to 28 U.S.C. § 1961.

47. The City shall pay to the State forty percent (40%) of each installment of the civil penalty plus any interest due by check payable to the “Mississippi Department of Environmental Quality.” Each check shall reference the case name and civil action number herein and shall be sent to:

Mississippi Department of Environmental Quality
Attn: Mona Varner
P. O. Box 2329
Jackson, Mississippi 39225

VIII. SUPPLEMENTAL ENVIRONMENTAL PROJECT

48. The City shall satisfactorily implement and complete a Supplemental Environmental Project (“SEP”) in accordance with all provisions of Appendix F of this Consent Decree. The SEP shall be completed in accordance with the schedule set forth in Appendix F.

49. As more particularly described in Appendix F, the SEP shall consist of projects to reduce extraneous flows entering the WCTS through defective private laterals and through illicit connections from residential properties the owners of which face financial hardship. The City may use contractors or consultants in planning and implementing the SEP.

50. With regard to the SEP, the City certifies the truth and accuracy of each of the following:

(a) That all cost information provided to EPA in connection with EPA’s approval of the SEP is complete and accurate and that the City in good faith estimates that the cost to implement the SEP is \$875,000.

(b) That, as of the date of executing this Consent Decree, the City is not required to perform or develop the SEP by any federal, state, or local law or regulation and is not required to perform or develop the SEP by agreement, grant, or as injunctive relief awarded in any other action in any forum.

(c) That the SEP is not a project that the City was planning or intending to construct, perform, or implement other than in settlement of the claims resolved in this Consent Decree.

(d) That the City has not received and will not receive credit for the SEP in any other enforcement action.

(e) That the City will not receive any reimbursement for any portion of the SEP from any other person.

(f) That the City is not a party to any open federal financial assistance transaction that is funding or could be used to fund the same activity as the SEP, and that, to the best of its knowledge and belief after reasonable inquiry, there is no such open federal financial transaction that is funding or could be used to fund the same activity as the SEP, nor has the same activity been described in an unsuccessful federal financial assistance transaction proposal submitted to EPA within two (2) years of the date of this settlement (unless the project was barred from funding as statutorily ineligible). For the purposes of this certification, the term "open federal financial assistance transaction" refers to a grant, cooperative agreement, loan, federally-guaranteed loan guarantee or other mechanism for providing federal financial assistance whose performance period has not yet expired.

51. SEP Completion Report. Within thirty (30) Days after the date set for completion of the SEP, the City shall submit a SEP Completion Report to EPA for review and approval. The SEP Completion Report shall contain all of the following information:

- (a) A detailed description of the SEP as implemented.
- (b) A description of any problems encountered in completing the SEP and the solutions thereto.
- (c) An itemized list of all eligible SEP costs expended.
- (d) Certification that the SEP has been fully implemented pursuant to the provisions of this Consent Decree.
- (e) A description of the environmental and public health benefits resulting from implementation of the SEP (with a quantification of the benefits and pollutant reductions, if feasible).

52. EPA may, in its sole discretion, require information in addition to that described in the preceding Paragraph, in order to evaluate the City's SEP Completion Report.

53. After receiving the SEP Completion Report, EPA shall notify the City whether or not the City has satisfactorily completed the SEP. If the City has not completed the SEP in accordance with this Consent Decree, stipulated penalties may be assessed under Section X of this Consent Decree.

54. Disputes concerning the satisfactory performance of the SEP and the amount of eligible SEP costs may be resolved under Section XII of this Decree (Dispute Resolution). No other disputes arising under this Section shall be subject to Dispute Resolution.

55. Each submission required under this Section shall be signed by an official with knowledge of the SEP and shall bear the certification language set forth in Paragraph 16.

56. Any public statement, oral or written, in print, film, or other media, made by the City making reference to the SEP under this Consent Decree shall include the following language: "This project was undertaken in connection with the settlement of an enforcement action, United States et al. v. City of Jackson, taken on behalf of the U.S. Environmental Protection Agency and the Mississippi Department of Environmental Quality under the Clean Water Act and the Mississippi Air and Water Pollution Control Law."

IX. REPORTING REQUIREMENTS

57. The City shall submit the following reports:

(a) Quarterly Reports. Beginning thirty (30) Days after the first full three (3) month period following the Date of Entry of this Consent Decree, and thirty (30) Days after each subsequent three (3)-month period thereafter until termination of the Consent Decree, the City shall submit to EPA for review and approval a Quarterly Report that shall include the following:

(i) the date, time, location, source, estimated duration, estimated volume, receiving water (if any), and cause of all SSOs occurring in the applicable three (3)-month period in a tabulated electronic format; and

(ii) the date, time, estimated duration, estimated volume, and cause of all Prohibited Bypasses occurring in the applicable three (3)-month period in a tabulated electronic format.

(b) Semi-Annual Reports. Beginning thirty (30) Days after the first full six (6)-month period following the Date of Entry of this Consent Decree, and thirty (30) Days after

each subsequent six (6)-month period until termination of the Consent Decree, the City shall submit to EPA for review and approval a Semi-Annual Report. Each Semi-Annual Report shall include, at a minimum:

(i) A description of projects and activities completed and milestones achieved during the previous applicable six (6)-month period pursuant to the requirements of this Consent Decree, in Gantt chart or similar format, including a description of the status of compliance or non-compliance with the requirements of this Consent Decree and, if applicable, the reasons for non-compliance. If any non-compliance cannot be fully explained at the time the report is due, the City shall include a statement to that effect in the report. The City shall investigate to determine the cause of the non-compliance and then shall submit an amendment to the report, including a full explanation of the cause of the non-compliance, within thirty (30) Days after submission of the Semi-Annual Report.

(ii) A summary of significant projects and activities anticipated to be performed, and milestones anticipated to be achieved, in the successive applicable six (6)-month period to comply with the requirements of this Consent Decree, in Gantt chart or similar format.

(iii) Any additional information the City determines is appropriate to demonstrate that the City is implementing the remedial actions required under this Consent Decree in an adequate and timely manner.

(c) Annual Reports. Beginning sixty (60) Days after the first full twelve (12)-month period following the Date of Entry of this Consent Decree, and sixty (60) Days after each subsequent twelve (12)-month period until termination of this Consent Decree, the City shall

submit to EPA for review and approval an Annual Report. Each Annual Report shall cover the most recent applicable twelve (12)-month period and shall include, at a minimum:

(i) A summary of the CMOM Programs implemented or modified pursuant to this Consent Decree, including a comparison of actual performance with any performance measures that have been established.

(ii) A trends analysis of the number, volume, duration, and cause of the City's SSOs for a twenty-four (24)-month period updated to reflect the SSOs that occurred during the previous twelve (12)-month period except that the first Annual Report shall only include the first twelve (12) months.

(iii) A trends analysis of the number, volume, duration, and cause of all Prohibited Bypasses for a twenty-four (24)-month period updated to reflect the Prohibited Bypasses that occurred during the previous twelve (12)-month period except that the first Annual Report shall only include the first twelve (12) months.

58. Whenever any violation of this Consent Decree or any other event affecting the City's performance under this Consent Decree or its NPDES Permits may pose an immediate threat to the public health or welfare or the environment, the City shall notify EPA and MDEQ orally or by electronic or facsimile transmission as soon as possible, but no later than twenty-four (24) hours after the City first knew of the violation or event. This procedure is in addition to the requirements set forth in the preceding Paragraph.

59. All reports shall be submitted to the persons designated in Section XVI of this Consent Decree (Notices).

60. Each report by the City under this Section shall be submitted in accordance with the provisions of Paragraph 16 of this Consent Decree. The certification requirement in Paragraph 16 does not apply to emergency or similar notifications where compliance would be impractical.

61. The reporting requirements of this Consent Decree do not relieve the City of any reporting obligations required by the CWA or its implementing regulations, the Mississippi Air and Water Pollution Control Law or its implementing regulations, or by any other federal, state, or local law, regulation, permit, or other requirement. Notification to EPA or MDEQ pursuant to this Section of an anticipated delay shall not by itself excuse the delay or otherwise satisfy the notification requirements set forth in Section XI (Force Majeure).

62. Any information provided pursuant to this Consent Decree may be used by the United States or the State in any proceeding to enforce the provisions of this Consent Decree and as otherwise permitted by law.

X. STIPULATED PENALTIES

63. The City shall be liable for stipulated penalties to the United States and the State for violations of this Consent Decree as specified below, unless excused under Section XI (Force Majeure). A violation includes failing to perform any obligation required by the terms of this Consent Decree, including any work plan or schedule approved under this Consent Decree, according to all applicable requirements of this Consent Decree and within the specified time schedules established by or approved under this Consent Decree.

64. If the City fails to pay the civil penalty required to be paid under Section VII of this Decree (Civil Penalty) when due, the City shall pay a stipulated penalty of \$1,000 per day for each day that the payment is late.

65. The following stipulated penalties shall accrue for each violation identified below:

(a) SSOs Reaching Waters. For each SSO that reaches waters of the United States or the State, a stipulated penalty may be assessed as follows:

If SSO Occurs:	Penalty Per SSO Per Day:
Within 7 years from Date of Entry	\$ 500
7 years or more from Date of Entry but before 10 years from Date of Entry	\$1,000
10 years or more from Date of Entry	\$2,000

(b) Prohibited Bypasses. For each Prohibited Bypass, a stipulated penalty may be assessed as follows:

If Prohibited Bypass Occurs:	Penalty Per Prohibited Bypass:
After April 30, 2014 but before 7 years from Date of Entry	\$1,000
7 years or more from Date of Entry	\$10,000

(c) Failure to Timely Submit Deliverable. For each day the City fails to Timely submit any Deliverable, a stipulated penalty for each such Deliverable may be assessed as follows:

Period of Noncompliance:	Penalty Per Deliverable Per Day:
1-30 days	\$500
More than 30 days	\$2,000

(d) Failure to Timely Implement Work. For each day the City fails to Timely implement any Work (other than work pursuant to the MDEQ Agreed Orders I and II or the Timely submittal of a Deliverable or the implementation of the SEP), daily stipulated penalties may be assessed for each such item of Work as follows:

Period of Noncompliance:	Penalty Per Violation Per Day:
1 - 30 days	\$500
31 - 60 days	\$1,000
61-180 days	\$2,000
More than 180 days	\$5,000

(e) Failure to Timely Implement SEP Milestones. For each Day the City fails to Timely implement a SEP milestone set forth in Section VIII or Appendix F, daily stipulated penalties may be assessed as follows:

Period of Noncompliance:	Penalty Per Violation Per Day:
1 - 30 days	\$500
More than 30 days	\$1,000

(f) Failure to Complete the SEP. After receiving the SEP Completion Report, in the event EPA notifies the City that the City has failed to satisfactorily complete the SEP in accordance with the terms of this Consent Decree as described in Section VIII and Appendix F (including the allowable expenditures for the SEP), a stipulated penalty of \$375,000 may be

assessed if the City cannot certify, with supporting documentation, that at least fifty (50) percent of the required amount of money has been spent on the SEP; and a stipulated penalty of \$300,000 may be assessed if the City has certified, with supporting documentation, that at least fifty (50) percent of the required amount of money has been spent on the SEP. Notwithstanding the foregoing, if EPA determines that the City has made good faith efforts to satisfactorily complete the SEP and has certified, with supporting documentation, that at least ninety (90) percent of the required amount of money has been spent on the SEP, the City shall not be liable for any stipulated penalty.

(g) Failure to Remove Sludge from the Savanna Street WWTP Storm Diversion Cells. For each Day the City fails to Timely remove sludge from the Savanna Street WWTP storm diversion cells in accordance with the schedule required by the MDEQ Agreed Order I, a stipulated penalty of \$100 per day may be assessed.

(h) Failure to Comply with the MDEQ Agreed Order II. For each Day the City fails to Timely submit its compliance plan or, once that plan is implemented, to meet the ammonia limits for the Presidential Hills WWTP as set forth in the MDEQ Agreed Order II, a stipulated penalty of \$100 per day may be assessed.

66. Stipulated penalties under this Section shall begin to accrue on the day after performance is due or on the day a violation occurs, whichever is applicable, and shall continue to accrue until performance is satisfactorily completed or until the violation ceases. Stipulated penalties shall accrue simultaneously for separate violations of this Consent Decree.

67. For stipulated penalties set forth in Paragraphs 64 and 65.(a) through (f), the City shall pay stipulated penalties to the United States and the State within sixty (60) Days of a

written demand by EPA. For stipulated penalties set forth in Paragraphs 64 and 65.(a) through (f), the City shall pay fifty percent (50%) of the total stipulated penalty amount due to the United States and fifty percent (50%) to the State. For stipulated penalties set forth in Paragraphs 65.(g) and (h), the City shall pay stipulated penalties to the State within sixty (60) Days of a written demand by MDEQ.

68. The United States may in the unreviewable exercise of its discretion, reduce or waive stipulated penalties otherwise due under this Consent Decree pursuant to Paragraphs 64 and 65.(a) through (f). MDEQ may in the unreviewable exercise of its discretion, reduce or waive stipulated penalties otherwise due under this Consent Decree pursuant to Paragraphs 65.(g) through (h).

69. Stipulated penalties shall continue to accrue as provided in Paragraph 66, during any Dispute Resolution, but need not be paid until the following:

(a) If the dispute is resolved by agreement or by a decision of the United States, after consultation with the State, that is not appealed to the Court, the City shall pay all accrued penalties determined to be owing, together with interest, within thirty (30) Days of the effective date of the agreement or the receipt of the United States' decision or order.

(b) If the dispute is appealed to the Court and the United States prevails in whole or in part, the City shall pay all accrued penalties determined by the Court to be owed, together with interest, within sixty (60) Days of receiving the Court's decision or order, except as provided in Paragraph 69.(c) below.

(c) If the District Court's decision is appealed, the City shall pay all accrued penalties determined to be owed, together with interest, within fifteen (15) Days of receiving the final appellate court decision.

70. The City shall pay stipulated penalties owing to the United States in the manner set forth and with the confirmation notices required by Paragraph 46, except that the transmittal letter shall state that the payment is for stipulated penalties and shall state for which violation(s) the penalties are being paid. The City shall pay stipulated penalties owing to the State in the manner set forth in Paragraph 47.

71. If the City fails to pay stipulated penalties according to the terms of this Consent Decree, the City shall be liable for interest on such penalties, as provided for in 28 U.S.C. § 1961, accruing as of the date payment became due. Nothing in this Paragraph shall be construed to limit the United States or the State from seeking any remedy otherwise provided by law for the City's failure to pay any stipulated penalties.

72. Subject to the provisions of Section XIV of this Consent Decree (Effect of Settlement/Reservation of Rights), the stipulated penalties provided for in this Consent Decree shall be in addition to any other rights, remedies, or sanctions available to the United States and the State for the City's violation of this Consent Decree or applicable law; provided, however, the State agrees that it shall only assess stipulated penalties for those matters addressed in Paragraphs 65.(g) through (h) pursuant to either this Consent Decree or the MDEQ Agreed Orders I and II, but not both.

XI. FORCE MAJEURE

73. “Force majeure,” for purposes of this Consent Decree, is defined as any event arising from causes beyond the control of the City, of any entity controlled by the City, or of the City’s consultants and contractors, that delays or prevents the performance of any obligation under this Consent Decree despite the City’s best efforts to fulfill the obligation. The requirement that the City exercise “best efforts to fulfill the obligation” includes using best efforts to anticipate any potential force majeure event and best efforts to address the effects of any such event (a) as it is occurring and (b) after it has occurred to prevent or minimize any resulting delay to the greatest extent possible. “Force Majeure” does not include the City’s financial inability to perform any obligation under this Consent Decree.

74. If any event occurs or has occurred that may delay the performance of any obligation under this Consent Decree, whether or not caused by a force majeure event, the City shall provide notice orally or by electronic or facsimile transmission to EPA and MDEQ, within seventy-two (72) hours of when the City first knew that the event might cause a delay. Within seven (7) Days thereafter, the City shall provide in writing to EPA and MDEQ an explanation and description of the reasons for the delay; the anticipated duration of the delay; all actions taken or to be taken to prevent or minimize the delay; a schedule for implementation of any measures to be taken to prevent or mitigate the delay or the effect of the delay; the City’s rationale for attributing such delay to a force majeure event if it intends to assert such a claim; and a statement as to whether, in the opinion of the City, such event may cause or contribute to an endangerment to public health, welfare, or the environment. The City shall include with any notice all available documentation supporting the claim that the delay was attributable to a force

majeure event. Failure to comply with the above requirements shall preclude the City from asserting any claim of force majeure for that event for the period of time of such failure to comply, and for any additional delay caused by such failure. The City shall be deemed to know of any circumstance of which the City, any entity controlled by the City, or the City's contractors knew or should have known.

75. If EPA, after a reasonable opportunity for review and comment by MDEQ, agrees that the delay or anticipated delay is attributable to a force majeure event, the time for performance of the obligations under this Consent Decree that are affected by the force majeure event will be extended by EPA, after a reasonable opportunity for review and comment by MDEQ, for such time as is necessary to complete those obligations. An extension of the time for performance of the obligations affected by the force majeure event shall not, of itself, extend the time for performance of any other obligation. EPA will notify the City in writing of the length of the extension, if any, for performance of the obligations affected by the force majeure event.

76. If EPA, after a reasonable opportunity for review and comment by MDEQ, does not agree that the delay or anticipated delay has been or will be caused by a force majeure event, EPA will notify the City in writing of its decision.

77. If the City elects to invoke the dispute resolution procedures set forth in Section XII (Dispute Resolution), it shall do so no later than fifteen (15) Days after receipt of EPA's notice. In any such proceeding, the City shall have the burden of demonstrating by a preponderance of the evidence that the delay or anticipated delay has been or will be caused by a force majeure event, that the duration of the delay or the extension sought was or will be warranted under the circumstances, that best efforts were exercised to avoid and mitigate the

effects of the delay, and that the City complied with the requirements of Paragraphs 73 and 74 above. If the City carries this burden, the delay at issue shall be deemed not to be a violation by the City of the affected obligation of this Consent Decree identified to EPA and the Court.

XII. DISPUTE RESOLUTION

78. Unless otherwise expressly provided for in this Consent Decree, the dispute resolution procedures of this Section shall be the exclusive mechanism to resolve disputes arising under or with respect to this Consent Decree. The City's failure to seek resolution of a dispute under this Section shall preclude the City from raising any such issue as a defense to an action by the United States or the State to enforce any obligation of the City arising under this Consent Decree.

79. Informal Dispute Resolution. Any dispute subject to Dispute Resolution under this Consent Decree shall first be the subject of informal negotiations. The dispute shall be considered to have arisen when the City sends the United States a written Notice of Dispute. Such Notice of Dispute shall state clearly the matter in dispute. The period of informal negotiations shall not exceed twenty (20) Days from the date the dispute arises, unless that period is modified by written agreement between the United States and the City. The United States shall consult with the State during the period of informal negotiations. If the United States and the City cannot resolve a dispute by informal negotiations, then the position advanced by the United States shall be considered binding unless, within forty-five (45) Days after the conclusion of the informal negotiation period, the City invokes formal dispute resolution procedures as set forth below.

80. Formal Dispute Resolution. The City shall invoke formal dispute resolution procedures, within the time period provided in the preceding Paragraph, by serving on the United States and the State a written Statement of Position regarding the matter in dispute. The Statement of Position shall include, but need not be limited to, any factual data, analysis, or opinion supporting the City's position and any supporting documentation relied upon by the City. The United States shall serve its Statement of Position within ninety (90) Days of receipt of the City's Statement of Position. The United States' Statement of Position shall include, but need not be limited to, any factual data, analysis, or opinion supporting that position and any supporting documentation relied upon by the United States. The United States shall consult with the State during preparation of its Statement of Position. The United States' Statement of Position shall be binding on the City, unless the City files a motion for judicial review of the dispute in accordance with the following Paragraph.

81. Judicial Dispute Resolution. The City may seek judicial review of the dispute by filing with the Court and serving on the United States and the State, in accordance with Section XVI of this Consent Decree (Notices), a motion requesting judicial resolution of the dispute. The motion must be filed within ten (10) Days of receipt of the United States' Statement of Position pursuant to the preceding Paragraph. The motion shall contain a written statement of the City's position on the matter in dispute, including any supporting factual data, analysis, opinion, or documentation, and shall set forth the relief requested and any schedule within which the dispute must be resolved for orderly implementation of the Consent Decree. The United States shall respond to the City's motion within the time period allowed by the Local Rules of

this Court. The United States shall consult with the State during preparation of its response.

The City may file a reply memorandum, to the extent permitted by the Local Rules.

82. Standard of Review.

a. Disputes Concerning Matters Accorded Record Review. Except as otherwise provided in this Consent Decree, in any dispute brought under Paragraphs 80 and 81 pertaining to the adequacy or appropriateness of plans, procedures to implement plans, schedules or any other items requiring approval by EPA under this Consent Decree; the adequacy of the performance of work undertaken pursuant to this Consent Decree; and all other disputes that are accorded review on the administrative record under applicable principles of administrative law, the City shall have the burden of demonstrating, based on the administrative record, that the position of the United States is arbitrary and capricious or otherwise not in accordance with law.

b. Other Disputes. Except as otherwise provided in this Consent Decree, in any other dispute brought under Paragraphs 80 and 81, the City shall bear the burden of demonstrating that its position complies with this Consent Decree and furthers the objectives of the Consent Decree.

83. The invocation of dispute resolution procedures under this Section shall not, by itself, extend, postpone, or affect in any way any obligation of the City under this Consent Decree, unless and until final resolution of the dispute so provides. Stipulated penalties with respect to the disputed matter shall continue to accrue from the first day of noncompliance, but payment shall be stayed pending resolution of the dispute as provided in Paragraph 69. If the City does not prevail on the disputed issue, stipulated penalties shall be assessed and paid as provided in Section X (Stipulated Penalties).

XIII. RIGHT OF ENTRY AND INFORMATION COLLECTION AND RETENTION

84. The United States, the State, and their representatives, including attorneys, contractors, and consultants, shall have the right of entry into any facility covered by this Consent Decree, at all reasonable times, upon presentation of credentials, to:

- (a) Monitor the progress of activities required under this Consent Decree.
- (b) Verify any data or information submitted to the United States or the State in accordance with the terms of this Consent Decree.
- (c) Obtain samples and, upon request, splits of any samples taken by the City or its representatives, contractors, or consultants.
- (d) Obtain documentary evidence, including photographs and similar data.
- (e) Assess the City's compliance with this Consent Decree.

85. Upon request, the City shall provide EPA and MDEQ or their authorized representatives splits of any samples taken by the City. Upon request, EPA and MDEQ shall provide the City splits of any samples taken by EPA or MDEQ.

86. Until five (5) years after the termination of this Consent Decree, the City shall retain, and shall instruct its contractors and agents to preserve, all non-identical copies of all documents, records, or other information (including documents, records, or other information in electronic form) in its or its contractors' or agents' possession or control, or that come into its or its contractors' or agents' possession or control, and that relate in any manner to the City's performance of its obligations under this Consent Decree. This information-retention requirement shall apply regardless of any contrary corporate or institutional policies or procedures. At any time during this information-retention period, upon request by the United

States or the State, the City shall provide copies of any documents, records, or other information required to be maintained under this Paragraph.

87. At the conclusion of the information-retention period provided in the preceding Paragraph, the City shall notify the United States and the State at least ninety (90) Days prior to the destruction of any documents, records, or other information subject to the requirements of the preceding Paragraph and, upon request by the United States or the State, the City shall deliver any such documents, records, or other information to EPA or MDEQ. The City may assert that certain documents, records, or other information is privileged under the attorney-client privilege or any other privilege recognized by federal law. If the City asserts such a privilege, it shall provide the following:

- (a) The title of the document, record, or information.
- (b) The date of the document, record, or information.
- (c) The name and title of each author of the document, record, or information.
- (d) The name and title of each addressee and recipient.
- (e) A description of the subject of the document, record, or information.
- (f) The privilege asserted by the City.

However, no documents, records, or other information created or generated pursuant to the requirements of this Consent Decree shall be withheld on grounds of privilege.

88. The City may also assert that information required to be provided under this Section is protected as Confidential Business Information ("CBI") under 40 C.F.R. Part 2. As to any information that the City seeks to protect as CBI, the City shall follow the procedures set forth in 40 C.F.R. Part 2.

89. This Consent Decree in no way limits or affects any right of entry and inspection, or any right to obtain information, held by the United States or the State pursuant to applicable federal or state laws, regulations, or permits, nor does it limit or affect any duty or obligation of the City to maintain documents, records, or other information imposed by applicable federal or state laws, regulations, or permits.

XIV. EFFECT OF SETTLEMENT/RESERVATION OF RIGHTS

90. This Consent Decree resolves the civil claims of the United States and the State for the violations alleged in the Complaint filed in this action through the Date of Lodging of this Consent Decree.

91. The United States and the State reserve all legal and equitable remedies available to enforce the provisions of this Consent Decree, except as expressly stated in Paragraph 90. This Consent Decree shall not be construed to limit the rights of the United States or the State to obtain penalties or injunctive relief under the CWA, the Mississippi Air and Water Pollution Control Law, or their implementing regulations, or under other federal or state laws, regulations, or permit conditions, except as expressly specified in Paragraph 90. The United States and the State further reserve all legal and equitable remedies to address any imminent and substantial endangerment to the public health or welfare or the environment arising at, or posed by, the City's Sewer System, whether related to the violations addressed in this Consent Decree or otherwise.

92. In any subsequent administrative or judicial proceeding initiated by the United States or the State for injunctive relief, civil penalties, other appropriate relief relating to the Sewer System or the City's violations, the City shall not assert, and may not maintain, any

defense or claim based upon the principles of waiver, res judicata, collateral estoppel, issue preclusion, claim preclusion, claim-splitting, or other defenses based upon any contention that the claims raised by the United States or the State in the subsequent proceeding were or should have been brought in the instant case, except with respect to claims that have been specifically resolved pursuant to Paragraph 90 of this Section.

93. This Consent Decree is not a permit, or a modification of any permit, under any federal, State, or local laws or regulations. The City is responsible for achieving and maintaining complete compliance with all applicable federal, State, and local laws, regulations, and permits; and the City's compliance with this Consent Decree shall be no defense to any action commenced pursuant to any such laws, regulations, or permits, except as set forth herein. The United States and the State do not, by their consent to the entry of this Consent Decree, warrant or aver in any manner that the City's compliance with any aspect of this Consent Decree will result in compliance with provisions of the CWA, the Mississippi Air and Water Pollution Control Law, or with any other provisions of federal, State, or local laws, regulations, or permits.

94. This Consent Decree does not limit or affect the rights of the City or of the United States or the State against any third parties, not party to this Consent Decree, nor does it limit the rights of third parties, not party to this Consent Decree, against the City, except as otherwise provided by law.

95. This Consent Decree shall not be construed to create rights in, or grant any cause of action to, any third party not party to this Consent Decree.

XV. COSTS

96. The Parties shall bear their own costs of this action, including attorneys' fees, except that the United States and the State shall be entitled to collect the costs (including attorneys' fees) incurred in any action necessary to collect any portion of the civil penalty or any stipulated penalties due but not paid by the City.

XVI. NOTICES

97. Unless otherwise specified herein, whenever notifications, submissions, or communications are required by this Consent Decree, they shall be made in writing and addressed as follows:

To the United States:

Chief, Environmental Enforcement Section
Environment and Natural Resources Division
U.S. Department of Justice
Box 7611 Ben Franklin Station
Washington, D.C. 20044-7611
Re: DOJ No. 90-5-1-1-09841

Karl Fingerhood
Environmental Enforcement Section
U.S. Department of Justice
Box 7611 Ben Franklin Station
Washington, D.C. 20044-7611

and

Chief, Clean Water Enforcement Branch
Water Protection Division
U.S. Environmental Protection Agency, Region 4
ATTN: Brad Ammons
61 Forsyth Street, S.W.
Atlanta, GA 30303
(404) 562-9769

To EPA:

Chief, Clean Water Enforcement Branch
Water Protection Division
U.S Environmental Protection Agency, Region 4
ATTN: Brad Ammons
61 Forsyth Street, S.W.
Atlanta, GA 30303
(404) 562-9769

To the State/MDEQ

Chief, Environmental Compliance and Enforcement Division
Office of Pollution Control
Mississippi Department of Environmental Quality
ATTN: Rusty Lyons
P.O. Box 2261
Jackson, MS 39225-2261
(901) 961-5588

To the City:

Mayor
City of Jackson, Mississippi
ATTN: Harvey Johnson, Jr., Mayor
P.O. Box 17
Jackson, MS 39205-0017
(601) 960-1084

Director, Department of Public Works
City of Jackson, Mississippi
ATTN: Dan Gaillet, P.E.
P.O. Box 17
Jackson, MS 39205-0017
(601) 960-2091

98. Any Party may, by written notice to the other Parties, change its designated notice recipient or notice address provided above.

99. Notices submitted pursuant to this Section shall be deemed submitted upon mailing, unless otherwise provided in this Consent Decree or by mutual agreement of the Parties in writing.

XVII. EFFECTIVE DATE

100. The Effective Date of this Consent Decree shall be the date upon which this Consent Decree is entered by the Court or a motion to enter the Consent Decree is granted, whichever occurs first, as recorded on the Court's docket.

XVIII. RETENTION OF JURISDICTION

101. The Court shall retain jurisdiction over this case until termination of this Consent Decree, for the purpose of resolving disputes arising under this Consent Decree or entering orders modifying this Consent Decree, pursuant to Sections XII and XIX, or effectuating or enforcing compliance with the terms of this Consent Decree.

XIX. MODIFICATION

102. The terms of this Consent Decree, including any attached appendices, may be modified only by a subsequent written agreement signed by all the Parties. Other than a modification made pursuant to Paragraph 72 (Force Majeure), when the modification constitutes a material change to this Decree, it shall be effective only upon approval by the Court. Non-material changes to this Consent Decree (including appendices) may be made by written agreement of the Parties without Court approval, and the Parties may by mutual agreement determine whether a modification is non-material.

103. Any disputes between the United States, the State, and the City concerning modification of this Consent Decree shall be resolved pursuant to Section XII of this Consent

Decree (Dispute Resolution), provided, however, that, instead of the burden of proof provided by Paragraph 82, the Party seeking the modification bears the burden of demonstrating that it is entitled to the requested modification in accordance with Federal Rule of Civil Procedure 60(b).

XX. TERMINATION

104. This Consent Decree may be terminated when the United States determines that the City has satisfactorily completed performance of its compliance (Section VI) and SEP (Section VIII) obligations required by this Consent Decree, provided that the City has fulfilled all other obligations of this Consent Decree, including payment of the civil penalty under Section VII of this Consent Decree and any accrued stipulated penalties as required by Section X of this Consent Decree not waived or reduced by the United States. The City may serve upon the United States a Request for Termination, certifying that the City has satisfied those requirements, together with all necessary supporting documentation.

105. Following receipt by the United States of the City's Request for Termination, the United States and the City shall confer informally concerning the Request and any disagreement that they may have as to whether the City has satisfactorily complied with the requirements for termination of this Consent Decree. If the United States, after consultation with the State, agrees that the Consent Decree may be terminated, the United States and the City shall submit, for the Court's approval, a joint stipulation terminating the Consent Decree.

106. If the United States, after consultation with the State, does not agree that the Consent Decree may be terminated, the City may invoke Dispute Resolution under Section XII of this Consent Decree. However, the City shall not seek Dispute Resolution of any dispute

regarding termination, under Paragraph 80 of Section XII, until one hundred-twenty (120) Days after service of its Request for Termination.

XXI. PUBLIC PARTICIPATION

107. This Consent Decree shall be lodged with the Court for a period of not less than thirty (30) Days for public notice and comment in accordance with 28 C.F.R. § 50.7. The United States reserves the right to withdraw or withhold its consent if the comments regarding the Consent Decree disclose facts or considerations indicating that the Consent Decree is inappropriate, improper, or inadequate. The City and the State each consent to entry of this Consent Decree without further notice and agrees not to withdraw from or oppose entry of this Consent Decree by the Court or to challenge any provision of the Consent Decree, unless the United States has notified the Parties in writing that it no longer supports entry of the Consent Decree.

XXII. SIGNATORIES/SERVICE

108. Each undersigned representative of the City, EPA, the Assistant Attorney General for the Environment and Natural Resources Division of the Department of Justice, MDEQ, and the State certifies that he or she is fully authorized to enter into the terms and conditions of this Consent Decree and to execute and legally bind the Party he or she represents to this document.

109. This Consent Decree may be signed in counterparts, and its validity shall not be challenged on that basis. The City agrees to accept service of process by mail with respect to all matters arising under or relating to this Consent Decree and to waive the formal service requirements set forth in Rules 4 and 5 of the Federal Rules of Civil Procedure and any applicable Local Rules of this Court including, but not limited to, service of a summons.

XXIII. INTEGRATION

110. This Consent Decree constitutes the final, complete, and exclusive agreement and understanding among the Parties with respect to the settlement embodied in the Consent Decree and supersedes all prior agreements and understandings, whether oral or written, concerning the settlement embodied herein. Other than Deliverables that are subsequently submitted and approved pursuant to this Consent Decree, no other document, nor any representation, inducement, agreement, understanding, or promise, constitutes any part of this Consent Decree or the settlement it represents, nor shall it be used in construing the terms of this Consent Decree.

XXIV. FINAL JUDGMENT

111. Upon approval and entry of this Consent Decree by the Court, this Consent Decree shall constitute a final judgment of the Court as to the United States, the State, and the City. The Court finds that there is no just reason for delay and therefore enters this judgment as a final judgment under Fed. R. Civ. P. 54 and 58.

XXV. APPENDICES

112. The following appendices are attached to and incorporated into this Consent Decree:

“Appendix A” is the MDEQ Agreed Order I entered into by MDEQ and the City on September 10, 2010, as amended.

“Appendix B” is the MDEQ Agreed Order II entered into by MDEQ and the City on August 23, 2011.

“Appendix C” is a map of the Sewersheds comprising the City’s WCTS.

“Appendix D” is the CDROM disk containing EPA Region IV guidance on Capacity, Management, Operations and Maintenance (“CMOM”) programs.

“Appendix E” is the City’s SORP.


“Appendix F” is the Supplemental Environmental Project.

Dated and entered this ___ day of _____, 20__.


UNITED STATES DISTRICT JUDGE
Southern District of Mississippi

WE HEREBY CONSENT to the entry of this Consent Decree, subject to the public notice and comment provisions of 28 C.F.R. § 50.7:

FOR PLAINTIFF UNITED STATES OF AMERICA:



IGNACIA S. MORENO
Assistant Attorney General
U.S. Department of Justice
Environment and Natural Resources Division



KARL J. FINGERHOOD
Trial Attorney
U.S. Department of Justice
Environment and Natural Resources Division
Environmental Enforcement Section
P.O. Box 7611
Ben Franklin Station
Washington, D.C. 20044-7611
Telephone: 202-514-7519
Facsimile: 202-616-2427

WE HEREBY CONSENT to the entry of this Consent Decree, subject to the public notice and comment provisions of 28 C.F.R. § 50.7:

FOR PLAINTIFF UNITED STATES OF AMERICA (Continued):

GREGORY K. DAVIS
United States Attorney
Southern District of Mississippi

SAMUEL LYNN MURRAY (MS Bar ID No. 3690)
Assistant U.S. Attorney
Southern District of Mississippi
501 E. Court St., Suite 4.430
Jackson, MS 39201
Telephone: (601) 973-2853
Fascimile: (601) 965-4023

WE HEREBY CONSENT to the entry of this Consent Decree, subject to the public notice and comment provisions of 28 C.F.R. § 50.7:

FOR PLAINTIFF UNITED STATES OF AMERICA (Continued):



MARY J. WILKES
Regional Counsel
United States Environmental Protection Agency
Region 4
61 Forsyth Street
Atlanta, GA 30303



WILLIAM B. BUSH, JR.
Associate Regional Counsel
United States Environmental Protection Agency
Region 4
61 Forsyth Street
Atlanta, GA 30303
Telephone: 404-562-9538
Facsimile: 404-562-9487

WE HEREBY CONSENT to the entry of this Consent Decree, subject to the public notice and comment provisions of 28 C.F.R. § 50.7:

FOR PLAINTIFF UNITED STATES OF AMERICA (Continued):

[REDACTED]

PAMELA J. MAZAKAS
Acting Office Director
Office of Civil Enforcement
Office of Enforcement and Compliance Assurance
United States Environmental Protection Agency


[REDACTED]

for MARK POLLINS
Division Director
Water Enforcement Division
Office of Civil Enforcement
Office of Enforcement and Compliance Assurance
United States Environmental Protection Agency


[REDACTED]

CAROL DEMARCO
Water Enforcement Division
Office of Civil Enforcement
Office of Enforcement and Compliance Assurance
United States Environmental Protection Agency
1200 Pennsylvania Ave., NW (2243A)
Washington, DC 20460
Telephone: 202-564-2412
Facsimile: 202-564-0024

FOR PLAINTIFF STATE OF MISSISSIPPI BY AND THROUGH THE MISSISSIPPI
COMMISSION ON ENVIRONMENTAL QUALITY AND THE MISSISSIPPI
DEPARTMENT OF ENVIRONMENTAL QUALITY:




TRUDY D. FISHER
Executive Director
Mississippi Department of Environmental Quality
P.O. Box 2261
Jackson, MS 39225




CHRISTOPHER G. WELLS
Senior Attorney
Office of Pollution Control
Mississippi Department of Environmental Quality
P.O. Box 2261
Jackson, MS 39225
Telephone: 601-961-5545
Facsimile: 601-961-5674


FOR THE CITY OF JACKSON:



HARVEY JOHNSON, JR.
Mayor
City of Jackson, Mississippi
P.O. Box 17
Jackson, MS 39205-0017
Telephone: 601-960-1084
Facsimile: 601-960-2504



PIETER TEEUWISSEN
City Attorney
Office of the City Attorney
P.O. Box 2779
Jackson, MS 39205-2779
Telephone: 601-960-1799
Facsimile: 601-960-1756



TERRELL S. WILLIAMSON
Legal Counsel
Office of the City Attorney
P.O. Box 2779
Jackson, MS 39205-2779
Telephone: 601-960-1799
Facsimile: 601-960-1756

APPENDIX A

BEFORE THE MISSISSIPPI COMMISSION
ON ENVIRONMENTAL QUALITY

MISSISSIPPI COMMISSION ON
ENVIRONMENTAL QUALITY

COMPLAINANT

VS.

ORDER NO. **5823 10**

CITY OF JACKSON
PO BOX 17
JACKSON, MISSISSIPPI 39205-0017

RESPONDENT

AGREED ORDER

COME NOW the Mississippi Commission on Environmental Quality ("Commission"), acting through the staff and Executive Director of the Mississippi Department of Environmental Quality ("MDEQ"), Complainant, and the City of Jackson, Respondent, in the above captioned cause and agree as follows:

1.

This Agreed Order addresses the following violations relating to Respondent's Savannah Street Waste Water Treatment Facility (the "SSWWTF") and its associated collection system:

- A. On March 21, 2009, a 100 million gallon per day ("MGD") influent pump failed at the SSWWTF. On March 27, 2009, discharges of untreated wastewater were observed from manholes located near the State Fairgrounds, the east end of High Street, and at Eubanks Creek near I-55 as a result of such wastewater backing up into the collection system due to the pump failure. On March 30, 2009, Respondent notified Complainant of these discharges that occurred as a result of a 100 MGD pump failure. Water samples taken on April 2, 2009 from the Pearl River indicated that impacts, as a result of the discharges, violated water quality

standards. Respondent was contacted by Complainant on April 20, 2009, and notified that these discharges constituted violations of NPDES Permit No. MS0024295 (the "Permit") (see Conditions T-24: Proper Operation, Maintenance, and Replacement, T-25: Duty to Mitigate, and T-30: Bypassing- Prohibition of Bypass.)

- B. On July 22, 2009, MDEQ staff observed Respondent diverting a portion of the SSWWTF's influent wastewater into the storm diversion cells located at the SSWWTF. On July 22, 2009, Respondent also released wastewater from the storm diversion cells and blended this flow into the main effluent from the SSWWTF. This blended flow was then discharged from the SSWWTF's Outfall 001. Respondent's actions were the result of the SSWWTF not having sufficient storage and/or treatment capacity to handle the volume of influent wastewater. The SSWWTF's storage and/or treatment capacity has been limited by the accumulation of excess sludge and solids in the storm diversion cells and in the aeration basins and secondary clarifiers within the SSWWTF as a result of, at least in part, Respondent's sludge handling facilities being unavailable to properly process the sludge and solids for disposal. This accumulation of sludge and thus this diversion of wastewater on July 22, 2009 constitutes a violation of the Permit (see Conditions T-24: Proper Operation, Maintenance, and Replacement and T-25: Duty to Mitigate).
- C. Mississippi Code 49-17-29 prohibits the discharge of any wastes into any waters of the State which reduce the quality of those waters. Complainant notified Respondent of the following discharges within the collection system:
- i. On August 11, 2009, MDEQ confirmed a discharge of untreated wastewater from a manhole located off Browning Street near Clinton. The discharge continued several days following MDEQ notifying Respondent of the discharge. Water samples taken on August 20, 2009 from Bakers Creek indicated that impacts, as a result of the discharge, violated water quality standards.
 - ii. On August 24, 2009, MDEQ confirmed a discharge of untreated wastewater from a lift station near the Brookwood Subdivision in south Hinds

County. The discharge continued several days following MDEQ notifying Respondent of the discharge. Water samples taken on August 27, 2009 from an unnamed tributary entering Trahon Creek indicated that impacts, as a result of the discharge, violated water quality standards.

- D. On June 24, 2009, Complainant notified Respondent that land application activities of wastewater treatment sludges had been conducted on properties without a current, valid permit in violation of Section II of the Mississippi Nonhazardous Waste Management Regulations. Further, Respondent failed to timely submit applications for permit reissuance for the Jackson Landfill, Parcel 2 and Parcel 3 Landfarm, Jackson Biosolids Beneficial Agricultural Application Sites, and the Berry Land Application Site in violation of Solid Waste Management Permit No. SW02501A0005, No. SW02501C0420, No. SW0250030464, and No. SW0250030468, respectively.

2.

In lieu of a formal enforcement hearing concerning the specific violation(s) listed above, Complainant and Respondent agree to settle this matter as follows:

- A. Respondent agrees to pay and Complainant agrees to accept a civil penalty in the amount of \$240,000.00. Respondent shall pay this penalty to MDEQ within thirty (30) days after this Agreed Order has been executed by the MDEQ Executive Director, or her designee (the "Effective Date").
- B. On or before August 31, 2010, Respondent shall submit to MDEQ for approval a Sewer Overflow Response Plan ("SORP") that will establish timely and effective methods and means of: (a) responding to, cleaning up, and/or minimizing the impact of all sanitary sewer overflows ("SSOs"); (b) timely reporting the location, volume, cause, impact, and other pertinent information of all SSOs to the appropriate regulatory agencies; and (c) notifying the potentially impacted public.
- i. For purposes of the SORP and this Agreed Order, the following definitions

shall apply:

- (a) "SSO" shall mean an overflow, spill, or release of wastewater from Respondent's Sewer System including: (i) Unpermitted Discharges; (ii) any overflows, spills, or releases of wastewater, including those that may not have reached waters of the State or waters of the United States; and (iii) all Building Backups.
- (b) "Unpermitted Discharge" shall mean a discharge of pollutants which reaches waters of the United States or the State from (i) the Sewer System, (ii) a Wastewater Treatment Plant ("WWTP") through a point source not specified in an NPDES Permit, or (iii) a WWTP which constitutes a prohibited Bypass.
- (c) "Building Backup" shall mean a wastewater backup into a building that is caused by blockages, malfunctions, or flow conditions in the Sewer System. A wastewater backup into a building that is caused by a blockage or other malfunction of a Private Lateral is not a Building Backup.
- (d) "Sewer System" shall mean the Wastewater Collection Transmission Systems ("WCTS") and the WWTPs.
- (e) "Wastewater Collection and Transmission Systems" or "WCTS" shall mean the municipal wastewater collection and transmission systems, including all pipes, force mains, gravity sewer lines, lift stations, pump stations, manholes and appurtenances thereto, which are owned or operated by Respondent.
- (f) "Wastewater Treatment Plant" or "WWTP" shall mean devices or systems used in the storage, treatment, recycling, and reclamation of municipal wastewater. For purposes of this Agreed Order, this definition shall include all facilities owned, managed, operated, and maintained by Respondent, including but not limited to the following facilities: Savanna Street WWTP, Trahon/Big Creek WWTP and Presidential Hills WWTP.

- (g) "Bypass" shall have the meaning set forth at 40 C.F.R. § 122.41(m).
 - (h) "Private Lateral" shall mean that portion of a sanitary sewer conveyance pipe, including that portion in the public right of way, that extends from the wastewater main to the single-family, multi-family, apartment or other dwelling unit or commercial or industrial structure to which wastewater service is or has been provided.
- ii. Within twenty-four (24) hours of the time Respondent first becomes aware of an SSO, Respondent shall provide in an oral report to MDEQ the location of the SSO by street address or any other appropriate method (i.e., latitude-longitude). The oral report shall be given to MDEQ's Environmental Compliance and Enforcement Division's Municipal and Private Facilities Branch at (601) 961- 5171.
- iii. Respondent shall also provide a written report to MDEQ for all SSOs within 5 days of the time Respondent becomes aware of the SSO. Respondent shall maintain a copy of any written reports prepared pursuant to this subparagraph for a period of not less than five (5) years from the date of the SSO. The written report shall contain the following:
 - (a) Location of the SSO by street address, or any other appropriate method (i.e., latitude-longitude);
 - (b) Estimated date and time when the SSO began and stopped, or if it is still an active SSO, the anticipated time to stop the SSO;
 - (c) Steps taken to respond to the SSO;
 - (d) Name of the receiving water, if applicable;
 - (e) An estimate of the volume (in gallons) of sewage discharged;

- (f) Description of the Sewer System component from which the SSO was released (such as manhole, crack in pipe, pump station wet well or constructed overflow pipe);
- (g) Estimate of the SSO's impact on public health and to water quality in the receiving water body;
- (h) Cause or suspected cause of the SSO;
- (i) The date of the last SSO at the same location;
- (j) Steps taken or to be taken to reduce, eliminate, and prevent reoccurrence of the SSO and a schedule of major milestones for those steps; and
- (k) Report of all notifications to the public and other agencies or departments.

If submitted within 24 hours of the SSO, this written report may be submitted in lieu of providing oral notification as stated in 2.B.ii. above.

- iv. Respondent shall maintain for all SSOs, for a period of not less than five (5) years from the date of the SSO, all records documenting the steps that have been and will be taken to prevent the SSO from recurring, including work order records associated with investigation and repair activities related to the SSO. Respondent shall also maintain for a period of not less than five (5) years from the date of the SSO a list and description of complaints from customers or others regarding an SSO.
- v. The SORP shall provide procedures for responding to SSOs to minimize the environmental impact and potential human health risk of SSOs. The SORP shall include, but not be limited to, the following:
 - (a) A detailed description of the actions Respondent will undertake to immediately provide notice to the public (through the local news media or other means including signs or barricades to restrict access) of the SSO;

- (b) A detailed description of the actions Respondent will undertake to provide notice to appropriate federal, state or local agencies/authorities;
- (c) A detailed plan (including the development of response standard operating procedures) to minimize the volume of untreated wastewater transmitted to the portion of the Sewer System impacted by the events precipitating the SSO to minimize overflow volumes;
- (d) For Building Backups, the SORP shall include a detailed plan describing the standard operating procedures to be followed by Respondent personnel in responding, including:
 - (1) A description of methods for communicating with customers about how to report Building Backups and how to obtain clean-up;
 - (2) A description of Respondent's response to Building Backups, including:
 - (A) The timeframe for responses;
 - (B) The measures taken to cleanup Building Backups caused by conditions in Respondent's Sewer System. Such measures shall include procedures necessary to disinfect and/or remove items potentially contaminated by Building Backups, and shall include wet vacuuming or other removal of spillage, wiping floors and walls with cleaning solution and disinfectant, flushing out and disinfecting plumbing fixtures, carpet cleaning and/or replacement and other appropriate measures to disinfect and/or remove items potentially contaminated by Building Backups; and
 - (C) The measures taken to correct or repair conditions in the Sewer System causing or contributing to Building Backups; and

- (3) A description of Respondent's follow-up process to insure adequacy of cleanup.
 - (e) A detailed plan of the resources to be used to correct or repair the condition causing or contributing to the SSO;
 - (f) A plan to ensure the preparedness, including response training of Respondent's employees, contractors, and personnel of other affected agencies necessary for the effective implementation of the SORP in the event of a SSO;
 - (g) Identification of SSO locations within the sewershed served by each pump station and those locations at which a SSO is likely to occur first in the event of pump station failure for each pump station; and
 - (h) Pump station-specific emergency procedures, bypass/pump-around strategies, and estimated storage capacity (i.e., maximum volume of sewage that can be stored in the event of a pump station failure or repair without causing a SSO and estimated time during which sewage can be stored before a SSO will occur). In the event that a repair may cause or lengthen the time of a SSO, the SORP shall provide a procedure for determining when additional storage or pump around will be needed.
- vi. Respondent shall provide adequate training necessary for its employees, contractors, and personnel of other affected agencies to effectively implement the SORP. The SORP shall provide training guidelines to ensure adequate response training is provided to management and field personnel responsible for responding to SSOs. Respondent shall establish procedures, and provide adequate training to response personnel for estimating volumes of wastewater released during SSOs.
- vii. Respondent shall identify and include in the SORP a list of those SSO locations within the sewershed that has been recorded as overflowing more

than once in the past two (2) years and those locations at which a SSO is likely to occur first in the event of pump station failure for each pump station. Respondent shall establish routine inspection routes to be performed after each rain event. The inspection routes shall include all SSOs identified as occurring more than once in the past two (2) years and those pump stations that are not monitored at a central location via telemetry, SCADA, or other remote monitoring device.

viii. Respondent acknowledges that the SORP to be implemented as a part of this Agreed Order may be deemed interim in nature despite being approved by MDEQ and, as a result, MDEQ and/or the United States Environmental Protection Agency may require additional measures to be included in the SORP.

- C. On or before August 31, 2010, Respondent shall submit to MDEQ for approval a written plan to address the proper maintenance of all pumps in the influent pump station at the SSWWTF. This plan should also include a contingency plan to be implemented in the event of pumps in the pump station failing or otherwise being taken off line to ensure adequate influent flow into the SSWWTF.
- D. On or before November 30, 2010, Respondent shall submit to MDEQ for approval a Sludge and Solids Removal Plan that shall provide for the removal and proper disposal of excess, accumulated sludge/solids from the SSWWTF's storm diversion cells. The Sludge and Solids Removal Plan shall identify the minimum amount of sludge/solids that are to remain in the storm diversion cells, so as to achieve the maximum design capacity of the storm diversion cells as certified by a Professional Engineer licensed in the State of Mississippi. The Sludge and Solids Removal Plan shall also include, at a minimum, a schedule for completion of removal and disposal activities not to exceed September 1, 2011. The plan shall take into account the flow during the sludge/solids removal so as to minimize the environmental impact of the removal process. The Plan shall provide for Respondent to demonstrate that the minimum amount of sludge to remain in the

storm diversion cells has been achieved using acceptable measuring techniques. The plan shall also address sludge management to include proper storage and proper disposal. After Respondent has commenced sludge/solids removal, the Plan shall also provide for Respondent to submit weekly Status Reports to MDEQ that shall include, at a minimum, the hours of sludge removal operations performed, the quantity of sludge/solids removed, any operational setbacks experienced (weather, equipment failure, etc.), and an analysis of Respondent's progress to complete work under the Plan on or before the September 1, 2011 deadline.

- E. On or before November 30, 2010, Respondent shall submit to MDEQ for approval a Sludge and Solids Removal Plan that shall provide for the removal and proper disposal of excess, accumulated sludge/solids from the SSWWTF's aeration basins and secondary clarifiers within the SSWWTF. The Sludge and Solids Removal Plan shall identify the minimum amount of sludge/solids that are to remain in the aeration basins and the secondary clarifiers so as to achieve the maximum secondary treatment of all flow discharged from the SSWWTF as certified by a Professional Engineer licensed in the State of Mississippi. The Sludge and Solids Removal Plan shall also include, at a minimum, a schedule for completion of removal and disposal activities not to exceed March 31, 2011. The plan shall take into account the flow during the sludge/solids removal so as to minimize the environmental impact of the removal process. The Plan shall provide for Respondent to demonstrate that the minimum amount of sludge to remain in the aeration basins and the secondary clarifiers has been achieved using acceptable measuring techniques. The plan shall also address sludge management to include proper storage and proper disposal. After Respondent has commenced sludge/solids removal, the Plan shall also provide for Respondent to submit weekly Status Reports to MDEQ that shall include the hours of sludge removal operations performed, the quantity of sludge/solids removed, any operational setbacks experienced (weather, equipment failure, etc.), and an analysis of Respondent's progress to complete work under the Plan on or before the March

31, 2011 deadline.

- F. On or before August 31, 2010, Respondent shall submit to MDEQ for approval an engineering study on its sludge handling and disposal practices associated with the SSWWTF. To eliminate the current and any future accumulation of excess sludge at the SSWWTF, this study, at a minimum, shall determine the need for additional sludge dewatering facilities, additional land application sites, and alternative means of final disposal. The study shall include a schedule, not to exceed June 30, 2011, for actions to be taken by Respondent to address and provide for these additional needs to be met for its sludge handling and disposal practices.
- G. Respondent shall immediately cease the land application of waste on properties that do not have a current, valid permit under Section II of the Mississippi Nonhazardous Waste Management Regulations and on properties that Respondent once held a solid waste management permit for such activities but did not submit a reissuance application 180 days prior to expiration.

3.

In addition to the penalty set forth in Paragraph 2.A. of this Agreed Order, Respondent agrees to pay a stipulated penalty of \$100 per day each day after the expiration of any deadline set forth in Paragraphs 2.B. – 2.G. until each item has been completed. MDEQ shall have the discretion to calculate and notify Respondent of the amount of accrued stipulated penalties on a periodic basis, which shall be no more frequently than monthly. Respondent agrees to pay the entire amount of the accrued stipulated penalties within 30 days of receipt of such notification from MDEQ.

4.

Notwithstanding the provision by this Agreed Order for stipulated penalties to accrue in certain circumstances, the Commission reserves the right to conduct a separate enforcement action concerning any violation by Respondent of this Agreed Order or of the laws or regulations within the jurisdiction of the Commission. If the Commission conducts a separate enforcement action concerning a violation for which stipulated penalties are provided in this Agreed Order, the Commission will be deemed to have waived the right to collect stipulated penalties in lieu of

the right to conduct the separate enforcement action. In that separate enforcement action, the Commission may seek penalties, injunctive relief, or other appropriate relief different from or in the excess of the amount of stipulated penalties included in this Agreed Order, up to and including the statutory maximum penalty.

5.

Nothing in this Agreed Order shall limit the rights of MDEQ or the Commission in the event Respondent fails to comply with this Agreed Order. The Agreed Order shall be strictly construed to apply to those matters expressly resolved herein.

6.


The civil penalty imposed in Paragraph 2.A of this Agreed Order addresses only those specific violations asserted in Paragraph 1. Nothing contained in this Agreed Order shall limit the rights of MDEQ, the Commission, or the United States Environmental Protection Agency to take enforcement or other actions, including the imposition of injunctive relief and/or penalties, against Respondent for past violations not specifically addressed herein and for future violations of any law, rule, regulation and/or permit.

7.

Respondent understands and acknowledges that it is entitled to an evidentiary hearing before the Commission pursuant to Miss. Code Ann. Section 49-17-31 (Rev. 2003), and that it has made an informed waiver of that right.

ORDERED, this the 10 day of September, 2010.

MISSISSIPPI COMMISSION ON
ENVIRONMENTAL QUALITY

BY: 
TRUDY D. FISHER
EXECUTIVE DIRECTOR
MISSISSIPPI DEPARTMENT
OF ENVIRONMENTAL QUALITY

AGREED, this the _____ day of _____, 2010.

CITY OF JACKSON

BY: _____


TITLE: _____

STATE OF Mississippi

COUNTY OF Hinds

PERSONALLY appeared before me, the undersigned authority in and for the jurisdiction aforesaid, the within named Henry Johnson, Jr. who first being duly sworn, did state upon his/her oath and acknowledge to me that he/she is the Mayor of the City of Jackson and is authorized to sign and enter this Agreement on behalf of the City of Jackson.

SWORN AND SUBSCRIBED BEFORE ME: this the 3rd day of August, 2010.



My Commission expires: Feb. 13, 2014

BEFORE THE MISSISSIPPI COMMISSION
ON ENVIRONMENTAL QUALITY

MISSISSIPPI COMMISSION ON
ENVIRONMENTAL QUALITY

COMPLAINANT

VS.

AMENDMENT TO
AGREED ORDER NO.5823 10

JACKSON POTW, SAVANNA STREET
PO BOX 17 DEPARTMENT OF PUBLIC WORKS
JACKSON, MISSISSIPPI 39205-0017

RESPONDENT

ORDER AMENDMENT

Mississippi Commission on Environmental Quality Order No. 5823 10, previously issued on September 10, 2010, in the above captioned matter, came before the Executive Director of the Mississippi Department of Environmental Quality (MDEQ) on Respondent's request for amendment. Having considered Respondent's request, the Executive Director finds that the requirements outlined in the above-referenced Order should be amended as follows:

1.

Paragraph 2.A. of Agreed Order No. 5823 10 is amended to read as follows:

Respondent agrees to pay, and Complainant agrees to accept, a civil penalty in the amount of \$240,000.00. Respondent shall pay this penalty to MDEQ in four equal installments in accordance with the following schedule:


<u>Installment Due Date</u>	<u>Installment Amount</u>
October 15, 2010	\$60,000.00
February 15, 2011	\$60,000.00
May 15, 2011	\$60,000.00
August 15, 2011	\$60,000.00

2.

This Order Amendment shall not, and is not intended to, supersede Order No. 5823 10, except to the limited extent described in Paragraph 1 above. Except as amended by Paragraph 1 above, all terms and conditions of Order No. 5823 10 shall remain in full force and effect.

ORDERED, this the 11 day of October, 2010.

MISSISSIPPI COMMISSION ON
ENVIRONMENTAL QUALITY

BY: 
TRUDY D. FISHER
EXECUTIVE DIRECTOR
MISSISSIPPI DEPARTMENT
OF ENVIRONMENTAL QUALITY

**BEFORE THE MISSISSIPPI COMMISSION
ON ENVIRONMENTAL QUALITY**

**MISSISSIPPI COMMISSION ON
ENVIRONMENTAL QUALITY**

COMPLAINANT

VS.

**AMENDMENT TO
AGREED ORDER NO. 5823 10**

**JACKSON POTW, SAVANNA STREET
PO BOX 17 DEPARTMENT OF PUBLIC WORKS
JACKSON, MISSISSIPPI 39205-0017**

RESPONDENT

AGREED ORDER AMENDMENT

Mississippi Commission on Environmental Quality Agreed Order No. 5823 10, previously issued on September 10, 2010, and amended on October 11, 2010, in the above captioned matter, came on this day for reconsideration upon the joint request of the Mississippi Commission on Environmental Quality, Complainant, and Jackson POTW, Savanna Street, Respondent, and the Executive Director of the Mississippi Department of Environmental Quality having received additional information in this cause, finds that the requirements outlined in the above-referenced Order should be amended as follows:

1.

Paragraph 2.D. of Agreed Order No. 5823 10 is amended to read as follows:

On or about December 3, 2010, Respondent submitted to MDEQ for approval its "Savanna Street Wastewater Treatment Plant Sludge Removal Plan." That plan contained four alternative proposals for the removal and proper disposal of excess, accumulated sludge/solids from the SSWWTF's storm diversion cells. The plan included, for each such

alternative, a schedule for completion of removal and disposal activities. After considering the alternative proposals, MDEQ tentatively approved implementation of "Option 2A" contained in the plan, but requested additional, clarifying information regarding implementation of that option. On June 3, 2011, Respondent submitted to MDEQ its "Savanna Street Wastewater Treatment Plant Sludge Removal Plan Addendum," and on July 19, 2011, Respondent submitted its "Sludge Removal Plan Addendum II." Those documents provided additional details regarding certain aspects of the sludge removal plan, including sludge excavation and dewatering and odor control. However, in the addendum, Respondent reserved the right to choose at a later date, depending upon contractor capabilities and resource availability, among various alternatives for sludge excavation, dewatering, and ultimate disposal. MDEQ has now approved the implementation of Option 2A of the sludge removal plan, as supplemented by the Savanna Street Wastewater Treatment Plant Sludge Removal Plan Addendum and Sludge Removal Plan Addendum II. Respondent shall immediately begin implementation of the plan. In accordance with the schedule of implementation provided for in the plan, Respondent shall notify MDEQ, in writing, on or before May 1, 2012, which alternatives for sludge excavation and dewatering Respondent will implement. After Respondent has commenced sludge/solids removal, the Respondent shall submit quarterly Status Reports to MDEQ that shall include, at a minimum, the hours of sludge removal operations performed, including the hours of dredging operations and ultimate disposal operations, the quantity of sludge/solids removed, the method(s) of disposal used, any operational setbacks experienced (weather, equipment failure, etc.), and an analysis of Respondent's progress to complete work under Option 2A on or before the December 31, 2017, deadline. In any event, Respondent, in accordance with the implementation schedule, shall remove all sludge not later than April 30, 2014 and shall dispose of all removed sludge no later than December 31, 2017.


2.

This Order Amendment shall not, and is not intended to, supersede Order No. 5823 10, or any previous amendment thereof, except to the limited extent described in Paragraph 1 above.

Except as amended by Paragraph 1 above, all terms and conditions of Order No. 5823 10, as previously amended on October 11, 2010, shall remain in full force and effect.

ORDERED, this the 29 day of September, 2011.

MISSISSIPPI COMMISSION ON
ENVIRONMENTAL QUALITY

BY: 
TRUDY D. FISHER
EXECUTIVE DIRECTOR
MISSISSIPPI DEPARTMENT
OF ENVIRONMENTAL QUALITY

APPENDIX B

BEFORE THE MISSISSIPPI COMMISSION
ON ENVIRONMENTAL QUALITY

MISSISSIPPI COMMISSION ON
ENVIRONMENTAL QUALITY

COMPLAINANT

VS.

ORDER NO. 6005 11

JACKSON POTW, PRESIDENTIAL HILLS
PO BOX 17
JACKSON, MISSISSIPPI 39205

RESPONDENT

AGREED ORDER

COME NOW the Mississippi Commission on Environmental Quality (Commission), acting through the staff and Executive Director of the Mississippi Department of Environmental Quality (MDEQ), Complainant, and the City of Jackson, Respondent, in the above captioned cause and agree as follows:

I.

Respondent owns and operates the Jackson POTW, Presidential Hills facility, located in Hinds County. Complainant reviewed Discharge Monitoring Reports for NPDES Permit No. MS0030295 from December 2009 through September 2010. By letters dated August 4, 2010, November 30, 2010, January 12, 2011, March 8, 2011, and March 24, 2011, Respondent was contacted by Complainant and notified of the following violations:

- A. The effluent BOD, 5-day limitation was exceeded during December 2009, January, August, and November 2010, and January -- February 2011.
- B. The effluent ammonia limitation was exceeded during January, February, April, June, August, and December 2010 and January -- February 2011.
- C. The effluent BOD percent removal limitation was not met during December 2009.

- D. The effluent suspended solids percent removal was not met during December 2009 and September 2010.

Subsequent to Complainant's last correspondence regarding effluent violations, Respondent reviewed discharge monitoring reports for March 2011 and advised Complainant the facility exceeded the effluent BOD, 5-day and ammonia nitrogen effluent limitations.

2.

In lieu of a formal enforcement hearing concerning the violation(s) listed above, Complainant and Respondent agree to settle this matter as follows:

- A. Respondent agrees to pay and Complainant agrees to accept a civil penalty in the amount of \$22,500.00. Respondent shall pay this penalty to MDEQ within forty-five (45) days after this Agreed Order has been executed by the MDEQ Executive Director, or her designee. The settlement payment above shall be submitted to the following address:

Mississippi Department of Environmental Quality
Attn: Mona Varner
P.O. Box 2339
Jackson, MS 39225

- B. On or before July 31, 2011, Respondent shall submit a report detailing the steps it intends to take to bring the wastewater treatment facility into compliance with its NPDES permit. The draft report shall be provided for review and comment by MDEQ prior to implementation. At a minimum, this report shall include the following:

1. A description of all viable options, including operational changes, equipment replacements or upgrades, and infrastructural changes or improvements, available to return the facility to compliance with its NPDES permit requirements.
2. A cost analysis (including capital improvement and operational and maintenance costs) and time lines for each of the viable options evaluated to bring the wastewater treatment facility into compliance.

3. The option(s) selected by Respondent to be implemented and a description of the basis for that selection.

- C. Respondent shall implement its selected option as detailed in the report required by 2.B., or as otherwise modified and agreed upon by Complainant and Respondent. Within 10 days of completion of implementation, Respondent shall submit written documentation to MDEQ of completion.
- D. On or before May 31, 2014, Respondent shall have either: (i) complied with the effluent limitations found in its NPDES permit for three consecutive months or (ii) ceased discharging from the Presidential Hills facility. Respondent shall demonstrate compliance through the submission of the required Discharge Monitoring Reports.

3.

Until such time that Respondent demonstrates compliance with its BOD, 5-day, ammonia nitrogen, BOD % removal, and total suspended solids % removal, but no later than May 31, 2014, Respondent shall comply with the following interim effluent limitations:

Parameter	Quantity/ Loading	Quantity/ Loading	Conc./ Quality	Conc./Quality	Frequency	Months
BOD, 5-day	94 lbs/day, Monthly Avg	141 lbs/day, Max Wkly Avg	15 mg/l, Monthly Avg	22.5 mg/l, Max Wkly Avg	Monthly	May - Oct
Ammonia Nitrogen	31 lbs/day Monthly Avg	47 lbs/day Max Wkly Avg	5 mg/l, Monthly Avg	8 mg/l, Max Wkly Avg	Monthly	May - Oct
BOD, 5-day	125 lbs/day, Monthly Avg	188 lbs/day, Max Wkly Avg	20 mg/l, Monthly Avg	30 mg/l, Max Wkly Avg	Monthly	Nov - Apr
Ammonia Nitrogen	125 lbs/day Monthly Avg	188 lbs/day Max Wkly Avg	20 mg/l, Monthly Avg	30 mg/l, Max Wkly Avg	Monthly	Nov - Apr
BOD, % Removal	*****	*****	65%, Minimum	*****	Monthly	Jan - Dec
TSS, % Removal	*****	*****	65%, Minimum	*****	Monthly	Jan - Dec

During the period that the interim limitations are applicable, Respondent agrees to pay to Complainant a stipulated penalty of \$100 for each violation of an interim limitation.

4.

If the Respondent fails to comply with any of the requirements established in Paragraphs 2.B.-C. of this Agreed Order, the Respondent shall pay a stipulated penalty of \$5,000 per day of violation of the relevant deadline. If the Respondent fails to achieve compliance as specified in Paragraph 2.D. of this Agreed Order, the Respondent shall pay a stipulated penalty of \$20,000.

5.

The per-day stipulated penalties referenced in Paragraph 4 above shall apply and accrue for a period of 60 days from the relevant deadline, after which time the Commission reserves the right to conduct a separate enforcement action concerning any violation by Respondent of the requirements established in Paragraphs 2.B.-C. of this Agreed Order. If the Commission conducts a separate enforcement action concerning a violation of any of the requirements established in Paragraphs 2.B.-C., the penalties sought and recovered in such separate enforcement action shall be in addition to any stipulated penalties which accrue during the 60-day period following the relevant deadline. In such separate enforcement action, the Commission may seek penalties, injunctive relief, or other appropriate relief different from or in the excess of the amount of stipulated penalties included in this Agreed Order, up to and including the statutory maximum penalty.

6.

Nothing in this Agreed Order shall limit the rights of MDEQ or the Commission in the event Respondent fails to comply with this Agreed Order. The Agreed Order shall be strictly construed to apply to those matters expressly resolved herein.

7.


Nothing contained in this Agreed Order shall limit the rights of MDEQ or the Commission to take enforcement or other actions against Respondent for violations not addressed herein and for future violations of environmental laws, rules, and regulations.

8.

Respondent understands and acknowledges that it is entitled to an evidentiary hearing before the Commission pursuant to Miss. Code Ann. Section 49-17-31 (Rev. 2003), and that it has made an informed waiver of that right.

ORDERED, this the 23 day of August, 2011.

MISSISSIPPI COMMISSION ON
ENVIRONMENTAL QUALITY

BY: 
TRUDY D. FISHER
EXECUTIVE DIRECTOR
MISSISSIPPI DEPARTMENT
OF ENVIRONMENTAL QUALITY

AGREED, this the _____ day of _____, 2011.

JACKSON POTW, PRESIDENTIAL HILLS

BY: _____

TITLE: _____

STATE OF _____

COUNTY OF _____

PERSONALLY appeared before me, the undersigned authority in and for the jurisdiction
aforesaid, the within named Harvey Johnson Jr who first being duly sworn, did state upon
his/her oath and acknowledge to me that he/she is the _____ of
Jackson POTW, Presidential Hills and is authorized to sign and enter this Agreement.

SWORN AND SUBSCRIBED BEFORE ME, this the 12 day of August, 2011.


My Commission expires: _____



Brenda Free
NOTARY PUBLIC

APPENDIX C

APPENDIX C



APPENDIX D



**GUIDE FOR EVALUATING CAPACITY,
MANAGEMENT, OPERATION, AND
MAINTENANCE (CMOM) PROGRAMS
AT SANITARY SEWER COLLECTION
SYSTEMS**

United States
Environmental Protection
Agency

Office of Enforcement and
Compliance Assurance (2224A)

EPA 305-B-05-002

www.epa.gov

January 2005



TABLE OF CONTENTS

1.	Introduction	1-1
1.1	Purpose of This Guide	1-1
1.2	Terminology	1-1
1.3	How to Use the Guide	1-2
1.4	Overview of Underlying Issues	1-3
1.5	Purpose of CMOM Programs	1-4
1.6	National Pollutant Discharge Elimination System Regulatory Requirement	1-5
1.7	EPA Region 4 MOM Programs Project	1-6
2.	Collection System Capacity, Management, Operation, and Maintenance Programs	2-1
2.1	Collection System Management	2-4
2.1.1	Organizational Structure	2-4
2.1.2	Training	2-10
2.1.3	Internal Communication	2-11
2.1.4	Customer Service	2-11
2.1.5	Management Information Systems	2-13
2.1.6	SSO Notification Program	2-14
2.1.7	Legal Authority	2-15
2.2	Collection System Operation	2-17
2.2.1	Budgeting	2-18
2.2.2	Monitoring	2-19
2.2.3	Hydrogen Sulfide Monitoring and Control	2-20
2.2.4	Safety	2-21
2.2.5	Emergency Preparedness and Response	2-22
2.2.6	Modeling	2-24
2.2.7	Mapping	2-25
2.2.8	New Construction	2-26
2.2.9	Pump Stations	2-26
2.3	Equipment and Collection System Maintenance	2-27
2.3.1	Maintenance Budgeting	2-28
2.3.2	Planned and Unplanned Maintenance	2-28
2.3.3	Sewer Cleaning	2-33
2.3.4	Parts and Equipment Inventory	2-35
2.4	Sewer System Capacity Evaluation - Testing and Inspection	2-36
2.4.1	Flow Monitoring	2-37
2.4.2	Sewer System Testing	2-38
2.4.3	Sewer System Inspection	2-39
2.5	Sewer System Rehabilitation	2-41

3.0 Checklist for Conducting Evaluations of Wastewater Collection System Capacity, Management, Operation, and Maintenance (CMOM) Programs	3-1
Appendix A Example Collection System Performance Indicator Data Collection Form	A-1
Appendix B Example Interview Schedule and Topics	B-1
Appendix C Information Sources	C-1
References	R-1

CHAPTER 1. INTRODUCTION

1.1 Purpose of this Guide

This guide identifies some of the criteria used by EPA to evaluate a collection system's management, operation, and maintenance (CMOM) program activities. The guide is intended for use by EPA and state inspectors as well as the regulated community – owners or operators of sewer systems collecting domestic sewage as well as consultants or other third-party evaluators or compliance assistance providers. Collection system owners or operators can review their own systems by following the checklist in Chapter 3 to reduce the occurrence of sewer overflows and improve or maintain compliance. The guidance herein may also be taken a step further. If a federal or state reviewer observes a practice that does not effectively meet the elements of a CMOM program, he or she may make recommendations to educate the operator, inspector, case developer, or those involved in a settlement agreement. Additionally, having key board members (policy makers) read this guide will also allow them to better understand the benefits of investing in good CMOM programs.

The guide is applicable to small, medium, and large systems; both publicly and privately owned systems; and both regional and satellite collection systems. Regardless of size, each owner or operator will have an organization and practices unique to its collection system. While these specific characteristics will vary among systems, the CMOM concepts and best management practices are likely to apply to all types of systems. Where appropriate, this document provides guidance on the differences.

This document does not, however, substitute for the CWA or EPA's regulations, nor is it a regulation itself. Thus, the document does not and cannot impose legally binding requirements upon these circumstances. EPA and state decision-makers retain the discretion to adopt approaches on a case-by-case basis that differ from this guidance where appropriate. EPA may change this guidance in the future.

Individuals reviewing a collection system are strongly encouraged to read the guidance portion of this document prior to conducting a review. Reviewers should use the checklist in Chapter 3 as the primary tool for questions during the paperwork and/or onsite review of the collection system.

While some sections or topics may not appear to relate directly to environmental performance, taken as a whole, they provide an indication of how well the utility is run.

1.2 Terminology

To provide a more user-friendly guidance and for clarification, the terminology for several terms has been modified. The following paragraphs list these terms and reasoning for the modifications.

Frequently, the term "COLLECTION SYSTEM OWNER OR OPERATOR", abbreviated as "OWNER OR OPERATOR," is used in this guide and refers to the entities responsible for the administration and oversight of the sewer system and its associated staff (in either a municipal or industrial context); capacity evaluation, management, operation, and maintenance programs; equipment; and facilities. The owner and operator may be two different entities. For example, the owner may own the infrastructure and be responsible for its maintenance while it designates responsibility for the day to day operation of

the system to the operator. It should be noted that the term used in EPA's CMOM Program Self Assessment Checklist is "MUNICIPAL WASTEWATER UTILITY OPERATORS" or "UTILITY" rather than "collection system owner or operator." Both refer to the same individual(s).

The term "REVIEW" is used in this document in place of "INSPECTION" or "AUDIT." Because "inspection" often refers to an evaluation conducted by the regulatory authority and "audit" has been used to refer to an evaluation with very specific requirements, "review" is more appropriately used to capture the wider universe of evaluations (e.g., those conducted by a regulatory authority, the system itself, and/or by a third-party).

Similarly, the term used to describe the person conducting the CMOM review is the "REVIEWER" – this could be either an inspector, a third party reviewer hired by the owner or operator, or personnel of the owner or operator performing a self-evaluation of the collection system.

The term "FACILITY" is used in this document to refer to the components of the collection system (e.g., pump stations, sewer lines).

1.3 How to Use the Guide

The guide and checklist provide a three-tiered approach to the CMOM review:

- Evaluation of the CMOM program, based on interviews with management and field personnel, as well as observation of routine activities and functions
- Review of pertinent records and information management systems
- Evaluation based on field/site review

Chapter 2 provides a breakdown and overview of each CMOM concept and what to look for when reviewing the system, defines the CMOM elements for the reviewer, and follows through with a discussion of the indicators or other clues about which the reviewer should be aware. Chapters 2 and 3 present detailed information on conducting reviews of collection systems. Chapter 3 contains the comprehensive reviewer checklist, supported by the information in Chapter 2. Appendix A presents a Collection System Performance Indicator Data Collection Form which provides examples of the types of information a reviewer should attempt to obtain while on-site.

The "one size does not fit all" approach to reviewing CMOM programs cannot be overstated. The principles covered in this guide are applicable to all wastewater collection systems, however, these principles may be implemented through different means depending on the system. Larger systems may have the resources and the need to implement more costly and complex means of meeting the CMOM program elements. In occasional cases a CMOM feature may not be implemented at all, due to characteristics of the system. A reviewer should be able to look at the system as a whole and determine whether certain key elements are present or should be present and to what extent the system incorporates the CMOM principles.

Reviewers will also find that the location or names of some documents, logs, or reports may vary from system to system. This guide tries to provide a general description of the materials the reviewer should request.

Although use of this guide cannot guarantee a collection system will avoid permit violations or discharge violations, generally, when owners or operators adequately practice the principles laid out in the guide, they should experience fewer problems and, therefore, fewer instances of noncompliance.

1.4 Overview of the Underlying Issues

Sanitary sewer collection systems are designed to remove wastewater from homes and other buildings and convey it to a wastewater treatment plant. The collection system is a critical element in the successful performance of the wastewater treatment process. EPA estimates that collection systems in the U.S. have a total replacement value between \$1 to \$2 trillion. Under certain conditions, poorly designed, built, managed, operated, and/or maintained systems can pose risks to public health, the environment, or both. These risks arise from sanitary sewer overflows (SSOs) from the collection system or by compromised performance of the wastewater treatment plant. Effective and continuous management, operation, and maintenance, as well as ensuring adequate capacity and rehabilitation when necessary, are critical to maintaining collection system capacity and performance while extending the life of the system.

EPA believes that every sanitary sewer system has the capacity to have an SSO. This may be due to a number of factors including, but not limited to:

- Blockages
- Structural, mechanical, or electrical failures
- Collapsed or broken sewer pipes
- Insufficient conveyance capacity
- Vandalism

Additionally, high levels of inflow and infiltration (I/I) during wet weather can cause SSOs. Many collection systems that were designed according to industry standards experience wet weather SSOs because levels of I/I may exceed levels originally expected; prevention of I/I has proven more difficult and costly than anticipated; or the capacity of the system has become inadequate due to an increase in service population without corresponding system upgrades (EPA 2004).



SSOs include untreated discharges from sanitary sewer systems that reach waters of the United States (photo: US EPA).

SSOs can cause or contribute to environmental and human health impacts (e.g., water quality standards violations, contamination of drinking water supplies, beach closures, etc.) which, in addition to flooded basements and overloaded wastewater treatment plants, are some symptoms of collection systems with inadequate capacity and improper management, operation, and maintenance. These problems create the need for both the owner or operator and the regulatory authority to conduct more thorough evaluations of sanitary sewer collection systems.

1.5 Purpose of CMOM Programs

CMOM programs incorporate many of the standard operation and maintenance activities that are routinely implemented by the owner or operator with a new set of information management requirements in order to:

- Better manage, operate, and maintain collection systems
- Investigate capacity constrained areas of the collection system
- Proactively prevent SSOs
- Respond to SSO events

The CMOM approach helps the owner or operator provide a high level of service to customers and reduce regulatory noncompliance. CMOM can help utilities optimize use of human and material resources by shifting maintenance activities from “reactive” to “proactive”—often leading to savings through avoided costs due to overtime, reduced emergency construction costs, lower insurance premiums, changes in financial performance goals, and fewer lawsuits. CMOM programs can also help improve communication relations with the public, other municipal works and regional planning organizations, and regulators.

It is important to note that the collection system board members or equivalent entity should ensure that the CMOM program is established as a matter of policy. The program should not be micro-managed, but an understanding of the resources required of the operating staff to implement and maintain the program is necessary.

In CMOM planning, the owner or operator selects performance goal targets, and designs CMOM activities to meet the goals. The CMOM planning framework covers operation and maintenance (O&M) planning, capacity assessment and assurance, capital improvement planning, and financial management planning. Information collection and management practices are used to track how the elements of the CMOM program are meeting performance goals, and whether overall system efficiency is improving.

On an periodic basis, utility activities should be reviewed and adjusted to better meet the performance goals. Once the long-term goal of the CMOM program is established, interim goals may be set. For instance, an initial goal may be to develop a geographic information system (GIS) of the system. Once the GIS is complete, a new goal might be to use the GIS to track emergency calls and use the information to improve maintenance planning.

An important component of a successful CMOM program is periodically collecting information on current systems and activities to develop a “snapshot-in-time” analysis. From this analysis, the owner or operator evaluates its performance and plans its CMOM program activities.

Maintaining the value of the investment is also important. Collection systems represent major capital investments for communities and are one of the communities’ major capital assets. Equipment and facilities will deteriorate through normal use and age. Maintaining value of the capital asset is a major goal of the CMOM program. The infrastructure is what produces sales and service. Proper reinvestment in capital facilities maintains the ability to provide service and generate sales at the least cost possible and helps ensure compliance with environmental requirements. As a capital asset, this will result in the

need for ongoing investment in the collection system and treatment plant to ensure design capacity while maintaining existing facilities and equipment as well as extending the life of the system.

The performance of wastewater collection systems is directly linked to the effectiveness of its CMOM program. Performance characteristics of a system with an inadequate CMOM program include frequent blockages resulting in overflows and backups. Other major performance indicators include pump station reliability, equipment availability, and avoidance of catastrophic system failures such as a collapsed pipe.

A CMOM program is what an owner or operator should use to manage its assets; in this case, the collection system itself. The CMOM program consists of a set of best management practices that have been developed by the industry and are applied over the entire life cycle of the collection system and treatment plant. These practices include:

- Designing and constructing for O&M
- Knowing what comprises the system (inventory and physical attributes)
- Knowing where the system is (maps and location)
- Knowing the condition of the system (assessment)
- Planning and scheduling work based on condition and performance
- Repairing, replacing, and rehabilitating system components based on condition and performance
- Managing timely, relevant information to establish and prioritize appropriate CMOM activities
- Training of personnel

1.6 National Pollutant Discharge Elimination System Regulatory Requirement

The National Pollutant Discharge Elimination System (NPDES) program prohibits discharges of pollutants from any point source into the nation's waters except as authorized under an NPDES permit.

EPA and state NPDES inspectors evaluate collection systems and treatment plants to determine compliance with permit conditions including proper O&M. Among others, these permit conditions are based on regulation in 40 CFR 122.41(e): "The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit."

When violations occur, the collection system or wastewater treatment plant owner or operator can face fines and requirements to implement programs to compensate residents and restore the environment. For example, in June 2004, the U.S. District Court for the Southern District of Ohio entered a consent decree resolving CSO, SSO, and wastewater treatment plant violations at the Hamilton County sewer system in Cincinnati, Ohio. In addition to a \$1.2 million civil penalty, the settlement included programs to clean up residents' basements, compensate residents, and implement measures to prevent further basement backups. The settlement also includes over \$5.3 million in supplemental environmental projects.



Sewer rehabilitation can include lining aging sewers (photo: NJ Department of Environmental Protection).

1.7 EPA Region 4 MOM Programs Project

EPA Region 4 created the “Publicly Owned Treatment Works MOM Programs Project” under which the Region invites permitted owners or operators, and contributing satellite systems, in watersheds it selects to perform a detailed self-assessment of the management, operation, and maintenance (MOM) programs associated with their collection system. Participants provide a report which includes the results of the review, any improvements that should be made, and schedules to make those improvements. Participants that identify and report a history of unpermitted discharges from their collection system, and a schedule for the necessary improvements, can be eligible for smaller civil penalties while under a remediation schedule.

EPA’s Office of Compliance coordinated with EPA Region 4 on the development of this CMOM Guide. This guide is based in part on material obtained from the Region 4 MOM Programs Project. Some of the more specific items of the Region 4 program have been omitted in order to provide a more streamlined review framework. The fundamental concepts behind CMOM have been maintained in this guide. By combining elements of the Region’s program with existing NPDES inspection guidance, this CMOM Guide provides a comprehensive framework for reviewers and regulated communities to evaluate the effectiveness of O&M throughout the collection system.



CHAPTER 2. COLLECTION SYSTEM CAPACITY, MANAGEMENT, OPERATION, AND MAINTENANCE PROGRAMS

This chapter provides an overview of the CMOM program elements. The information will help evaluate wastewater collection system operation and maintenance (O&M) practices. The key elements of the CMOM program, which are presented in detail in the following sections, include:

- Collection System Management
- Collection System Operation
- Collection System Maintenance
- Collection System Capacity Evaluation

In addition to this overview, there are several areas (e.g., 2.1.3 Internal Communications, 2.1.4 Customer Service, etc.) in this guide that go into greater depth regarding the operation and maintenance of a collection system. The intent of this detail is not only to provide the owner or operator with suggestions as to what to look for in their own program, but to provide the reviewer a complete overview of good operations, in general, regardless of a particular item resulting in poor performance or a violation.

For EPA and state inspectors or other reviewers, conducting an evaluation of collection system CMOM programs shares many similarities with other types of compliance reviews. Overall, the reviewer would examine records, interview staff and conduct field investigations, generally in that order although tailored, if necessary, to meet site-specific needs. Prior to performing the on-site interviews and evaluations, preliminary information may be requested that will provide an overall understanding of the organization to allow for a more focused approach for the review. This information also provides a basis for more detailed data gathering during on site activities. The information typically requested prior to the review should include a schematic map of the collection system (could be as-built drawings) and any written operations or maintenance procedures. Depending on the volume of information, the collection system owner or operator may need ample lead time to gather and copy these documents. Alternatively, the reviewer may offer to examine the documents and bring them back when doing the on-site review so that extra copies are not necessary. No matter which method is used, the importance of up-front preparation cannot be overemphasized. With the exception of pump stations and manholes, much of the collection system is not visible. Therefore, the more complete the reviewer's understanding of the system is prior to the review, the more successful the assessment will be.

The reviewer would then proceed with the on-site activities. Guidance for conducting compliance reviews is provided in the *NPDES Compliance Inspection Manual* (EPA 2004). The manual provides the general procedures for performing compliance reviews and is a valuable source of information on such topics as entry, legal authority, and responsibilities of the reviewer. Although CMOM evaluations are not specifically addressed in the manual, the general

review procedures can be applied to CMOM reviews. Another good reference for general review information is the *Multi-Media Investigations Manual, NEIC* (EPA 1992). Some issues with entry are specific to CMOM reviews. Some facilities may be on private property and the reviewer may need property owner consent for entry.

Documents to Review On-site Include:

- Organization chart(s)
- Staffing plans
- Job descriptions
- Sewer use ordinance
- Overall map of system showing facilities such as pump stations, treatment plants, major gravity sewers, and force mains
- O&M budget with cost centers¹ for wastewater collection
- Performance measures for inspections, cleaning, repair, and rehabilitation
- Recent annual report, if available
- Routine reports regarding system O&M activities
- Collection system master plan
- Capital improvement projects (CIP) plan
- Flow records or monitoring
- Safety manual
- Emergency response plan
- Management policies and procedures
- Detailed maps/schematics of the collection system and pump stations
- Work order management system
- O&M manuals
- Materials management program
- Vehicle management and maintenance records
- Procurement process
- Training plan for employees
- Employee work schedules
- Public complaint log
- Rate ordinance or resolution
- Financial report ("notes" section)
- As built plans
- Discharge monitoring reports (DMRs)

The above list is not all inclusive nor will all utilities necessarily have formal, written documentation for each of the items listed. The *Collection System Performance Indicator Data Collection Form*, included as Appendix A, provides examples of the types of information a reviewer should attempt to obtain while on-site.

Interviews are generally conducted with line managers and supervisors who are responsible for the various O&M activities

Reviewer - Point to Note

A schedule should be established by the reviewer for the staff interviews and field assessments.

¹ A cost center is any unit of activity, group of employees, line of products, etc., isolated or arranged in order to allocate and assign costs more easily.

and support services staff from engineering, construction, human resources, and purchasing, where appropriate. Appendix B presents an example agenda and schedule that would be used for a large collection system owner or operator. The collection system's size and physical characteristics will determine the length of time needed for the review. A guideline for the time required, given a two person review team, would be two days for a small system, and a week or more for large systems.

Field reviews are typically conducted after interviews. The following is a list of typical field sites the team should visit:

- Mechanical and electrical maintenance shop(s)
- Fleet maintenance facilities (vehicles and other rolling stock)
- Materials management facilities (warehouse, outside storage yards)
- Field maintenance equipment storage locations (i.e., crew trucks, mechanical and hydraulic cleaning equipment, construction and repair equipment, and television inspection equipment)
- Safety equipment storage locations
- Pump stations
- Dispatch and supervisory control and data acquisition (SCADA) systems
- Crew and training facilities
- Chemical application equipment and chemical storage areas (use of chemicals for root and grease control, hydrogen sulfide control [odors, corrosion])
- Site of SSOs, if applicable
- A small, but representative, selection of manholes

Collection system operators typically assist with manhole cover removal and other physical activities. The inspector should refrain from entering confined spaces. A confined space is defined by the Occupational Safety and Health Administration (OSHA) as a space that: (1) is large enough and so configured that an employee can bodily enter and perform assigned work; and (2) has limited or restricted means for entry or exit; and (3) is not designed for continuous employee occupancy [29 CFR 1910.146(b)]. A "permit-required confined space (permit space)" is a confined space that has one or more of the following characteristics: (1) contains or has a potential to contain a hazardous atmosphere; (2) contains a material that has the potential for engulfing an entrant; (3) has an internal configuration such that an entrant could be trapped or asphyxiated by inwardly converging walls or by a floor which slopes downward and tapers to a smaller cross-section; or (4) contains any other recognized serious safety or health hazard [29 CFR 1910.146(b)].

Though OSHA has promulgated standards for confined spaces, those standards do not apply directly to municipalities, except in those states that have approved plans and have asserted jurisdiction under Section 18 of the OSHA Act. Contract operators and private facilities do have to comply with the OSHA requirements and the inspector may find that some municipalities elect to do so voluntarily. In sewer collection systems, the two most common confined spaces are the underground pumping station and manholes. The underground pumping station is typically entered through a relatively narrow metal or concrete shaft via a fixed ladder. Inspectors conducting the field evaluation component of the CMOM audit should be able to identify and

avoid permit-required confined spaces. Although most confined spaces are unmarked, confined spaces that may have signage posted near their entry containing the following language:

**DANGER–PERMIT REQUIRED–CONFINED SPACE
AUTHORIZED PERSONNEL ONLY**

If confined space entry is absolutely necessary, inspectors should consult with the collection system owner or operator first, have appropriate training on confined space entry, and use the proper hazard detection and personal safety equipment. More information on confined space entry can be found in *Operation and Maintenance of Wastewater Collection Systems Volumes I and II* (California State University (CSU) Sacramento 1996; CSU Sacramento 1998).

2.1 Collection System Management

Collection system management activities form the backbone for operation and effective maintenance activities. The goals of a management program should include:

- Protection of public health and prevention of unnecessary property damage
- Minimization of infiltration, inflow and exfiltration, and maximum conveyance of wastewater to the wastewater treatment plant
- Provision of prompt response to service interruptions
- Efficient use of allocated funds
- Identification of and remedy solutions to design, construction, and operational deficiencies
- Performance of all activities in a safe manner to avoid injuries

Management Documents to Review

- Organization chart(s)
- Staffing plans—Number of people and classifications
- Job descriptions for each classification
- Sewer use ordinance
- Safety manual
- Training program documentation
- Notes to financial reports

Without the proper procedures, management and training systems, O&M activities may lack organization and precision, resulting in a potential risk to human health and environmental contamination of surrounding water bodies, lands, dwellings, or groundwater. The following sections discuss the common elements of a robust collection system management program.

2.1.1 Organizational Structure

Well-established organizational structure, which delineates responsibilities and authority for each position, is an important component of a CMOM program for a collection system. This information may take the form of an organizational chart or narrative description of roles and

responsibilities, or both. The organizational chart should show the overall personnel structure, including operation and maintenance staff.

Additionally, up-to-date job descriptions should be available. Job descriptions should include the nature of the work performed, the minimum requirements for the position, the necessary special qualifications or certifications, examples of the types work, lists of licences required for the position, performance measures or promotion potential. Other items to note in regard to the organizational structure are the percent of staff positions currently vacant, on average, the length of time positions remain vacant, and the percent of collection system work that is contracted out.

Reviewer - Point to Note

The reviewer may want to note the turnover rate and current levels of staffing (i.e., how many vacant positions exist and for how long they have been vacant). This may provide some indication of potential understaffing, which can create response problems.

Reviewers should evaluate specific qualifications of personnel and determine if the tasks designated to individuals, crews, or teams match the job descriptions and training requirements spelled out in the organizational structure. From an evaluation standpoint, the reviewer might try to determine what type of work is performed by outside contractors and what specific work is reserved for collection system personnel. If much of the work is contracted, it is appropriate to review the contract and to look at the contractor's capabilities. If the contractor handles emergency response, the reviewer should examine the contract with the owner or operator to determine if the emergency response procedures and requirements are outlined.

The inclusion of job descriptions in the organizational structure ensures that all employees know

their specific job responsibilities and have the proper credentials. Additionally, it is useful in the course of interviews to discuss staff management. The reviewer should note whether staff receive a satisfactory explanation of their job descriptions and responsibilities. In addition, when evaluating the CMOM program, job descriptions will help a reviewer determine who should be interviewed.

Reviewer - Point to Note

A reviewer should look for indications that responsibilities are understood by employees. Such indications may include training programs, meetings between management and staff, or policies and procedures.

When evaluating the organizational structure, the reviewer should look for the following:

- Except in very small systems, operation and maintenance personnel ideally should report to the same supervisor or director. The supervisor or director should have overall responsibility for the collection system.
- In some systems, maintenance may be carried out by a city-wide maintenance

organization, which may also be responsible for such diverse activities as road repair and maintenance of the water distribution system. This can be an effective approach, but only if adequate lines of responsibility and communication are established.

- In general, one supervisor should manage a team of individuals small enough that is safe and effective. However, the individuals on the team may have additional employees reporting to them. This prevents the top supervisors from having to track too many individuals. The employee-supervisor ratio at individual collection systems will vary depending on their need for supervisors.

In a utility with well-established organizational structure, staff and management should be able to articulate their job and position responsibilities. Personnel should be trained to deal with constantly changing situations and requirements, both regulatory and operational.

The system's personnel requirements vary in relation to the overall size and complexity of the collection system. In very small systems, these responsibilities may include operation of the treatment plant as well as the collection system. In many systems, collection system personnel are responsible for the stormwater as well as wastewater collection system. References providing staff guidelines or recommendations are available to help the reviewer determine if staffing is adequate for the collection system being reviewed. Following is a list of available references:

- *Manpower Requirements for Wastewater Collection Systems in Cities of 150,000 to 500,000 Population* (EPA 1974)
- *Manpower Requirements for Wastewater Collection Systems in Cities and Towns of up to 150,000 Population* (EPA 1973)
- *Operation and Maintenance of Wastewater Collection Systems, Volume II* (California State University (CSU) Sacramento 1998)

Volumes I and II of *Operations and Maintenance of Wastewater Collection Systems* can be obtained through:

Office of Water Programs
California State University Sacramento
6000 J Street
Sacramento, CA 95819-6025
phone: 916/278-6142
www.owp.csus.edu

The following tables have been taken from the two EPA documents listed above to provide the reviewer with guidance. However, these documents may not take into account technological advances that have occurred since their publication date that might reduce staffing requirements. For instance, advances in remote data acquisition and telemetry have likely reduced the number

of field inspection staff needed for systems with several pump stations. Other system-specific characteristics should also be accounted for when using these tables. An example of this might be collection systems that are not primarily constructed of brick will not require the masons the tables specify.

tables specify.										100-10										100-11										100-12										100-13										100-14										100-15										100-16										100-17										100-18										100-19										100-20										100-21										100-22										100-23										100-24										100-25										100-26										100-27										100-28										100-29										100-30										100-31										100-32										100-33										100-34										100-35										100-36										100-37										100-38										100-39										100-40										100-41										100-42										100-43										100-44										100-45										100-46										100-47										100-48										100-49										100-50										100-51										100-52										100-53										100-54										100-55										100-56										100-57										100-58										100-59										100-60										100-61										100-62										100-63										100-64										100-65										100-66										100-67										100-68										100-69										100-70										100-71										100-72										100-73										100-74										100-75										100-76										100-77										100-78										100-79										100-80										100-81										100-82										100-83										100-84										100-85										100-86										100-87										100-88										100-89										100-90										100-91										100-92										100-93										100-94										100-95										100-96										100-97										100-98										100-99										100-100										100-101										100-102										100-103										100-104										100-105										100-106										100-107										100-108										100-109										100-110										100-111										100-112										100-113										100-114										100-115										100-116										100-117										100-118										100-119										100-120										100-121										100-122										100-123										100-124										100-125										100-126										100-127										100-128										100-129										100-130										100-131										100-132										100-133										100-134										100-135										100-136										100-137										100-138										100-139										100-140										100-141										100-142										100-143										100-144										100-145										100-146										100-147										100-148										100-149										100-150										100-151										100-152										100-153										100-154										100-155										100-156										100-157										100-158										100-159										100-160										100-161										100-162										100-163										100-164										100-165										100-166										100-167										100-168										100-169										100-170										100-171										100-172										100-173										100-174										100-175										100-176										100-177										100-178										100-179										100-180										100-181										100-182										100-183										100-184										100-185										100-186										100-187										100-188										100-189										100-190										100-191										100-192										100-193										100-194										100-195										100-196										100-197										100-198										100-199										100-200										100-201										100-202										100-203										100-204										100-205										100-206										100-207										100-208										100-209										100-210										100-211										100-212										100-213										100-214										100-215										100-216										100-217										100-218										100-219										100-220										100-221										100-222										100-223										100-224										100-225										100-226										100-227										100-228										100-229										100-230										100-231										100-232										100-233										100-234										100-235										100-236										100-237										100-238										100-239										100-240										100-241										100-242										100-243										100-244										100-245										100-246										100-247										100-248										100-249										100-250										100-251										100-252										100-253										100-254										100-255										100-256										100-257										100-258										100-259										100-260										100-261										100-262										100-263										100-264										100-265										100-266										100-267										100-268										100-269										100-270										100-271										100-272										100-273										100-274										100-275										100-276										100-277										100-278										100-279										100-280										100-281										100-282										100-283										100-284										100-285										100-286										100-287										100-288										100-289										100-290										100-291										100-292										100-293										100-294										100-295										100-296										100-297										100-298										100-299										100-300										100-301										100-302										100-303										100-304										100-305										100-306										100-307										100-308										100-309										100-310										100-311										100-312										100-313										100-314										100-315										100-316										100-317										100-318										100-319										100-320										100-321										100-322										100-323										100-324										100-325										100-326										100-327										100-328										100-329										100-330										100-331										100-332										100-333										100-334										100-335										100-336										100-337										100-338										100-339										100-340										100-341										100-342										100-343										100-344										100-345										100-346										100-347										100-348										100-349										100-350										100-351										100-352										100-353										100-354										100-355										100-356										100-357										100-358										100-359										100-360										100-361										100-362										100-363										100-364										100-365										100-366										100-367										100-368										100-369										100-370										100-371										100-372										100-373										100-374										100-375										100-376										100-377										100-378										100-379										100-380										100-381										100-382										100-383										100-384										100-385										100-386										100-387										100-388										100-389										100-390										100-391										100-392										100-393										100-394										100-395										100-396										100-397										100-398										100-399										100-400										100-401										100-402										100-403										100-404										100-405										100-406										100-407										100-408										100-409										100-410										100-411										100-412										100-413										100-414										100-415										100-416										100-417										100-418										100-419										100-420										100-421										100-422										100-423										100-424										100-425										100-426										100-427										100-428										100-429										100-430										100-431										100-432										100-433										100-434										100-435										100-436										100-437										100-438										100-439										100-440										100-441										100-442										100-443										100-444										100-445										100-446										100-447										100-448										100-449										100-450										100-451										100-452										100-453										100-454										100-455										100-456										100-457										100-458										100-459										100-460										100-461										100-462										100-463										100-464										100-465										100-466										100-467										100-468										100-469										100-470										100-471										100-472										100-473										100-474										100-475										100-476										100-477										100-478										100-479										100-480										100-481										100-482										100-483										100-484										100-485										100-486										100-487										100-488										100-489										100-490										100-491										100-492										100-493										100-494										100-495										100-496										100-497										100-498										100-499										100-500										100-501										100-502										100-503										100-504										100-505										100-506										100-507										100-508										100-509										100-510										100-511										100-512										100-513										100-514										100-515										100-516										100-517										100-518										100-519										100-520										100-521										100-522										100-523										100-524										100-525										100-526										100-527										100-528										100-529										100-530										100-531										100-532										100-533										100-534										100-535										100-536										100-537										100-538										100-539										100-540										100-541										100-542										100-543										100-544										100-545										100-546										100-547										100-548										100-549										100-550										100-551										100-552										100-553										100-554										100-555										100-556										100-557										100-558										100-559										100-560										100-561										100-562										100-563										100-564										100-565										100-566										100-567										100-568										100-569										100-570										100-571										100-572										100-573										100-574										100-575										100-576										100-577										100-578										100-579										100-580										100-581										100-582										100-583										100-584										100-585										100-586										100-587										100-588										100-589										100-590										100-591										100-592										100-593										100-594										100-595										100-596										100-597										100-598										100-599										100-600										100-601										100-602										100-603										100-604										100-605										100-606										100-607										100-608										100-609										100-610										100-611										100-612										100-613										100-614										100-615										100-616										100-617										100-618										100-619										100-620										100-621										100-622										100-623										100-624										100-625										100-626										100-627										100-628										100-629										100-630										100-631										100-632										100-633										100-634										100-635										100-636										100-637										100-638										100-639										100-640										100-641										100-642										100-643										100-644										100-645										100-646										100-647										100-648										100-649										100-650										100-651										100-652										100-653										100-654										100-655										100-656										100-657										100-658										100-659										100-660										100-661										100-662										100-663										100-664										100-665										100-666										100-667										100-668										100-669										100-670										100-671										100-672										100-673										100-674										100-675										100-676										100-677										100-678										100-679										100-680										100-681										100-682										100-683										100-684										100-685										100-686										100-687										100-688										100-689										100-690										100-691										100-692										100-693										100-694										100-695										100-696										100-697										100-698										100-699										100-700										100-701										100-702										100-703										100-704										100-705										100-706										100-707										100-708										100-709										100-710										100-711										100-712										100-713										100-714										100-715										100-716										100-717										100-718										100-719										100-720										100-721										100-722										100-723										100-724										100-725										100-726										100-727										100-728										100-729										100-730										100-731										100-732										100-733										100-734										100-735										100-736										100-737										100-738										100-739										100-740										100-741										100-742										100-743										100-744										100-745										100-746										100-747										100-748										100-749										100-750										100-751										100-752										100-753										100-754										100-755										100-756										100-757										100-758										100-759										100-760										100-761										100-762										100-763										100-764										100-765										100-766										100-767										100-768										100-769										100-770										100-771										100-772										100-773										100-774										100-775										100-776										100-777										100-778										100-779										100-780										100-781										100-782										100-783										100-784										100-785										100-786										100-787										100-7									
-----------------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	--------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	---------	--	--	--	--	--	--	--	--	--	-------	--	--	--	--	--	--	--	--	--

**STAFF COMPLEMENTS FOR WASTEWATER COLLECTION SYSTEM MAINTENANCE
POPULATION SIZE
(Estimated Number of Personnel)**

Occupational Title	5,000		10,000		25,000		50,000		100,000	
	(a)	(b)	(a)	(b)	(a)	(b)	(a)	(b)	(a)	(b)
Superintendent	1	5	1	10	1	20	1	40	1	40
Assistant Superintendent										
Maintenance Supervisor							1	40	2	80
Foreman	1	15	1	20	1	20	1	40	1	40
Maintenance Man II	1	15	1	20	1	20	1	40	1	40
Maintenance Man I	1	15	1	20	2	60	3	120	5	200
Mason II							1	40	1	40
Mason I									1	40
Maint. Equipment Personnel					1	40	2	80	3	120
Construction Equipment Personnel	1	15	1	20	1	20	1	40	1	40
Auto. Equipment Personnel									1	40
Photo. Inspection Technician									1	40
Laborer	1	15	1	20	2	40	2	80	5	200
Dispatcher							1	40	2	80
Clerk Typist							1	20	1	20
Stock Clerk							1	40	1	40
Sewer Maint. Staff	6	80	6	110	9	220	16	620	27	1,060
Maintenance Mechanic II	see comment (c) below									
Maintenance Mechanic I	see comment (d) below									
Maintenance Mechanic Helper	see comment (d) below									
Construction Inspection Supervisor	see comments (e) and (f) below									
Total Staff										

(a) Estimated number of personnel.

(b) Estimated total man-hours per week.

(c) Multiply number of lift stations maintained by 8/3.

(d) Multiply number of lift station visits per week by 1.

(e) Multiply estimated construction site visits per week by 8/3.

(f) Determined by the number of Construction Inspectors employed and developed on a judgmental basis.

Unit processes included in this staffing table are:

1. Maintenance of sanitary sewer main lines & appurtenances (laterals not included).
2. Maintenance of storm sewer main lines.
3. Maintenance of lift stations.
4. Inspection of newly constructed sewer main lines and appurtenances.

(U.S. EPA 1973)

STAFF COMPLEMENTS FOR WASTEWATER COLLECTION SYSTEM MAINTENANCE
POPULATION SIZE
(Estimated Number of Personnel)

Occupational Title	150,000	200,000	300,000	400,000	500,000
Superintendent	1	1	1	1	1
Assistant Superintendent	1	1	1	1	1
Maintenance Supervisor II	1	1	1	1	1
Maintenance Supervisor I	1	2	2	3	3
Equipment Supervisor	1	1	1	1	1
TV Technician II	1	2	2	3	3
TV Technician I	1	2	2	3	3
Foreman	2	3	4	5	6
Maintenance Man II	3	5	6	8	9
Maintenance Man I	11	17	22	29	33
Mason II	1	2	2	3	3
Mason I	1	2	2	3	3
Maintenance Equipment Personnel	6	8	12	15	18
Construction Equipment Personnel	3	4	6	8	9
Auto. Equipment Personnel	2	3	4	5	6
Laborer	7	10	14	18	22
Dispatcher	2	2	2	3	3
Stock Clerk	1	2	2	3	3
Clerk Typist	2	2	2	3	3
Sewer Maintenance Staff	48	70	88	116	131
Maintenance Mechanic II	see comment (a) below				
Maintenance Mechanic I	see comment (b) below				
Maintenance Mechanic Helper	see comment (b) below				
Electrician	see comment (c) below				
Construction Inspector Supervisor	see comment (d) below				
Construction Inspector	see comment (e) below				
Total Staff					

(a) Divide number of lift stations maintained by 15.

(b) Divide number of lift station visits per week by 40

(c) Divide number of lift stations maintained by 15.

(d) Determined by the number of Construction Inspectors employed and developed on a judgmental basis.

(e) Divide estimated daily construction site visits by 2.

Unit processes included in this staffing table are:

1. Maintenance of sanitary sewer main lines & appurtenances (laterals not included).
2. Maintenance of storm sewer main lines.
3. Maintenance of lift stations.
4. Inspection of newly constructed main lines and appurtenances.

(U.S. EPA 1974)

2.1.2 Training

The commitment of management to training is key to a successful program. It is important to recognize training as a budget expense item. A guideline for the typical amount of funding for training is three to five percent of the gross budget for the collection system. However, in large collection systems or those undergoing extensive construction this percentage may be considerably lower, and, in systems with a high turnover, training costs may be higher due to orienting new employees. Other changes, such as incorporation of new technology, will have a short-term impact on training costs. Although training is not explicitly required under current regulations, a collection system with untrained or poorly trained collection system personnel runs a greater risk of experiencing noncompliance.

The following elements are essential for an effective training program:

- Fundamental mission, goals, and policies of the collection system are addressed
- Mandatory training requirements are identified for key employees
- On-the-job training progress and performance are measured
- Effectiveness of the training is assessed including periodic testing, drills, or demonstrations
- New employees receive training

The owner or operator should generally provide training in the following areas:

- Routine line maintenance (may be on-the-job training only)
- Safety during confined space entry (every system should also have a strict policy and permit program)
- Traffic control (where applicable)
- Record keeping
- Pump station O&M
- Electrical and instrumentation (may be a combination of formal and on-the-job training)
- Public relations and customer service
- SSO/Emergency response
- Pump station operations and maintenance
- Pipe repair; bursting or cured in place pipe (CIPP); or closed circuit TV and trench/shoring (where these activities are not outsourced)

Sources of Training

Training is required to safely perform inspections, follow replacement procedures, and lubricate and clean parts and equipment. Following are the many sources of maintenance training:

- Manufacturer
- In-house
- On-the-job (OJT)
- Industry-wide (e.g., consultants, regulatory authorities, professional associations, or educational institutions)

The training program should identify the types of training required and offered. Types of training vary, but may include general environmental awareness, specific equipment, policies and

procedures, and conducting maintenance activities. If the owner or operator is carrying out its own training, the reviewer should evaluate one or more examples of training materials to answer the following questions: are the materials appropriate to the training topic and the level of those being trained; and are they likely to accomplish the intended goal?

Owner or Operator - Point to Note

The owner or operator should routinely assess the effectiveness of training through periodic testing, drills, demonstrations, or informal reviews, and improve training based on this assessment.

2.1.3 Internal Communication

Communication is essential to ensuring that collection systems run efficiently and effectively. It is especially important that an effective communication link exists between wastewater treatment plant operators and collection system crews as well as with other municipal departments.

Effective communication requires the top-down, bottom-up, and lateral exchange of information amongst staff. Examples of top-down communication are bulletin board posters, paycheck inserts, regular staff meetings, e-mail or informal brown-bag lunch discussions. Examples of bottom-up communication may include the establishing environmental committees, confidential hotlines, e-mail, or direct open discussions. Collection system owners or operators may also offer incentives to employees for performance, and encourage them to submit suggestions for ways to improve the performance of the collection system. "Front line" employees are often an excellent source of ideas, issues, and information about how to improve performance at the work site. In this context, the reviewer can check for morale-boosting activities or reward programs, such as "Employee of the Month" and "Employee of the Year."

The reviewer should attempt to determine lines of internal communication to ensure all employees receive information and have an appropriate forum to provide feedback. The reviewer should assess the level of communication by interviewing several levels of staff or by simply observing collection system teams on work assignments. The owner or operator should have procedures and be able to demonstrate internal communication between the various levels and functions of the collection system regarding its management, operation, and maintenance programs.

2.1.4 Customer Service

The community often knows very little about the wastewater treatment and collection services performed for them. The community may only be aware of the collection system and its owner or operator through articles in local newspapers, public radio and television announcements, or only when there is an SSO. Collection system representatives should talk to schools and universities, make presentations to local officials and businesses about the wastewater field. Formal presentations can also be given to citizens, building inspectors, public utility officials,

and members of the media.

An effective customer service and public relations program ensures that the owner or operator addresses all incoming inquiries, requests, and complaints in a timely fashion. From this information, owners or operators may further develop or revise programs to better address areas of concern. The reviewer should examine customer service records for the following:

- Personnel who received the complaint or request
- Date and nature of the complaint or request
- Location of the problem
- Name, address, and telephone number of the customer
- Cause of the problem
- To whom the follow-up action was assigned
- The initial date of the follow-up action
- Date the complaint or request was resolved
- Total days to end the problem
- Feedback to the customer

Awareness of past issues, population served, compliance history, and other elements help a reviewer determine whether the amount and types of inquiries, requests, or complaints are increasing or decreasing. For example, there may have been many complaints during only a certain week. The reviewer can examine those records to determine if there were specific circumstances (e.g., a large precipitation event) that caused the increase in inquiries or complaints.

Reviewer - Point to Note

To fully understand the context of customer inquiries, requests, or complaints, a reviewer should understand the history, topography, boundaries, and demographics of the collection system's jurisdiction before site evaluations are conducted.

Employees who handle customer service should be specifically trained to handle complaints, requests, or inquiries. These employees should be provided with sample correspondence, Q/A's, or "scripts" to help guide them through written or oral responses to customers. The reviewer should look for procedures on how to answer the telephone, e-mail, and other communication used by personnel. A reviewer may evaluate staff telephone responses by evaluating:

- The number of persons available to answer calls
- The number of repeat callers
- The average length of calls
- The volume of calls per day

Collection system field crews and their activities are the most visible segment of any wastewater treatment organization. Workers project a public image for their system on city and town streets. For this reason, personnel need to be trained in what to expect in public situations. For example,

collection system supervisory staff should be familiar with the areas around public rights-of-way and easements to which their field crews must gain access to service facilities. Additionally, crew leaders should know how to deal with the public when approached.

Collection systems field crews influence the public's confidence in the collection system owner or operator. Reviewers should observe whether personnel wear uniforms or not, and if vehicles and equipment are identifiable as utility property and kept in good working order. Vehicles should be equipped with adequate emergency lighting and flashers, traffic control signs and barriers, etc. Before major construction or maintenance work begins, owners or operators should notify homeowners where properties may be affected. Methods of notification may include door hangers, newspaper notices, fliers, signs, or public radio or television announcements. Information should also be provided to residents on cleanup and safety procedures following basement backups and other overflows.

2.1.5 Management Information Systems

The ability of the owner or operator to effectively manage its collection system is directly related to its ability to maintain access to the most current information concerning the facilities. Maintenance of this current information is an effort involving all members of the collection system from the staff answering the telephone to the worker in the street. Operational information informs and clarifies financial information. This will make the financial information more useful for the policy makers, leading to better decisions. A satisfactory management information system should provide the owner or operator with the following advantages:

- Maintain preventive maintenance and inspection schedules
- Offer budgetary justification
- Track repairs and work orders
- Organize capital replacement plans
- Manage tools and equipment inventories
- Create purchase orders
- Record customer service inquiries, complaints, or requests
- Provide measurement of effectiveness of program and O&M activities



A growing number of sewer systems have shifted to computer-based collection system management [photo: Milwaukee Metropolitan Sewerage District (MMSD)].

Owners and operators have been shifting to computer-based systems to manage data. Only the smaller collection system owners or operators may still rely on paper management systems.

Computer-based Maintenance Management Systems (CMMSs) are designed to manage the data needed to track the collection system's O&M performance. Geographic Information Systems (GIS) are used to map and locate facilities and because of computer-based compatibility, can often easily be integrated with a CMMS. The computer-based system however, can only be as accurate as the data used to develop it, which was most likely paper files.

Types of Management Information Tracking

- Customer service
- Safety incident
- Emergency response
- Process change
- Inspection scheduling and tracking
- Monitoring and/or sampling schedules
- Compliance
- Planned maintenance (schedules and work orders)
- Parts inventory

Regardless of the information management style chosen, the collection system should have written instructions regarding the use of the management information systems. These procedures may include operating the system, upgrading the system, accessing data and information, and generating and printing reports. The system should be kept current with accurate information. Work reports from the field crews should be complete, accurate, and legible.

The reviewer may select some number of complaints and see how well they can be tracked through the system to an ultimate conclusion. Work reports generated by the field crew should be randomly chosen and scanned for legibility and completeness. The reviewer should do a random check of the timeliness and accuracy of data entry. Additionally, the reviewer should obtain selected original data sources (such as field reports) and compare them to the appropriate database output to determine how long entry takes. This will provide a check on how current the database is and what data entry backlog exists.

2.1.6 SSO Notification Program

The owner or operator should maintain a written procedure indicating the entities, (e.g., drinking water purveyors, the public, public health officials, and the regulatory authority) that should be notified in the event of an SSO. The procedure should clearly indicate the chain of communication used to notify the proper personnel of an SSO event for reporting and remediation. The procedure should include the names, titles, phone numbers, and responsibility of all personnel involved. The reviewer should verify that the personnel listed in the procedure are still in the position listed and are aware of their responsibilities.

Reviewer - Point to Note

To verify the effectiveness of the notification program, the reviewer should walk an overflow occurrence report through the chain of events that would occur from the time of initial notification.

The procedure may allow for different levels of response for different types of SSOs. For example, the regulatory authority may request that SSOs due to sewer line obstructions be

reported on a monthly basis. Therefore, the procedure may simply be to gather this information from the maintenance information system and have the appropriate personnel put together a reporting form. A chronic SSO at a pump station that discharges when overloaded during wet weather may require a more complex notification procedure, including immediate telephone notification to specified authorities.

To verify the effectiveness of the notification program, the reviewer should walk an overflow occurrence report through the chain of events that would occur from the time of initial notification. This can be done by choosing several random overflow events from the complaint records and observing whether they are handled as procedures dictate. The minimum information that should be reported for an SSO includes the date, time, location, cause, volume of the overflow (which may be estimated), how it was stopped, and any remediation methods taken. The reviewer should not only verify that the SSO notification procedures are appropriate, but also verify that the owner or operator has reliable methods for the detection of overflows and a phone number or hotline for the public to report observed overflow events.

2.1.7 Legal Authority


The collection system owner or operator should select and enforce the legal authority necessary to regulate the volume of flow entering the collection system, including residential and commercial customers, satellite communities and industrial users. The legal authority may take the form of sewer use ordinances, contracts, service agreements, and other legally binding documents.

A **satellite community** is a collection systems which does not own the treatment facility to which it discharges.

The pretreatment program seeks to prevent the discharge of materials into the sewer system (by non-domestic users) that interfere with proper operation of the wastewater treatment plant or may pass through the plant untreated. At the time the operator of a wastewater treatment plant submits its pretreatment program to the regulatory authority for approval, the plant operator must include a statement from the city solicitor or other legal authority that the plant has the authority to carry out the program [40 CFR 403.9(a)(1)]. The reviewer should verify the existence of this statement and inquire as to whether any significant changes have occurred in the program such that the legal authority may need further review. Additionally, some owners or operators may have a pretreatment program approved by the state, through which discharge permits are issued to industrial users and enforcement is conducted. Further information on legal authority under the pretreatment program may be found in *Procedures Manual for Reviewing a POTW Pretreatment Program Submission* (EPA 1983).

The owner or operator should have the authority to ensure that new and rehabilitated sewers and connections have been properly designed, constructed, and tested before being put into service. This authority could take the form of design and performance specifications in a sewer use ordinance or other legal document such as a statute or series of contracts or joint powers agreements. The ordinance or legal document should contain, at a minimum, general prohibitions, adequate grease control requirements and measures, prohibitions on stormwater inflow, infiltration from laterals, and new construction standards.

The grease control section of the document should contain the requirement to install grease traps at appropriate facilities (e.g., restaurants). Additionally, these facilities should be required to properly maintain the grease traps and pump them out on a regular basis. The document should also address periodic inspections of grease traps by collection system personnel and the ability to enforce (i.e., levy fines on persistent offenders).



General Prohibitions

- Fire and explosion hazards
- Corrosive and obstructive materials
- Material which may cause interference at the wastewater treatment plant
- Heat which may inhibit biological activity at the wastewater treatment plant
- Oils or petroleum products which may cause interference or pass through the wastewater treatment plant

The owner or operator should maintain strict control over the connection of private sewer laterals to sewer mains. These connections have significant potential as sources of infiltration. Standards for new connections should be clearly specified. The sewer use ordinance should contain provisions for inspection, approval of new connections, and a program to implement the requirements. A method to maintain control over existing connections is to

require an inspection of the lateral prior to sale of a property. It is important to note that implementing this type of program may require a change to the local ordinance or code.

The owner or operator should also have the legal authority to prohibit stormwater connections to the sanitary sewer. Stormwater connections may include catch basins; roof, cellar and yard drains; sump pumps; direct connections between the storm and sanitary sewers; leaking manhole covers; uncapped cleanouts; and the direct entrance of streams into the collection system. This practice is now discouraged. Direct stormwater connections to a separate sanitary sewer system are known as inflow. Inflow can severely impact the ability of the collection system to transport flows to the treatment plant during wet weather, leading to overflows and noncompliance with the wastewater treatment plant's NPDES permit.



Sources of stormwater in the collection system may include building downspouts connected directly to the system (photo: MMSD).

Satellite communities should not be allowed to contribute excessive flows that cause or contribute to overflows, flooding, or noncompliance at the wastewater treatment plant. Should

Owner or Operator - Point to Note

The owner or operator should have a comprehensive program which addresses flows from satellite communities.

any of these situations exist, it is not sufficient for the owner or operator to charge the satellite community for the excess flow. The owner or operator must be able to prohibit the contribution of the excess flow. This may be done through a legal inter-jurisdictional agreement between the wastewater treatment plant owner or operator and the satellite community that addresses allowable flows and sets requirements. The reviewer should examine all contracts between systems and their

satellites (unless too numerous, then select representative contracts). Contracts should have a date of termination and allow for renewal under renegotiated terms. Contracts should limit flow from satellite communities and limit peak wet weather flow rates.

2.2 Collection System Operation

Collection systems have little of what is traditionally referred to as “operability” as compared to a wastewater treatment plant (i.e., the number of ways to route the wastewater is typically limited). However, the design of some collection systems does allow flow to be diverted or routed from one pipe to another or even to different treatment plants. This can be accomplished by redirecting flow at a pump station from one discharge point to another or opening and closing valves on gravity sewers and force mains.

Owner or Operator - Point to Note

There should be detailed, written procedures available to guide owners or operators through flow routing activities. Also, there should be operating procedures for mechanical equipment such as pump station pump on/off and service rotation settings or in-line grit removal (grit trap) operations.

There are many reasons why the owner or operator may want to divert flows; among them, to relieve overloading on a system of piping or the wastewater treatment plant or to add more flow to piping serving an area not yet fully developed to maintain a cleansing velocity.

2.2.1 Budgeting

The budget is one of the most important variables in the CMOM program. Although an adequate budget is not a guarantee of a well operated collection system, an inadequate budget will make

attaining this goal difficult. Funding can come from a variety of sources, including user fees or appropriations from the state or local government.

Reviewer - Point to Note

Reviewers need to determine the source of the funding for the collection system and who controls it. Reviewers should also request budget documents, summaries, or pie charts to learn more about the systems' budget.

A key element of the operation budget program is the tracking of costs in order to have accurate records each time the annual operating budget is developed. Having an annual baseline provides documentation for future budget considerations and provides justification for future rate increases. Collection system management

should be aware of the procedures for calculating user rates and for recommending and making user rate changes.

Collection system and wastewater treatment plant costs may be combined into one budget, or budget line items may be divided into each of two individual budgets. For example, electrical and mechanical maintenance work performed by plant staff on a pump station may be carried as an O&M cost in the treatment plant budget, although pumping stations are generally considered to be a collection system component.

The cost of preventive and corrective maintenance and major collection system repairs and alterations are key items in the annual operating budget. The collection system owner or operator should keep adequate records of all maintenance costs, both in-house and contracted, plus the costs for spare parts. This will assist in the preparation of the following year's budget. In general, there should be an annual (12-month cycle) budget of discretionary and non-

discretionary items. There may also be a Capital Improvement Plan (CIP) which may encompass small projects (one to two year cycles) or larger projects (three to five year cycles). Larger projects may include items such as equipment, labor, training, or root cause failure analysis.

Examples of O&M Budget Items

- Labor (usually at least 50% of total budget)
- Utilities
- Capital
- Maintenance materials and supplies
- Chemicals
- Motor vehicles
- Contracted services

The major categories of operating costs are labor, utilities, and supplies. Cost accounting for

these categories should include information on unit costs, total costs, and the amount and/or quantities used. The reviewer should evaluate the current and proposed budget, and current year balance sheets. In examining current and proposed expenditure levels, the reviewer should consider:

- Whether the budgets include contributions to capital reserve (sinking) funds. These funds are savings for replacement of system components once they reach their service life.
- Whether all income from water and sewer billings supports those functions, or if it goes into the general fund.
- Whether raising user fees is a feasible option to meet budget needs based on recent expenditure history.

2.2.2 Monitoring

The collection system owner or operator may be responsible for fulfilling some water quality or other monitoring requirements. Responsibilities may include:

- Monitoring discharges into the collection system from industrial users
- Monitoring to determine the effects of SSOs on receiving waters
- Monitoring required as part of an NPDES permit, a 308 letter, administrative order, or consent decree

The owner or operator should maintain written procedures to ensure that sampling is carried out in a safe, effective, and consistent manner. The procedures should specify, at a minimum the following:

- Sampling location(s)
- Sample volumes, preservatives, and holding times
- Instructions for the operation of any automatic sampling and/or field monitoring (e.g., pH or dissolved oxygen) equipment
- Sampling frequency
- Sampling and analytical methodologies
- Laboratory QA/QC

Records should be maintained of sampling events. These records should at a minimum include the following:

- Date, time, and location of sampling
- Sample parameters
- Date shipped or delivered to the laboratory

2.2.3 Hydrogen Sulfide Monitoring and Control

The collection system owner or operator should have a program under which they monitor areas of the collection system which may be vulnerable to the adverse effects of hydrogen sulfide. It may be possible to perform visual inspections of these areas. The records should note such items as the condition of metal components, the presence of exposed rebar (metal reinforcement in concrete), copper sulfate coating on copper pipes and electrical components, and loss of concrete from the pipe crown or walls.

Areas Subject to Generation of Hydrogen Sulfide:

- Sewers with low velocity conditions and/or long detention times
- Sewers subject to solids deposition
- Pump stations
- Turbulent areas, such as drop manholes or force main discharge points
- Inverted siphon discharges

As mentioned in Section 2.4.2, the collection system owner or operator should be carrying out routine manhole inspections. The hydrogen sulfide readings generated as a result of these inspections should be added to the records of potential areas of corrosion. A quick check of the pH of the pipe crown or structure enables early indication of potential hydrogen sulfide corrosion. A pH of less than four indicates further investigation is warranted. "Coupons" may be installed in structures or pipelines believed to be potentially subject to corrosion. Coupons are small pieces of steel inserted into the area and measured periodically to determine whether corrosion is occurring.

Reviewer - Point to Note

The reviewer should be aware that a system in which infiltration and inflow (I/I) has successfully been reduced may actually face an increased risk of corrosion. The reviewer should pay particular attention to the hydrogen sulfide monitoring program in these systems.

The reduction of flow through the pipes allows room for hydrogen sulfide gases to rise into the airway portion of the sewer pipe and react with the bacteria and moisture on the pipe walls to form sulfuric acid. Sulfuric acid corrodes ferrous metals and concrete.

There are several methods to prevent or control hydrogen sulfide corrosion. The first is proper design. Design considerations are beyond the scope of this manual but may be found in the *Design Manual: Odor and Corrosion Control in Sanitary Sewerage Systems and Treatment Plants* (EPA 1985). The level of dissolved sulfide in the wastewater may also be reduced by chemical or physical means such as aeration, or the addition of chlorine, hydrogen peroxide, potassium permanganate, iron salts, or sodium hydroxide. Whenever chemical control agents are used, the owner or operator should have procedures for their application and maintain records of the dosages of the various chemicals. Alternatively, sewer cleaning to remove deposited solids reduces hydrogen sulfide generation. Also, air relief valves may be installed at the high points of the force main system. The valve allows air to exit thus avoiding air space at the crown of the pipe where acid can form. The reviewer should examine the records to see that these valves are

receiving periodic maintenance.

Collection systems vary widely in their vulnerability to hydrogen sulfide corrosion. Vitrified clay and plastic pipes are very resistant to hydrogen sulfide corrosion while concrete, steel, and iron pipes are more susceptible. The physical aspects of the collection system are also important. Sewage in pipes on a decline that moves the wastewater at a higher velocity will have less hydrogen sulfide than sewage in pipes where the wastewater may experience longer detention times. Therefore, some systems may need a more comprehensive corrosion control program while some might limit observations to vulnerable points.

2.2.4 Safety

The reasons for development of a safety program should be obvious for any collection system owner or operator. The purpose of the program is to define the principles under which the work is to be accomplished, to make the employees aware of safe working procedures, and to establish and enforce specific regulations and procedures. The program should be in writing (e.g., procedures, policies, and training courses) and training should be well documented.

The purpose of safety training is to stress the importance of safety to employees. Safety training can be accomplished through the use of manuals, meetings, posters, and a safety suggestion program. One of the most common reasons for injury and fatalities in wastewater collection systems is the failure of victims to recognize hazards. Safety training cuts across all job descriptions and should emphasize the need to recognize and address hazardous situations. Safety programs should be in place for the following areas:

- Confined spaces
- Chemical handling
- Trenching and excavations
- Material Safety Data Sheets (MSDS)
- Biological hazards in wastewater
- Traffic control and work site safety
- Lockout/Tagout
- Electrical and mechanical safety
- Pneumatic or hydraulic systems safety

Point to Note

Although a safety program may not be explicitly required under current NPDES regulations, an excessive injury rate among personnel increases the likelihood of collection system noncompliance with other requirements. Furthermore, when good safety practices are not followed, there may be a risk to the public or to collection system workers.

The collection system owner or operator should have written procedures which address all of the

above issues and are made available to employees. In addition to training, safety programs should incorporate procedures to enforce the program. For example, this could include periodic tests or “pop” quizzes to monitor performance and/or compliance and follow-up on safety related incidents.

The owner or operator should maintain all of the safety equipment necessary for system staff to perform their daily activities and also undertake any emergency repairs. This equipment should include, at minimum:

Reviewer - Point to Note


The reviewer should, in the course of interviewing personnel, determine their familiarity with health and safety procedures according to their job description.

- Atmospheric gas testing equipment
- Respirators and/or self-contained breathing apparatus
- Full body harness
- Tripods or non-entry rescue equipment
- Hard hats
- Safety glasses
- Rubber boots
- Rubber and/or disposable gloves
- Antibacterial soap
- First aid kit
- Protective clothing
- Confined space ventilation equipment
- Traffic and/or public access control equipment
- Hazardous gas meter

Each field crew vehicle should have adequate health and safety supplies. If the reviewer has access to the municipal vehicle storage area, he or she might choose to check actual vehicle stocks, not just supplies in storage.

2.2.5 Emergency Preparedness and Response

The collection system owner or operator should have a comprehensive plan in place for dealing with both routine and catastrophic emergencies. Routine emergencies include situations such as overflowing manholes, line breaks, localized electrical failure, and power outages at pump stations. Catastrophic emergencies include floods, tornados, earthquakes, other natural events, serious chemical spills, or widespread electrical



SSOs can include overflows out of manholes onto city streets, sidewalks, and surrounding areas (photo: U.S. EPA).

failure. Ideally, this plan is written, reviewed, and adjusted as needed at periodic intervals.

The reviewer should determine if the emergency response plan generally follows the guidelines described below. The location where the plan is housed may vary but, in general, such a document should be available in the yard office or other building commonly accessible to and frequented by collection system personnel. The emergency preparedness and response procedures may be contained in the collection system's O&M manual, or may be reflected in the descriptions of equipment and unit operations. Putting emergency procedures in a stand-alone document, rather than combining it with other information in the O&M manual, makes it easier for collection system personnel to find information.

The plan should utilize the most current information on the collection system. For larger systems, a structured analysis, or *risk assessment*, should be made of the collection system, treatment plant, and the community. The risk assessment should identify areas where the collection system is vulnerable to failure and determine the effect and relative severity to collection systems operations, equipment and public safety, and health of such a failure. The risk assessment should concentrate on such factors as topography, weather, sewer system size, and other site-specific factors which reflect the unique characteristics of the system. Once the areas of vulnerability are known, the collection system owner or operator should have appropriate plans in place to ensure collection system operations continue for the duration of the emergency.

The plans must clearly identify the steps staff should take in the event of emergency situations. Plans should include information on when it is appropriate to initiate and cease emergency operations. The plans should be very specific as to the collection system or repair equipment involved. Instructions should be available which explain how to operate equipment or systems during an emergency event when they are not functioning as intended but are not fully inoperable. The plan should also include specific procedures for reporting events that result in an overflow or other noncompliance event to the appropriate authorities.

The owner or operator should track emergency situations to become better prepared for future emergencies and to assist with reporting and maintaining compliance with emergency-related requirements. Typical components of an emergency program may include:

- General information regarding emergencies, such as telephone numbers of collection system personnel, fire department, and ambulance.
- Identification of hazards (e.g., chlorine storage areas) and use of universal classification system for hazards: combustible material, flammable liquids, energized electrical circuits, and hazardous materials.
- Vulnerability analysis that identifies the various types of emergencies that could occur, such as natural disasters, power outages, or equipment failures.
- Emergency response procedures.
- Methods to reduce risk of emergencies.
- Responsibilities of staff and management.

- Continuous training.

Procedures for emergency response plans should be understood and practiced by all personnel in order to ensure safety of the public and the collection system personnel responding. Procedures should be specific to the type of emergency that could occur. It is important to keep detailed records of all past emergencies in order to constantly improve response training, as well as the method and timing of future responses. The ability to deal with emergencies depends on the knowledge and skill of the responding crews, in addition to availability of equipment. The crew should be able to rapidly diagnose problems in the field under stress and select the right equipment needed to correct the problem. If resources are limited, consideration should be given to contracting other departments or private industries to respond to some emergency situations, for example, those rare emergencies that would exceed the capacity of staff.

2.2.6 Modeling

Computer programs (modeling programs) are available that are capable of simulating the different flows within the collection system. The purpose of modeling is to determine system capacity requirements with respect to sewer design and structural conditions. Therefore the input of accurate data on sizes, location, elevation, and condition of sewer system components such as pipes, manholes, and pump stations is necessary. When possible, flow monitoring data should be used to calibrate the model.

Modeling is also useful in examining effects before and after rehabilitation. For example, models can be applied to “before” and “after” scenarios to estimate the effects of repairs. If a collection system is not experiencing any capacity related issues (i.e., overflows, bypasses, basement backups, street flooding, hydraulic overload at the treatment plant, etc.) then maintenance of a model may be optional for that system, although most medium and large systems should maintain a model of the larger diameter portion of their system. If any of the mentioned conditions are occurring then development and maintenance of a model is essential to performing a capacity assessment in the problem areas.

Computer modeling is a specialized and complex subject. The reviewer may not have a comprehensive knowledge of modeling. If this is the case the he or she should obtain the following basic information:

- Is the owner or operator using a model?
- What areas of the collection system are being modeled and why?
- What model (including the version) is being used? Who developed the model and when?

Reviewer - Point to Note

The reviewer should determine whether a model used by the owner or operator:

- Has user support
- Has adequate documentation such as a user’s manual that describes data input requirements, output to be expected, model capabilities and limitations, and hardware

- How are the modeling results being used?

2.2.7 Mapping

The importance of maintaining accurate, current maps of the collection system cannot be overstated. Efficient collection system maintenance and repairs are unlikely if mapping is not adequate. Collection system maps should clearly indicate the information that personnel need to carry out their assignments. The collection system maps should contain information on the following:

- Main, trunk and interceptor sewers
- Building/house laterals
- Manholes
- Cleanouts
- Force mains
- Pump stations
- Service area boundaries
- Other landmarks (roads, water bodies, etc.)

Collection system maps should have a numbering system which uniquely identifies all manholes and sewer cleanouts. The system should be simple and easy to understand. Manholes and sewer cleanouts should have permanently assigned numbers and never be renumbered. Maps should also indicate the property served and reference its cleanout.

Sewer line maps should indicate the diameter, the length between the centers of manholes, and the slope or direction of flow. The dimensions of easements and property lines should be included on the maps. Other information that should be included on maps are access and overflow points, a scale, and a north arrow. All maps should have the date the map was drafted and the date of the last revision. Although optional, maps often include materials of pipe construction. Maps may come in different sizes and scales to be used for different purposes. Detailed local maps may be used by maintenance or repair crews to perform the duties. However, these detailed local maps should be keyed to one overall map that shows the entire system.

Geographic Information System (GIS) technology have made the mapping and map updating process considerably more efficient. GIS is a computerized mapping program capable of combining mapping with detailed information about the physical

Key Design Characteristics

- Line locations, grades, depths, and capacities
- Maximum manhole spacing and size
- Minimum pipe size
- Pumping Station dimensions and capacities
- Drop manholes
- Flow velocities and calculations (peak flow and low-flow)
- Accessibility features
- Other technical specifications (e.g., materials, equipment)

structures within the collection system. If a GIS program is being used by the owner or operator, the reviewer should ask if the program is capable of accepting information from the owner or operator's management program.

Specific procedures should be established for correction of errors and updating maps and drawings. Field personnel should be properly trained to recognize discrepancies between field conditions and map data and record changes necessary to correct the existing mapping system. Reviewers should check to see that maps and plans are available to the personnel in the office and to field personnel or contractors involved in all engineering endeavors.

2.2.8 New Construction

The owner or operator should maintain strict control over the introduction of flows into the system from new construction. New construction may be public (i.e., an expansion of the collection system) or private (i.e., a developer constructing sewers for a new development). Quality sanitary sewer designs keep costs and problems associated with operations, maintenance, and construction to a minimum. Design flaws are difficult to correct once construction is complete. The reviewer should be aware that this has historically not been adequately addressed in some collection systems. The owner or operator should have standards for new construction, procedures for reviewing designs and protocols for inspection, start-up, testing, and approval of new construction. The procedures should provide documentation of all activities, especially inspection. Reviewers should examine construction inspection records and be able to answer the following:

- Does the volume of records seem reasonable given system size?
- Do records reflect that the public works inspectors are complying with procedures?

The state or other regulatory authority may also maintain standards for new construction. The standards held by the owner or operator should be at least as stringent. Start-up and testing should be in accordance with the manufacturers' recommendation where applicable and with recognized industry practices. Each step of the review, start-up, testing, and approval procedures should be documented.

The owner or operator approval procedure should reflect future ease of maintenance concerns. After construction is complete, a procedure for construction testing and inspection should be used. Construction supervision should be provided by qualified personnel such as a registered professional engineer.

2.2.9 Pump Stations

Proper operation, maintenance, and repair of pump stations typically requires special electrical, hydraulic, and mechanical knowledge. Pump station failure may damage equipment, the environment, or endanger public health. Variation in equipment types, pump station

configuration, and geographical factors determine pump station design and O&M requirements.

The reviewer should verify that the O&M manual contains procedures in writing for the following:

- Are pumps rotated manually or automatically? If manually, how frequently?
- Are wet well operating levels set to limit pump starts and stops?
- Is there a procedure for manipulating pump operations (manually or automatically) during wet weather to increase in-line storage of wet weather flows?
- Is flow monitoring provided? How is the data collected used?
- Does the pump station have capacity-related overflows? Maintenance related overflows? Is overflow monitoring provided?
- Is there a history of power outages? Is there a source of emergency power? If the emergency power source is a generator, is it regularly exercised under load?

2.3 Equipment and Collection System Maintenance

Every collection system owner or operator should have a well-planned, systematic, and comprehensive maintenance program. The goals of a maintenance program should include:

- Prevention of overflows
- Maximization of service and system reliability at minimum cost
- Assurance of infrastructure sustainability (i.e., ensure all components reach their service life)

There should then be procedures which describe the maintenance approach for various systems. In addition, there should be detailed instructions for the maintenance and repair of individual facilities. These instructions should provide a level of detail such that any qualified collection system personnel or repair technician could perform the repair or maintenance activity.

Maintenance may be planned or unplanned. There are essentially two types of planned maintenance; predictive and preventive. Predictive maintenance is a method that tries to look for early warning signs of equipment failure such that emergency maintenance is avoided. Preventive maintenance consists of scheduled maintenance activities performed on a regular basis. There are two types of unplanned maintenance, corrective and emergency. Corrective maintenance consists of scheduled repairs to problems identified under planned or predictive maintenance. Emergency maintenance are activities (typically repairs) performed in response to a serious equipment or line failure where action must be taken immediately. The goal of every owner or operator should be to reduce corrective and emergency maintenance through the use of planned and predictive maintenance. The reviewer should evaluate the progress of the owner or operator in achieving that goal. The goals of the reviewer in assessment of the maintenance program are:

- Identify SSOs caused by inadequate maintenance
- Determine maintenance trends (i.e., frequent emergency maintenance performed as opposed to predictive maintenance)
- Identify sustainability issues (i.e., inadequate maintenance to allow system components to reach service life and/or many components nearing or at service life)

2.3.1 Maintenance Budgeting

The cost of a maintenance program is a significant part of the annual operating budget. The collection system owner or operator should track all maintenance costs incurred throughout the year, both by internal staff and contractors, to ensure that the budget is based on representative costs from past years. Budgets should be developed from past cost records which usually are categorized according to preventive maintenance, corrective maintenance, and projected and actual major repair requirements. Annual costs should be compared to the budget periodically to control maintenance expenditures.

The reviewer should evaluate the maintenance budget keeping in mind the system's characteristics, such as age. Costs for emergency repairs should be a relatively small percentage of the budget; five to ten percent would not be considered excessive. The establishment of an "emergency reserve" may also be included as part of the maintenance budget. This is especially useful where full replacement is not funded. The budget should also be considered in light of maintenance work order backlog. The labor budget should be evaluated for consistency with local pay rates and staffing needs and the reviewer should compare local pay rates and staffing needs according to the tables in Section 2.1.1.

2.3.2 Planned and Unplanned Maintenance

A planned maintenance program is a systematic approach to performing maintenance activities so that equipment failure is avoided. Planned maintenance is composed of predictive and preventive maintenance. In the end, a good planned maintenance program should reduce material and capital repair and replacement costs, improve personnel utilization and morale, reduce SSOs, and sustain public confidence.

Examples of predictive maintenance includes monitoring equipment for early warning signs of impending failure, such as excess vibration, heat, dirty oil, and leakage. Assessment and inspection activities can be classified as predictive maintenance. Vibration and lubrication analyses, thermography, and ultrasonics are among the more common predictive maintenance tools. Predictive maintenance also takes into account historical information about the system as all systems will deteriorate over time. A predictive maintenance program strives to identify potential problem areas and

Reviewer - Point to Note

The reviewer should inquire as to whether tools such as vibration and lubrication analysis, thermography, or ultrasonics are used, and obtain information on the extent of the programs.

uncover trends that could affect equipment performance. Predictive maintenance offers an early warning. It allows collection system personnel to detect early signs of increasing rates of wear and therefore failure, and thus shift a “corrective” task into a “planned” task. To be truly effective predictive, however, maintenance should not spur personnel into doing the work too soon and wasting useful life and value of the equipment in question.

The basis of a good predictive maintenance program is recordkeeping. Only with accurate recordkeeping can baseline conditions be established, problem areas identified, and a proactive approach taken to repairs and replacement.

Effective preventive maintenance minimizes system costs and environmental impacts by reducing breakdowns and thus the need for corrective or emergency maintenance, improves reliability by minimizing the time equipment is out of service, increases the useful life of equipment thus avoiding costly premature replacement, and avoids potential noncompliance situations. An effective preventive maintenance program includes:

- Trained personnel
- Scheduling based on system specific knowledge
- Detailed instructions related to the maintenance of various pieces of equipment
- A system for recordkeeping
- System knowledge in the form of maps, historical knowledge and records

An effective preventive maintenance program builds on the inspection activities and predictive maintenance described in Sections 2.4.1 to 2.4.4, and includes a well thought-out schedule for these activities.

The basis of the schedule for mechanical equipment maintenance (i.e., pump station components) should be the manufacturers’ recommended activities and frequencies. This schedule may then be augmented by the knowledge and experience of collection system personnel to reflect the site-specific requirements. The schedule for sewer line cleaning, inspection, root removal, and repair activities should be based on periodic inspection data. In most systems, uniform frequencies for sewer line cleaning, inspection, and root removal are not necessary and inefficient. In many systems, a relatively small percentage of the pipe generates most of the problems. Efficient use of inspection data allows the owner or operator to implement a schedule in the most constructive manner. In rare cases it may be appropriate to reduce maintenance frequency for a particular piece of equipment. An example of a scheduling code and maintenance schedule for a pump is shown below:

Lubrication

Lubrication is probably one of the most important maintenance activities for mechanical systems, such as pumps and motors. Frequency of lubrication, choice of lubricant and lubrication procedure are all important factors in this activity. These items should closely follow manufacturer instructions, but may be modified to fit site-specific conditions and particular equipment applications.

Rotary Pump Maintenance Schedule	
Frequency	Maintenance Required
D	Check packing gland assembly
D	Check discharge pressure
S	Inspect and lubricate bearings
A	Flush bearings and replace lubricant

D = Daily

A = Annually

S = Semiannually

Typically, there is a maintenance card or record for each piece of equipment within the collection system. These records should contain maintenance recommendations, schedule, and instructions on conducting the specific maintenance activity. The records should include documentation regarding any maintenance activities conducted to date and other observations related to that piece of equipment or system. Maintenance records are generally kept where maintenance personnel have easy access to them. The reviewer should examine the full series of periodic work orders (i.e. weekly, monthly, semiannually, and annually) for a selection of system components (e.g., a few pump stations, several line segments). The reviewer should then compare the recommended maintenance frequency to that which is actually performed. He or she should also look at the backlog of work; not focusing solely on the number of backlogged work orders, but on what that number represents in time. A very large system can have a hundred orders backlogged and only be one week behind. In a computerized system, a listing of all open work orders is usually very simple for collection system personnel to generate. The owner or operator should be able to explain their system for prioritizing work orders.

The reviewer needs to clearly understand the following:

- How the maintenance data management system works
- How work orders are generated and distributed
- How field crews use the work orders
- How data from the field is collected and returned
- How and on whose authority work orders are closed out

The reviewer should check to see if data entry is timely and up to date.

Unplanned maintenance is that which takes place in response to equipment breakdowns or emergencies. Unplanned maintenance may be corrective or emergency maintenance. Corrective maintenance could occur as a result of preventive or predictive maintenance activities which identified a problem situation. A work order should be issued so that the request for corrective maintenance is directed to the proper personnel. An example of non-emergency corrective maintenance could be a broken belt on a belt driven pump. The worn belt was not detected and

replaced through preventive maintenance and therefore the pump is out of service until corrective maintenance can be performed. Although the pump station may function with one pump out of service, should another pump fail, the situation may become critical during peak flow periods.

If the information can be easily generated the reviewer should select a sampling of work orders and compare them to the corrective maintenance database to determine if repairs are being made in a timely manner. Reviewers should note the current backlog of corrective maintenance work orders. A corrective maintenance backlog of two weeks or less would indicate an owner or operator in control of corrective maintenance. The owner or operator should be able to explain corrective maintenance work orders that have not been completed within six months.

Corrective maintenance takes resources away from predictive and preventive maintenance. When corrective maintenance becomes a predominant activity, personnel may not be able to perform planned maintenance, thus leading to more corrective maintenance and emergency situations. Emergency maintenance occurs when a piece of equipment or system fails, creating a threat to public health, the environment, or associated equipment. This type of maintenance involves repairs, on short notice, of malfunctioning equipment or sewers. A broken force main, totally non-functional pump station, and street cave-ins are all examples of emergency situations.

Types of Portable Emergency Equipment

- Bypass pumps
- Portable generator
- Air compressor, trailer-mounted
- Manhole lifters and gas testing equipment
- Sewer rodder and/or flushing machine
- Portable lights and hand tools
- Chemical spray units (for insects and rodent control)
- Truck (1-ton) and trailers
- Vacuum truck
- Repair equipment for excavation (backhoe, shoring equipment, concrete mixers, gasoline operated saws, traffic control equipment, etc.)
- Confined space entry gear

Emergency crews should be geared to a 24-hour-a-day, year-round operation. Most large systems have staffed 24-hour crews; many small systems have an "on-call" system. The owner or operator should be able to produce written procedures which spell out the type of action to take in a particular type of emergency and the equipment and personnel requirements necessary to carry out the action. The crews should have copies of these procedures and be familiar with them. Equipment must be located in an easily accessible area and be ready to move in a short period of time. Vehicles and equipment must be ready to perform, under extreme climatic conditions if necessary. The emergency crew

Reviewer - Point to Note

The reviewer should note the presence of supplies during the review of the yard where equipment and spare parts are maintained and personnel are dispatched.

may need materials such as piping, pipe fittings, bedding materials and concrete. The owner or operator should have supplies on hand to allow for two point (i.e. segment, fitting, or appurtenance) repairs of any part of its system.

Pump stations should be subject to inspection and preventive maintenance on a regular schedule. The frequency of inspection may vary from once a week, for a reliable pump station equipped with a telemetry system, to continuous staffing at a large pump station. The basic inspection should include verification that alarm systems are operating properly, wet well levels are properly set, all indicator lights and voltage readings are within acceptable limits, suction and discharge pressures are within normal limits, that the pumps are running without excessive heat or vibration and have the required amount of lubrication, and that the emergency generator is ready if needed. Less frequent inspections may include such items as vibration analysis and internal inspection of pump components.

Owner or Operator - Point to Note

Occasionally a supervisor should perform an unscheduled inspection to confirm that tasks have been performed as expected.

Observations and tasks performed should be recorded in a log book or on a checklist at the pump station. It is important to note how this data returns to the central maintenance data management system. At the time of the inspection, collection system personnel may perform minor repairs if necessary. If non-emergency repairs are required that are beyond the staff's training, it will probably be necessary to prepare a work order which routs a request through the proper channels to initiate the repair action. During the review the reviewer should check a random number of work orders to see how they move through the system. The reviewer should note whether repairs are being carried out promptly. In pump stations, for critical equipment (pumps, drives, power equipment, and control equipment), there should not be much backlog, unless the staff is waiting for parts.

During the review, the reviewer should also make on-site observations of a representative pump stations. The reviewer should plan at least half an hour to look at the simplest two-pump prefabricated station, and one to two hours to look at a larger station. In large systems, drive time between stations may be significant. The reviewer should strive to see a range of pump station sizes and types (i.e., the largest, smallest, most remote and any that review of work orders has indicated might be problematic).

Overall, the pump station should be clean, in good structural condition and exhibit minimal odor. The reviewer should note the settings of the pumps (i.e., which are operating, which are on stand-by, and which are not operating and why). The operating pumps should be observed for noise, heat, and excessive vibration. The settings in the wet well should be noted (as indicated on the controls, as direct observation of the reviewer in the wet well is not recommended) and the presence of any flashing alarm lights. The reviewer is reminded of the atmospheric hazards in a pump station (make sure ventilation has been running prior to arrival) and to avoid confined

space entry. If the pump station has an overflow its outlet should be observed, if possible, for signs of any recent overflows such as floatable materials or toilet paper. The reviewer should check the log book and/or checklist kept at the pump station to ensure that records are current and all maintenance activities have been performed. Below is a listing of items that indicate inadequate maintenance:

- Overall poor housekeeping and cleanliness
- Excessive grease accumulation in wet well
- Excessive corrosion on railings, ladders, and other metal components
- Sagging, worn, improperly sized, or inadequate belts
- Excessive equipment out of service for repair or any equipment for which repair has not been ordered (i.e., a work order issued)
- Pumps running with excessive heat, vibration, or noise
- Peeling paint and/or dirty equipment (the care given to equipment's outer surfaces often, but not always, mirrors internal condition)
- Check valves not closing when pumps shut off
- Inoperative instrumentation, alarms, and recording equipment
- "Jury-rigged" repairs (i.e., "temporary" repairs using inappropriate materials)
- Leakage from pumps, piping, or valves (some types of pump seals are designed to "leak" seal water)
- Inadequate lighting or ineffective/inoperative ventilation equipment

2.3.3 Sewer Cleaning

The purpose of sewer cleaning is to remove accumulated material from the sewer. Cleaning helps to prevent blockages and is also used to prepare the sewer for inspections. Stoppages in gravity sewers are usually caused by a structural defect, poor design, poor construction, an accumulation of material in the pipe (especially grease), or root intrusion. Protruding traps (lateral sewer connections incorrectly installed so that they protrude into the main sewer) may catch debris which then causes a further buildup of solids that eventually block the sewer. If the flow is less than approximately 1.0 to 1.4 feet per second, grit and solids can accumulate leading to a potential blockage.

Results of Various Flow Velocities

<u>Velocity</u>	<u>Result</u>
2.0 ft/sec.....	Very little material buildup in pipe
1.4-2.0 ft/sec.....	Heavier grit (sand and gravel) begin to accumulate
1.0-1.4 ft/sec.....	Inorganic grit and solids accumulate
Below 1.0 ft/sec.....	Significant amounts of organic and inorganic solids accumulate

(EPA 1974)

There are three major methods of sewer cleaning: hydraulic, mechanical, and chemical.

Hydraulic cleaning (also referred to as flushing) refers to any application of water to clean the pipe. Mechanical cleaning uses physical devices to scrape, cut, or pull material from the sewer. Chemical cleaning can facilitate the control of odors, grease buildup, root growth, corrosion, and insect and rodent infestation. For additional information on sewer cleaning methods refer to Volumes I and II of *Operation and Maintenance of Wastewater Collection Systems* (CSU Sacramento 1996 and 1998).

The backbone of an effective sewer cleaning program is accurate recordkeeping. Accurate recordkeeping provides the collection system owner or operator with information on the areas

Sewer Cleaning Records

- Date, time, and location of stoppage or routine cleaning activity
- Method of cleaning used
- Cause of stoppage
- Identity of cleaning crew
- Further actions necessary and/or initiated
- Weather conditions



Root and grease buildup can cause blockages in a sewer system [photo: North Carolina Department of Natural Research (NCDNR)].

of the collection system susceptible to stoppages such that all portions of the system can be on an appropriate schedule. The reviewer should examine the records for legibility and completeness. He or she should then review the database to determine if entry of the field notes is current and accurate.

Sewers vary widely in their need for preventive cleaning. The collection system in a restaurant district may require cleaning every six months in order to prevent grease blockages. An area of the sewer system with new PVC piping and no significant grease contribution with reasonable and consistent slopes (i.e., no sags) may be able to go five years with no problems.

The owner or operator should be able to identify problem collection system areas, preferably on a map. Potential problem areas identified should include those due to grease or industrial discharges, hydraulic bottlenecks in the collection system, areas of poor design (e.g., insufficiently sloped sewers), areas prone to root intrusion, sags, and displacements. The connection between problem areas in the collection system and the preventive maintenance cleaning schedule should be clear. The owner or operator should also be able to identify the number of stoppages experienced per mile of sewer pipe. If the system is experiencing a steady increase in stoppages, the reviewer should try to determine the cause (i.e., lack of preventive maintenance funding, deterioration of the sewers due to age, an increase in grease producing activities, etc).

2.3.4 Parts and Equipment Inventory

An inventory of spare parts, equipment, and supplies should be maintained by the collection system owner or operator. The inventory should be based on equipment manufacturer's recommendations, supplemented by historical experience with maintenance and equipment problems. Without such an inventory, the collection system may experience long down times or periods of inefficient operation in the event of a breakdown or malfunction.

Files should be maintained on all pieces of equipment and major tools. The owner or operator should have a system to assure that each crew always has adequate tools. Tools should be subject to sign out procedures to provide accountability. Tools and equipment should be replaced at the end of their useful life. The reviewer should inquire as to how

this is determined and how funds are made available to ensure this is the case. In addition, the reviewer should look at the tools and note their condition.

Basic Equipment Inventory

- Type, age, and description of the equipment
- Manufacturer
- Fuel type and other special requirements
- Operating costs and repair history

The owner or operator should maintain a yard where equipment, supplies, and spare parts are maintained and personnel are dispatched. Very large systems may maintain more than one yard. In this case, the reviewer should perform a visual survey at the main yard. In small to medium size systems, collection system operations may share the yard with the department of public works, water department, or other municipal agencies. In this case the reviewer should determine what percentage is being allotted for collection system items. The most important features of the yard are convenience and accessibility.

The reviewer should observe a random sampling of inspection and maintenance crew vehicles for equipment as described above. A review of the equipment and manufacturer's manuals aids in determining what spare parts should be maintained. The owner or operator should then consider the frequency of usage of the part, how critical the part is, and finally how difficult the part is to obtain when determining how many of the part to keep in stock. Spare parts should be kept in a clean, well-protected stock room. Critical parts are those which are essential to the operation of the collection system. Similar to equipment and tools management, a tracking system should be in place, including procedures on logging out materials, when maintenance personnel must use them. The owner or operator should be able to produce the spare parts inventory and clearly identify those parts deemed critical. The reviewer should evaluate the inventory and selected items in the stockroom to determine whether the specified number of these parts are being maintained.

Owner or Operator - Point to Note

The owner or operator should have a procedure for determining which spare parts are critical.

2.4 Sewer System Capacity Evaluation - Testing and Inspection

The collection system owner or operator should have a program in place to periodically evaluate the capacity of the sewer system in both wet and dry weather flows and ensure the capacity is maintained as it was designed. The capacity evaluation program builds upon ongoing activities and the everyday preventive maintenance that takes place in a system. The capacity evaluation begins with an inventory and characterization of the system components. The inventory should include the following basic information about the system:

- Population served
- Total system size (feet or miles)
- Inventory of pipe length, size, material and age, and interior and exterior condition as available
- Inventory of appurtenances such as bypasses, siphons, diversions, pump stations, tide or flood gates and manholes, etc., including size or capacity, material and age, and condition as available
- Force main locations, length, size and materials, and condition as available
- Pipe slopes and inverts
- Location of house laterals - both upper and lower

The system then undergoes general inspection (described below in Sections 2.4.1 to 2.4.4) which serves to continuously update and add to the inventory information.

The next step in the capacity evaluation is to identify the location of wet weather related SSOs, surcharged lines, basement backups, and any other areas of known capacity limitations. These areas warrant further investigation in the form of flow and rainfall monitoring and inspection procedures to identify and quantify the problem. The reviewer should determine that the capacity evaluation includes an estimate peak flows experienced in the system, an estimate of the capacity of key system components, and identifies the major sources of I/I that contribute to hydraulic overloading events. The capacity evaluation should also make use of a hydraulic model, if any, to identify areas with hydraulic limitations and evaluate alternatives to alleviate capacity limitations. Short and long term alternatives to address hydraulic deficiencies should be identified, prioritized, and scheduled for implementation.



A sewer inspection is an important part of a sewer system capacity evaluation (photo: N.J. Department of Environmental Protection).

2.4.1 Flow Monitoring

Fundamental information about the collection system is obtained by flow monitoring. Flow monitoring provides information on dry weather flows as well as areas of the collection system potentially affected by I/I. Flow measurement may also be performed for billing purposes, to assess the need for new sewers in a certain area, or to calibrate a model. There are three techniques commonly used for monitoring flow rates: (1) permanent and long-term, (2) temporary, and (3) instantaneous. Permanent installations are done at key points in the collection system such as the discharge point of a satellite collection system, pump stations, and key junctions. Temporary monitoring consists of flow meters typically installed for 30-90 days. Instantaneous flow metering is performed by collection system personnel, one reading is taken and then the measuring device is removed. The collection system owner or operator should have a flow monitoring plan that describes their flow monitoring strategy or should at least be able to provide the following information:

- Purpose of the flow monitoring
- Location of all flow meters
- Type of flow meters
- Flow meter inspection and calibration frequency

A flow monitoring plan should provide for routine inspection, service, and calibration checks (as opposed to actual calibration). In some cases, the data is calibrated rather than the flow meter. Checks should include taking independent water level (and ideally velocity readings), cleaning accumulated debris and silt from the flow meter area, downloading data (sometimes only once per month), and checking the desiccant and battery state. Records of each inspection should be maintained.

Flow measurements performed for the purpose of quantifying I/I are typically separated into three components: base flow, infiltration, and inflow. Base flow is generally taken to mean the wastewater generated without any I/I component. Infiltration is the seepage of groundwater into pipes or manholes through defects such as cracks, broken joints, etc. Inflow is the water which enters the sewer through direct connections such as roof leaders, direct connections from storm drains or yard, area, and foundation drains, the holes in and around the rim of manhole covers, etc. Many collection system owners or operators add a third classification: rainfall induced infiltration (RII). RII is stormwater that enters the collection system through defects that lie so close to the ground surface that they are easily reached. Although not from piped sources, RII tends to act more like inflow than infiltration.

In addition to the use of flow meters, which may be expensive for a small owner or operator, other methods of inspecting flows may be employed such as visually monitoring manholes during low-flow periods to determine areas with excessive I/I. For a very small system, this technique may be an effective and low-cost means of identifying problem areas in the system which require further investigation.

The owner or operator should have in place a program for the efficient identification of excessive I/I. The program should look at the wastewater treatment plant, pump stations, permanent meter flows, and rainfall data to characterize peaking factors for the whole system and major drainage basins. The reviewer should evaluate the program including procedures and records associated with the flow monitoring plan. Temporary meters should be used on a “roving” basis to identify areas with high wet weather flows. Areas with high wet weather flows should then be subject to inspection and rehabilitation activities.

2.4.2 Sewer System Testing

Sewer system testing techniques are often used to identify leaks which allow unwanted infiltration into the sewer system and determine the location of illicit connections and other sources of stormwater inflow. Two commonly implemented techniques include smoke testing and dyed water testing. Regardless of the program(s) implemented by the owner or operator, the reviewer should evaluate any procedures and records that have been established for these programs. The reviewer should also evaluate any public relations program and assess how the owner or operator communicates with the public during these tests (i.e., when there is a possibility of smoke entering a home or building).

Smoke testing is a relatively inexpensive and quick method of detecting sources of inflow in sewer systems, such as down spouts, or driveway and yard drains and works best suited for detecting cross connections and point source inflow leaks. Smoke testing is not typically used on a routine basis, but rather when evidence of excessive I/I already exists. With each end of the sewer of interest plugged, smoke is introduced into the test section, usually via a manhole. Sources of inflow can then be identified when smoke escapes through them.

Areas Usually Smoke Tested

- Drainage paths
- Ponding areas
- Roof leaders
- Cellars
- Yard and area drains
- Fountain drains
- Abandoned building sewers
- Faulty service connections

If the collection system owner or operator implements a regular program of smoke testing, the program should include a public notification procedure. The owner or operator should also have procedures to define:

- How line segments are isolated
- The maximum amount of line to be smoked at one time
- The weather conditions in which smoke testing is conducted (i.e., no rain or snow, little wind and daylight only)

The results of positive smoke tests should be documented with carefully labeled photographs. Building inspections are sometimes conducted as part of a smoke testing program and, in some cases, may be the only way to find illegal connections. If properly connected to the sanitary sewer system, smoke should exit the vent stacks of the surrounding properties. If traces of the


smoke or its odor enter the building, it is an indication that gases from the sewer system may also be entering. Building inspections can be labor intensive and require advanced preparation and communication with the public.

Dyed water testing may be used to establish the connection of a fixture or appurtenance to the sewer. It is often used to confirm smoke testing or to test fixtures that did not smoke. As is the case with smoke testing, it is not used on a routine basis but rather in areas that have displayed high wet weather flows. Dyed water testing can be used to identify structurally damaged manholes that might create potential I/I problems. This is accomplished by flooding the area close to the suspected manholes with dyed water and checking for entry of dyed water at the frame-chimney area, cone/corbel, and walls of the manhole.

2.4.3 Sewer System Inspection

Visual inspection of manholes and pipelines are the first line of defense in the identification of existing or potential problem areas. Visual inspections should take place on both a scheduled basis and as part of any preventive or corrective maintenance activity. Visual inspections provide additional information concerning the accuracy of system mapping, the presence and degree of I/I problems, and the physical state-of-repair of the system. By observing the manhole directly and the incoming and outgoing lines with a mirror, it is possible to determine structural condition, the presence of roots, condition of joints, depth of debris in the line, and depth of flow. The reviewer should examine the records of visual inspections to ensure that the following information is recorded:

- Manhole identification number and location
- Cracks or breaks in the manhole or pipe (inspection sheets and/or logs should record details on defects)
- Accumulations of grease, debris, or grit
- Wastewater flow characteristics (e.g., flowing freely or backed up)
- Inflow
- Infiltration (presence of clear water in or flowing through the manhole)
- Presence of corrosion
- Offsets or misalignments
- Condition of the frame
- Evidence of surcharge
- Atmospheric hazard measurements (especially hydrogen sulfide)
- If repair is necessary, a notation as to whether a work order has been issued



Damage to the sewer system infrastructure, such as this broken manhole cover allows stormwater into the sewer system (photo: Limno-Tech, Inc.)

Manholes should undergo routine inspection typically every one to five years. There should be a baseline for manhole inspections (e.g., once every two years) with problematic manholes being inspected more frequently. The reviewer should conduct visual observation at a small but representative number of manholes for the items listed above.

There are various pipeline inspection techniques, the most common include: lamping, camera inspection, sonar, and CCTV. These will be explained further in the following sections.

2.4.3.1 Sewer System Inspection Techniques

Sewer inspection is an important component of any maintenance program. There are a number of inspection techniques that may be employed to inspect a sewer system. The reviewer should determine if a inspection program includes frequency and schedule of inspections and procedures to record the results. Sewer system cleaning should always be considered before inspection is performed in order to provide adequate clearance and inspection results. Additionally, a reviewer should evaluate records maintained for inspection activities including if information is maintained on standardized logs and should include:

- Location and identification of line being inspected
- Pipe size and type
- Name of personnel performing inspection
- Distance inspected
- Cleanliness of the line
- Condition of the manhole with pipe defects identified by footage from the starting manhole
- Results of inspection, including estimates of I/I

Lamping involves lowering a still camera into a manhole. The camera is lined up with the centerline of the junction of the manhole frame and sewer. A picture is taken down the pipe with a strobe-like flash. A disadvantage of this technique is that only the first 10-12 feet of the pipe can be inspected upstream and downstream of the access point. Additionally, it has limited use in small diameter sewers. The benefits of this technique include not requiring confined space entry and little equipment and set-up time is required.

Camera inspection is more comprehensive than lamping in that more of the sewer can be viewed. A still camera is mounted on a floatable raft and released into a pipe. The camera takes pictures with a strobe-like flash as it floats through the sewer pipe. This technique is often employed in larger lines where access points are far apart. Similarly to lamping, portions of the pipe may still be missed using this technique. Obviously, there also must be flow in the pipe for the raft to float. This technique also does not fully capture the invert of the pipe and its condition.

Sonar is a newer technology deployed similarly to CCTV cameras, described in more detail below. The sonar emits a pulse which bounces off the walls of the sewer. The time it takes for

this pulse to bounce back provides data providing an image of the interior of the pipe including its structural condition. A benefit of this technique is that it can be used in flooded or inaccessible sections of the sewer. The drawback is that the technique requires heavy and expensive equipment.

Sewer scanner and evaluation is an experimental technology where a 360 degree scanner produces a full digital picture of the interior of the pipe. This technique is similar to sonar in that a more complete image of a pipe can be made than with CCTV, but not all types of sewer defects may be identified as readily (i.e., infiltration, corrosion).

Closed Circuit Television (CCTV) inspections are a helpful tool for early detection of potential problems. This technique involves a closed-circuit camera with a light which is self-propelled or pulled down the pipe. As it moves it records the interior of the pipe. CCTV inspections may be done on a routine basis as part of the preventive maintenance program as well as part of an investigation into the cause of I/I. CCTV, however, eliminates the hazards associated with confined space entry. The output is displayed on a monitor and videotaped. A benefit of CCTV inspection is that a permanent visual record is captured for subsequent reviews.

2.5 Sewer System Rehabilitation

The collection system owner or operator should have a sewer rehabilitation program. The objective of sewer rehabilitation is to maintain the overall viability of a collection system. This is done in three ways: (1) ensuring its structural integrity; (2) limiting the loss of conveyance and wastewater treatment capacity due to excessive I/I; and (3) limiting the potential for groundwater contamination by controlling exfiltration from the pipe network. The rehabilitation program should build on information obtained as a result of all forms of maintenance and observations made as part of the capacity evaluation and asset inventory to assure the continued ability of the system to provide sales and service at the least cost. The reviewer should try to gain a sense of how rehabilitation is prioritized. Priorities may be stated in the written program or may be determined through interviews with system personnel.

There are many rehabilitation methods. The choice of methods depends on pipe size, type, location, dimensional changes, sewer flow, material deposition, surface conditions, severity of I/I, and other physical factors. Non-structural repairs typically involve the sealing of leaking joints in otherwise sound pipe.


Structural repairs involve either the replacement of all or a portion of a sewer line, or the lining of the sewer. These repairs can be carried out by excavating usually for repairs limited to one or two pipe segments (these are known as point repairs) or by trenchless technologies (in which repair is carried out via existing manholes or a limited number of access excavations).

The rehabilitation program should identify the methods that have been used in the past, their success rating and methods to be used in the future. An reviewer who wants further guidance on methods of rehabilitation may consult:

Guide for Evaluating CMOM Programs at Sanitary Sewer Collection Systems

- Technology Description from 2004 Report to Congress (EPA 2004)
- *Operation and Maintenance of Wastewater Collection Systems*, Volumes I and II (CSU Sacramento 1996 and 1998)
- *Existing Sewer Evaluation and Rehabilitation* (WEF 1994)

The reviewer should determine the owner's or operator's policies regarding service lateral rehabilitation since service laterals can constitute a serious source of I/I. Manholes should not be neglected in the rehabilitation program. Manhole covers can allow significant inflow to enter the system because they are often located in the path of surface runoff. Manholes themselves can also be a significant source of infiltration from cracks in the barrel of the manhole.



The owner or operator should be able to produce documentation on the location and methods used for sewer rehabilitation. The reviewer should compare the rehabilitation accomplished with that recommended by the capacity evaluation program. When examining the collection system rehabilitation program, the reviewer should be able to answer the following questions:

- Is rehabilitation taking place before it becomes emergency maintenance?
- Are recommendations made as a result of the previously described inspections?
- Does the rehabilitation program take into account the age and condition of the sewers?

CHAPTER 3. CHECKLIST FOR CONDUCTING EVALUATIONS OF WASTEWATER COLLECTION SYSTEM CAPACITY, MANAGEMENT, OPERATION, AND MAINTENANCE (CMOM) PROGRAMS

The following is a comprehensive checklist available for use in the review process. The checklist consists of a series of questions organized by major categories and sub-categories. The major category is followed by a brief statement describing the category. Following the sub-category is a brief clarifying statement. References are then given.

Questions are provided in a table format that includes the question, response, and documentation available.

Response is completed by using information and data acquired from the data and information request, onsite interviews, and site reviews. An alternative to this process is to transmit the entire checklist to the collection system owner or operator to complete and return electronically.

Table of Contents

I.	General Information - Collection System Description	3-4
II.	Continuing Sewer Assessment Plan	3-5
III.	Collection System Management	3-6
	A. Organizational Structure	3-6
	B. Training	3-7
	C. Communication and Customer Service	3-8
	D. Management Information Systems	3-10
	E. SSO Notification Program	3-11
	F. Legal Authority	3-12
IV.	Collection System Operation	3-14
	A. Budgeting	3-14
	B. Compliance	3-16
	C. Water Quality Monitoring	3-17
	D. Hydrogen Sulfide Monitoring and Control	3-18
	E. Safety	3-19
	F. Emergency Preparedness and Response	3-21
	G. Modeling	3-23
	H. Engineering - System Mapping and As-built Plans (Record Drawings)	3-24
	I. Engineering - Design	3-25
	J. Engineering - Capacity	3-26
	K. Engineering - Construction	3-27
	L. Pump Station Operation	3-28
	1. Pump Stations - Inspection	3-29
	2. Pump Stations - Emergencies	3-30
	3. Pump Stations - Emergency Response and Monitoring	3-31
	4. Pump Stations - Recordkeeping	3-32
	5. Pump Stations - Force Mains and Air/Vacuum Valves	3-33
V.	Collection System Maintenance	3-34
	A. Maintenance Budgeting	3-34
	B. Planned Maintenance	3-35
	C. Maintenance Scheduling	3-36
	D. Maintenance Right-of-Way	3-37
	E. Sewer Cleaning	3-38
	1. Sewer Cleaning - Cleaning Equipment	3-39
	2. Sewer Cleaning - Chemical Cleaning and Root Removal	3-40
	F. Parts Inventory	3-41
	G. Equipment and Tools Management	3-42
VI.	Management Information Systems: Performance Indicators	3-43
VII.	Sewer System Capacity Evaluation (SSES)	3-45
	A. Internal TV Inspection	3-45
	B. Survey and Rehabilitation (general)	3-46
	C. Sewer Cleaning Related to I/I Reduction	3-47
	D. Flow Monitoring	3-48
	E. Smoke Testing and Dyed Water Flooding	3-49

F. Manhole Inspection	3-50
VIII. Rehabilitation	3-52
A. Manhole Repairs	3-52
B. Mainline Sewers	3-53

I. General Information - Collection System Description

Question	Response	Documentation Available	
		Yes	No
Size of service area (acres).			
Population of service area.			
Number of pump stations.			
Feet (or miles) of sewer.			
Age of system (e.g., 30% over 30 years, 20% over 50 years, etc.).			

Comments:

II. Continuing Sewer Assessment Plan

Question	Response	Documentation Available	
		Yes	No
Does the collection system experience problems related to I/I? How do these problems manifest themselves? (Manhole overflows, basement flooding, structure, SSOs)			
How does the owner or operator prioritize investigation, repairs and rehabilitation related to I/I?			
What methods are considered to remedy hydraulic deficiencies?			
Does the plan include a schedule for investigative activities?			
Is the plan regularly updated?			

Comments:

III. A. Collection System Management: Organizational Structure

Question	Response	Documentation Available	
		Yes	No
Is an organizational chart available that shows the overall personnel structure for the collection system, including operation and maintenance staff?			
Are there organizational charts that show functional groups and classifications?			
Are up to date job descriptions available that delineate responsibilities and authority for each position?			
Are the following items discussed in the job descriptions: <input type="checkbox"/> nature of work to be performed, <input type="checkbox"/> minimum requirements for the position, <input type="checkbox"/> necessary special qualifications or certifications, <input type="checkbox"/> examples of the types of work, <input type="checkbox"/> list of licences required for the position, <input type="checkbox"/> performance measures or promotional potential?			
Does the organizational chart indicate how many positions are budgeted as opposed to actually filled?			
On average, how long do positions remain vacant?			
Are collection system staff responsible for any other duties, (e.g., road repair or maintenance, O&M of the storm water collection system)?			

Comments:

III. B. Collection System Management: Training

Question	Response	Documentation Available	
		Yes	No
Is there a documented formal training program?			
Does the training program address the fundamental mission, goals, and policies of the collection system owner or operator?			
Does the owner or operator provide training in the following areas: <input type="checkbox"/> safety, <input type="checkbox"/> routine line maintenance, <input type="checkbox"/> confined space entry, <input type="checkbox"/> traffic control, <input type="checkbox"/> record keeping, <input type="checkbox"/> electrical and instrumentation, <input type="checkbox"/> pipe repair, <input type="checkbox"/> bursting CIPP, <input type="checkbox"/> public relations, <input type="checkbox"/> SSO/emergency response, <input type="checkbox"/> pump station operations and maintenance, <input type="checkbox"/> CCTV and trench/shoring, <input type="checkbox"/> other?			
Which of these programs have formal curriculums?			
Does On-the-Job (OJT) training use Standard Operating and Standard Maintenance Procedures (SOPs & SMPs)?			
Is OJT progress and performance measured?			
Does the owner or operator have mandatory training requirements identified for key employees?			
What percentage of employees met or exceeded their annual training goals during the past year?			
Which of the following methods are used to assess the effectiveness of the training: <input type="checkbox"/> periodic testing, <input type="checkbox"/> drills, <input type="checkbox"/> demonstration, <input type="checkbox"/> none?			
What percentage of the training offered by the owner or operator is in the form of the following: manufacturer training, on-the-job training, in-house classroom training, industry-wide training?			

Comments:

III. C. Collection System Management: Communication and Customer Service

Question	Response	Documentation Available	
		Yes	No
What type of public education/outreach programs does the owner or operator have about user rates?			
Do these programs include communication with groups such as local governments, community groups, the media, schools, youth organizations, senior citizens? List applicable groups.			
Is there a public relations program in place?			
Are the employees of the collection system trained in public relations?			
Are there sample correspondence or "scripts" to help guide staff through written or oral responses to customers?			
What methods are used to notify the public of major construction or maintenance work: <input type="checkbox"/> door hangers, <input type="checkbox"/> newspaper, <input type="checkbox"/> fliers, <input type="checkbox"/> signs, <input type="checkbox"/> other, <input type="checkbox"/> none?			
Is the homeowner notified prior to construction that his/her property may be affected?			
Is information provided to residents on cleanup procedures following basement backups and overflows from manholes when they occur?			
Which of the following methods are used to communicate with system staff: <input type="checkbox"/> regular meetings, <input type="checkbox"/> bulletin boards, <input type="checkbox"/> e-mail, <input type="checkbox"/> other?			
How often are staff meetings held (e.g., daily, weekly, monthly)?			
Are incentives offered to employees for performance improvements?			
Does the owner or operator have an "Employee of the Month/Quarter/Year" program?			

Question	Response	Documentation Available	
		Yes	No
How often are performance reviews conducted (e.g., semi-annually, annually, etc.)?			
Does the owner or operator regularly communicate with other municipal departments?			
Does the owner or operator have a formal procedure in place to evaluate and respond to complaints?			
What are the common complaints received?			
Does the owner or operator have a process for customer evaluation of the services provided?			
Do customer service records include the following information: <input type="checkbox"/> personnel who received the complaint or request, <input type="checkbox"/> nature of complaint or request, <input type="checkbox"/> to whom the follow-up action was assigned, <input type="checkbox"/> date of the complaint or request, <input type="checkbox"/> date the complaint or request was resolved, <input type="checkbox"/> customer contact information, <input type="checkbox"/> location of the problem, <input type="checkbox"/> date the follow-up action was assigned, <input type="checkbox"/> cause of the problem, <input type="checkbox"/> feedback to customer?			
Does the owner or operator have a goal for how quickly customer complaints (or emergency calls) are resolved?			
What percentage of customer complaints (or emergency calls) are resolved within the timeline goals?			
How are complaint records maintained? (i.e., computerized) Is this information used as the basis for other activities such as routine preventative maintenance?			

Comments:

III. D. Collection System Management: Management Information Systems

Question	Response	Documentation Available	
		Yes	No
What types of work reports are prepared by the O&M Staff?			
Do the work reports include enough information? (See example report forms)			
How are records kept?			
Are records maintained for a period of at least three years?			
Are the records able to distinguish activities taken in response to an overflow event?			
Does the owner or operator use computer technology for its management information system? (Computer Based Maintenance Management Systems, spreadsheets, data bases, SCADA, etc). If so, what type of system(s) is used?			
Are there written instructions for managing and tracking the following information: <input type="checkbox"/> complaint work orders, <input type="checkbox"/> scheduled work orders, <input type="checkbox"/> customer service, <input type="checkbox"/> scheduled preventative maintenance, <input type="checkbox"/> scheduled inspections, <input type="checkbox"/> sewer system inventory, <input type="checkbox"/> safety incidents, <input type="checkbox"/> scheduled monitoring/sampling, <input type="checkbox"/> compliance/overflow tracking, <input type="checkbox"/> equipment/tools tracking, <input type="checkbox"/> parts inventory?			
Do the written instructions for tracking procedures include the following information: <input type="checkbox"/> accessing data and information, <input type="checkbox"/> instructions for using the tracking system, <input type="checkbox"/> updating the MIS, <input type="checkbox"/> developing and printing reports?			
How often is the management information system updated (immediately, within one week of the incident, monthly as time permits)?			

Comments:

III. E. Collection System Management: SSO Notification Program

Question	Response	Documentation Available	
		Yes	No
Does the owner or operator have standard procedures for notifying state agencies, health agencies, the regulatory authority, and the drinking water purveyor of overflow events?			
Are above notification procedures dependent on the size or location of the overflow? If so, describe this procedure.			
Is there a Standard form for recording overflow events? Does it include location, type, receiving water, estimated volume, cause?			
Are chronic SSO locations posted?			

Comments:

III. F. Collection System Management: Legal Authority

Question	Response	Documentation Available	
		Yes	No
Does the collection system receive flow from satellite communities?			
What is the total area from satellite communities that contribute flow to the collection system (acres or square miles)?			
Does the owner or operator require satellite communities to enter into an agreement?			
Does the agreement include the requirements listed in the sewer use ordinance (SUO)?			
Do the agreements have a date of termination and allow for renewal under different terms?			
Does the owner or operator maintain the legal authority to control the maximum flow introduced into the collection system from satellite communities?			
Are standards, inspections, and approval for new connections clearly documented in a SUO?			
Does the SUO require satellite communities to adopt the same industrial and commercial regulator discharge limits as the owner or operator?			
Does the SUO require satellite communities to adopt the same inspection and sampling schedules as required by the pretreatment ordinance?			
Does the SUO require the satellite communities or the owner or operator to issue control permits for significant industrial users?			
Does the SUO contain provisions for addressing overstrength wastewater from satellite communities?			
Does the SUO contain procedures for the following: inspection standards, pretreatment requirements, building/sewer permit issues?			

Does the SUO contain general prohibitions of the following materials: <input type="checkbox"/> fire and explosion hazards, <input type="checkbox"/> oils or petroleum, <input type="checkbox"/> corrosive materials, <input type="checkbox"/> materials which may cause interference at the wastewater treatment plant, <input type="checkbox"/> obstructive materials?		
Does the SUO contain procedures and enforcement actions for the following: <input type="checkbox"/> fats, oils, and grease (FOG); <input type="checkbox"/> I/I; building structures over the sewer lines; <input type="checkbox"/> storm water connections to sanitary lines; <input type="checkbox"/> defects in service laterals located on private property; <input type="checkbox"/> sump pumps, air conditioner?		

Comments:

IV. A. Collection System Operation: Budgeting

Question	Response	Documentation Available	
		Yes	No
What are the owner or operator's current rates?			
What is the average annual fee for residential users?			
How are user rates calculated?			
How often are user charges evaluated and adjusted based on that evaluation?			
How many rate changes have there been in the last 10 years and what were they?			
Does the owner or operator receive sufficient funding from its revenues?			
Are collection system enterprise funds used for non-enterprise fund activities?			
Is there a budget for annual operating costs?			
Does the budget provide sufficient line item detail for labor, materials and equipment?			
Are costs for collection system O&M separated from other utility services, i.e., water, storm water and treatment plants?			
Do O&M managers have current O&M budget data?			
What is the collection system's average annual O&M budget?			
What percentage of the collection system's overall budget is allocated to maintenance of the collection system?			
Does the owner or operator have a Capital Improvement Plan (CIP) that provides for system repair/replacement on a prioritized basis?			
What is the collection system's average annual CIP budget?			

Question	Response	Documentation Available	
		Yes	No
What percentage of the maintenance budget is allotted to the following maintenance: Predictive maintenance (tracking design, life span, and scheduled parts replacement), preventative maintenance (identifying and fixing system weakness which, if left unaddressed, could lead to overflows), corrective maintenance (fixing system components that are functioning but not at 100% capacity/efficiency), emergency maintenance (reactive maintenance, overflows, equipment breakdowns).			
Does the owner or operator have a budgeted program for the replacement of under-capacity pipes?			
Does the owner or operator have a budgeted program for the replacement of over-capacity pipes?			
Are O&M staff involved in O&M budget preparation?			
How are priorities determined for budgeting for O&M during the budget process?			
Does the owner or operator maintain a fund for future equipment and infrastructure replacement?			
How is new work typically financed?			

Comments:

IV. B. Collection System Operation: Compliance

Question	Response	Documentation Available	
		Yes	No
Does the owner or operator have inter-jurisdictional or inter-municipal agreements?	Already asked		
Is there a sewer-use and a grease ordinance?			
Is there a process in place for enforcing sewer and grease ordinances?			
Are all grease traps inspected regularly?			
How does the owner or operator learn of new or existing unknown grease traps?			
Who is responsible for enforcing the sewer ordinance and grease ordinance? Does this party communicate with the utility department on a regular basis?			
Are there any significant industrial dischargers to the system?			
Is there a pretreatment program in place? If so, please describe.			
Is there an ordinance dealing with private service laterals?			
Is there an ordinance dealing with storm water connections or requirements to remove storm water connections?			

Comments:

IV. C. Collection System Operation: Water Quality Monitoring

Question	Response	Documentation Available	
		Yes	No
Is there a water quality monitoring program in the service areas?			
If so, who performs the monitoring?			
How many locations are monitored?			
What parameters are monitored and how often?			
Is water quality monitored after an SSO event?			
Are there written standard sampling procedures available?			
Is analysis performed in-house or by a contract laboratory?			
Are chain-of-custody forms used?			

Comments:

IV. D. Collection System Operation: Hydrogen Sulfide Monitoring and Control

Question	Response	Documentation Available	
		Yes	No
Are odors a frequent source of complaints? How many?			
Are the locations of the frequent odor complaints documented?			
What is the typical sewer slope? Does the owner or operator take hydrogen sulfide corrosion into consideration when designing sewers?			
Does the collection system owner or operator have a hydrogen sulfide problem, and if so, does it have in place corrosion control programs? What are the major elements of the program?			
Does the owner or operator have written procedures for the application of chemical dosages?			
Are chemical dosages, dates, and locations documented?			
Does the owner or operator have a program in place for renewing or replacing severely corroded sewer lines to prevent collapse?			
Are the following methods used for hydrogen sulfide control: <input type="checkbox"/> aeration, <input type="checkbox"/> iron salts, <input type="checkbox"/> enzymes, <input type="checkbox"/> activated charcoal canisters, <input type="checkbox"/> chlorine, <input type="checkbox"/> sodium hydroxide, <input type="checkbox"/> hydrogen peroxide, <input type="checkbox"/> potassium permanganate, <input type="checkbox"/> biofiltration, <input type="checkbox"/> others?			
Does the system contain air relief valves at the high points of the force main system?			
How often are the valves maintained and inspected (weekly, monthly, etc.)?			
Does the owner or operator enforce pretreatment requirements?			

Comments:

IV. E. Collection System Operation: Safety

Question	Response	Documentation Available	
		Yes	No
Is there a documented safety program supported by the top administration official?			
Is there a Safety Department that provides training, equipment, and an evaluation of procedures?			
If not, who provides safety training?			
Does the owner or operator have written procedures for the following: <input type="checkbox"/> lockout/tagout, <input type="checkbox"/> MSDS, <input type="checkbox"/> chemical handling, <input type="checkbox"/> confined spaces permit program, <input type="checkbox"/> trenching and excavations, <input type="checkbox"/> biological hazards in wastewater, <input type="checkbox"/> traffic control and work site safety, <input type="checkbox"/> electrical and mechanical systems, <input type="checkbox"/> pneumatic and hydraulic systems safety?			
What is the agency's lost-time injury rate(percent or in hours)?			
Is there a permit required confined space entry procedure for manholes, wetwells, etc.? Are confined spaces clearly marked?			
Are the following equipment items available and in adequate supply: <input type="checkbox"/> rubber/disposable gloves; <input type="checkbox"/> confined space ventilation equipment; <input type="checkbox"/> hard hats, <input type="checkbox"/> safety glasses, <input type="checkbox"/> rubber boots; <input type="checkbox"/> antibacterial soap and first aid kit; <input type="checkbox"/> tripods or non-entry rescue equipment; <input type="checkbox"/> fire extinguishers; <input type="checkbox"/> equipment to enter manholes; <input type="checkbox"/> portable crane/hoist; <input type="checkbox"/> atmospheric testing equipment and gas detectors; <input type="checkbox"/> oxygen sensors; <input type="checkbox"/> H ₂ S monitors; <input type="checkbox"/> full body harness; <input type="checkbox"/> protective clothing; <input type="checkbox"/> traffic/public access control equipment; <input type="checkbox"/> 5-minute escape breathing devices; <input type="checkbox"/> life preservers for lagoons; <input type="checkbox"/> safety buoy at activated sludge plants; <input type="checkbox"/> fiberglass or wooden ladders for electrical work; <input type="checkbox"/> respirators and/or self-contained breathing apparatus; <input type="checkbox"/> methane gas or OVA analyzer; <input type="checkbox"/> LEL metering?			
Are safety monitors clearly identified?			
How often are safety procedures reviewed and revised?			

Question	Response	Documentation Available	
		Yes	No
Are workplace accidents investigated?			
How does the Administration communicate with field personnel on safety procedures; memo, direct communication, video, etc.?			
Is there a Safety Committee with participation by O&M staff? How often does it meet?			
Is there a formal Safety Training Program? Are records of training maintained?			

Comments:

IV. F. Collection System Operation: Emergency Preparedness and Response

Question	Response	Documentation Available	
		Yes	No
Does the owner or operator have an emergency response plan? A contingency plan?			
How often is the plan reviewed and updated? What was the date it was last updated?			
Does the plan take into consideration vulnerable points in the system, severe natural events, failure of critical system components, vandalism or other third party events, and a root cause analysis protocol?			
Are staff trained and drilled to respond to emergency situations? Are responsibilities detailed for all personnel who respond to emergencies?			
Are there emergency operation procedures for equipment and processes?			
Does the owner or operator have standard procedures for notifying state agencies, local health departments, the regulatory authority, and drinking water authorities of significant overflow events?			
Does the procedure include an up-to-date list of the names, titles, phone numbers, and responsibilities of all personnel involved?			
Do work crews have immediate access to tools and equipment during emergencies?			
Is there a public notification plan? If so, does it cover both regular business hours and off-hours?			
Does the owner or operator have procedures to limit public access to and contact with areas affected with SSOs?			
Does the owner or operator use containment techniques to protect the storm drainage systems?			

Do the overflow records include the following information: <input type="checkbox"/> date and time, <input type="checkbox"/> cause(s), <input type="checkbox"/> names of affected receiving water(s), <input type="checkbox"/> location, <input type="checkbox"/> how it was stopped, <input type="checkbox"/> any remediation efforts, <input type="checkbox"/> estimated flow/volume discharged, <input type="checkbox"/> duration of overflow?			
Does the owner or operator have signage to keep public from affected area?			
Is there a hazard classification system? Where is it located?			
Does the owner or operator conduct vulnerability analyses?			
Are risk assessments performed? How often?			

Comments:

IV. G. Collection System Operation: Modeling

Question	Response	Documentation Available	
		Yes	No
Does the owner or operator have a hydraulic model of the collection system including pump stations? What model is used?			
What uses does the model serve (predicting flow capacity, peak flows, force main pressures, etc.)?			
Does the model produce results consistent with observed conditions?			
Is the model kept up to date with respect to new construction and repairs that may affect hydraulic capacity?			

Comments:

IV. H. Collection System Operation: Engineering - System Mapping and As-built Plans (Record Drawings)

Question	Response	Documentation Available	
		Yes	No
What type of mapping/inventory system is used?			
Is the mapping tied to a GPS system?			
Are "as-built" plans (record drawings) or maps available for use by field crews in the office and in the field?			
Do field crews record changes or inaccuracies and is there a process in place to update "as built" plans (record drawings)?			
Do the maps show the date the map was drafted and the date of the last revision?			
Do the sewer line maps include the following: <input type="checkbox"/> scale; <input type="checkbox"/> north arrow; <input type="checkbox"/> date the map was drafted; <input type="checkbox"/> date of the last revision; <input type="checkbox"/> service area boundaries; <input type="checkbox"/> property lines; <input type="checkbox"/> other landmarks; <input type="checkbox"/> manhole and other access points; <input type="checkbox"/> location of building laterals; <input type="checkbox"/> street names; <input type="checkbox"/> SSOs/CSOs; <input type="checkbox"/> flow monitors; <input type="checkbox"/> force mains; <input type="checkbox"/> pump stations; <input type="checkbox"/> lined sewers; <input type="checkbox"/> main, trunk, and interceptor sewers; <input type="checkbox"/> easement lines and dimensions; <input type="checkbox"/> pipe material; <input type="checkbox"/> pipe diameter; <input type="checkbox"/> pipe diameter; <input type="checkbox"/> installation date; <input type="checkbox"/> slope; <input type="checkbox"/> manhole rim elevation; <input type="checkbox"/> manhole coordinates; <input type="checkbox"/> manhole invert elevation; <input type="checkbox"/> distance between manholes?			
Are the following sewer attributes recorded: <input type="checkbox"/> size, <input type="checkbox"/> shape, <input type="checkbox"/> invert elevation, <input type="checkbox"/> material, <input type="checkbox"/> separate/combined sewer, <input type="checkbox"/> installation date?			
Are the following manhole attributes recorded: <input type="checkbox"/> shape, <input type="checkbox"/> type, <input type="checkbox"/> depth, <input type="checkbox"/> age, <input type="checkbox"/> material?			
Is there a systematic numbering and identification method/system established to identify sewer system manhole, sewer lines, and other items (pump stations, etc.)?			

Comments:

IV. I. Collection System Operation: Engineering - Design

Question	Response	Documentation Available	
		Yes	No
Is there a document which details design criteria and standard construction details?			
Is life cycle cost analysis performed as part of the design process?			
Is there a document that describes the procedures that the owner or operator follows in conducting design review? Are there any standard forms that are used as a guide?			
Are O&M staff involved in the design review process?			
Does the owner or operator have documentation on private service lateral design and inspection standards?			
Does the owner or operator attempt to standardize equipment and sewer system components?			

Comments:

IV. J. Collection System Operation: Engineering - Capacity

Question	Response	Documentation Available	
		Yes	No
What procedures are used in determining whether the capacity of existing gravity sewer system, pump stations and force mains are adequate for new connections?			
Is any metering of flow performed prior to allowing new connections?			
Is there a hydraulic model of the system used to predict the effects of new connections?			
Is there any certification as to the adequacy of the sewer system to carry additional flow from new connections required?			

Comments:

IV. K. Collection System Operation: Engineering - Construction

Question	Response	Documentation Available	
		Yes	No
Who constructs new sewers? If other than the owner or operator, does the owner or operator review and approve the design?			
Is there a document that describes the procedures that the owner or operator follows in conducting their construction inspection and testing program?			
Are there any standard forms that guide the owner or operator in conducting their construction inspection and testing program?			
Is new construction inspected by the owner or operator or others?			
What are the qualifications of the inspector(s)?			
What percentage of time is a construction inspector on site?			
Is inspection supervision provided by a registered professional engineer?			
How is the new gravity sewer construction tested? (Air, water, weirs, etc.)			
Are new manholes tested for inflow and infiltration?			
Are new gravity sewers televised?			
What tests are performed on pump stations?			
What tests are performed on force mains?			
Is new construction built to standard specifications established by the owner or operator and/or the State?			
Is there a warranty for new construction? If so, is there a warranty inspection done at the end of this period?			

Comments:

IV. L. Collection System Operation: Pump Station Operation

Question	Response	Documentation Available	
		Yes	No
How many pump stations are in the system? How many have backup power sources?			
Are enough trained personnel assigned to properly maintain pump stations?			
Are these personnel assigned full-time or part-time to pump station duties?			
Are there manned and un-manned pump stations in the system? How many of each?			
Is there a procedure for manipulating pump operations (manually or automatically during wet weather to increase in-line storage of wet weather flows?			
Are well-operating levels set to limit pump start/stops?			
Are the lead, lag, and backup pumps rotated regularly?			

Comments:

IV. L. 1. Collection System Operation: Pump Stations - Inspection

Question	Response	Documentation Available	
		Yes	No
How often are pump stations inspected?			
What work is accomplished during inspections?			
Is there a checklist?			
Are records maintained for each inspection?			
What are the average annual labor hours spent on pump station inspections?			
Are there Standard Operating Procedures (SOPs) and Standard Maintenance Procedures (SMPs) for each station?			
What are the critical operating characteristics maintained for each station? Are the stations maintained within these criteria?			

Comments:

IV. L. 2. Collection System Operation: Pump Stations - Emergencies

Question	Response	Documentation Available	
		Yes	No
Is there an Emergency Operating Procedure for each pump station?			
Is there sufficient redundancy of equipment in all pump stations?			
Who responds to lift station failures and overflows? How are they notified?			
How is loss of power at a station dealt with? (i.e. on-site electrical generators, alternate power source, portable electric generator(s))			
What equipment is available for pump station bypass?			
What process is used to investigate the cause of pump station failure and take necessary action to prevent future failures?			

Comments:

IV. L. 3. Collection System Operation: Pump Stations - Emergency Response and Monitoring

Question	Response	Documentation Available	
		Yes	No
How are lift stations monitored?			
If a SCADA system is used, what parameters are monitored?			

Comments:

IV. K. Collection System Operation: Engineering - Construction

Question	Response	Documentation Available	
		Yes	No
Who constructs new sewers? If other than the owner or operator, does the owner or operator review and approve the design?			
Is there a document that describes the procedures that the owner or operator follows in conducting their construction inspection and testing program?			
Are there any standard forms that guide the owner or operator in conducting their construction inspection and testing program?			
Is new construction inspected by the owner or operator or others?			
What are the qualifications of the inspector(s)?			
What percentage of time is a construction inspector on site?			
Is inspection supervision provided by a registered professional engineer?			
How is the new gravity sewer construction tested? (Air, water, weirs, etc.)			
Are new manholes tested for inflow and infiltration?			
Are new gravity sewers televised?			
What tests are performed on pump stations?			
What tests are performed on force mains?			
Is new construction built to standard specifications established by the owner or operator and/or the State?			
Is there a warranty for new construction? If so, is there a warranty inspection done at the end of this period?			

Comments:

IV. L. Collection System Operation: Pump Station Operation

Question	Response	Documentation Available	
		Yes	No
How many pump stations are in the system? How many have backup power sources?			
Are enough trained personnel assigned to properly maintain pump stations?			
Are these personnel assigned full-time or part-time to pump station duties?			
Are there manned and un-manned pump stations in the system? How many of each?			
Is there a procedure for manipulating pump operations (manually or automatically during wet weather to increase in-line storage of wet weather flows?			
Are well-operating levels set to limit pump start/stops?			
Are the lead, lag, and backup pumps rotated regularly?			

Comments:

IV. L. 1. Collection System Operation: Pump Stations - Inspection

Question	Response	Documentation Available	
		Yes	No
How often are pump stations inspected?			
What work is accomplished during inspections?			
Is there a checklist?			
Are records maintained for each inspection?			
What are the average annual labor hours spent on pump station inspections?			
Are there Standard Operating Procedures (SOPs) and Standard Maintenance Procedures (SMPs) for each station?			
What are the critical operating characteristics maintained for each station? Are the stations maintained within these criteria?			

Comments:

IV. L. 2. Collection System Operation: Pump Stations - Emergencies

Question	Response	Documentation Available	
		Yes	No
Is there an Emergency Operating Procedure for each pump station?			
Is there sufficient redundancy of equipment in all pump stations?			
Who responds to lift station failures and overflows? How are they notified?			
How is loss of power at a station dealt with? (i.e. on-site electrical generators, alternate power source, portable electric generator(s))			
What equipment is available for pump station bypass?			
What process is used to investigate the cause of pump station failure and take necessary action to prevent future failures?			

Comments:

IV. L. 3. Collection System Operation: Pump Stations - Emergency Response and Monitoring

Question	Response	Documentation Available	
		Yes	No
How are lift stations monitored?			
If a SCADA system is used, what parameters are monitored?			

Comments:

IV. L. 4. Collection System Operation: Pump Stations - Recordkeeping

Question	Response	Documentation Available	
		Yes	No
Are operations logs maintained for all pump stations?			
Are manufacturer's specifications and equipment manuals available for all equipment?			
Are pump run times maintained for all pumps?			
Are elapsed time meters used to assess performance?			

Comments:

IV. L. 5. Collection System Operation: Pump Stations - Force Mains and Air/Vacuum Valves

Question	Response	Documentation Available	
		Yes	No
Does the owner or operator regularly inspect the route of force mains?			
Does the owner or operator have a program to regularly assess force main condition?			
Is there a process in place to investigate the cause of force main failures?			
Does the owner or operator have a regular maintenance/inspection program for air/vacuum valves?			
Have force main failures been caused by water hammer?			

Comments:

V. A. Equipment and Collection System Maintenance: Maintenance Budgeting

Question	Response	Documentation Available	
		Yes	No
How does the collection system owner or operator track yearly maintenance costs?			
Is there a maintenance cost control system?			
Are maintenance costs developed from past cost records?			
How does the owner or operator categorize costs? Preventive? Corrective? Projected Costs? Projected Repair?			
How does the owner or operator control expenditures?			

Comments:

V. B. Equipment and Collection System Maintenance: Planned Maintenance

Question	Response	Documentation Available	
		Yes	No
Are preventive maintenance tasks and frequencies established for all pump stations and equipment?			
How were preventive maintenance frequencies established?			
What percentage of the operator's time is devoted to planned as opposed to unplanned maintenance?			
What predictive maintenance techniques are used as part of PM program?			
Is there a formal procedure to repair or replace pump stations and equipment when useful life is reached?			
Has an energy audit been performed on pump station electrical usage?			
Is an adequate parts inventory maintained for all equipment?			
Is there a sufficient number of trained personnel to properly maintain all stations?			
Who performs mechanical and electrical maintenance?			
Are there Standard Maintenance Procedures (SMPs) for each station?			

Comments:

V. C. Equipment and Collection System Maintenance: Maintenance Scheduling

Question	Response	Documentation Available	
		Yes	No
Does the owner or operator plan and schedule preventive and corrective maintenance activities?			
Is there an established priority system? Who sets priorities for maintenance?			
Is a maintenance card or record kept for each piece of mechanical equipment within the collection system?			
Do equipment maintenance records include the following information: <input type="checkbox"/> maintenance recommendations, <input type="checkbox"/> instructions on conducting the specific maintenance activity, <input type="checkbox"/> other observations on the equipment, <input type="checkbox"/> maintenance schedule, <input type="checkbox"/> a record of maintenance on the equipment to date.			
Are dated tags used to show out-of-service equipment?			
Is maintenance backlog tracked?			
How is O&M performance tracked and measured?			
What percent of repair finds are spent on emergency repairs?			
Are corrective repair work orders backlogged more than six months?			
Is maintenance performed for other public works divisions?			
How are priorities determined for this work?			
How is this work funded?			
Are maintenance logs maintained for all pump stations?			

Comments:

V. D. Equipment and Collection System Maintenance: Maintenance Right-of-Way

Question	Response	Documentation Available	
		Yes	No
Does the owner or operator perform scheduled maintenance on Rights-of-Way and Easements?			
Does the owner or operator monitor street paving projects?			
Does the owner or operator have a program to locate and raise manholes (air valves, etc) as needed?			
How are priorities determined?			
How is the effectiveness of the maintenance schedule measured?			

Comments:

V. E. Equipment and Collection System Maintenance: Sewer Cleaning

Question	Response	Documentation Available	
		Yes	No
Is there a routine schedule for cleaning sewer lines on a system wide basis, e.g., at the rate of once every seven to twelve years or a rate of between 8% and 14% per year?			
What is the owner or operator's goals for annual system cleaning?			
What percent of the sewer lines are cleaned, even high/repeat cleaning trouble spots, during the past year?			
Is there a program to identify sewer line segments that have chronic problems and should be cleaned on a more frequent schedule?			
What is the average number of stoppages experienced per mile of sewer pipe per year?			
Has the number of stoppages increased, decreased, or stayed the same over the past five years?			
Are stoppages diagnosed to determine the cause?			
Are stoppages plotted on maps and correlated with other data such as pipe size and material, or location?			
Do the sewer cleaning records include the following information: <input type="checkbox"/> date and time, <input type="checkbox"/> cause of stoppage, <input type="checkbox"/> method of cleaning, location of stoppage or routine cleaning activity, <input type="checkbox"/> identity of cleaning crew, <input type="checkbox"/> further actions necessary/initiated?			
If sewer cleaning is done by a contractor are videos taken of before and after cleaning?			

Comments:

V. E. 1. Equipment and Collection System Maintenance: Sewer Cleaning - Cleaning Equipment

Question	Response	Documentation Available	
		Yes	No
What type of cleaning equipment does the owner or operator use?			
How many cleaning units of each type does the owner or operator have? What is the age of each?			
How many cleaning crews and shifts does the owner or operator employ?			
How many cleaning crews are dedicated to preventive maintenance cleaning?			
How many cleaning crews are dedicated to corrective maintenance cleaning?			
What has the owner or operator's experience been regarding pipe damage caused by mechanical equipment?			
Where is the equipment stationed?			

Comments:

V. E. 2. Equipment and Collection System Maintenance: Sewer Cleaning - Chemical Cleaning and Root Removal

Question	Response	Documentation Available	
		Yes	No
Does the owner or operator have a root control program?			
Does the owner or operator have a FOG program?			
Are chemical cleaners used?			
What types of chemical cleaners are used?			
How often are they applied?			
How are the chemical cleaners applied?			
What results are achieved through the use of chemical cleaners?			

Comments:

V. F. Equipment and Collection System Maintenance: Parts Inventory

Question	Response	Documentation Available	
		Yes	No
Does the owner or operator have a central location for the storage of spare parts?			
Have critical spare parts been identified?			
Are adequate supplies on hand to allow for two point repairs in any part if the system?			
Is there a parts standardization policy in place?			
Does the owner or operator maintain a stock of spare parts on its maintenance vehicles?			
What method(s) does the owner or operator employ to keep track of the location, usage, and ordering of spare parts? Are parts logged out when taken by maintenance personnel for use?			
Does the owner or operator salvage specific equipment parts when equipment is placed out-of-service and not replaced?			
How often does the owner or operator conduct a check of the inventory of parts to ensure that their tracking system is working?			
Who has the responsibility of tracking the inventory?			
For those parts which are not kept in inventory, does the owner or operator have a readily available source or supplier?			

Comments:

V. G. Equipment and Collection System Maintenance: Equipment and Tools Management

Question	Response	Documentation Available	
		Yes	No
Is there a list of equipment and tools used for operation and maintenance?			
Do personnel feel they have access to the necessary equipment and tools to do all aspects of operation and maintenance of the collection system?			
Is there access to suitable equipment if the owner or operator's equipment is down for repair?			
Does the owner or operator own or have access to portable generators?			
Where does the owner or operator store its equipment?			
Is a detailed equipment maintenance log kept?			
Are written equipment maintenance procedures available?			
What is the procedure for equipment replacement?			
Are the services of an in-house vehicle and equipment maintenance services used?			
What is the typical turnaround time for equipment and vehicle maintenance?			

Comments:

VI. Management Information Systems: Performance Indicators

Question	Response	Documentation Available	
		Yes	No
How many sanitary sewer overflows (SSOs) have occurred in the last 5 years? How many less than 1,000 gallons?			
Does the owner or operator document and report all SSOs regardless of size?			
Does the owner or operator document basement backups?			
Are there areas that experience basement or street flooding?			
How many SSOs have reached "Waters of the US"? Is there a record?			
Approximately, what percent of SSOs discharge were from each of the following in the last 5 years: manholes, pump stations, main and trunk sewers, lateral and branch sewers, structural bypasses?			
What is the per capita wastewater flow for the maximum month and maximum week or day?			
What is average annual influent BOD?			
What is the ratio of maximum wet weather flow to average dry weather flow?			
Approximately, what percent of SSO discharge were caused by the following in the last 5 years: debris buildup, collapsed pipe, root intrusion, capacity limitations, excessive infiltration and inflow, FOG, vandalism?			
What percent of SSOs were released to: soil; surface water; basements; paved areas; coastal, ocean, or beach areas; rivers, lakes or streams?			
For surface water releases, what percent are to surface waters that could affect: contact recreation, shellfish growing areas, drinking water sources?			
How many chronic SSO locations are in the collection system?			

Are pipes with chronic SSOs being monitored for sufficient capacity and/or structural condition?			
Prior to collapse, are structurally deteriorating pipelines being monitored for renewal or replacement?			
What is the annual number of mainline sewer cave-ins? What was the cause (i.e. pipe corrosion, leaks, etc.)			
What other types of performance indicators does the owner or operator use?			

Comments:

VII. A. Sewer System Capacity Evaluation (SSES): Internal TV Inspection

Question	Response	Documentation Available	
		Yes	No
Does the owner or operator use internal T.V. inspection? If so please describe the program.			
Do the internal TV record logs include the following: <input type="checkbox"/> pipe size, type, length, and joint spacing; <input type="checkbox"/> distance recorded by internal TV; <input type="checkbox"/> results of the internal TV inspection; <input type="checkbox"/> internal TV operator name; <input type="checkbox"/> cleanliness of the line; <input type="checkbox"/> location and identification of line being televised by manholes?			
Is a rating system used to determine the severity of the defects found during the inspection process?			
Is there documentation explaining the codes used for internal TV results reporting?			
Approximately what percent of the total defects determined by TV inspection during the past 5 years were the following:			
Are main line and lateral repairs checked by internal TV inspection after the repair(s) have been made?			

Comments:

VII. B. SSES: Survey and Rehabilitation (general)

Question	Response	Documentation Available	
		Yes	No
Have SSES's been performed in the past? If so, is documentation available?			
Has any sewer rehabilitation work been done in the past 15 years? If so, please describe?			
Does the owner or operator have standard procedures for performing SSES work?			
Do the SSES reports include recommendations for rehabilitation, replacement, and repair?			
Were defects identified in the SSES repaired?			
Does the owner or operator have a multi-year Capital Improvements Program that includes rehabilitation, replacement, and repair?			
How are priorities established for rehabilitation, replacement, and repair?			
Has the owner or operator established schedules for performing recommended rehabilitation, both short term and long term?			
Has funding been approved for the recommended rehabilitation?			
Is post rehabilitation flow monitoring used to assess the success of the rehabilitation?			

Comments:

VII. C. SSES: Sewer Cleaning Related to I/I Reduction

Question	Response	Documentation Available	
		Yes	No
Are sewers cleaned prior to flow monitoring?			
Are sewers cleaned prior to internal T.V. inspection?			
When cleaning, is debris removed from the system?			

Comments:

VII. D. SSES: Flow Monitoring

Question	Response	Documentation Available	
		Yes	No
Does the owner or operator have a flow monitoring program? If so, please describe.			
Does the owner or operator have a comprehensive capacity assessment and planning program?			
Are flows measured prior to allowing new connections?			
Number of permanent meters? Number of temporary meters?			
What type(s) of meters are used?			
Number of rain gauges?			
How frequently are flow meters checked?			
Do the flow meter checks include: <input type="checkbox"/> independent water level, <input type="checkbox"/> checking the desiccant, <input type="checkbox"/> velocity reading, <input type="checkbox"/> cleaning away debris, <input type="checkbox"/> downloading data, <input type="checkbox"/> battery condition?			
Are records maintained for each inspection?			
Do the flow monitoring records include: <input type="checkbox"/> descriptive location of flow meter, <input type="checkbox"/> type of flow meter, <input type="checkbox"/> frequency of flow meter inspection, <input type="checkbox"/> frequency of flow meter calibration?			
Are flow data used for billing, capacity analysis, and/or I/I investigations?			
What is the ratio of peak wet weather flow to average dry weather flow at the wastewater treatment plant?			
Does the owner or operator have any wet weather capacity problems?			
Are low points or flood-plain areas monitored during rain events?			
Does the owner or operator have any dry weather capacity problems?			

VII. E. SSES: Smoke Testing and Dyed Water Flooding

Question	Response	Documentation Available
		Yes No
Does the owner or operator have a smoke testing program to identify sources of inflow and infiltration into the system including private service laterals and illegal connections? If so please describe.		
Are there written procedures for the frequency and schedule of smoke testing?		
Is there a documented procedure for isolating line segments?		
Is there a documented procedure for notifying local residents that smoke testing will be conducted in the area?		
What is the guideline for the maximum amount of line to be tested at one time?		
Are there guidelines for the weather conditions under which smoke testing should be conducted?		
Do the written records contain location, address, and description of the smoking element that produced a positive result?		
What follow-up occurs as a result of positive results for smoke or dye testing?		
Is there a goal for the percent of the system smoke tested each year?		
What percent of the system has been smoke tested over the past year?		
Does the owner or operator have a dyed water flooding program If so please describe.		
Is there a goal for the percent of the system dye tested each year?		
What percent of the system has been dye tested over the past year?		
Does the owner or operator share smoke and dye testing equipment with another owner or operator?		

Comments:

VII. F. SSES: Manhole Inspection

Question	Response	Documentation Available	
		Yes	No
Does the owner or operator have a routine manhole inspection and assessment program?			
What is the purpose of the inspection program?			
Does the owner or operator have a goal for the number of manholes inspected annually?			
How many manholes were inspected during the past year?			
Do the records for manhole/pipe inspection include the following: <input type="checkbox"/> conditions of the frame and cover; <input type="checkbox"/> evidence of surcharge; offsets or misalignments; <input type="checkbox"/> atmospheric hazards measurements; <input type="checkbox"/> details on the root cause of cracks or breaks in the manhole or pipe including blockages; <input type="checkbox"/> recording conditions of corbel, walls, bench, trough, and pipe seals; <input type="checkbox"/> presence of corrosion, if repair is necessary; <input type="checkbox"/> manhole identifying number/location; wastewater flow characteristics; <input type="checkbox"/> accumulations of grease, debris, or grit; <input type="checkbox"/> presence of infiltration, location, and estimated quantity; <input type="checkbox"/> inflow from manhole covers?			
Are manholes susceptible to inflow identified and inspected on a regular frequency?			
Is there a data management system for tracking manhole inspection activities?			
What triggers whether a manhole needs rehabilitation?			
Does the owner or operator have a multi-year Capital Improvements Program that includes rehabilitation, replacement, and repair of manholes?			
How are priorities established for rehabilitation, replacement, and repair of manholes?			
Has the owner or operator established schedules for performing rehabilitation, both short term and long term of manholes?			

Question	Response	Documentation Available	
		Yes	No
Has funding been approved for the rehabilitation of manholes?			
Does the owner or operator have a grouting program?			

Comments:

VIII. A. Rehabilitation: Manhole Repairs

Question	Response	Documentation Available	
		Yes	No
What rehabilitation techniques are used for manhole repairs?			
How are priorities determined for manhole repairs?			
What type of documentation is kept?			
Does the owner or operator use manhole inserts?			
Are they used system wide or only on low lying manholes?			

Comments:

VIII. B. Rehabilitation: Mainline Sewers

Question	Response	Documentation Available	
		Yes	No
What type of main line repairs has the owner or operator used in the past?			
Does the owner or operator currently use any of above techniques for main line repairs? What other techniques is the owner or operator presently using?			
How are priorities established for main line repairs?			
What type of follow-up is performed after the repair (e.g., CCTV)?			

Comments:

EXAMPLE

COLLECTION SYSTEM PERFORMANCE INDICATOR DATA COLLECTION FORM

I. General Information

- A. Agency Name _____
- B. Agency Address
Street _____
City _____ State _____ Zip _____
- C. Contact Person _____
- D. Telephone: Voice _____ Fax _____ Email _____
- E. Data provided for latest fiscal/calendar year, 20____

II. Collection System Description

- A. Service Area _____ Square miles
- B. Population Served _____
- C. System Inventory _____

Miles of gravity sewer	Miles of force main	Number of maintenance access structures	Number of pump stations	Number of siphons	Number of air, vacuum, or air/vacuum relief valves

- D. Number of Service Connections:
Residential _____ Commercial _____ Industrial _____ Total _____
- E. Lateral Responsibility (check one)
1. At main line connection only _____
 2. From main line to property line or easement/cleanout _____
 3. Beyond property line/cleanout _____
 4. Other _____
- F. System combined (storm and sanitary)? Yes ___ No ___ If yes, % combined ____
- G. Average Annual Precipitation _____ inches
- H. System Flow Characteristics (total for service area)

Peak Dry Weather Flow (MGD)	Peak Wet Weather Flow (MGD)	Average Daily Flow (MGD)

III. Special Conditions

A. Indicate local conditions that are accounted for during design, construction, operation, and maintenance of the collection system.

1. Precipitation: Yes ____ No ____ If yes, provide brief explanation ____

2. Terrain: Yes ____ No ____ If yes, provide brief explanation ____

3. Soils: Yes ____ No ____ If yes, provide brief explanation ____

4. Temperature: Yes ____ No ____ If yes, provide brief explanation ____

5. Groundwater: Yes ____ No ____ If yes, provide brief explanation ____

6. Geology: Yes ____ No ____ If yes, provide brief explanation ____

7. Other: ____

B. Is corrosion a significant problem? Yes ____ No ____

• Is there a corrosion control program in place? Yes ____ No ____

C. Is odor a significant problem? Yes ____ No ____

• Is there an odor control program in place? Yes ____ No ____

D. Is grease a significant problem? Yes ____ No ____

• Is there a grease control program in place? Yes ____ No ____

E. Are roots a significant problem? Yes ____ No ____

• Is there a root control program in place? Yes ____ No ____

IV. Age Distribution of Collection System

Age	Gravity Sewer, miles	Force Mains, miles or feet	Number of Pump Stations
0 - 25 years			
26 - 50 years			
51 - 75 years			
> 76 years			

V. Size Distribution of Collection System

Diameter in inches	Gravity Sewer, miles	Force Mains, miles or feet
8 inches or less		
9 - 18 inches		
19 - 36 inches		
> 36 inches		

VI. Distribution of Gravity Sewer By Material

- A. Vitrified Clay Pipe (VCP) _____ Miles
- B. Reinforced Concrete Pipe (RCP) _____ Miles
- C. Unreinforced Concrete Pipe (CP) _____ Miles
- D. Plastic (all types) _____ Miles
- E. Brick _____ Miles
- F. Other _____ Miles
- G. Other _____ Miles
- H. Other _____ Miles

VII. Distribution of Force Mains By Material

- A. Reinforced Concrete Pipe (RCP) _____ (circle one) miles or feet
- B. Prestressed Concrete Cylinder Pipe (PCCP) _____ miles or feet
- C. Asbestos Cement Pipe (ACP) _____ miles or feet
- D. Polyvinyl Chloride (PVC) _____ miles or feet
- E. Steel _____ miles or feet
- F. Ductile Iron _____ miles or feet
- G. Cast Iron _____ miles or feet
- H. Techite (RPMP) _____ miles or feet
- I. High Density Polyethylene (HDPE) _____ miles or feet
- J. Fiberglass Reinforced Plastic (FRP) _____ miles or feet
- K. Other _____ miles or feet

VIII. Preventive Maintenance of System

A. Physical Inspection of Collection System, Preventive Maintenance

Inspection Activity	Total Annual Labor Hours Expended for This Activity	Total Completed (Miles of Pipe or Manholes Inspected Annually)	Crew Size (s)
CCTV			
Visual Manhole Inspection, Surface Only			
Visual Manhole Inspection, Remove Cover			
Visual Gravity Line Inspection, Surface Only			
Visual Force Main Inspection, Surface Only			
Other (Sonar, etc.)			

B. Mechanical and Hydraulic Cleaning, Preventive Maintenance

Cleaning Activity	Total Annual Labor Hours Expended for This Activity	Total Annual Labor Hours Expended for Scheduled PM	Total Miles Cleaned Annually	Crew Size (s)	Range of Pipe Diameters Cleaned
Hydraulic Jet					
Bails, Kites, Scooters					
Combination Machines					
Rod Machines					
Hand Rodding					
Bucket Machines					
Chemical Root Control					
Chemical or Biological Grease Control					

IX. Dry Weather Stoppages

- A. Number of stoppages, annually _____
- B. Average time to clear stoppage _____
- C. Number of stoppages resulting in overflows and/or backups annually _____
- D. Total quantity of overflow(s) _____
- E. Is there an established procedure for problem diagnosis? Yes ____ No ____
- F. Are future preventive measures initiated based on diagnosis? Yes ____ No ____
- G. What equipment is available for emergency response? _____

X. Repairs and Rehabilitation, Proactive

- A. Number of annual spot repairs identified _____
- B. Number of annual spot repairs completed _____
- C. Percent of spot repairs contracted _____
- D. Number of manholes identified for rehabilitation _____
- E. Number of manholes rehabilitated annually _____
- F. Percent of manhole repairs contracted _____
- G. Feet of main line needing rehabilitation _____
- H. Feet of main line rehabilitated _____
- I. Percent of main line rehabilitation contracted _____
- J. Number of manholes scheduled for rehabilitation under Capital Improvement Program (s) _____
- K. Feet of main line scheduled for rehabilitation under Capital Improvement Program (s) _____

XI. Repairs and Rehabilitation, Reactive

- A. Number of annual line features _____
- B. Number of line repairs _____

XII. Pump Stations

- A. Number of pump stations inspected _____
 - Frequency of inspections _____ (daily, every other day, weekly)
- B. Number of inspection crews _____
- C. Crew size _____
- D. Number of pump stations with pump capacity redundancy _____
- E. Number of pump stations with backup power sources _____
- F. Number of pump stations with dry weather capacity limitations _____
- G. Number of pump stations with wet weather capacity limitations _____
- H. Number of pump stations calibrated annually _____
- I. Number of pump stations with permanent flowmeters _____
- J. Number of pump stations with remote status monitoring _____
- K. Number of pump stations with running time meters _____
- L. Number of mechanical maintenance staff assigned to mechanical maintenance _____
- M. Number of electrical maintenance staff assigned to electrical maintenance _____
- N. Total labor hours scheduled annually for electrical and mechanical PM tasks _____
- O. Total labor hours expended annually for electrical and mechanical PM tasks _____

XIII. Pump Station Failures, Dry Weather

- A. Number of failures resulting in overflows/bypass or backup, annually _____
- B. Total quantity of overflow/bypass _____ Gallons or MG
- C. Average time to restore operational capability _____ hours
- D. Total labor hours expended for electrical and mechanical corrective maintenance tasks _____
- E. Is failure mode and effect diagnosed? Yes ____ No ____
- F. Are future preventive measures initiated based on diagnosis? Yes ____ No ____
- G. What equipment is available for emergency response? _____

XIV. Force Mains

- A. Force mains inspected annually _____ miles or feet (visual surface inspection of alignment)
- B. Force mains monitored annually _____ miles or feet (pressure profile, capacity)
- C. Number of force main failures annually _____
- D. Cause(s) of force main failures _____

XV. Air Relief/Vacuum Valves

- A. What is frequency of valve inspections? _____
- B. What is frequency of PM (backflushing, etc)? _____
- C. Number of annual valve failures _____
- D. Cause(s) of valve failures _____

XVI. System Operation and Maintenance Efficiency

- A. Total full time or full time equivalent staff assigned to O & M (excluding administration staff but including line managers, supervisors) _____
- B. Total estimated labor hours actually expended for active O & M tasks (this is the total above less hours for sick, vacation, holidays, training, breaks, etc., not directly related to performing O & M tasks) _____

XVII. Level of Service

- A. Average annual rate for residential users _____
- B. Rate based on: water consumption _____ Flat rate _____ Other _____
- C. Number of complaints annually _____
- D. Number of complaints that are agency responsibility _____
- E. Number of public health or other warnings issued annually _____
- F. Number of claims for damages due to backups annually _____
- G. Total cost of claims settled annually _____

XVIII. Financial

- A. Total annual revenue received from wastewater _____
 - 1. % of revenue for long-term debt _____
 - 2. % of revenue for treatment and disposal _____
 - 3. % of revenue for collection and conveyance _____
- B. Current value of collection system assets _____
- C. Annual O & M expenditure _____
- D. Annual CIP expenditure for repair, replacement, or rehabilitation _____
- E. Annual O & M training budget _____
- F. Total number of O & M personnel (including administrative in O & M department) _____
- G. Number of personnel with collection system certification _____
- H. Number of personnel qualified for collection system certification _____
- I. Amount of O & M budget allocated for contracted services _____
- J. Hydroflush cost per foot _____
- K. Rodding cost per foot _____
- L. Bucketing cost per foot _____
- M. CCTV cost per foot _____
- N. Spot repairs, cost each _____

XIX. Safety

- A. Total labor hours assigned to O & M _____
- B. Number of lost time injuries _____
- C. Total lost time days _____
- D. Total cost of lost time injuries _____

XX. Regulatory

- A. Total number of violations issued annually _____
- B. Total cost of fines paid annually _____
- C. What is minimum reportable quantity in gallons? _____
- D. What is time reporting requirement? _____
- E. Number of annual WWTP upsets due to wet weather flow _____

XXI. General

- A. Has SSES been performed on system? Yes _____ No _____
- B. Total O & M positions currently budgetd _____
- C. Total O & M positions currently filled _____
- D. Is computerized maintenance management system (s) used for O & M managing? Yes ____ No ____
- E. Is GIS system used for O & M managing? Yes _____ No _____

XXII. Procedures or Other Documentation Available

- A. Overflow, bypass and containment Yes _____ No _____
- B. Problem evaluation and solution Yes _____ No _____
- C. Cleanup procedure Yes _____ No _____
- D. Failure mode and effect procedure Yes _____ No _____
- E. O & M budget process Yes _____ No _____
- F. O & M budget with line item detail Yes _____ No _____
- G. Long-range CIP planning for system expansion, rehabilitation, and replacement Yes _____ No ____
- H. Is there a written procedure for cleanup to mitigate effect of overflow? Yes _____ No _____
- I. Is there a written procedure for containing overflows and bypasses? Yes _____ No _____
- J. Is there an established procedure for containing overflows and bypasses? Yes _____ No _____
- K. Is there an established procedure for problem evaluation and solution? Yes _____ No _____
- L. Is there an established procedure for cleanup to mitigate effect of overflow? Yes _____ No _____
- M. Is there a grease control program? Yes _____ No _____
- N. Is there a pretreatment program? Yes _____ No _____
- O. Is there a private source I/I reduction program? Yes _____ No _____
- P. Do you have chronic O & M problems that are designed into your system? Yes _____ No _____
If yes, provide brief description _____
- Q. Do you have chronic O & M problems that are constructed into your system? Yes _____ No ____
If yes, provide brief description _____
- R. How would you rate your construction inspection program?
Very effective _____ Needs improvement _____ Poor _____

XXIII. Definitions/Clarifications

- A. Maintenance access structures, most commonly manholes, in your system that are incorporated into your O & M program.
- B. Pump capacity redundancy is the ability to maintain pumping at design capacity with the largest pump out of service.
- C. Remote status monitoring is any remote monitoring system such as alarm telemetry or SCADA that provides remote pump station status information.
- D. You will notice that in the section on stoppages and pump station failures, we are asking for dry weather incidents only. Dry weather system performance is a good indicator or effectiveness of O & M program. If you have wet weather information that you wish to provide also, please do.
- E. Under the Special Conditions sections we are identifying conditions that are present in your system that require consideration during design, construction, and O & M of your system.

- F. Any of the questions dealing with labor hours are designed to determine total labor hours irrespective of crew size or crews that are only assigned to cleaning, for example, less than full time.
- G. Our goal is to obtain data that can be or are standardized and that are accurate. We also realize that some data may not be available; however, data can be accurately estimated. If you estimate data please follow with an (E).
- H. If data is not available please indicate "NA." If data does not apply to your system, please indicate by "DNA."
- I. Failure mode and effect refers to any established procedure you have to diagnose system failures to determine the cause and effect of the failure. This can apply to crews clearing stoppages or to pump station failures.
- J. Pump station inspection (XII) means scheduled inspection by operators to verify station operation and perform PM. It excludes electrical or mechanical craft maintenance.
- K. Stoppage in section IX refers only to stoppages other than pump stations. Pump stations are covered in Section XIII. Backup in this case refers to a basement or other structure backup as opposed to main line sewer backup.

XXIV. Additional Comments

Appendix B

EXAMPLE INTERVIEW SCHEDULE AND TOPICS

EXAMPLE INTERVIEW SCHEDULE AND TOPICS

Days 1 and 2 Interviews

Work Practice or Maintenance Function	Description	Examples of Discussion Topics and Supporting Documents	Name	Interview Date, Time, and Location
Senior Management	<p>Discuss project expectations, report review and comment process.</p> <p>Overview of organizational structure and "culture".</p> <p>Identify sensitive issues and how to approach.</p> <p>Schedule</p>			
Project Kick off Meeting	<p>Overview and purpose of project.</p> <p>Interview and field assessment process.</p> <p>Report content and review process.</p> <p>Questions and answers</p>	None		
Physical Inspection and Testing – Gravity sewer system	<p>Visual Inspection, pipe alignment.</p> <p>CCTV</p> <p>Smoke and Dye Testing</p> <p>Other</p>	<p>Reports, inspection forms, performance data, inspection strategy, crew assignments and schedules, equipment available, current expenditures and budgeted amounts, area maps, Standard Operating Procedures, field maps.</p>		

Work Practice or Maintenance Function	Description	Examples of Discussion Topics and Supporting Documents	Name	Interview Date, Time, and Location
Preventive Maintenance - Mechanical and hydraulic cleaning	High velocity jets and combination machines. Other hydraulic methods Rodding Machines Bucket Machines	Reports, performance data, preventive maintenance cleaning strategy, crew assignments and schedules, equipment available, current and budgeted, problem areas, Standard Operating Procedures, Standard Maintenance Procedures, problem diagnosis		
Chemical and biological cleaning	Root control Grease control Odor control Corrosion control	Grease control ordinance, enforcement, odor and corrosion control strategy, root control program, design for O&M considerations, materials used (MSDS), reports, performance data, preventive maintenance cleaning strategy, crew assignments and schedules, equipment available, current and budgeted, problem areas, Standard Operating Procedures, Standard Maintenance Procedures, problem diagnosis, public education, enforcement		
Pump Stations	Routine inspection Electrical and mechanical maintenance SCADA Standby/emergency systems Valves Forcemains	Logs, inspection sheets, Standard Maintenance Procedures, Standard Operating procedures, pump station inventory and attribute data base, spares inventory, Reports, performance data, preventive maintenance strategy, crew assignments and schedules, equipment available, current and budgeted, critical pump stations, Standard Operating Procedures, Standard Maintenance Procedures, problem diagnosis, preventive and predictive maintenance methods, maintenance tasks and frequencies, O&M manuals, capacity issues		

Work Practice or Maintenance Function	Description	Examples of Discussion Topics and Supporting Documents	Name	Interview Date, Time, and Location
Training and Certification	Training program, technical, supervisory and management. Certification program	Knowledge, skills and abilities, basic skills, career paths, minimum qualifications, certification, educational assistance program, internal and external training, OJT, training budget		
Work Management	Planning and scheduling work Materials management Priority Backlog management Procurement Manual or Computer Maintenance Management System (CMMS)	Complaints and emergencies normal hours and after hours. Corrective, preventive and predictive maintenance work orders, work backlog, labor utilization, reports,		

Work Practice or Maintenance Function	Description	Examples of Discussion Topics and Supporting Documents	Name	Interview Date, Time, and Location
Safety	<p>Safety committee</p> <p>Safety meetings</p> <p>Safety enforcement</p> <p>Documentation of comprehensive safety training</p> <p>Compliance with safety regulations</p> <p>Documentation of effectiveness of safety program (e.g., reduction of accidents)</p> <p>Documentation of attendance and learning at safety training sessions</p>	Policy and procedures for trenching, confined space, lockout tagout, PPE. Safety manual, formal training, tracking, accident investigation		
Financial	<p>Annual O&M Budget</p> <p>Rates</p> <p>CIP for rehabilitation/rehab</p> <p>Non-enterprise fund allocations</p>	O&M budget process, line item accounts, five year CIP plan, repair, rehabilitation, replacement strategy for pipes and pump stations		

Work Practice or Maintenance Function	Description	Examples of Discussion Topics and Supporting Documents	Name	Interview Date, Time, and Location
Construction and Repair	Emergency repair	Reports, inspection forms, performance data, inspection strategy, crew assignments and schedules, equipment available, current and budgeted, area maps, Standard Operating Procedures, field maps,		
	Spot repairs, gravity system			
	Rehabilitation			
	Lateral installation			
	Inspection			
	New Construction			
Fleet Management	Testing	Inventory, repair and replacement process, maintenance turn around time, preventive maintenance, Standard Operating Procedures, Standard Maintenance Procedures, CMMS,		
	Maintenance			
	Replacement			
	Availability			
	Budgeting			

Day 3 - Field

Pump Stations

Work Practice or Maintenance Function	Description	Examples of Discussion Topics and Supporting Documents	Name	Interview Date, Time and Location
Pump Station Maintenance	Submersible Cast in place wet well dry well Prefabricated Grinder/Low Pressure System	Logs, O&M manuals, on-site procedures, vehicles and equipment, SCADA, Supervisory controls, electrical systems, flow meters, HVAC, variable speed systems, chronic problems, pumps and hydraulic systems.		

Day 4 – Field

Facilities and Crews

Work Practice or Maintenance Function	Description	Examples of Discussion Topics and Supporting Documents	Name	Interview Date, Time and Location
Facilities	Electrical and mechanical repair shops and equipment Warehouse and equipment storage areas Vehicle maintenance shops Crew areas; locker rooms, training areas, dispatch areas	Logs, O&M manuals, on-site procedures, vehicles and equipment, SCADA, Supervisory controls, electrical systems, flow meters, HVAC, variable speed systems, chronic problems, pumps and hydraulic systems,		
Crews	CCTV Cleaning Construction Repair	N/A		
Exit Interview	Overview of findings for week	None		

Appendix C

INFORMATION SOURCES

Information Sources
(Updated November 2004)

WEBSITES (water and/or wastewater-oriented; financial related)

EPA National Compliance Assistance Clearinghouse	www.epa.gov/clearinghouse
Compliance Assistance Centers	http://www.assistancecenters.net
Construction Industry Compliance Assistance Center	www.cicacenter.org
EPA NPDES website	http://www.epa.gov/npdes
EPA Operator On-Site Technical Assistance Program-104(g) (hands-on assistance to small municipal WWTP operators at no cost to community)	www.epa.gov/owm/mab/smcomm/104g/sstc.htm
EPA Office of Wastewater Management	www.epa.gov/owm
EPA Clean Water Tribal Grant Program	www.epa.gov/owm/mab/indian/cwisa.htm
EPA Colonias Program	www.epa.gov/owm/mab/mexican
EPA Clean Water State Revolving Loan Fund Program	www.epa.gov/owm/cwfinance/cwsrf
EPA Website (Headquarters & Regions)	www.epa.gov/
EPA Small Business Gateway	http://www.epa.gov/smallbusiness
Environmental Finance Center	http://sspa.boisestate.edu/efc
National Environmental Services Center/WV University	www.nesc.wvu.edu
Local Govt. Environmental Assistance Network	www.lgean.org
Rural Community Assistance Program (RCAP)	www.rcap.org
Water Environment Federation (WEF)	www.wef.org
AMSA	www.amsa-cleanwater.org/pubs/
American Water Works Assoc. (AWWA)	http://www.awwa.org/
National Association of Towns & Townships (NATAT)	http://www.natat.org/

PUBLICATIONS /TRAINING VIDEOS /NEWSLETTERS, etc.

EPA National Service Center For Environmental Publications (NSCEP)
USEPA/NSCEP
PO Box 42419
Cincinnati, OH 45242
Tele: 1-800-490-9198 or 513-489-8190 (fax: 513-489-8695)

EPA Office of Water Resource Center
Tele: 202-566-1729 (24 hours)
center.water-resources@epa.gov

National Environmental Services Center (formerly the National Small Flows Clearinghouse)
West Virginia University Small Business Gateway
P.O. Box 6064
Morgantown, WV 26506
Tele: 1-800-624-8301

California State University - Sacramento
Tele: 916-278-6142
(training videos, etc.)

List Compiled by Sharie Centilla, USEPA/OECA
centilla.sharie@epa.gov
33

REFERENCES

California State University (CSU) Sacramento. 1996. Operation and Maintenance of Wastewater Collection Systems. Volume I, Fifth Ed. Prepared for EPA, Office of Water Programs Operations. Sacramento, CA: California State University, Sacramento Foundation.

California State University (CSU) Sacramento. 1998. Operation and Maintenance of Wastewater Collection Systems. Volume II, Fifth Ed. Prepared for EPA, Office of Water Programs Operations. Sacramento, CA: California State University, Sacramento Foundation.

U.S. EPA National Enforcement Investigations Center (NEIC). 1992. Multi-media Investigations Manual. EPA-330/9-89-003-R.

U.S. Environmental Protection Agency. 1974. "Process Design Manual for Sulfide Control in Sanitary Sewerage Systems." Prepared for the Technology Transfer Office of the U.S. Environmental Protection Agency. EPA 625/1-74-005. pg. 3-27.

U.S. EPA Office of Water. 1973. *Manpower Requirements for Wastewater Collection Systems in Cities and Towns of up to 150,000 Population*. EPA-832-R-73-104.

U. S. EPA Office of Water. 1974. *Manpower Requirements for Wastewater Collection Systems in Cities of 150,000 to 500,000 Population*. EPA-832-R-74-102.

U.S. EPA Office of Water. 1983. *Procedures Manual for Reviewing a POTW Pretreatment Program Submission*. EPA-833-B-83-200.

U.S. EPA Office of Water. 1985. *Design Manual: Odor and Corrosion Control in Sanitary Sewerage Systems and Treatment Plants*. EPA-625-1-85-018.

U.S. EPA Office of Water. 2004. NPDES Compliance Inspection Manual. EPA-305-X-03-004.

U.S. EPA Office of Water. 2004. *Report to Congress: Impacts and Controls on CSOs and SSOs*. EPA-833-R-04-001.

Water Environment Federation. 1994. *Existing Sewer Evaluation & Rehabilitation*: WEF Manual of Practice FD-6, ASCE Manuals and Reports on Engineering Practice No. 62. Alexandria, VA: WEF.

**EPA Region 4
Guide to
Collection and Transmission System
Management, Operation, and Maintenance Programs**

Version 1.1



PURPOSE & DISCLAIMER

This document is the work product of the EPA Region 4, Water Protection Division, Clean Water Enforcement Branch (CWEB) and supercedes a previous draft dated September 2003 (Version 1.0). This document serves as an introduction for new Region 4 inspectors in the CWEB Municipal Infrastructure Enforcement Program and contains descriptive information for utilities conducting self-assessments in the Region 4 Management, Operation, and Maintenance (MOM) Programs Project.

The MOM Programs Project is conducted in compliance with EPA Policy, EPA Guidance, and Rules and Regulations promulgated under the Clean Water Act. If some statement or part of the document is not in compliance with the Act, EPA Policy, EPA Guidance or the Rules and Regulations, then it should not be construed as conveying rights not conveyed by the Clean Water Act, EPA Policy, or the Rules and Regulations.

October 2011

TABLE OF CONTENTS

Contents

INTRODUCTION	1
SYSTEM PROFILE AND PERFORMANCE SUMMARY	4
MANAGEMENT PROGRAMS	6
1. Organization.....	6
a. Organizational Chart	6
b. Relation to Other Municipal Functions.....	6
2. Training.....	6
a. Technical Training Program.....	6
b. Skills Training Program	6
c. Safety Training Program	7
3. Safety	7
a. Safety Authority	7
b. Confined Space Program	7
c. General Safety Procedures Program	7
d. Traffic Management Procedures Program	7
e. Lock-Out/Tag-Out Program	7
f. Safety Equipment Program	7
g. Safety Performance Program	8
4. Information Management Systems (IMS).....	8
a. Management Programs IMS.....	8
b. Operation Programs IMS	8
c. Maintenance Programs IMS	8
d. Customer Service IMS	8
5. Engineering	8
a. Collection and Transmission System Plans Program.....	8
b. System Inventory Program.....	9
c. Mapping Program.....	9
d. Sewer System Design Program.....	9
e. New Construction and Rehabilitation Inspection Program	9
f. Acquisition Considerations Program	9

g. Continuous Sewer System Assessment Program	9
h. Infrastructure Rehabilitation Program	11
i. System Capacity Assurance Program	11
6. Overflow Tracking.....	12
a. State Agency Reporting Program.....	12
b. Local Agency Reporting Program	12
c. Records Management Program	12
7. Financial Analyses	12
a. Cost Analysis Program.....	12
b. Capital Improvement Financing Program.....	12
c. Budget and Customer Rate Program	13
8. Equipment and Supplies	13
a. Spare Parts Inventory Program	13
b. Equipment and Tools Inventory Program	13
c. Vehicle Repair Program	13
9. Customer Service	13
a. Complaint Management Program	13
b. Public Information Program.....	13
c. Public Education Program.....	13
10. Legal Support.....	14
a. Inter-Jurisdictional Agreement Program	14
b. Sewer Ordinance Program	14
11. Water Quality Monitoring.....	14
a. Routine Monitoring Program	14
b. Investigative Monitoring Program	14
c. Impact Monitoring Program.....	14
12. Contingency Plan for Utility Infrastructure	15
a. Contingency Planning Program	15
b. Response Flow Diagram	16
OPERATION PROGRAMS	17
1. Pump Station Operation.....	17
a. Preventive Operation Program	17
b. Reactive Operation Program	17

2. Pretreatment Program	17
3. Corrosion Control Program.....	17
4. Fats, Oils, and Grease Control Program	17
5. Service Connection/Disconnection Program	18
6. Private Haulers Program	18
7. Line Location Program	18
MAINTENANCE PROGRAMS	19
1. Pump Station Preventive Maintenance	19
a. Pump Station Repair Program.....	19
b. Electrical Maintenance Program	19
c. Mechanical Maintenance Program.....	19
d. Physical Maintenance Program.....	19
2. Gravity Line Preventive Maintenance	19
a. Routine Hydraulic Cleaning Program	19
b. Routine Mechanical Cleaning Program	19
c. Root Control Program	20
d. Manhole Preventive Maintenance Program	20
3. Air Valve Preventive Maintenance Program	20
4. Maintenance of Way	20
a. Maintenance of Rights-of-Way and Easements Program	20
b. Street Paving Monitoring Program	20
5. Reactive Maintenance Program	20

INTRODUCTION

A utility should develop an appropriate, comprehensive Management, Operation and Maintenance (MOM) Program for the sewerage infrastructure (sewer system and wastewater treatment plant) which it owns and operates. A comprehensive MOM Program is comprised of individual management, operation, and maintenance programs, each of which:

- is specific to, and tailored for, the utility's infrastructure;
- has a written purpose explaining why the program is needed; has specific written goal(s) establishing the accomplishment(s) desired for the current fiscal year;
- has the details of the activities and procedures that are followed to implement the program written down in the form of Standard Management Procedures (SP), Standard Operating Procedures (SOP), and/or Standard Maintenance Procedures (SMP) that are used by the utility's personnel;
- is implemented by well-trained personnel; has established appropriate performance measures which are tracked by management; and,
- has a written procedure requiring periodic review, evaluation, and any necessary revision.

An important concept is that MOM programs are utility-specific. Most, if not all, of the programs described in this guide are based on actual programs observed at proactive utilities. However, utilities may have different titles for the various MOM programs described in this guide and may have them organized very differently. Some utilities may be organized in a way that they consolidate some of the MOM programs described in this guide, or they may exclude part of a program described in this guide because of justifiable circumstances. Utilities may also have additional MOM programs that are not contained in this guide.

Tailored to the Utility

The utility should have programs tailored to match its geographic, physical, and climatic conditions; level of complexity; infrastructure configuration; and level of sophistication. Utilities may also have a number of their MOM programs implemented through a managed contract rather than by their own trained personnel.

Program Purpose

The purpose of a given MOM program is the reason why the program is needed and why it exists.

Example: The purpose our utility's smoke testing program is to identify sources of inflow our sewer system that need to be eliminated so that we can regain some of our peak flow capacity.

Program Goal

The individual program goal(s) establishes the accomplishments desired for the given MOM program during the upcoming fiscal year.

Example: The goal our smoke testing program for this fiscal year is to reclaim system peak

capacity, and to reduce treatment plant hydraulic loading by identifying sources of inflow to the system by conducting investigations in the ABC and DEF sewersheds. This goal will be accomplished in a cost-effective manner using our personnel and by using a contractor.

Program Documentation

The program documentation specifies, in writing, the specific details of the activities and procedures that personnel follow to implement the program. Program documentation should be maintained in a central location and made available to all personnel.

Example: Our utility has a long-term, ongoing, smoke testing program. The program priorities and standard operating procedures are contained in a manual entitled "Smoke Testing Program for Utility X."

Implemented by Trained Personnel

Training programs are established and followed to ensure that utility personnel are well-trained to implement each program and successfully achieve each program's goals.

Example: All personnel assigned to our smoke testing activity receive three hours of basic training followed by eighty (80) hours of on-the-job training to assure competency. Our contract with outside sources to conduct smoke testing requires the contractor to follow our standard operating procedures.

Performance Measures

Appropriate performance measures should be established for each program and reviewed at minimum on an annual basis.

Example: During this fiscal year, the performance goal is to smoke test 200,000 lineal feet of gravity sewer in two sewersheds selected according to our priority procedures. Last year, we exceeded our performance goal of 178,000 lineal feet of gravity sewer by smoke testing 193,000 lineal feet. As a result, 623 defects were identified and passed on to our rehabilitation and private service lateral programs for correction.

Periodic Evaluation

An evaluation by utility management should occur for each program, annually at minimum, to evaluate how well a program accomplished the program goals established at the beginning of the period and to determine whether the program, as presently implemented, is using the most efficient approach. Remedies should be identified and scheduled to correct any deficiencies. Questions the evaluation should answer are:

- Are there program design, resource or implementation deficiencies that keep the program from achieving its performance measures?
- Are these program deficiencies leading to sanitary sewer overflows, permit violations or other

Clean Water Act violations?

- Are there program deficiencies leading to decreased customer service and/or unwarranted deterioration of utility assets?
- Are there changes that should be made to the program that will make its implementation more efficient, thereby conserving resources for better implementation of other programs?

Example: The smoke testing program has yielded good results during the past four years. Following our priority criteria, most of the significant inflow problems have been eliminated. Next year the program will be reduced by 25% and the resources applied to our maintenance of way program. Peak flows will be monitored at key locations to determine if this reduction in the smoke testing program will need to be reversed in the future. Additionally, we are conducting a cost analysis to determine whether we should contract out for all smoke testing work in the future.

SYSTEM PROFILE AND PERFORMANCE SUMMARY

A proactive utility will maintain a profile of its system as a basis for explaining its situation to regulatory agencies, the public, and when networking with other utilities. A profile typically contains basic population and inventory information as well as a recent system performance summary. An example of a system performance summary is provided on the following page.

Population Served:

Number of Customers:

Number of Treatment Plants:

Total Wastewater Design Treatment Capacity:

Total Volume of Wastewater Treated:

Miles of Gravity Sewers:

Number of Manholes:

Number of Inverted Siphons:

Number of Pump Stations:

Miles of Force Main:

Number of Employees:

Annual Capital Improvement Budget:

Annual Operation and Maintenance Budget: ...

Total Annual Operating Budget:

System-Wide MOM Programs Recent Performance Summary												
Performance Measures for Previous 12 Months		Year	Month									
A. Number of Customer Complaints												
B. Number of NPDES Permit Violations												
C. Number of Capacity-Related Overflows												
D. Number of Maintenance-Related Overflows												
E. Number of Operations-Related Overflows												
F. Number of Blockages												
G. Number of Cave-Ins												
H. Number of Pump Station Failures												
I. Peak Flow Factor at Treatment Plant (1 hour high/dry month avg.)												
J. Monthly Average Treatment Plant Flow Rate (gal/capita/day)												
K. Monthly High One Day Treatment Flow Rate (gal/capita/day)												
L. Number of By-Passes at Treatment Plant												
M. Volume of Treatment Plant By-Passes (gal)												
N. WWTP Weekly Average Influent BOD (mg/L)												

MANAGEMENT PROGRAMS

1. Organization

a. Organizational Chart

An organizational chart clearly depicts all units in the organization, the lines of authority between the various organization units, a description of the functions of each of the organization units, the title and duties of each position in the organization units and an indication of whether or not each position is currently budgeted and filled.

b. Relation to Other Municipal Functions

An organizational chart clearly depicts the relationship of the sewerage utility to other municipal functions such as public works, streets and drainage, building inspection, building permits, and public health. There is a mechanism for updating the chart in manner timely to changes which may occur in the organization.

2. Training

a. Technical Training Program

This program specifies requirements (curriculum) for initial and refresher training to ensure each employee has a level of knowledge, commensurate with duties, of the overall functions of the utility's infrastructure. This program also includes outside technical training and networking opportunities, such as conferences and seminars, that are made available to employees.

The program includes the extent to which employee certification, at either the State or the utility's organization level, is required as a basis for obtaining or maintaining a position. Records of technical training are maintained and the degree to which completed technical training is tied to promotion and pay is specified. Finally, the program specifies the technical training required before an employee is permitted to undertake specific work assignments or tasks.

b. Skills Training Program

This program specifies requirements (curriculum) for initial and refresher training to ensure each employee has a level of knowledge, commensurate with duties, of the specific equipment to be used and the procedures to be followed in carrying out duties. This program should include outside skills training opportunities, such as manufacturers' or vendors' training workshops, that are made available to employees.

The program includes the extent to which employee certification, at either the State or the utility's organization level, is required as a basis for obtaining or maintaining a position. Records of skills training, whether formal or on-the-job apprenticeship, are maintained and the degree to which completed training is tied to promotion and pay is specified. Finally, the program specifies the skills and on-the-job training required before an employee is permitted to undertake specific work assignments or tasks.

c. Safety Training Program

This program specifies requirements (curriculum) for initial and refresher training to ensure each employee has an adequate level of knowledge regarding on-the-job safety. The program includes the extent to which employee safety certification at the State or at the utility's organization level is required as a basis for obtaining or maintaining a position. Records of safety training, including on-the-job safety meetings, are maintained. Finally, the program specifies the safety training required before an employee is permitted to undertake specific work assignments or tasks.

3. Safety

a. Safety Authority

A Safety Authority (whether a safety department, safety committee, safety officer, or similar mechanism) is present to establish utility safety policy, oversee compliance, and maintain the overall Safety Program. Program maintenance includes specifying safety resources needed for utility activities, assuring record of appropriate standard reporting forms, and establishing a Safety Review Board if appropriate.

b. Confined Space Program

This program provides marking for confined spaces, and uses a permitting system and written standard procedures for confined space entry.

c. General Safety Procedures Program

This program provides instruction in defensive driving, first aid, CPR, personal sanitation, personal protection clothing, and similar general work-related safety issues.

d. Traffic Management Procedures Program

This program provides for standard traffic management techniques, off-hour scheduling of line work, and coordination with law enforcement.

e. Lock-Out/Tag-Out Program

This program provides signs on equipment involved in the program, limitation to authorized personnel, required tag information, and permit requirements.

f. Safety Equipment Program

This program assures the availability of appropriate safety equipment such as tripods and hoists, well-calibrated atmospheric testing equipment, self-contained breathing apparatuses, lights and barricades, exhaust fans, and personal protective clothing.

g. Safety Performance Program

This program tracks parameters such as number of injuries, lost days, and workman's compensation claims to be used by management to assess Safety Program effectiveness.

4. Information Management Systems (IMS)

a. Management Programs IMS

This information management system enables utility management to adequately evaluate operation, maintenance, customer service (complaint response), and system rehabilitation activities so that overall system performance can be determined and utility planning can be conducted.

b. Operation Programs IMS

This information management system is used to track scheduled operational activities and to enhance operational performance. The system ensures timely production of operating reports and standardized data collection methods are used by field personnel (e.g., forms or PDA files). The system requires data review by the field supervisor and securely preserves operating records. While the system need not be computer-based, it should be capable of feeding information to the Management Programs IMS.

c. Maintenance Programs IMS

This information management system is used to track scheduled maintenance activities and to enhance maintenance performance. The system ensures timely production of maintenance reports and standardized data collection methods are used by field personnel (e.g., forms or PDA files). The system requires data review by the field supervisor and securely preserves maintenance records. While the system need not be computer-based, it should be capable of feeding information to the Management Programs IMS.

d. Customer Service IMS

This information management system is used to track reactive activities (i.e., emergencies or customer complaints) and to enhance customer service. The system ensures timely production of complaint reports and standardized data collection methods are used by field personnel (e.g., work order forms or PDA files). The system requires data review by the field supervisor and securely preserves service records. While the system need not be computer-based, it should be capable of feeding information into the Management Programs IMS.

5. Engineering

a. Collection and Transmission System Plans Program

This program ensures a full set of as-built plans for the collection and transmission system are available, field crews have ready access to the plans, and a written standard procedure is present to account changes, update the plans, and supply revised versions to field crews in a timely manner.

b. System Inventory Program

This program ensures an inventory of the utility's collection and transmission system is present, updated, and cataloged by service area or sewershed. The inventory lists the system components with their attributes and characteristics (e.g., pipe age, pipe size, pipe material, invert elevation, pump sizes, location of inverted siphons, pump stations, manholes, etc.).

c. Mapping Program

This program ensures adequately detailed maps are available to be used in conjunction with the utility's MOM programs. At minimum, the maps depict the location of gravity sewer lines, force mains, air valves, manholes (by identifying numbers), pump stations, major appurtenances, and the size of pipes.

d. Sewer System Design Program

This program ensures all new sewer system construction will be adequately designed and constructed using specifications that assure the integrity of the infrastructure. The program includes documented design criteria (e.g., slope and bedding materials), use of standardized construction details, use of standardized materials and construction practices, a standard design review process which includes review by utility personnel for possible maintenance concerns, standardized review forms, and record keeping procedures.

e. New Construction and Rehabilitation Inspection Program

This program ensures new construction or rehabilitative work is properly inspected, and built using the utility's standard construction specifications (including use of best management practices to prevent stream pollution). The program includes use of standardized construction procedures, standardized construction testing procedures, standardized inspection and testing forms/reports, and assurance that the inspection is conducted under the authority and supervision of a registered Professional Engineer. The program also provides subsequent closed circuit television (CCTV) inspection of line construction prior to expiration of the warranty, and retention of the tapes for reference.

f. Acquisition Considerations Program

This program ensures prospective infrastructure is inspected and evaluated for compliance with the utility's standard design and construction criteria before it is acquired by the utility from another entity. The program includes written standard procedures to conduct the evaluation and estimate the time/cost requirements to bring the infrastructure into compliance with utility standards.

g. Continuous Sewer System Assessment Program

i.) Prioritization

This program prioritizes sewer service areas (i.e., sewersheds) for sewer system assessment activities. Prioritization is based upon information such as complaints, flow monitoring (including flow isolation studies), historical location of sewer overflows, pump station run times, field crew work orders, and other relevant information available to the utility.

ii.) Dyed Water Flooding

This program conducts dyed water testing, when appropriate, to locate sources of inflow and other illicit connections to the sewer system. The program includes written standard procedures, standard forms, performance measures, and a mechanism for including dyed water testing information in the IMS.

iii.) Corrosion Defect Identification

This program identifies locations within the sewer infrastructure subject to corrosion and provides for inspection of those locations for corrosion on a routine basis. The program includes written procedures for corrosion identification, corrosion identification forms, performance goals, corrosion defect analysis, and a mechanism for including corrosion defect information in the IMS.

iv.) Manhole Inspection

This program ensures routine inspection of manholes within the sewer system. The program includes standard manhole inspection procedures, manhole inspection forms, performance goals, manhole defect analysis, and a mechanism for including manhole inspection information in the IMS.

v.) Flow Monitoring

This program supplies flow monitoring data to support engineering analyses related to sewer system capacity and peak flow evaluations, and to assist scheduling of sewer line maintenance. The program may include installation of an appropriate number of calibrated permanent and/or temporary flow meters, or rudimentary use of visual flow observations taken during base flow periods in wet and dry seasons. The latter option is more cost-effective for some very small utilities. Either program should include a procedure for adequate rainfall measurement, servicing meters, and a mechanism for including flow monitoring information in the IMS.

vi.) Closed Circuit Television (CCTV)

This program provides internal inspection of the integrity of gravity sewer lines. The appropriate number of qualified CCTV personnel and dedicated equipment, or the scope of a CCTV contract, is determined to ensure sewer inspection work is completed properly. The program includes standard operating procedures (including pre-inspection cleaning), performance measures, and mechanisms for including CCTV information in the IMS and retaining CCTV tapes.

vii.) Gravity System Defect Analysis

This program analyzes gravity sewer system defects. The program includes standard defect codes, written defect identification procedures and guidelines, a standardized process for cataloging gravity system defects, a mechanism for including gravity system defect information in the IMS, and training specified for personnel.

viii.) Smoke Testing

This program identifies sources of inflow into the gravity sewer system by use of smoke

testing equipment. The program includes written standard smoke testing procedures, smoke testing forms, performance goals, smoke testing defect analysis, and a mechanism for including smoke testing information in the IMS.

ix.) Service Lateral Investigations

This program investigates infiltration and inflow contributions and other problems originating in service laterals. The program includes written standard investigation techniques, standard investigation forms, performance goals, standard analysis procedures, and a mechanism for including service lateral investigation information in the IMS.

x.) Pump Station Performance and Adequacy

This program permits evaluation of pump station performance and pump station adequacy. The program includes trend analysis of pump run-time meter, pump start-counter, or amperage data; historical review of the fundamental causes of pump failures; use of appropriate remote monitoring and alarm notification equipment; and a mechanism for including pump station performance information in the IMS.

h. Infrastructure Rehabilitation Program

This program rehabilitates gravity sewer lines, force mains, manholes, pump stations, and related appurtenances. The program includes a process for prioritizing rehabilitation, inventory of all completed rehabilitation (including a breakdown of the rehabilitation techniques used), inspection and performance measurement for all completed rehabilitation, written schedules for rehabilitation work, and a mechanism for including rehabilitation information in the IMS.

i. System Capacity Assurance Program

i.) Capacity Assurance for New Connections

This program ensures there is adequate capacity to collect, transmit, and treat additional sewage expected as a result of prospective new sewer connections. The program is integrated into, or thoroughly coordinated with, the building permit process. It is also integrated into the Acquisition Considerations Program described above in 5(f). The program has a mechanism for including capacity assurance information in the IMS.

ii.) Protocols for Capacity Assurance

The program includes, but is not limited to: use of standardized design flow rate rules of thumb (i.e., regarding pipe roughness, manhole head losses, accuracy of distance and slope on as-built drawings, and water use); use of techniques to predict the impacts of additional flow (i.e., use of a hydraulic model of gravity system, pressure system, and other appropriate techniques); and use of flow metering to confirm mathematical estimations of existing peak flow. The program requires certification of adequate capacity by a registered Professional Engineer, and includes an IMS mechanism for integrating analysis from this program with information on infiltration/inflow reduction activities.

6. Overflow Tracking

a. State Agency Reporting Program

This program includes written standard operating procedures which clearly define the minimum State Agency reporting requirements for events where sewage leaves the infrastructure before treatment, and the steps utility personnel must follow to meet or exceed those reporting requirements.

b. Local Agency Reporting Program

This program provides secondary notice to the public and to other appropriate organizations (e.g., downstream utilities with water intakes and local public health authorities) when an overflow presents an imminent and substantial threat to public health or the environment. The program includes written criteria for making this notice, procedures for notifying news media and posting notices at stream locations, and may also prepare an annual summary report available to the public.

c. Records Management Program

This program tracks all events where sewage leaves the utility's collection or transmission system before treatment (i.e., overflows to land, directly to waters, or indirectly to waters by storm drains or other paths). The program uses standardized forms which record, at minimum, the following information for response and inclusion in the IMS:

- ❖ Location of the discharge
- ❖ Name of the receiving water and description of the pathway (e.g., storm drain)
- ❖ Estimation of the discharge volume and the method of estimation
- ❖ Description of the system component that is source of the discharge
- ❖ Date and time the discharge started and stopped
- ❖ Root cause, or suspected root cause, of the discharge
- ❖ Steps taken to eliminate the discharge and steps taken to prevent reoccurrence.

7. Financial Analyses

a. Cost Analysis Program

This program regularly analyzes and projects future utility management, operations, and maintenance costs needed to properly implement these utility programs. The cost analyses include, at a minimum: overhead, labor and equipment, financial impacts of outsourcing certain activities, overtime, and the financial impacts imposed by organizational departments or agencies outside the utility. Cost analyses are performed for all management, operations, and maintenance equipment and the capital infrastructure investment. Cost analyses incorporate life cycle depreciation and establish cost-effective points for replacement. The program has a mechanism for including such replacement points in the IMS.

b. Capital Improvement Financing Program

This program analyzes, projects, plans and finances capital improvement needs established through proper engineering study. Capital improvement financing is planned using a five (5) year planning horizon with annual updates.

c. Budget and Customer Rate Program

This program establishes the annual utility budget and recommends customer rates. The program assures that the budget and funding provided by customer rates will meet the cost and capital financing needs set by programs 7(a) and 7(b) above.

8. Equipment and Supplies

a. Spare Parts Inventory Program

This program ensures proper management of the utility spare parts inventory including spare pipe. The program includes adequate parts storage facilities, identification and retention of an adequate number of critical spare parts (i.e., those which are difficult to obtain quickly but critical to proper operations), control of access to spare parts, an organized system for inventory management (either manual or computerized), arrangement with local vendors for common parts, and specification of spare parts to be carried on vehicles.

b. Equipment and Tools Inventory Program

This program ensures proper management of the utility equipment and tools inventory. The program includes adequate equipment and tools storage facilities, control of access to equipment and tools, an organized system for inventory management (either manual or computerized), and specification of equipment and tools to be carried on vehicles.

c. Vehicle Repair Program

This program ensures proper management of utility vehicles. The program includes provisions for vehicle maintenance and vehicle repair. Performance measures for the program will consider turn-around time, cost factors, contract maintenance, and the life cycle cost analysis performed for vehicles.

9. Customer Service

a. Complaint Management Program

This program ensures proper complaint management. The program includes written standard management procedures for dispatchers (i.e., dispatch priorities, work order generation, and standardized complaint and problem codes). The program uses an organized record keeping procedure (including the use of standardized forms) which facilitates tracking work orders and follow-up with customers, and uses a mechanism to evaluate response performance and supply this information to the IMS.

b. Public Information Program

This program communicates utility activities which may closely impact the public (e.g., smoke testing, major construction or maintenance, or emergency maintenance), and ensures communication of activities which may coincide with those of other departments and agencies (e.g., street paving).

c. Public Education Program

This program educates the public and solicits support regarding issues such as service lateral maintenance, grease management, food disposals, inflow sources,

maintenance/rehabilitation needs requiring increased rates, and problems caused by basement sump pumps.

10. Legal Support

a. Inter-Jurisdictional Agreement Program

This program develops, negotiates, and enforces agreements with neighboring utilities which send the utility flow or with major volume sewer customers. The program ensures that the agreements require the second party to have proper management, operation, and maintenance programs so the utility's infrastructure is not stressed by problems originating across jurisdictional boundaries. The program also ensures the agreements address flow-based capacity issues, specify the life of the agreement, have credible provisions for enforcement, and have provisions for modification.

b. Sewer Ordinance Program

This program develops, revises, and amends sewer ordinances as needed to support the proper management, operation, and maintenance of the utility. The program provides adequate legal authority for the utility regarding sewer use, grease management, pretreatment, private service laterals, sump pumps and roof drains, private haulers, recovering costs of damage to utility infrastructure, and other legal authorities as required. Legal support is provided for case work and guidance for utility staff.

11. Water Quality Monitoring

a. Routine Monitoring Program

This program determines the existence of unpermitted discharges originating at locations where sewers cross waterways or at other isolated or remote sewer locations. The program includes scheduled sampling during dry weather periods from a network of monitoring stations. The program also includes a map of the sampling network, and formally establishes sampling frequency, sampling parameters (i.e., fecal coliform and others), standard sampling procedures, quality assurance/quality control procedures, and a mechanism for including program information in the IMS.

b. Investigative Monitoring Program

This program determines the source of industrial, commercial, or sanitary wastewater resulting from cross connections with the stormwater drainage system, and typically activates through complaints or discovery by operations personnel. The program has formally established sampling parameters (i.e., fecal coliform and others), standard sampling procedures, quality assurance/quality control procedures, and a mechanism for including program information in the IMS.

c. Impact Monitoring Program

This program determines the impact of pollution resulting from discharges occurring within the utility infrastructure before treatment. Combined with the reporting programs described in Overflow Tracking (6) above, this program assists the utility, regulatory authorities, and public health authorities determine the appropriate response to protect health and/or the environment. The program has formally established sampling parameters (i.e., fecal coliform

and others), standard sampling procedures, quality assurance/quality control procedures, and a mechanism for including program information in the IMS.

12. Contingency Plan for Utility Infrastructure

a. Contingency Planning Program

This program develops and modifies contingency plans for the sewer system and the treatment facilities that will be implemented during emergency situations. The planning process includes a preparedness committee of senior and experienced management and field personnel. A system overview is conducted to determine vulnerability to a variety of events which may be due to utility failures, natural causes, or failures caused by another party. Based upon these hypothetical events and past experience taken from root cause failure information in the IMS, prediction system component failure is made. Strategies to timely repair or overcome such component failures are developed, and the six (6) major contingency plan components are available in writing: public notification, agency notification, emergency flow control, emergency operation and maintenance, preparedness training, and water quality monitoring (described in 11(c) above).

i.) Public Notification

The public notification component includes a set of criteria, developed with input from local public health authorities, which are used as a basis for initiating public notification; a step-by-step procedural flow diagram; a list of manager names and phone numbers; a plan for regular business hours, off-hours, weekends, and holidays; a list of *Public Contacts* with phone numbers; identification of managers authorized to give statements; and pre-scripted news releases.

ii.) Agency Notification

The agency notification component includes a set of criteria, developed with input from appropriate local, State, and Federal authorities, which are used as a basis for initiating agency notification; a step-by-step procedural flow diagram; a list of manager names and phone numbers; a plan for regular business hours, off hours, weekends, and holidays; a list of *Agency Contacts* with phone numbers; identification of personnel authorized to contact agencies; and copies of standard reporting forms used by the agencies.

iii.) Emergency Flow Control

The emergency flow control component is used to reduce overflow volumes and pollution where possible. The component includes a set of criteria which are used as a basis for initiating emergency flow control procedures; a step-by-step procedural flow diagram; a list of manager names and phone numbers; a plan for regular business hours, off-hours, weekends, and holidays; a list of *Emergency Flow Control Contacts* with phone numbers; identification of personnel authorized to initiate the emergency flow control program; and standard emergency flow control reporting forms.

Flow control activities may include flow re-routing, flow diversion, household flow reduction and advisories, commercial flow reduction and advisories, water pressure reduction and advisories, or use of pretreatment program protocols set forth in permits for

significant industrial users. The initiating criteria, reporting forms and report formats should be developed in cooperation with significant industrial users and appropriate local, State, and Federal authorities.

iv.) Emergency Operation and Maintenance

The emergency operation and maintenance component includes a set of criteria which are used as a basis for initiating emergency operation and maintenance procedures; a step-by-step procedural flow diagram; a list of manager names and phone numbers; a plan for regular business hours, off-hours, weekends, and holidays; a list of *Emergency Operation and Maintenance Contacts* with phone numbers; identification of personnel authorized to initiate emergency operation and maintenance procedures; and standard reporting forms.

The initiating criteria, reporting forms, and report formats should be developed in cooperation with utility's insurance representatives, State and Federal emergency management agencies, and the State regulatory authority. Further, development of the emergency operations and maintenance component should include analyses of the need and use of stand-by equipment (prearranged rentals), stand-by contractors, and access to critical spare parts.

v.) Preparedness Training

The preparedness training component ensures that all personnel are fully aware of procedures and able to efficiently implement the Contingency Plan. The preparedness training component includes specialized training courses, field trials, and special emergency situation safety training.

b. Response Flow Diagram

This diagram includes the roles of senior management and field personnel and shows the relationship of the six (6) major contingency plan components: public notification, agency notification, emergency flow control, emergency operation and maintenance, preparedness training, and water quality monitoring.

OPERATION PROGRAMS

1. Pump Station Operation

a. Preventive Operation Program

This program ensures reliable operation of the transmission system through use written standard operating procedures available for both manned and unmanned stations. Procedures may include reading and recording information from pump run-time meters, or start counters, or taking amperage readings; recording wet well conditions and grease accumulation; checking and resetting (as necessary) wet-well set points; checking and recording system pressure; checking remote monitoring and alarm equipment components; checking operation of alarms and stand-by power; and reporting maintenance needs. The program has established schedules, routes, priorities, standard forms, performance measures, and a mechanism for including program information in the IMS.

b. Reactive Operation Program

This program ensures timely response to atypical situations in the transmission system through use of written standard operating procedures available for both manned and unmanned stations. Procedures may include initiating auxiliary power with portable generators, installing portable pumps during high flow, or initiating the Contingency Plan. The program has established standard forms and reporting procedures, performance measures, and a mechanism for including program information in the IMS.

2. Pretreatment Program

This program ensures that operation of the utility's treatment facility is protected from pollutant pass-through or interference. If a utility has industrial or commercial users it may have this program which includes industrial user identification, permitting, monitoring and inspections, enforcement, and other components. Personnel involved with the utility pretreatment program will have frequent communication with operation and maintenance personnel to detect possible pretreatment permit violations. The program has standard operating procedures, performance measures, inspection schedules, and a mechanism for including program information in the IMS.

3. Corrosion Control Program

This program provides for inspection of the utility infrastructure for corrosion caused by hydrogen sulfide or other corrosives, the development and implementation of site-specific corrosion control measures, a monitoring program to evaluate corrosion control measures, program performance measures, and a mechanism for including program information in the IMS.

4. Fats, Oils, and Grease Control Program

This program prevents fats, oils, and grease from entering the utility infrastructure, therefore preserving sewer capacity, prolonging the infrastructure life, reducing overflow events, and saving the utility maintenance costs. The program includes a grease control ordinance, grease trap and interceptor design standards, permitting and inspecting commercial grease traps and interceptors, a credible enforcement component, a public education component for residential sources, performance measures, and a mechanism for including program information in the IMS.

5. Service Connection/Disconnection Program

This program includes written standard procedures for new sewer tap installation or for sewer disconnection; inspection of all new service connections to, or disconnections from, the utility sewer; a credible enforcement program; performance measures; and a mechanism for notifying personnel in the Mapping Program or including program information in the IMS.

6. Private Haulers Program

This program issues permits to private commercial or septic tank waste haulers discharging to the utility, and includes written standard operating procedures for inspection/sampling of the haulers, a credible enforcement program, program performance measures, and a mechanism for including program information in the IMS.

7. Line Location Program

This program responds to requests for utility sewer line locates, and includes written standard line location procedures, defined prioritization to assist scheduling, appropriate staffing and equipment for the average number of requests, standard line location procedures, standard forms, performance measures, and a mechanism for including program information in the IMS.

MAINTENANCE PROGRAMS

1. Pump Station Preventive Maintenance

a. Pump Station Repair Program

This program is a reactive maintenance component intended to repair pump stations that are currently in a state of disrepair but still cost-effective to service. The program includes established priorities for pump station repairs, maintaining an ongoing inventory of completed repairs, a work schedule for pump station repairs, and a mechanism for including pump station repair information in the IMS. Upon completion of pump station repairs, service activities are transferred to the pump station Preventive maintenance program.

b. Electrical Maintenance Program

This program is a component of the pump station Preventive maintenance program. The program includes an established number of crews and personnel required to perform effective electrical maintenance, written standard electrical maintenance procedures, scheduling Preventive maintenance, standard forms, performance measures, and a mechanism for including electrical maintenance information in the IMS.

c. Mechanical Maintenance Program

This program is a component of the pump station Preventive maintenance program. The program includes an established number of crews and personnel required to perform effective mechanical maintenance, written standard mechanical maintenance procedures, scheduling Preventive maintenance, standard forms, performance measures, and a mechanism for including mechanical maintenance information in the IMS.

d. Physical Maintenance Program

This program is a component of the pump station Preventive maintenance program. The program includes an established number of crews and personnel required to perform effective physical maintenance, written standard physical maintenance procedures, scheduling, standard forms, performance measures, and a mechanism for including physical maintenance information in the IMS.

2. Gravity Line Preventive Maintenance

a. Routine Hydraulic Cleaning Program

This program includes accurately determined cleaning needs, established priorities and scheduled cleaning activities, support of an appropriate number of crews and personnel, acquired necessary equipment (e.g., Jet Unit, Combination Unit, etc.), written standard hydraulic cleaning procedures, standard forms, performance measures, and a mechanism for including hydraulic cleaning information in the IMS.

b. Routine Mechanical Cleaning Program

This program includes accurately determined cleaning needs, established priorities and scheduled cleaning activities, support of an appropriate number of crews and personnel, acquired necessary equipment (e.g., Rodders, Bucket Machine, etc.), written standard mechanical cleaning procedures, standard forms, performance measures, and a mechanism

for including mechanical cleaning information in the IMS.

c. Root Control Program

This program includes accurately determined root control needs, established priorities and scheduled activities, support of an appropriate number of crews and personnel, acquired necessary equipment (e.g., mechanical, chemical, etc.), written standard root control procedures, standard forms, performance measures, and a mechanism for including root control information in the IMS.

d. Manhole Preventive Maintenance Program

This program includes accurately determined manhole maintenance needs, established priorities and scheduled activities, support of an appropriate number of crews and personnel, acquired necessary equipment (rings and lids, structural repair, etc.), written standard manhole maintenance procedures, standard forms, performance measures, and a mechanism for including manhole maintenance information in the IMS.

3. Air Valve Preventive Maintenance Program

This program provides for inspection and maintenance of air valves located on force mains (including regular valve exercise). The program includes an established number of crews and personnel required to perform effective Preventive maintenance, written standard air valve maintenance procedures, scheduling, standard forms, performance measures, and a mechanism for including air release valve maintenance information in the IMS.

4. Maintenance of Way

a. Maintenance of Rights-of-Way and Easements Program

This program includes accurately determined maintenance needs, established priorities and scheduled activities, support of an appropriate number of crews and personnel (based on the number of waterway crossings and/or miles of sewer off-street), written standard maintenance procedures, standard forms, performance measures, and a mechanism for including maintenance information in the IMS.

b. Street Paving Monitoring Program

This program includes accurately determined monitoring needs, established priorities and scheduled activities, coordination with storm drain projects and street and highway officials, support of an appropriate number of crews and personnel, acquired necessary equipment (e.g., manhole and valve raising, etc.), written standard monitoring procedures, standard forms, performance measures, and a mechanism for including monitoring information in the IMS.

5. Reactive Maintenance Program

This program provides response to customer complaints or other unscheduled system problems forwarded by dispatchers. The program includes support of an appropriate number of crews and personnel, written standard response procedures including a protocol for initiating the Contingency Plan, standard forms, collection of information in support of failure analysis, sewer map availability, performance measures, and a mechanism for including reactive maintenance information in the IMS.

SYSTEM PROFILE AND PERFORMANCE SUMMARY

A proactive utility will maintain a profile of its system as a basis for explaining its situation to regulatory agencies, the public, and when networking with other utilities. A profile typically contains basic population and inventory information as well as a recent system performance summary. An example of a system performance summary is provided on the following page.

Population Served: _____

Number of Customers: _____

Number of Treatment Plants: _____

Total Wastewater Design Treatment Capacity: _____

Total Volume of Wastewater Treated: _____

Miles of Gravity Sewers: _____

Number of Manholes: _____

Number of Inverted Siphons: _____

Number of Pump Stations: _____

Miles of Force Main: _____

Number of Employees: _____

Annual Capital Improvement Budget: _____

Annual Operation and Maintenance Budget: ... _____

Total Annual Operating Budget: _____

EFFICIENCY MADE EASY

Promotes water efficient products and practices, saving H₂O and electricity. Partners receive recognition and use of EPA logo.

~ Success story: Georgia's Cobb County replaced 1682 toilets with low flow saving 9.5 million gal./yr.

www.epa.gov/watersense

Artie Buff, 404-562-9336



Water conservation in action.

NATIONAL PARTNERSHIP FOR ENVIRONMENTAL PRIORITIES (NPEP)

Partnership with EPA that reduces the use of any of the 31 Priority Chemicals (e.g. Lead, Polycyclic Aromatic Hydrocarbons (PAHs).

~ Success stories: Wirerobe Works eliminated 27,000 lbs. Lead, Saving \$50,000/yr.

www.epa.gov/epaoswer/hazwaste/minimize/partnership.htm

Dave Langston, 404-562-8478



PERFORMANCE TRACK

Go above and beyond legal requirements. Benefits: Reduced Reporting under Maximum Achievable Control Technology (MACT), Extended Accumulation for RCRA Waste, and more.

~ Success story: Rohm and Haas Electronic Materials replaced burner control sections with high-efficiency motor controllers. Saving \$49,000/yr. and reducing energy use by 3.7 billion BTU/yr.

www.epa.gov/performance-track

Reggie Barrino, 404-562-9635

ENERGY STAR

Save money through energy efficient products and practices. Covers 50 product categories. In 2007, program saved consumers \$16 billion in energy costs.

~ Success story: Marriott instituted various energy saving techniques saving \$6 million; 3M increases energy efficiency 9%, saves \$10 million.

www.energystar.gov

Danny Orlando, 404-562-9087

WASTE REDUCTION RESOURCE CENTER (WTRC)

Pollution Prevention (P2) Info clearinghouse—Online technical P2 library/case studies, training courses, Topic Hubs, P2 News, State P2 Contact Information.

<http://wtrc.p2pays.org>

1-800-476-8686

WASTE WISE

Information geared towards municipal solid waste and select industrial wastes (e.g. packaging, paper, wood pallets, batteries) Free technical assistance, case studies, and public recognition/awards.

~ Success story: Pepsi switched from corrugated to reusable shipping, saving \$44 million.

www.epa.gov/wastewise

Rhonda Rollins, 404-562-8664



Wooden pallets being prepared for reuse.

RESOURCE CONSERVATION CHALLENGE (RCC)

Save money and energy - Manage materials more efficiently through recycling and reuse.

www.epa.gov/rcc

www.epa.gov/region4/recycle

~ Success story: Rooms To Go's comprehensive recycling program grossed over \$1 million in 2007.

Dee Rodgers-Smith (Solid Waste), 404-562-8688

Mary Beth Van Pelt (Organics), 404-562-8615

Kim Clifton (E-Waste), 404-562-8477

Steve Smith (C&D), 404-562-8501

SECTOR-SPECIFIC REGULATORY COMPLIANCE ASSISTANCE

COMPLIANCE ASSISTANCE CENTERS

Make sense of environmental regulations, in terminology directly related to your industry. Save money on compliance and reduce wastes. Sectors include: chemicals, printing, auto repair, and more.

www.epa.gov/compliance/assistance

Wesley Hardegree, 404-562-9629




Mills like the one above can get help with environmental regulations.

INDUSTRY SECTOR NOTEBOOKS

Profiles environmental challenges for more than 35 manufacturing, transportation and agricultural sectors. Covers typical operations, pollutants, regulations, P2 opportunities, common environmental violations, and voluntary initiatives.

www.epa.gov/compliance/sectornotebooks.html



United States Environmental Protection Agency

Mention of trade names, products, or services does not convey official EPA approval, endorsement, or recommendation.

STATE POLLUTION PREVENTION (P2) RESOURCES

Find all the P2 State contacts at:

~ <http://wtrrc.p2pays.org>

EPA partnership programs and general P2
~ www.epa.gov/partners and www.epa.gov/p2

Buy environmentally responsible computers
~ www.epeat.net

Recycling opportunities for practically everything.
~ www.earth911.org

Best management practices/Lower plant energy bills
~ www1.eere.energy.gov/industry

ADDITIONAL SUCCESS STORIES

~ EPA's Colorado Lab—Reduces water usage 50%, saving 650,000 gallons, and \$1,900/yr.

~ Retail complex in Oregon uses native landscaping—maintenance costs reduced 80%, and water bill \$2,400.

~ Fiberglass Mfr. reduces waste acetone by 80%, goes from Small Quantity Generator (SQG) to Conditionally Exempt Small Quantity Generator (CESQG).

~ Dow reconditions steel drums, Saves \$2.3 million, conserves 7.8 million lbs of steel.

~ Seydel's (textiles) reduction & re-manufacturing efforts generates \$518,000 in revenue.

~ Institute for Local Self-reliance (ISLR) deconstructs/recycles home, nets \$7,400 in materials.

Make your pockets GREENER with Voluntary Programs



EPA has over 60 voluntary programs to help you reduce waste, understand legal requirements, and save millions; with flexible, market-driven solutions. Other companies have saved millions of dollars...and so can you!



ENVIRONMENTAL PROTECTION AGENCY REGION 4

61 Forsyth St.
Atlanta, GA 30303
www.epa.gov/region4

For More Information Contact
Waste Reduction Resource Center
1-800-476-8686

EPA Region 4
Introduction to Conducting Evaluations
of
Municipal Wastewater Collection System
Management, Operation, and Maintenance Programs

Version 1.0



PURPOSE & DISCLAIMER

This document is the work product of the EPA Region 4, Water Management Division, Water Programs Enforcement Branch (WPEB) and supercedes a 10-30-1996 draft previously released. This document serves as an introduction for new Region 4 inspectors in the WPEB Municipal Infrastructure Enforcement Program and as introductory information for utilities invited to participate in the Region 4 Management, Operation, and Maintenance (MOM) Programs Project. Questions in this document are provided to initiate the thought process necessary for conducting an evaluation of a collection system. Formal instruction for conducting an evaluation under the MOM Programs Project is provided in separate literature.

The MOM Programs Project is conducted in compliance with EPA Policy, EPA Guidance, and Rules and Regulations promulgated under the Clean Water Act. If some statement or part of the document is not in compliance with the Act, EPA Policy, EPA Guidance or the Rules and Regulations, then it should not be construed as conveying rights not conveyed by the Clean Water Act, EPA Policy, or the Rules and Regulations.

September 2003

Introduction

Many collection systems have received minimal maintenance for many years. This has resulted in deteriorated sewers with a high potential for overflows, cave-ins, hydraulic overloads at treatment plants, and other problems. There are two central reasons for conducting an evaluation of a municipal collection system:

Public and Environmental Health

Sanitary sewer overflows (SSOs) are a frequent cause of water quality violations. Beach closings, flooded basements, closed shellfish beds, and overloaded water treatment plants are a few of the symptoms of an inadequate collection system. Streams influenced by frequent SSOs support only the hardiest of species.



Legal Considerations

A discharge permit issued through the National Pollutant Discharge Elimination System (NPDES) requires that the “permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) that are installed or used by the permittee to achieve compliance with the conditions of this permit.” SSOs may be considered a violation of this permit provision.



SSOs may also be considered an unpermitted discharge of pollutants from a point source, as defined in the Clean Water Act.

A goal of the collection system evaluation should be to discover if a utility is plagued by overflows and/or bypasses within its system of conveyance to a treatment facility. If so, what are the impacts? Is the utility aware of the problem? Are they taking appropriate steps to address the problem in a timely manner and prevent future reoccurrence?

Management

The first stop on any evaluation should be the “home office.” This location is a point of administration, and may include functions such as utility management, finance, engineering, planning, procurement, warehousing, personnel, or legal review. In a large city, this work may be split between different departments. A small town may have only one or two people doing some of these activities. Much of the information needed from this source can be obtained before the evaluation by a written request. Areas of review should include:



✓ *Financial Administration*

EPA and others have published guidance on the financial aspects of operating a wastewater utility. This is the single most important aspect of utility operation. Inadequate funding diminishes the chances for success.


User Rate/User Charge

- What are the utility's current rates?
- How are user rates calculated?
- How often are user charges adjusted based on that evaluation?
- Does the utility receive full funding from its revenue?
- Are utility funds used for other government activities?



Budget

The utility should be operating on an annual budget that details funding for all functions.



- Does the utility budget for annual operating costs?
- Does the budget provide sufficient itemization?
- Does the utility maintain a fund for future equipment and infrastructure replacement? How is work financed?

- Does the budget provide for sufficient funding?

Public Education/Outreach

The utility should be talking with the public on issues such as user rates and charges. It is up to the utility to educate the public on wastewater treatment, its impact on water resources, and the importance of keeping the user rates current. By maximizing resources and operating facilities efficiently, the utility may be able to delay increases in user rates for a short time. Adjustments for more efficient operation should be made before approaching the public on these issues.



- What type of public education/outreach programs does the utility have about the use of income from utility rates?
- Do these programs include communication with several groups such as local governments, community groups, the media, young people (schools, youth organizations)?

✓ Personnel Administration

Organization

- Is an organizational chart available which shows the various positions budgeted and filled?
- Are position descriptions available?

Operator Safety Program

A utility can have several levels of a safety program. It should consist of top administration, a safety department, a safety committee, and field personnel. For a small utility, top administration could be the mayor while a large utility could employ a personnel manager. All utilities should have a safety program that includes a safety policy, safety training and promotion, and accident investigation and reporting.

- Is there a documented safety program supported by a top administration official?
- Is there a safety department that provides training,




equipment, and an evaluation of procedures?

- Are all operators required to follow safe work procedures, such as the use of protective clothing and headgear, confined spaces, lock-out/tag-out policies, etc.?
- Is there a confined space entry procedure for manholes, wet wells, etc.?
- How often are safety procedures reviewed and revised?
- Does the safety department communicate with field personnel on safety by a procedures memo, direct communication, a video, etc.?

✓ *Equipment and Tools Administration*

The amount and types of equipment and tools held by a utility depend on the size, age, and condition of the system. The decision as to the type and amount of equipment to have on hand is a difficult one. A small utility may find it hard to justify the purchase of expensive, specialized equipment. The utility must identify the problems in the collection system and arrange for the appropriate tools and equipment accordingly. An alternative to purchasing is leasing, contracting, or sharing costs with other communities.



- Is there a list of equipment and tools used for operation and maintenance?
- Do field personnel feel they have access to the necessary equipment and tools to do all aspects of the operation and maintenance of its collection system?
- Is there access to suitable equipment if the utility's equipment is down for repair?
- Does the utility own or have ready access to a sufficient number of emergency power generators?
- Where does the utility store its equipment?
- Is a detailed equipment maintenance log kept?
- Are written equipment maintenance procedures available?

- What is the procedure for equipment replacement?
- If an in-house motor pool is used, what is the turnaround time for service?

Equipment that has reached its useful life should be replaced. To reduce the financial burden of equipment replacement, a fund should be established for equipment replacement. A utility should keep detailed records on the cost of operating the equipment to make good decisions about equipment replacement.

✓ *Legal Administration*

The utility should have legal documents to protect its collection system. Typically, sewer ordinances exist to satisfy Clean Water Act pretreatment regulations and to assure the utility's compliance with its NPDES permit. A legally sound sewer ordinance will give the utility retribution when corrosive and/or toxic materials are introduced into the collection system. Another important element is a grease control ordinance. Grease traps should be inspected by the utility for compliance. Some utilities choose to permit each trap owner.



- Is there a sewer use and a grease control ordinance?
- Is there active enforcement of the sewer and grease control ordinances?
- Are all grease traps inspected regularly?
- How does the utility learn of new or existing grease traps?
- Who is responsible for enforcing the sewer ordinance and grease ordinance? Does this party communicate with the utility department on a regular basis?
- Are there any significant industrial dischargers to the system?
- Is there a pretreatment program in place?

✓ **Engineering Administration**

System Mapping and As-Built Plans

The utility should have an overall map of the collection system with sufficient detail to allow easy interpretation. There should be a collection system inventory organized by plant service areas that include the following information:



Gravity Lines:	Lineal feet by diameter
Manholes:	Number
Pump Stations:	Number by type
Force Mains:	Lineal feet by diameter
Air Release Valves:	Number and location
Inverted Siphons:	Number and location
Other Major Appurtenances:	Number and location
Service Population	By facility service area


A sewer atlas detailing the location of the above items should be available. The type of sewer atlas used by the utility will depend on their needs and resources. A large metropolitan utility may find that a sophisticated, computerized mapping system is required. A small community may be satisfied with a hand-drafted version.

- What type of mapping/inventory system is used?
- Is there a procedure for recording changes and updating the mapping system?

Mapping and inventory revisions should occur when there are changes in the collection system such as additions or repairs. Comprehensive maps of the system should be printed annually for large utilities, and a staff of “mappers” will likely be required to keep the maps up to date. Utilities may alternatively choose to contract map services. This is especially true if much catch-up work is required.

Design and Capacity Analysis


Through the interview and document review process, the evaluator should discover design procedures and the criteria needed for new work. In particular, the evaluator should discover how the utility determines the adequacy of the existing system for transmitting and treating future flows. The evaluator should discover what control the utility has over new connections to the system.



- Is there a document which details the design criteria and standard construction details for gravity sewers, force mains, and pump stations?
- Is there a document that describes the procedures that the utility follows in conducting a design review? Are there any standard forms that guide the utility?
- What procedures are used in determining whether the existing sewer system capacity is adequate for new connections?
- Is any flow metering accomplished prior to allowing new connections?
- Is there a mathematical model of flow in the system used to predict the effects of new connections?
- Is any certification required which attests capacity is available for a new connection before it is made?

Construction

Through the interview and document review process, the evaluator should determine what procedures the utility uses to inspect and test new construction. These activities are important to ensure that new facilities do not contribute to future operation and maintenance problems. Excessive infiltration and inflow problems can exist with new construction if not properly built.



- Is there a document that describes the procedures that the utility follows in conducting their construction inspection and testing program? Are there any standard forms that guide the utility in conducting their construction inspection and testing program?
- Is new construction inspected by the utility or others?
- What are the qualifications of the inspector(s)?
- Is inspection supervision provided by a registered Professional Engineer?
- How is new construction tested? (air, water, weirs, etc.)
- Is new construction televised using closed-circuit camera techniques?
- Is new construction built to standard specs set by the local utility and/or the State?

- Is there a warranty for new construction? If so, is there a warranty inspection done at the end of this period?

Sewer System Evaluation Survey (SSES) and Rehabilitation

The SSES and sewer rehabilitation program is a structured methodology for finding the holes in a system and fixing them. Cost analysis is the major factor in determining the scope of rehabilitation. Due to the requirements of EPA's Construction Grants Program, many systems did evaluation surveys as a condition of their grant. Some systems also received grant funds for rehabilitation.

The SSES is a two-phase operation. The first phase is to gather preliminary information and technical data. Flow monitoring, records and map evaluations, and system inspection are some of the tasks to be completed. Prioritizing areas for further evaluation is the end result of phase one.

The second phase is to conduct further testing of the prioritized sewer areas identified in the preliminary phase and analyze these results. Rehabilitation recommendations based on a cost-effective analysis is the end result of phase two and concludes the SSES.

Rehabilitation may consist of a variety of techniques designed to reduce inflow and infiltration into the sewer system. Many methods are available with highly variable costs and service lives. Rehabilitation costs are usually significantly less than replacement costs.

SSES and rehabilitation activities are best described as a highly intensive program of operation and maintenance. Because over time many utilities have neglected proactive operation and maintenance of their sewer systems, these activities are often used to "catch-up" to a condition which can be maintained on a regular basis. Many of the techniques used in SSES and rehabilitation activities are described in the Operation and Maintenance section of this document, and should also be elements found in a proactive operation and maintenance program.


- Have SSES activities been performed in the past? If so, is documentation available?
- Has any sewer rehabilitation work been done in the past 15 years?
- How many sanitary sewer overflows have occurred in the last year?
- Is there a record?



✓ *Water Quality Monitoring*

Monitoring streams in the service areas can help identify problems in the collection system such as leaking pipes, washed-out stream crossings, and other pollution sources which could be attributed to the sewer system. Fecal Coliform is a common parameter monitored to detect potential contamination from sewers.

- Is there a water quality monitoring program in the service areas?
- If so, what parameters are monitored and at what frequency?
- How many locations are monitored?



✓ *Management Information Systems*

A management information system uses data from work reports prepared by field personnel to optimize the operation and maintenance of the collection system. A powerful tool, the information system is used as an aide to schedule preventive and reactive work on the system. It can also be used to measure efficiency, and track and develop costs.

- What types of work reports are prepared by the field personnel?

Examples include:

- Main Sewer Construction
- Main Sewer Maintenance
- Main Sewer Repair
- Structure Maintenance
- Structure Repair or Abandonment
- Building Sewer Maintenance
- Building Sewer Repair

- Do the work reports include complete and useful information?
- How are records kept?
- Does the facility use computer software to manage information? If so, what type of systems are used?

- What kind of management reports are generated from the work report data?

Examples include:

- Payroll
- Production
- Work Costs
- System Inventory
- Main line maintenance history
- Service line maintenance history
- Main and service line repair history

Performance Indicators

Performance indicators are used to determine the condition of the system. These indicators are not absolute because there may be other reasons to suggest a less than adequate system condition. However, if several of the factors indicate possible problems, further investigation is warranted.

- What is the per capita wastewater flow for the maximum month, week, and day?

EPA considers Infiltration/Inflow (I/I) to be excessive if the total daily flow during periods of high groundwater exceeds 120 gallons per capita per day (gpcd), and during a storm event exceeds 275 gpcd.

- What is average annual BOD of the treatment facility influent?

An average of much less than 200 mg/L may indicate excessive I/I.

- What is the ratio of maximum wet weather flow to average dry weather flow?

A review of 10 case studies by EPA found that peak wet weather flow ranged from 3.5 to 20 times the average dry weather flow. Typically, as the ratio approaches 4 to 5, the likelihood of surcharge and overflow increases.

- What is the annual number of overflows, and what are the causes (i.e., grease blockages, debris blockages, pump malfunctions, overloaded sewers, lift station power loss, etc.)?
- What is the annual number of sewer cave-ins? What were the causes (i.e., pipe corrosion, root intrusion, leaks, etc.)

✓ ***Complaints***

- How are public complaints handled?
- What are the common complaints received?
- How often are these complaints reported?
- Is there a record?
- Does the utility have a procedure in place to evaluate and respond to complaints?

✓ ***Public Relations***

- Is there a public relations program in place?
- Are the employees of the utility trained in public relations?
- What type of public notification is given for treatment plant upsets or collection system overflows?
- Is the public notified prior to major construction or maintenance work?
- How often does the utility communicate with other municipal departments?

✓ ***Emergency Maintenance and/or Contingency Plans***

- Does the utility have a written emergency maintenance plan?
- What type of equipment does the utility have available for emergency maintenance?
How quickly can the utility access that equipment in case of an emergency?

✓ ***Spare Parts Inventory Management***

- Does the utility have a central location for the storage of spare parts?
- Have spare parts which are difficult to obtain, but critical to operation been identified?
- Does the utility maintain a stock of common spare parts on its maintenance vehicles?


- What methods are employed to keep track of the location, usage, and reordering of spare parts? Are parts logged out when taken by maintenance personnel for use?
- Does the utility salvage specific equipment parts when equipment is placed out of service and not replaced?
- How often does the utility conduct a check of the inventory of parts to ensure their tracking system is working?
- Who has the responsibility to track the inventory?

Operation and Maintenance

The operation and maintenance (O&M) of a wastewater collection system is a difficult undertaking. Besides keeping the system in good working order, a proper O&M program should convey all wastewater to the treatment plant. A well-operated system will employ many, if not all, of the techniques described in this section.

✓ *Maintenance Scheduling*

- Does the utility schedule its maintenance activities?
- How are priorities determined?
- How is the effectiveness of the maintenance schedule measured?



✓ *Sewer Cleaning*

Sewer utilities have been cleaning lines for a long time. Most sewer cleaning programs have been directed towards emergency situations which occur due to stoppages. A better O&M program will have regular cleaning schedules for the system.

- Is there a routine schedule established for cleaning sewer lines on a system-wide basis (e.g., “once every seven to twelve years,” or “between 8% and 14% per year”)?

- Is there a process present to identify sewer line segments that have chronic problems and that should be cleaned on a more frequent schedule?

Cleaning Equipment

Mechanical cleaning equipment, such as a rodding device or bucket machine, has been the mainstay of utility cleaning operations for a long time. Though this type of equipment is still in use, hydraulic cleaning equipment which uses water pressure directed through a nozzle has generally replaced the need for mechanical equipment.

- What type of cleaning equipment does the sewer utility use?
- How many cleaning units of each type does the utility have?
- How many cleaning crews and shifts does the utility employ?
- How many cleaning crews are dedicated to routine cleaning?
- How many cleaning crews are dedicated to emergency cleaning?
- What has the utility's experience been regarding pipe damage caused by mechanical cleaning equipment?
- Where is the cleaning equipment stationed?

Chemical Cleaning and Root Removal

Roots are a major cause of stoppages in many systems, so root removal and control is an important utility operation.

- Does the utility have a root control program?
- Are chemical cleaners used? What types?
- How often are they applied?
- How are the chemical cleaners applied?
- What results are achieved through the use of chemical cleaners?

✓ *Hydrogen Sulfide Monitoring and Control*

The presence of hydrogen sulfide gas in gravity and pressure sewer lines can, and often does, lead to serious and catastrophic corrosion of concrete pipes and the metallic components of sewer systems. Hydrogen sulfide corrosion is usually a problem in areas having little topographic relief where there may be long travel times. Hydrogen sulfide corrosion can also be a problem downstream from pump stations having long wet well holding times.

- Are odors a frequent source of complaints?
- Has the sewer utility verified the existence/non-existence of a hydrogen sulfide problem, and if one is present, does it have in place corrosion control programs?
- What are the major elements of the utility's program?

A control program could be use of chemicals or aeration to prevent the formation of hydrogen sulfide. Pipe materials which resists corrosion are also effective. Often, a combination of approaches will be included in a program.



✓ *Lift Stations*


Lift stations are an important part of most wastewater systems. In coastal or other areas with little topographical relief, lift stations are a major O&M item. The effects of deteriorated collection systems are often realized at lift stations in the form of severe overflows during rain events.

Operation

- How many personnel are detailed to pump station operations and maintenance?
- Are these personnel assigned full-time or part-time to pump station duties?
- Is there sufficient redundancy of equipment?

Emergencies

- Who responds to lift station overflows? How are they notified?



- How is loss of power at a station dealt with? (e.g., on-site electrical generators, alternate power source, portable electric generators)

Alarms and Monitoring

- How are lift stations monitored?

The answer to this question will depend on the station size, and the size and complexity of the system. In many systems, audible alarms or flashing lights are used to indicate a problem at the station. Reliance is placed on either the local populace or law enforcement to notice and report an alarm. In more modernized systems, alarm conditions are remotely monitored at a central location. This is particularly true for the larger stations. These SCADA (Supervisory Control and Data Acquisition) systems allow for real-time control, monitoring, and record keeping from remote locations.

Inspection

- How often are lift stations visited?
- What is inspected during these visits?
- Is there a checklist?



Preventative and Routine Maintenance

- Is there a preventive maintenance program for lift station equipment, and if so, what is involved in this program?
- Is an adequate parts inventory maintained for all equipment?
- Is there a sufficient number of trained personnel to properly maintain all stations?

Record keeping

- Are O&M logs maintained for all pump stations?
- Are manufacturer's specifications and equipment manuals available for all equipment?
- Are run-times or ampere readings recorded for all pumps? How is this information used to assess performance?

Force Mains and Air Release/Vacuum Valves

Force mains and air release/vacuum valves are an integral part of the transmission system. Force mains receive the lift station effluent and convey it to the gravity system or the treatment plant. Air release/vacuum valves are installed at the high points of the force main.

The route of force mains should be inspected regularly in order to determine if any leaks are present. This is particularly true where the route is through remote areas. Air release/vacuum valves should be identified and receive regular documented maintenance. Malfunctions of these valves can lead to overflows and/or a reduced hydraulic capacity of the force main.

- Does the utility schedule and conduct inspections of force main routes?
- Does the utility have a scheduled maintenance/inspection program for air release/vacuum valves?

✓ Sewer System Evaluation

As discussed in the Management section, many of the techniques in use for SSES work should be a part of a utility's operation and maintenance program. Larger utilities can justify the purchase of much of the equipment used in this effort.

Flow Monitoring



Flow monitoring data collection and evaluation should be an important part of a good O&M program. A well-designed flow monitoring program will give a snapshot of the current condition of the system. By isolating the portions of the system that are making the greatest contribution to the problem, resources can be directed where they will be of greatest benefit.

Techniques used to monitor flow include continuous metering, nighttime field measurements, quantification of pump run-times, and flow measurements taken at the treatment plant. Continuous flow measurement at key locations throughout the collection system will give the most accurate indication of system integrity. The other techniques have been used to some advantage with smaller systems.

Use of meters which measure depth of flow and velocity will allow accurate results, even under surcharged conditions. Meters are available which allow continuous data recording

which can either be downloaded locally or transmitted to a remote location. Coupled with appropriate software, this is a powerful tool for sewer system evaluation.

- Does the utility have a flow monitoring program? If so, what methods are used?

Manhole Inspection

Inspecting manholes is an important part of any maintenance program. Often utilities are unaware of the location of many of their manholes. This is unfortunate since manholes are an important source of I/I and are good indicators of problems in the system. Missing manhole lids and offset manhole cones are often the result of sewer overflows. Debris on manhole steps or high waterlines indicate the presence of surcharged conditions.

Some utilities use manhole inserts to reduce inflow to the system. A manhole insert is a small, tub-shaped plastic device installed at the top of the manhole and held in position by the manhole lid. Its purpose is to catch water that enters the manhole via holes in the lid or via the access pick holes.

- Does the utility have a routine manhole inspection program?
- Is there a data management system for documenting and tracking manhole inspection activities?
- What triggers whether a manhole needs rehabilitation?

Sewer Cleaning Related to I/I Reduction

- Are sewers cleaned prior to flow monitoring?
- Are sewers cleaned prior to televised inspection?

Televised Inspection

Inspecting sewers using closed-circuit television (CCTV) cameras is a powerful tool for I/I reduction. Leaking joints or punctures can be easily detected and often repaired at the time of inspection. CCTV is also a good method to inspect the integrity of new construction before the warranty expires.

- Does the utility use televised inspection? If so, in what context?


Smoke Testing and Dyed Water Flooding

These techniques are useful to locate defects in the system and illegal connections.

- Does the utility use smoke testing to identify sources of inflow into the system?
- Does the utility use dyed water flooding to identify suspected sources (indirect connections) of inflow into the system when smoke testing yields inconclusive results?
- Is there a data management system for tracking these activities?
- Is there a document that describes the procedures that the utility follows? Are there any standard forms?

✓ **Rehabilitation**

Several techniques are available for sewer rehabilitation. A determination of the best techniques to apply to a particular situation should be made following the SSES and an economic analysis comparing the different options.



Main Line Repairs

Point and Replacement Repairs

Point repairs consist of repairing cracked, corroded, or broken gravity sewers and force mains. This work typically includes excavation to the location of the break, removal of the broken pipe section(s) and replacement with new pipe.

Joint Testing and Grouting

Joint testing and grouting are done on sewer line sections with leaking joints but no structural defects. This work can be done in conjunction with the routine televising of lines. Grouting has a limited life and must be repeated every 5-10 years.

Sewer Lining

Sewer lining is a technique which returns pipe to new condition. Many of the current systems can be used where pipe is structurally deficient. Due to the limited excavation required for these techniques, they are good choices where surface construction would cause much disruption.

- What type of main line repairs has the utility used in the past?
- Does the utility currently use any of above techniques for main line repairs?

Manhole Repairs

Manhole repairs consist of repairing structural defects or leakage in individual manholes and castings. The structural repair work may include:

- Complete manhole replacement
 - Replacing castings (lid and frame)
 - Replacing defective adjusting rings or top segments
 - Spray relining the existing manhole
 - Grouting fissures to eliminate leakage
- What rehabilitation techniques are used for manhole repairs?
 - What type of documentation is kept?

✓ Service Laterals


Service laterals can often be the largest source of I/I to a system. Taps, joints, and locations of structural damage are common points where I/I may be introduced into the collection system. Most utilities have legally established what part(s) of the service lateral they maintain. Jurisdiction may cover the tap only, cover all construction to the property line, or cover construction all the way to the building. The utility itself may not have direct control over installation of new service laterals. Typically the municipality's building inspectors have this responsibility. What is important is that there is communication and a consistency of standards between the utility and building departments.

- To what degree does the utility have responsibility for service laterals?
- Does the utility have a written procedure for the approval and inspection of new construction service laterals?
- Does the utility require service laterals to meet certain standards of construction? How are these standards made available to builders?
- Does the utility have a procedure to actively find and remove illegal tap-ins?
- What is the utility's jurisdiction related to repair/replacement of service laterals?
- Does the utility include I/I originating from service laterals as part of their system evaluations?

✓ *Alternative Collection Systems*

Alternative collection systems differ significantly from the conventional gravity sewer commonly employed to convey wastewater. Alternative systems include: grinder pump pressure systems, septic tank effluent pump (STEP) systems, small diameter gravity systems, and vacuum collection systems. Each system has its own unique operation and maintenance requirements and could be found as a subset of a system which is predominately gravity sewer or by itself as a stand-alone utility.

Although each alternative system operates differently and has different maintenance requirements, all require a similar management system. In each system appurtenances are located at each residence, so the utility needs to have ready access, maintain adequate spare parts, and install alarm systems to notify the utility of any problems between inspections.



Grinder Pump Systems

Grinder systems employ a holding tank (typically up to 100 gallons and located near an individual residence) which houses a small pump with a grinder attached. Wastewater is discharged intermittently using float controls. The collection system is comprised mostly of 1½" and 2" PVC plastic lines. Manholes are generally not installed, but cleanouts should be installed at the ends of all lines and at critical points. Air release valves are installed at the downstream side of high points. Pressures are low.

A system serving 500 homes would include 500 individual pump stations so a utility needs to have an appropriate staffing level for maintenance. A minimum of two personnel should be available. Generally speaking, a staff including two full-time employees per 1,000 stations has been found sufficient for well-designed systems.

Major sources of emergency maintenance include electrical problems and grease buildup in the holding tanks, resulting in failure of the floats to activate the pumps. Corrosion within the holding tank can also be a problem. Grinding solids reduces the likelihood of solids deposition, but hydrogen sulfide may be a problem where the pressure line discharges to the treatment plant or into a gravity collection system.

Pump preventive maintenance is critical and adequate spare pumps should be in inventory. Pumps and grinders may require frequent replacement and overhaul. Pump life is limited and a plan to replace all pumps should be in place. Infiltration is generally not a problem, but exfiltration may occur through deteriorated joints.

Septic Tank Effluent Pump Systems

STEP systems are similar to the grinder pump system except a septic tank replaces the holding tank and grinders are not present on the pumps. A greater range in pump types (centrifugal, progressive cavity, etc.) are common with these systems. Although the septic tank provides preliminary treatment and solids settlement, it is part of the collection system.



Significant infiltration may occur with poorly sealed and constructed septic tanks. Lines are generally sized assuming low infiltration rates. High infiltration rates will increase pump operation and may reduce pump life.

The wastewater is highly septic and can cause odor and corrosion problems where the pressure line discharges into a conventional manhole or treatment works. Proper operation and maintenance of the septic tank is essential for proper function of the collection system, so tanks should be pumped out on a set schedule.

Small Diameter Gravity Sewers

Like STEP systems, small diameter gravity systems use septic tanks for preliminary treatment and solids removal. However, no pumps are used. The septic tank overflows into a small diameter (4" and up) pipe placed at a moderate grade. The lower solids concentration in the wastewater results in less deposition of solids in the pipe.

Cleanouts are generally used in place of manholes, and pipes are sized assuming low infiltration rates. Similar to the STEP system, the integrity and maintenance of the septic tank is a critical factor for proper operation.

Vacuum Sewer Systems

Vacuum systems have a central vacuum station which includes vacuum pumps, holding tanks, and pressure pumps. The vacuum pumps provide a continuous suction in the collection line. A holding tank and vacuum valve are installed near each residence.

When the wastewater reaches a set level in the holding tank, the valve is opened to release a slug of liquid into the collection line. A loss of vacuum in the system will generally trigger a fault condition. Major breaks may cause the system to shut down, and leaks are difficult to locate. Once the wastewater arrives at a central vacuum station, it enters a holding tank and is pumped to the treatment facility through a force main.

- Does the utility have control of the near-residence portions of the collection system?
- Who owns the near-residence systems?
- Does the utility do periodic inspections of the near-residence facilities?
- What is the frequency of these inspections?
- Are pressure check valves installed on pumps?
- Are clean-outs installed at the end of each branch line?
- Is a pipe locating system installed?
- Are air release valves installed on the downstream side of high points?
- Does the system have a warning alarm system at each residence?
- How does the utility respond to the alarm system?
- Are odor control systems are installed?



Useful References for Management, Operations, and Maintenance Programs

The following references may be obtained from their cited sources. Documents referenced to California State University, Sacramento may be obtained by contacting:

California State University, Sacramento
Office of Water Programs
6000 J Street
Sacramento, California 95819-6025
(Tel) 1-916-278-6142 (Fax) 1-916-278-5959
(E-mail) wateroffice@csus.edu

Documents referenced to the Water Environment Federation may be obtained by contacting:

Water Environment Federation
601 Wythe Street
Alexandria, VA 22314-1994 USA
(Member Services Center) 1-800-666-0206
(Fax) 1-703-684-2492 (E-mail) pubs@wef.org
(Internet) <http://www.wef.org/TechResCatalog/marketplace/>

Documents referenced to the Environmental Protection Agency may be obtained by contacting either the NCEP (if in stock) or the NTIS:

U.S. Environmental Protection Agency
National Service Center for Environmental Publications
P.O. Box 42419
Cincinnati, OH 45242
(Tel) 1-800-490-9198 (Fax) 1-513-489-8695
(Internet) <http://www.epa.gov/ncepihom/orderpub.html>

National Technical Information Service
5285 Port Royal Road
Springfield, VA 22161
(Tel) 1-800-553-NTIS (Fax Orders) 1-703-605-6900
(E-mail) orders@ntis.fedworld.gov
(Internet) <http://www.ntis.gov/ordering.htm>

The EPA Region 4 Guide may be obtained by contacting Region 4 directly:

U.S. Environmental Protection Agency, Region 4
Water Management Division
Water Programs Enforcement Branch
61 Forsyth Street, SW
Atlanta, GA 30303-8909

Useful References for Management, Operations, and Maintenance Programs

- Sewer System Infrastructure Analysis and Rehabilitation, October 1991, United States Environmental Protection Agency, EPA/625/6-91/030
 - Collection Systems: Methods for Evaluating and Improving Performance, 1998, California State University, Sacramento Foundation, Rick Arbour and Ken Kerri, USEPA Grant No. CX924908-01-0
 - Wastewater Collection Systems Management, Manual of Practice 7, 1998, Water Environment Federation, 601 Wythe Street, Alexandria, Virginia, 22314
 - Operation and Maintenance of Wastewater Collection Systems, A Field Study Program, Fifth Edition, Volume 1, 1996, California State University, Sacramento
 - Operation and Maintenance of Wastewater Collection Systems, A Field Study Program, Fifth Edition, Volume 2, 1996, California State University, Sacramento
 - NPDES Compliance Inspection Manual, Chapters 4 and 9, September 1994, EPA 300-B-94-014
 - Handbook for Retrofitting POTWs, July 1989, EPA 625-689-020
 - Pretreatment Compliance Monitoring and Enforcement Guidance, September 1986, United States Environmental Protection Agency
 - Guidance for Conducting a Pretreatment Compliance Inspection, September 1991, EPA 300R-92-009
 - EPA Region 4 Guide for Conducting Evaluations of Municipal Wastewater Collection System Management, Operation, and Maintenance Programs, October 30, 1996
- = Available for viewing on-line at the National Environmental Publications Internet Site (NEPIS). Go to www.epa.gov/ncen/epihom/nepishom and search using the document code (e.g., 625689020).

APPENDIX E

Appendix E

Sewer Overflow Response Plan



Prepared By:
City of Jackson
Water/Sewer Utilities Division
200 S. President Street, Rm 405
P.O. Box 17
Jackson, MS 39205-0017
Voice: (601) 960-2090
Fax: (601) 968-3502
Submitted On: September 28, 2011
Approved On: October 10, 2011
Amended On: _____, 20__

Sewer Overflow Response Plan

Sewer System Owner:

City of Jackson
200 S. President Street, Room 405
PO Box 17
Jackson, MS 39205-0017

Contact Persons:

Harvey Johnson, Jr., Mayor
(601) 960-1084

Chris Mims, Director of Communications
Office of the Mayor
(601) 960-1084
Public Service Announcements

Dan Gaillet, Director of Public Works
(601) 960-2091
dgaillet@city.jackson.ms.us

David Willis, Deputy Director of Public Works
(601) 960-2090
dwillis@city.jackson.ms.us

Prentiss Guyton, Manager
W. Anthony Harkless, Wastewater Operations Engineer
Vacant, Wastewater Collections Engineer
Water/Sewer Utilities Division
(601) 960-2090
pguyton@city.jackson.ms.us
Cojanthony@yahoo.com

Terry "Butch" Mayfield, Superintendent
Sewer Maintenance Division
(601) 960-1868

Regulatory Agencies to Receive Sewer Overflow Report:

MS Department of Environmental Quality
Office of Pollution Control
P. O. Box 2261
Jackson, MS 39225
Contact Person:
Rusty Lyons, P.E., Manager,
Compliance and Enforcement
Phone: (601) 961-5588
Fax: (601) 961-5674
Email: rusty_lyons@deq.state.ms.us

Hinds County Health Department
Environmental Health
539 E Beasley Road
PO Box 20
Jackson, MS 39205-0020
Sherrie Payne, Regional Environmentalist
Marvin Bolden, County Environmentalist
Lakeshia Paige, County Environmentalist
Phone: (601)-957-1026
Fax: (601)-957-1053
sherrie.payne@msdh.state.ms.us
marvin.bolden@msdh.state.ms.us
lakeshia.paige@msdh.state.ms.us

TABLE OF CONTENTS

I. AUTHORITY	1
II. GENERAL	1
III. OVERFLOW IDENTIFICATION AND RESPONSE PROCEDURE.....	3
IV. BUILDING BACKUPS PROCEDURE.....	11
V. PUBLIC ADVISORY PROCEDURE.....	12
VI. REGULATORY AGENCY NOTIFICATION PLAN.....	15
VII. LONG TERM CORRECTIVE ACTION PROCEDURES.....	16
VIII. PERSONNEL TRAINING	17
IX. MAINTENANCE OF SORP.....	18
X. APPENDICES	19

I. AUTHORITY

This Sewer Overflow Response Plan (SORP) is prepared to facilitate proper incident reporting procedures outlined in MDEQ Agreed Order No **5823 10** and Section 750-2.7 Incident Reporting of the NPDES permits.

II. GENERAL

The Sewer Overflow Response Plan (SORP) is designed to facilitate the proper response to sewer overflows to by the appropriate City of Jackson (COJ) personnel and the proper reporting of such overflows to State and Local Authorities. For the purpose of this plan the City of Jackson or City of Jackson personnel includes all contractors who provide labor, materials, services or any other resource to comply with all applicable regulations and goals. Quick response will minimize the effects of the overflow with respect to impacts on public health, the environment, beneficial uses and water quality of surface waters and on customer service. The SORP further includes provisions for safety pursuant to the directions provided by the Mississippi Department of Environmental Quality (MDEQ) and that notification and reporting is made to the MDEQ and the Hinds County Department of Health (HCDH) when applicable.

A. Purpose

The purpose of the SORP is to:

1. Develop a proactive procedure to identify potential and actual sewer overflows;
2. Develop an immediate response plan to minimize health and environmental impacts from overflows;
3. Establish procedures to quickly eliminate the overflow;
4. Develop protocols to report SSOs to MDEQ and other agencies as appropriate; and
5. Develop public notification procedures to be used as appropriate.

"Sanitary Sewer Overflow" or "SSO" shall mean any discharge of wastewater to waters of the United States or the State from the City's Sewer System through a point source not specified in any NPDES permit, as well as any overflow, spill, or release of wastewater to public or private property from the Sewer System that may not have reached waters of the United States or the State, including all Building Backups.

The "POTENTIAL" SSO location is defined as the manhole or point at which an SSO is likely to occur in the event of a pump station failure. These were located by observing the lowest manhole (usually the closest to the pump station if not the pump station itself) by United Water and the City. These were visual observations only and not surveyed at this time.

This SORP is developed to address the fundamental types of SSOs:

• **Wet Weather Overflows**

Wet weather overflows result from excessive flows during significant rain events and/or elevated ground and surface water conditions. They can be attributed to a number of factors, including, but not limited to, the following:


- Downspouts
- Footing drains
- Sump pumps
- Leaking service laterals
- System Infiltration
- Flooding from the stormwater system

• **Dry Weather Overflows**

Overflows during dry weather are most often caused by flow restrictions or system disruptions. Dry weather SSOs can be attributed to a number of factors including, but not limited to, the following:

- Bottlenecks and/or blockages
- Grease
- Roots
- Debris
- Mechanical failures
- Sewer main breaks

Additionally, each of these types of SSO can lead to a discharge to either land, water of the U.S. or State, or within a building. The protocols outlined in the following sections describe the appropriate response to a SSO based on its location as shown on the following chart.



The SORP Long Term Corrective Actions Procedures (Section VII) discusses the type, location, destination, cause, impact, and containment and remediation requirements of SSO, as well as prevention measures.

The effective date of this plan is October 10, 2011. All schedules/proposed deadlines within this plan begin on the effective date. A detailed implementation plan can be found in Appendix A.

B. Organization of Plan

The key elements of the SORP are addressed individually as follows:

Section III	Overflow Identification and Response Procedure
Section IV	Building Backups Procedure
Section V	Public Advisory Procedure
Section VI	Regulatory Agency Notification Procedure
Section VII	Long Term Corrective Action Procedures
Section VIII	Personnel Training
Section IX	Maintenance of SORP
Section X	Appendices

III. OVERFLOW IDENTIFICATION AND RESPONSE PROCEDURE

The Overflow Identification & Response Procedure presents a strategy for the COJ to identify and then mobilize labor, materials, tools and equipment to correct or repair conditions, which may cause or contribute to a sewer overflow. The plan considers a wide range of potential system failures that could create an overflow to surface waters, land or buildings.

A. Receipt of Information Regarding an SSO

An overflow may be detected by COJ personnel or by others. COJ is diligent in attempting to identify SSOs before they become a public issue. After each significant rainfall event, COJ personnel shall remotely monitor or inspect potential and known SSO locations for problems. Significant rain events include those rain events that are known to be, or suspected of being, associated with, or contributing to SSO occurrences, regardless of the intensity, duration or measured rain gauge size of the event. In addition, other public offices such as police and fire departments are to report any SSOs encountered. COJ personnel are responsible to act based on received notification of sewage overflow from the wastewater collection system, and to provide immediate response to investigate and/or correct reported sewer overflow. Generally, telephone calls from the public reporting sewer overflows are received at the public offices identified in Appendix B. If received by another public office, that office will alert Public Works.

The call taker (person who received notice of an SSO) obtains all relevant information available regarding the overflow including:

- a. Time and date call was received;
- b. Caller's name and phone number;
- c. Specific location of problem;
- d. Description of problem;
- e. Time overflow was noticed by the caller;
- f. Observations of the caller such as odor and duration; and
- g. All relevant information that helps COJ personnel to quickly locate, assess and stop the overflow.

The call taker records initial information including their name in a Sewer System Work Order (Appendix C) and notifies Sewer Maintenance Division personnel. In addition to the Work Order form, which is used for sewer maintenance activities, reports of an overflow require additional information. Overflows are entered into a Wastewater SSO Assessment Form (Appendix C). In addition all information regarding a SSO is entered into the SSO database system.

B. Dispatch of Personnel to Site of Reported Sewer Overflow

The COJ will dispatch maintenance personnel to confirm reported overflows as soon as reasonably possible of receiving notification of the overflow(s). During the normal business hours, the goal of the City is for this confirmation to take place in less than one hour of the notification. During non-business hours, this confirmation should normally take place within two hours of the notification. In addition, the COJ proposes to divide the City, using existing police precincts, into sewer response zones. Each zone will have personnel and equipment assigned and located within that zone for SSO response. These zone response teams should be in place within 24 months. In the interim, COJ will continue to respond from existing maintenance facilities within the proposed time frame. These zones are shown on an Exhibit in Appendix D. The City is using the police precinct zones since these zones were previously defined and provided for a reasonable response area for each team. Until verified, the report of a possible spill will not be referred to as a "sewer overflow" only as a "maintenance activity". COJ personnel will complete the Wastewater SSO Assessment Form (Appendix C) within 24 hours of the reported activity and upon confirmation, provide the information orally to the MDEQ. The COJ Supervisor, Superintendent, Wastewater Collections engineer, or authorized designee is responsible for reviewing, updating and signing the final Sewage Overflow Report. Sewage overflow response internal notification and tracking protocol is summarized in Appendix D.

If the overflow will affect swimming areas during the swimming season, public drinking water intakes, or if it results in a fish kill, the COJ shall notify the MDEQ contact person and the HCHD contact person orally, immediately upon confirmation of the SSO. After business hours, any significant overflows should be reported to the MEMA 24 hour response number. An Exhibit showing the swimming areas can be found in Appendix D.

Failure of any element within the sanitary sewer collection system that threatens to cause or causes a SSO shall trigger an immediate response to isolate and correct the problem. Personnel and equipment shall be available to respond to any SSO locations. Additional maintenance personnel shall be "on call" in the event extra manpower is needed.

1. Dispatching Maintenance Personnel

- When COJ personnel receive notification of a potential sewer overflow, the COJ will dispatch maintenance personnel with appropriate resources as required.
- Maintenance personnel may be dispatched by telephone or radio or other means. The appropriate personnel, materials, supplies and equipment will be provided as needed.

2. Maintenance Personnel Instructions

- The call taker must verify that the entire message has been received and acknowledged by the maintenance personnel who were dispatched. All personnel being dispatched to the site of an SSO will proceed immediately to the site of the overflow. Any delays or conflicts in assignments will be reported immediately for resolution.
- In all cases responding maintenance personnel shall report their findings, including possible damage to private and/or public property, to their supervisor immediately upon completing their investigation. If the supervisor has not received findings from the field crew within one (1) hour of dispatch the supervisor will contact the responding maintenance personnel to determine the status of the investigation. The call time, dispatch time, and arrival time will be shown on the Wastewater Overflow Form.

3. Additional Resources

Should the superintendent or the wastewater collections engineer receive requests for additional personnel, material, supplies, and equipment from maintenance personnel working at the site of a sewer overflow, the request will be immediately forwarded to the appropriate supervisory personnel.

4. Preliminary Assessment of Damage to Private and Public Property

COJ personnel will take photographs of the sewer overflow impacted area in order to thoroughly document the nature and extent of impacts. Photographs will be retained for filing with the Overflow Report. COJ personnel shall only enter private property with permission from the property owner or tenant-in-possession.

5. Field Supervision and Inspection

- The COJ Superintendent, Wastewater Collections engineer, or authorized designee shall be responsible for verbally notifying MDEQ and HCDH within the specified 24 hour time period and submitting the Overflow Report to MDEQ. The contact information and required reporting timeframe can be found in Appendix E.
- The COJ Superintendent or Wastewater Collections engineer shall visit the site of the sewer overflow during and/or after work to ensure that provisions of this Overflow Response Plan and other directives are met.

6. Coordination with Hazardous Materials Response

- Upon arrival at the scene of a sewer overflow, should a suspicious substance (e.g., oil sheen, foamy residue) be found on the ground surface, or should a suspicious odor (e.g., gasoline) not common to the sewer system be detected, the COJ sewer maintenance crew shall immediately contact the responsible supervisor for guidance before taking further action.
- Should the supervisor determine the need to alert the hazardous material response team, the maintenance personnel shall await the hazardous waste team response.
- Contact the MDEQ 24-hour Emergency Response after hours at 1-800-222-6362.
- Upon arrival of the Hazardous Material Response Team, the COJ sewer maintenance personnel will take direction from the person with the lead authority of that team. Only after that authority determines it is safe and appropriate, will the COJ sewer maintenance personnel proceed under the SORP with the containment, clean-up activities and correction.

C. Overflow Correction, Containment, and Clean-Up

This section describes specific actions to be performed by COJ sewer maintenance personnel once a SSO has been identified and confirmed according to the procedures outlined in previous sections.

The objectives of these actions are:

- To protect public health, environment and property from sewage overflows and restore surrounding area back to normal as soon as possible;
- To establish perimeters and control zones with appropriate traffic cones and barricades, vehicles or use of natural topography (e.g. hills, berms);
- To promptly notify the regulatory agency with preliminary overflow information and potential impacts; and
- To contain the sewer overflow to the maximum extent possible including preventing the discharge of sewage into waters of the US and/or State.

1. Responsibilities of Maintenance Personnel Upon Arrival

It is the responsibility of the first personnel who arrive at the site of a sewer overflow to protect the health and safety of the public by mitigating the impact of the overflow to the maximum extent possible. If the overflow is not the responsibility of The City of Jackson, but there is imminent danger to public health, public or private property, or to the quality of waters of the state, then the COJ Supervisor, Superintendent, Wastewater Collections engineer, or authorized designee shall take prudent emergency action.

Upon arrival at a SSO, the COJ sewer maintenance personnel perform the following:

- Determines the cause of the overflow, e.g. sewer line blockage, pump station mechanical or electrical failure, sewer line break, etc.;
- Takes immediate steps to stop the overflow, e.g. relieves pipeline blockage, manually operates pump station controls, utilize portable by-pass pump system, repairs pipe, etc. Extraordinary steps may be considered where overflows from private property threaten public health and safety (e.g., an overflow running off of private property into the public right-of-way). Record what the blockage material is. For example: grease, rags, etc.;
- Requests additional personnel, materials, supplies, or equipment that will expedite and minimize the impact of the overflow; and
- If needed, identifies and requests assistance or additional resources to correct the overflow or to assist in determination of its cause.

2. Initial Measures for Containment

When possible, initiate measures to contain the overflowing sewage and recover sewage that has already been discharged. Take all steps necessary to minimize the impact to public health and the environment

- Determine the immediate destination of the overflow, e.g. storm drain, street curb gutter, body of water, stream bed, inside building, etc.;
- Identify and request the necessary materials and equipment to contain or isolate the overflow, if not readily available;
- Establish control zones to help prevent public access using appropriate signs and barricades; and
- Take immediate steps to contain the overflow, e.g., block or bag storm drains, recover through vacuum truck, divert into downstream manhole, etc.

3. Additional Measures Under Potentially Prolonged Overflow Conditions

In the event of a prolonged sewer line blockage or a sewer line collapse, set up a portable by-pass pumping operation around the obstruction.

- Take appropriate measures to determine the proper size and number of pumps required to effectively handle the sewage flow.
- Implement continuous or periodic monitoring of the by-pass pumping operation as required.
- Address regulatory agency issues in conjunction with emergency repairs.

Pump Station Emergency Procedures

Numerous pump stations throughout COJ's system have a pump station bypass into the force main. If the SSO is caused by pump failure at one of these stations, maintenance personnel should call for a portable by-pass pump system to be brought to the pump station so the station can utilize the bypass into the force main and continue to function while the station is being repaired. If the SSO occurs at a pump station without a pump station bypass into the force main a detailed plan for avoiding an additional SSO during the repair period will be included in the detailed resource plan for the SSO which is submitted to MDEQ. For example, COJ could utilize a temporary HDPE force main to transfer flow to the gravity system.

In addition, the COJ will conduct an evaluation and analysis to determine the storage volume and pump around procedures for each pump station. The COJ is currently reviewing existing documents to determine the extent of field work required to adequately estimate the storage volume for each pump station. The pump station emergency operations plan and volume inventory shall be completed within 180 days of MDEQ's approval of this SORP. This inventory will also include which stations have an emergency bypass into the force main. For those stations without a bypass a schedule will be submitted for the construction of the needed bypass within 12 months of the completed inventory. Appendix C contains a table of the potential overflow location for each pump station. These sites are shown on the included map as well.

4. Cleanup

Sewer overflow sites shall be cleaned thoroughly after an overflow, so that no sewage related residue (e.g., sewage solids, papers, rags, plastics, and rubber products) remains.

- Whenever possible digital photos should be taken of the area before and after cleanup.
- Where practical, thoroughly flush the area clear of any sewage or wash-down water. Solids and debris are to be flushed, swept, raked, picked-up, and transported for proper disposal. Next the area shall be thoroughly flushed clear of any sewage or wash-down water.
- Secure the overflow area to prevent contact by members of the public until the site has been thoroughly cleaned.
- Where appropriate, disinfect and deodorize the overflow site.
- Where sewage has resulted in ponding, pump the pond dry and dispose of the residue in accordance with applicable regulations and policies.
- If a ponded area contains sewage, which cannot be pumped dry, it may be treated with lime and aerated. If sewage has discharged into a body of water that may contain fish or other aquatic life, do not use bleach. Contact the MDEQ for specific instructions. See Appendix E for contact information.
- When backup is in a building, follow the procedures outlined in Section IV.

5. Minimize Transmitted Flows

Minimize the volume of untreated wastewater transmitted (via gravity or force main) into the portion of the sewer system impacted by the events precipitating the SSO.

- When an area is experiencing an SSO, determine the upstream (or tributary) areas that are contributing to the overflow and utilize the collection system for temporary storage. This may include temporary plugs in the gravity main or by manually controlling lift station pumps so as to pump on a delayed basis.
- When possible, utilize temporary pumps and force main to pump around the affected area.
- In extreme situations, it may be necessary to shut down commercial or industrial facilities that contribute high volumes of wastewater or to request the general public to limit water use. This action should only be performed by the Director of Public Works.

D. Sewage Overflow Report

The Wastewater SSO Assessment Form in Appendix C contains information which is required to be reported to MDEQ and possibly to HCDH depending upon the nature of the spill. The SSO Assessment Form will be provided to MDEQ within 5 days of the SSO. The COJ maintenance crew leader completes a Wastewater SSO Assessment Form then promptly notifies the COJ Water/Sewer Utilities Division and MDEQ when the overflow is eliminated. Along with the Assessment Form, when the corrective action is not a permanent one, the Superintendent, Wastewater Collections engineer, or authorized designee will prepare a detailed resource plan and milestone schedule for long term corrective action for the cause of the SSO. This plan and schedule will be submitted with the SSO Assessment form. Monitoring of compliance with the plan and schedule milestones will be conducted quarterly after the original occurrence.

If the overflow will affect swimming areas during the swimming season, public drinking water intakes, or results in a fish kill the COJ shall notify the MDEQ contact person and the HCDH contact person immediately upon confirming the discharge. See Appendix E for contact information.

In addition to the Assessment Form all information regarding a SSO will be entered into a Work Order and SSO database system which will be purchased and maintained by the City. This database system will allow the City to maintain long term records including, but not limited to, location, cause, date, volume, and corrective actions taken for SSOs throughout the City. The Work Order and SSO database will retain a minimum of five years of data. The City is purchasing and implementing a new data management system. This system shall be in place within 9-12 months of MDEQ's approval of this SORP. In the interim, the City will have all data entered into a MS Office database system by a contractor. At this time, the proposed contractor for data entry is WEI-AJA, LLC. Both the City and contractor will have access to the data. This data will be transferred to the new system once it is implemented. Information regarding the sewer overflow includes the following:

- Determination if the sewage overflow had reached waters of the State and/or waters of the US, i.e., all overflows where sewage was observed running to such waters, or there was obvious indication (e.g. sewage residue) that sewage flowed to these waters;
- Determination that the sewage overflow had not reached surface waters by describing conditions at the sewage overflow, which support this determination.
- Determination of the start date and time of the sewer overflow by one of the following methods:
 1. Date and time information received and/or reported to have begun and later substantiated by COJ sewer maintenance personnel; or
 2. Visual observation;
- Determination of the stop date and time of the sewer overflow by one of the following methods:
 1. When the blockage is cleared and/or flow is controlled or contained; or
 2. The arrival time of the COJ sewer maintenance personnel, if the overflow stopped between the time it was reported and the time of arrival.
- Determination of the volume of the sewer overflow using the "San Diego Method". This method uses image of overflowing manholes to provide a visual comparison. COJ shall complete its own image inventory for various flows within 180 days of MDEQ's approval of this SORP. Until the COJ image inventory is complete, the EPA provided images will be used.
- Photograph the event, when possible.
- Assessment of any damage to the exterior areas of public/private property. COJ sewer maintenance personnel shall not enter private property for purposes of estimating damage to structures, floor and wall coverings, and other personal property without authorization from their supervisor. Procedures for SSOs within an existing building are outlined in Section IV.

E. Customer Satisfaction

COJ personnel will follow up in person or by telephone with the entity who was reporting the overflow within five working days after work is complete. The cause of the overflow and its resolution will be disclosed.

IV. BUILDING BACKUPS PROCEDURE

A. Communication Plan

SSOs that backup into a building may be reported by any member of the public or customer served by the COJ's Wastewater Collection and Treatment System including homeowners, tenants in rental properties or personnel who work in commercial, industrial or institutional properties. Points of contact and phone numbers to call in the event of a building backup during normal working hours, Monday through Friday from 8:00 AM to 5:00 PM, are listed in the telephone directory. Customers can call the Utilities Division at 601-960-1189 or the Sewer Maintenance Division at 601-960-1875 to report building backups. After hours and on weekends, citizens should call the emergency number at 601-960-1875. In order to make customers aware of these numbers, the following will be added to all water/sewer bills: "To Report a Sewer Problem – Call 601-960-1189 or 601-960-1875 after business hours"

B. Response Process

Upon notification of a building backup, representatives of the COJ's Sewer Department will follow the timeframes and processes outlined in Section III of this plan entitled "Overflow Response Procedure". The personnel flow chart for this response can be found in Appendix D. Accordingly, COJ personnel will conduct a site investigation within the timelines outlined previously for business and non-business hours to determine if the cause is a problem in the COJ system or if it has occurred as a result of a failure on the customer's (private) side of the system.

If the building backup is found to be caused by a collection system failure on the public main, the COJ will immediately begin the response process to correct the problem and, in addition, will provide the property owner, property owner's representative or tenant with the names and contact information for authorized independent cleaning contractors who they may contact to clean and sanitize all indoor areas affected by the building backup. The independent cleaning contractor will use measures consistent with the standards in that industry to remove all waste and disinfect the affected areas. The work of the independent cleaning contractor is limited to cleaning the waste from the affected areas indoors and disinfecting those areas. The independent cleaning contractor will not be authorized to perform any services to repair or restore private property or the structure affected by the building backup. By providing the names of authorized independent cleaning contractors, the City does not assume responsibility for damages to the private property or structure affected by the building backup and will only pay the authorized independent cleaning contractor for costs associated with cleaning the waste from the affected building and for disinfecting the affected areas within the building. Neither this provision nor any other provision of the Sewer Overflow Response Plan shall be construed to create any private claim or cause of action against the City or other governmental entity, or to require the City or other governmental entity to compensate any private party for any loss or damage alleged to arise from or relate to a sanitary sewer overflow or building backup.

As part of the advanced planning and preparation, the Public Works Department will ensure that a list of authorized private contractors are maintained and that any such authorized

contractors are fully equipped to respond to building back-up events and perform various clean-up measures caused by sewage contamination. Those meetings will be conducted within 90 days of the adoption of the SORP. A list of authorized contractors will be created within 90 days after the completion of the interview process. Only contractors equipped to fully and quickly respond to a building backup will be included on the list of responding contractors. The City will expect all authorized contractors to respond as quickly as possible, but in no case longer than 6 hours, unless circumstances warrant and are documented. A list of authorized contractors can be found in Appendix B.

If a building backup is found to be caused by a private service lateral failure, the customer will be advised that the public collection system is functional and that they should seek the services of a plumber/professional cleaning service to remedy the problem at their expense.

C. System Repair Process

The materials and construction procedures to be used to correct or repair conditions in the COJ Sewer System will be in accordance with all applicable federal, state and local laws and regulations. No safety regulations, materials requirements or quality of construction craftsmanship will be compromised in the interest of getting the problem repaired quickly. The repair process will follow the procedures outlined in Section III.

D. Response Follow-Up

Measures taken to correct or repair conditions in the COJ sewer system that caused the building backup will be in accordance with those described in Section VII of this plan entitled "Long Term Corrective Actions Procedures". In addition, COJ personnel will follow up in person or by telephone with the entity who reported the overflow within five working days after cleaning work is complete. The cause of the overflow and its resolution will be discussed along with the adequacy of the clean-up. The City will annually review the effectiveness and timeliness of each contractor's performance in responding to building backups to determine whether the contractor should remain on the authorized list. Should the City receive any complaints about a contractor's performance, or should the contractor not respond within 6 hours of notification the City will immediately investigate and review the contractor's performance to determine whether the contractor should remain on the authorized list.

V. PUBLIC ADVISORY PROCEDURE

This section describes the actions the City of Jackson will take, in cooperation with the MDEQ and/or HCDH, to limit public access to areas potentially impacted by sewer overflows from the wastewater collection system.

When evaluating the potential impact of an SSO on public health and the environment, sensitivity factors will be evaluated. These factors will determine the level of public notification and clean up activity required. These sensitivity factors include proximity or impact to:

- Streams, rivers, creeks, and other natural waterways
- Heavy pedestrian or inhabited areas
- Special facilities such as schools, public parks, walking trails, etc.
- Swimming Areas
- Drinking Water Intakes

A. Control Zones

The first COJ personnel on site will attempt to prevent public access by establishing a control zone around the perimeter of the affected surface area using appropriate signs and barricading practices. The temporary signs and barricades will warn passersby to avoid contact with this area. Barricading practices will include, but be not limited to, cones, warning tape, barrels, barricades, etc. The limits, duration, and most appropriate control zone plan will vary on a case-by-case situation.

1. Location of Control Zones

Although the location of temporary signs and barricades will vary for each site, the goal will always be to warn the public to avoid contact until the cleanup is complete. When possible, the control zone will be posted:

- Just beyond the limits of the impacted surface area
- Near high pedestrian and/or vehicular traffic areas
- Other appropriate locations.

2. Duration of Control Zones

Signs and barricades will be posted as soon as the overflow is confirmed and they will remain in place until clean up activities are complete. The timeframe may vary depending on the extent of the response activities, which may include significant mitigation and cleanup requirements. Example signs can be found in Appendix B.

3. Public Information

The Public Works Director or their designee will answer questions from customers about COJ response to SSOs and, when necessary, will respond to the customer reporting the SSO to explain COJ's response. The control zone signs also include the contact number {(601)-960-1875} for the public to call for additional information. Contact information for public offices to be notified can be found in Appendix B. When deemed appropriate, the Public Works Director or his designee will issue a news release to warn customers about the SSO.

News Release [See Appendix B]

COJ maintains a standard news release on SSOs that can be quickly adapted to the particular situation and issued if COJ determines there is a significant threat to

public health. Contact information for media outlets can also be found in Appendix A.

Customer Letters [See Appendix B]

In situations where a service line issue has been identified, COJ sends letters to residential and commercial customers in the affected area. The letters advise the customer of their service line condition and their responsibility in alleviating future SSO by removing roots, extraneous water, disposing of grease and other materials properly and including a brochure on proper disposal.

Public Notification Decision Matrix

Event	Action
Overflow into streams	COJ will place temporary signs along the stream at public access points unless posted otherwise. Additional notification will be considered in conjunction with MDEQ and HCHD.
Overflow in a residential or high traffic area, such as a school or public park.	COJ will place temporary signs in the area of the overflow. Additional notification will be considered in conjunction with MDEQ and HCHD.
Overflow creating a significant health hazard or significant volume has reached waters of the US and/or State	COJ will issue a news release and place temporary signs in the area of the overflow. Additional notification will be considered in conjunction with MDEQ and HCHD.

VI. REGULATORY AGENCY NOTIFICATION PLAN

The Regulatory Agency Notification Plan establishes procedures that the City of Jackson follows to provide formal notice to the MDEQ in the event of a SSO. Agency notifications will be performed in parallel with other internal notifications. Internal notification and mobilization of COJ sewer maintenance personnel are established in Section III - Overflow Response Procedure.

Using data supplied during the verification process and updates from the maintenance personnel, the Sewer Maintenance Superintendent prepares initial and final Overflow/Bypass Reports. Initial report will be provided orally to the MDEQ and if necessary the HCDH within 24 hours from the time the COJ became aware of the SSO. If the overflow will affect swimming areas during the swimming season, public drinking water intakes, or results in a fish kill the COJ shall notify the MDEQ contact person and the HCDH contact person orally, or MEMA, if after business hours, immediately upon confirming the discharge. Contact information can be found in Appendix E.

COJ shall prepare and provide the written final report (digital or hard copy) to the regulatory agency within five (5) days after the COJ becomes aware of the overflow. The wastewater collections engineer is responsible for meeting the notification requirement. The superintendent prepares written notification to the appropriate regulatory agency of any confirmed overflows. The wastewater collections engineer signs these notifications. In addition, the detailed resource plan and milestone schedule for long term corrective action regarding SSOs will be submitted with the written report. Regardless of other notifications, a Report of Noncompliance form is required to be submitted with the monthly Discharge Monitoring Report.

A. Immediate Notification

If the overflow will affect swimming areas during the swimming season, public drinking water intakes, or results in a fish kill, the COJ shall notify the MDEQ contact person and the HCDH contact person orally, or MEMA if after business hours, immediately upon confirming the discharge.

COJ shall fax the initial and any updated Wastewater SSO Assessment Form to:

MDEQ	
Attn:	Environmental Compliance and Enforcement Division
	Municipal and Private Facilities
Telephone:	(601) 961-5171
Fax:	(601) 961-5674

B. Secondary Notification

Wastewater collections engineer, Superintendent, or authorized designee may contact other agencies, as necessary, as well as other interested and possibly impacted parties.

Hinds County Health Department
Environmental Health
539 E Beasley Road
PO Box 20
Jackson, MS 39205-0020
Contact Person:

Sherri Payne, Regional Environmentalist
Marvin Bolden, County Environmentalist
Lakeshia Paige, County Environmentalist
Phone: (601)-957-1026
Fax: (601)-957-1053
sherrie.payne@msdh.state.ms.us
marvin.bolden@msdh.state.ms.us
lakeshia.paige@msdh.state.ms.us

VII. LONG TERM CORRECTIVE ACTION PROCEDURES

The type of mitigation and remediation will vary depending on the cause of the SSO. Wet weather SSO are usually caused by inflow and infiltration (I/I), not by blockages or other problems in the system. Mitigation of wet weather overflows may not be possible until the overflow subsides, but when it does, the City will implement all necessary steps to clean up and disinfect the overflow site.

In addition, the City will remotely monitor or establish routine inspection routes to be completed after each significant rain event. Significant rain events include those rain events that are known to be, or suspected of being, associated with, or contributing to SSO occurrences, regardless of the intensity, duration or measured rain gauge size of the event. This inspection will look for visual signs of a SSO at locations having more than one SSO in the past two years and all pump stations not on a central monitoring system. A map of these locations and sample inspection form can be found in Appendix C. As the City begins these inspections, the most efficient inspection routes will be determined. The inspection program will be maintained by the City with the assistance of a contractor if needed. The City will supply the results of the inspection to the contractor to add to the appropriate database. The City will use the established rain gauges throughout the City to determine the intensity and duration of the rain event. The location of the rain gauges provides adequate coverage for each Police Precinct and is shown on the SSO Inspection Map in Appendix C. Initially, all sites will be inspected following each significant rain event. As rainfall information and inspection results are collected, these results will allow the COJ to evaluate the inspection list and determine when each site should be inspected based on rainfall intensity and duration. In addition any new sites where multiple SSOs have occurred will be added and those sites where permanent corrective action has been completed and SSOs are no longer occurring will be removed after demonstrating that the previously identified SSO is shown not to overflow during an average 2 year, 24 hour intensity rain storm. The Utility Manager will be responsible for the management of the inspection program. The SSO list will be reviewed monthly by the contractor to determine the appropriate status of each SSO.

Dry weather events will be addressed using several methods. COJ field professionals will identify the most effective method or combination of methods to return service to the system. Field crews will use television inspection to determine the most effective way to resolve any service disruption. CCTV inspection will identify the cause and location of the blockage and the necessary techniques needed to eliminate it. The following summarizes common abatement resolution activities. These resolution techniques can be used independently or combined based on field conditions and CCTV inspection.

- **Roots/Grease**

Combination cleaner/flusher equipment is used to remove any grease, roots, or other obstructions from the line. A root cutter attachment may be necessary to remove the obstruction. Heavy roots and related pipeline integrity problems (through CCTV inspections) are reviewed for replacement and/or rehabilitation. Heavy cleaning may also be achieved through third party services as appropriate.

- **Collapsed Pipe/Sewer Breaks**

An emergency pipe repair will be required to replace the defective or collapsed pipe. A work order will be initiated immediately and necessary containment and diversion procedures will be in place until the appropriate repairs are completed.

- **Mechanical Failures/Treatment Facility Malfunctions**

Portable by-pass pumping systems may be used until the repairs are completed at collapsed pipe, the pump station or treatment facility. The responding crews will notify their maintenance supervisor to acquire additional support from construction crews as soon as the emergency repairs are identified.

- **Remove I/I**

The City will evaluate systemic wet weather SSO and implement corrective measures as part of the Overflow Abatement Program. Currently the City is engaged in a program of I/I identification and repair as an ongoing SSES program.

The City's Work Order and SSO database tracking system will also be used to identify recurring problems within the system so each problem can be addressed properly.

VIII. PERSONNEL TRAINING

COJ personnel will conduct training for the appropriate response crews and support staff to ensure their compliance with the SORP. These training sessions will be organized based on the latest SORP, as well as other reference materials. Training sessions will be supplemented with a practical hands-on field component to prepare response personnel for anticipated situations.

The Utility Manager will be responsible for management of the training program. This will include signing off on completed training as well as reviewing required and future training needs. The training will be conducted by the City's chosen training contractor. The first training sessions were conducted by WEI-AJA, LLC in December 2010.

Also, COJ will conduct refresher sessions annually or when changes are made to the SORP to ensure the same results. COJ will oversee the SORP to ensure that the established procedures are being followed during implementation and field operation.

A detailed training plan is included in Appendix F. Appropriate training materials are being prepared separately.

IX. MAINTENANCE OF SORP

COJ will review the SORP during the first quarter of each year and amend it as appropriate. Any changes or amendments to this SORP shall be sent to MDEQ by April 30 after each annual review. The review shall be conducted by the Public Works Director or his designee. Review shall include, at a minimum, the following activities:

- * Conduct workshop with managers and key personnel to review response activities and gather suggestions for new or revised procedures
- * Review all contact lists and update as necessary
- * Update the SORP as needed in regard to updated regulatory requirements

X. APPENDICES

Appendix A – Detailed Implementation Plan

Appendix B - Public Offices, Media Contact, and Authorized Cleanup Contractors Contact Information

Appendix C – Wastewater SSO Assessment Forms & Maps

Appendix D - Sewer Overflow Response Internal Notification & Tracking Protocol

Appendix E – Regulatory Agency Contact Information and Notification Period

Appendix F – Personnel Training Documents

SORP Implementation Plan

1. Personnel – Advertise all vacant positions within the Sewer Division – 31 Positions (See Attached Personnel Schedule). Positions will be advertised within 60 days of SORP adoption. (See Attached Crew Description for the general description of crew responsibilities regarding SORP).
2. Training – COJ and its subcontractors will begin preparing training materials to begin SORP Training Classes for all relevant personnel within 60 days.
3. PS Evaluation - COJ will begin an inspection of each pump station to determine the capacity and needed improvements. The storage capacity of each station will be determined within 180 days.
4. Post Rainfall Inspection – COJ will begin inspecting known and potential overflow locations after each rainfall immediately upon adoption of the SORP. Until all staffing needs are met, COJ will use subcontractors to complete these inspections.
5. Recordkeeping and Reporting - COJ will immediately begin sending all SSO reports to subcontractor for entry into a MS Office database. This system will be utilized until the new data management system is online.
6. Response Zones – Within 24 months, the COJ will establish response teams within each police precinct to respond to any SSO's. In the interim, existing staff and subcontractors will respond to all SSO's.
7. Equipment Needs – Existing aging equipment will have to be replaced in order for sewer crews to adequately perform. COJ will evaluate existing equipment and prioritize needed equipment purchases within 60 days.

Sewer Division Crew Description

Construction Crews

The sewer division will include one superintendent and four-field supervisors. The field supervisors will manage eight construction crews. Each supervisor will manage one precinct with two construction crews. Each construction crew will include a crew leader, one heavy equipment operator II, two heavy equipment operators I, one equipment operator II, three maintenance workers II and two maintenance workers I. These crews will install paid taps, repair main lines, repair cave-ins, raise manholes top, etc.

SORP Crews

The supervisor will also manage two Sewer Overflow Response Crews. Each crew will include a crew leader, one heavy equipment operator II, two maintenance workers II, and a maintenance worker I. These crews will responds to any SSO reports, clean main lines, and televise main lines, locate manholes, smoke test, dye test, and inspect manholes.

Equipment Assignments:

Each Construction crew will need one crew/ tool truck, two 14 yd. dump trucks, one backhoe, one air compressor, small pumps 2-inch to 3-inch, pipe saws, backhoe trailer, and other construction equipment.

Each SORP Response Crew will need one tv truck, one combination jet truck, laptop, pumps, plugs, etc.

Two track excavators, two rubber tire backhoes (for back filling), and one bulldozer, will support all eight construction crews.

CURRENT PERSONNEL SCHEDULE

POST CENTER	OCCUPATION CODE	POSITION TITLE	FSLA	RANGE	2003	2004	2005	2006	2007	2008	2009	2010	2011	VACANT POSITIONS as of 10-15-2010
52210 SEWER ADMINISTRATION														
	0283-0-01	SENIOR CIVIL ENGINEER	S	E	031	0	0	1	1	1	1	1	1	1
	0051-0-01	CIVIL ENGINEER II	S	E	029	0	0	1	0	1	1	1	1	0
	0060-0-01	CIVIL ENGINEER I	S	E	027	1	1	1	1	0	0	0	0	0
	9802-0-01	PROJECT/CONSTRUCTION MANAGER	S	E	027	0	0	0	0	0	0	0	0	0
	6576-0-01	ENGINEERING GRADUATE	S	NE	026	1	1	0	0	0	0	0	0	0
	0315-0-01	SEWER SYSTEMS SUPERINTENDENT	S	E	025	0	0	0	0	0	0	0	0	0
	6577-0-01	ENGINEERING TECHNICIAN	S	NE	024	0	0	1	1	1	1	1	1	0
	0425-0-01	METERING STATION TECHNICIAN	S	NE	020	1	1	1	1	1	1	1	1	0
	0112-0-01	ENGINEERING INSPECTOR	S	NE	019	1	1	0	0	0	0	0	0	0
	0107-0-01	DRAFTING TECHNICIAN	S	NE	014	3	3	3	3	3	3	3	3	1
	0008-0-01	ADMINISTRATIVE SECRETARY	S	NE	014	1	1	1	1	1	1	1	1	1
	0270-0-01	SECRETARY	S	NE	012	1	1	1	1	1	1	1	1	0
	0309-0-01	SEWER METER MAINTENANCE WORKER	S	NE	009	1	1	1	1	1	1	1	1	0
Total Full-Time					10	10	10	10	10	11	11	11	11	3
Total Allocated Positions														
52215 MAINTENANCE SUPPLY														
	0245-0-01	PURCHASING MANAGER	S	E	026	0	0	1	1	1	1	1	1	0
	0256-0-01	PURCHASING SUPERVISOR	S	E	023	0	0	1	1	1	1	1	1	0
	0160-0-01	INVENTORY CONTROLLER	S	NE	016	0	0	1	1	1	1	1	1	0
	0432-0-01	OFFICE COORDINATOR	S	NE	019	0	0	1	1	1	1	1	1	0
	0149-0-01	HEAVY EQUIPMENT OPERATOR I	S	NE	012	0	0	1	1	1	1	1	1	0
	0326-0-01	STOREKEEPER	S	NE	010	0	0	3	3	3	3	3	3	0
	0175-0-01	MAINTENANCE WORKER II	W	NE	009	0	0	1	1	1	1	1	1	0
Total Full-Time					0	0	5	5	5	5	5	5	5	0
Total Allocated Positions														
52220 SEWER OPERATIONS & MAINTENANCE														
	0310-0-01	SEWER SYSTEMS SUPERINTENDENT	S	E	025	1	1	1	1	1	1	1	1	0
	0432-0-01	OFFICE COORDINATOR	S	NE	018	1	1	1	1	1	1	1	1	0
	0311-0-01	SEWER SYSTEMS SUPERVISOR	S	E	018	3	3	3	3	3	3	3	3	1
	0074-0-01	CREW LEADER	S	NE	014	1	1	1	1	1	1	1	1	0
	0059-0-01	ADMINISTRATIVE SECRETARY	S	NE	014	1	1	1	1	1	1	1	1	0
	0160-0-01	HEAVY EQUIPMENT OPERATOR II	S	NE	012	1	1	1	1	1	1	1	1	0
	0117-0-01	EQUIPMENT OPERATOR II	S	NE	012	1	1	1	1	1	1	1	1	0
	0149-0-01	HEAVY EQUIPMENT OPERATOR I	S	NE	012	0	0	6	6	6	6	6	6	4
	0279-0-01	SECRETARY	S	NE	012	1	1	1	1	1	1	1	1	0
	0247-0-01	PUBLIC SERVICE DISPATCHER	S	NE	011	0	0	5	5	5	5	5	5	1
	0116-0-01	EQUIPMENT OPERATOR I	S	NE	010	3	3	3	3	3	3	3	3	2
	0253-0-01	SENIOR MAINTENANCE WORKER	W	NE	011	3	3	3	3	3	3	3	3	3
	0179-0-01	MAINTENANCE WORKER II	W	NE	009	23	23	23	23	23	22	17	17	2
	0175-0-01	MAINTENANCE WORKER I	W	NE	007	2	2	1	1	1	2	2	2	3
	0234-0-01	SENIOR CLERK/STODMAN	W	NE	007	0	0	1	1	1	1	1	1	0
Total Full-Time					60	60	60	60	60	59	59	59	59	24
Total Allocated Positions														
52225 SEWER EVALUATION SERVICE														
	0311-0-01	SEWER SYSTEMS SUPERVISOR	S	E	018	1	1	1	1	1	1	1	1	0
	0074-0-01	CREW LEADER	S	NE	016	4	4	4	4	4	4	4	4	0
	0279-0-01	SECRETARY	S	NE	012	1	1	1	1	1	1	1	1	0
	0149-0-01	HEAVY EQUIPMENT OPERATOR I	S	NE	012	4	4	4	4	4	4	4	4	1
	0252-0-01	SENIOR MAINTENANCE WORKER	W	NE	011	12	12	12	12	12	11	11	11	0
	0179-0-01	MAINTENANCE WORKER II	W	NE	009	32	32	32	32	32	22	22	22	8
Total Full-Time					32	32	32	32	32	32	22	22	22	7
Total Allocated Positions														
SEWER DEPARTMENT TOTAL FULL-TIME														
					92	97	101	101	101	101	101	101	101	31
Total					101					101				

APPENDIX B- PUBLIC OFFICES, MEDIA CONTRACT, AUTHORIZED CLEANUP CONTRACTORS CONTACT INFORMATION

Contact Name	Telephone
City of Jackson Water/Sewer Utilities Division:	(601) 960-2090
City of Jackson Sewer Maintenance Division:	(601) 960-1875
JWP Project Manager:	(601) 421 0610
Savanna Street Wastewater Treatment Plant (SSWWTP):	(601) 372-3439
Fire Department:	911 emergency or (601) 960-1234
COJ Police:	911 emergency or (601) 960-1234
Hinds County Health Department	(601)-957-1026

MDEQ

During Normal Operating Hours – 8:00 a.m. – 5:00 p.m.

MDEQ Operator – 601-961-5171

MDEQ ECED Municipal & Private Facilities Branch Manager – 601-961-5588

MDEQ ECED Engineer for Jackson – 601-961-5319

After Normal Operating Hours (non-emergency)

(Voice Mail)

MDEQ ECED Municipal & Private Facilities Branch Manager – 601-961-5588

MDEQ ECED Engineer for Jackson – 601-961-5319

After Normal Operating Hours (emergency)

MEMA 24-hour State Warning Point – 1-800-222-6362

LIST OF MEDIA CONTACTS TO REPORT OVERFLOW

Contact Name	Telephone
Clarion Ledger:	(601) 961-7250
WLBT:	(601) 948-3333
WJTV:	(601) 372-6311
WAPT:	(601) 922-1607

STANDARD PRESS RELEASE

COJ maintains a standard press release on SSO that can be quickly adapted to the particular situation and issued if COJ determines there is a significant threat to public health.

NEWS RELEASE

DATE XXXXXXXXX

For Immediate Release

For More Information

Contact: Public Works Director

601-960-2091

COJ Alerts Customers to Sanitary Sewer Overflow

COJ issued an alert today to people in the [insert area(s)] concerning a sanitary sewer overflow.

"The overflow occurred as a result of [significant rain event/ a blockage/ or other]," said Public Works Director or Authorized Designee. "COJ responds to overflows in a manner consistent with state and federal standards. We warn passersby to avoid contact by posting signs and using barricades, and we disinfect the area after the overflow stops."

- Location of overflow (by street address or other appropriate method)
- Cause of the SSO
- Destination of the SSO flow (e.g. waterbody, name of receiving water, MS4 system, etc.)
- Estimated Volume

Note: Use this paragraph if the overflow is in a recreational area or significantly affects a stream etc.

The signs do not necessarily prohibit use of recreational areas, unless posted otherwise. The Mississippi Department of Environment (MDEQ) determines whether to post nearby waterways that may have been affected if water quality testing indicates a need.

Overflows pose hazards similar to those in public restrooms or even your own bathroom. If you, your family, or your pets do have contact with the overflow, wash thoroughly with soap and water.

Remember: Washing your hands carefully and often is the best defense against illness carried by animal or human waste.

If you have questions or need to report an overflow, please call COJ at (601)-960-1875.

CUSTOMER NOTIFICATION LETTER

Maintenance of Sewer Service Connection

These letters will be modified by the author per specific location and condition

FIRST NOTIFICATION

Date: XXXXX

Name: XXXXXXXX

Address: XXXXXXXX

RE: Notice of collection system non-compliance

The Municipal Code of the City of Jackson requires that owners maintain their sewer service line "in such a condition as to safeguard the property, life and health of others". Specifically this means that excess ground water overloading the public system through joint leaks, sump pumps, roof drain or surface water inlets or sewer line blockages due to root intrusion, grease and/or debris from the service line is prohibited.

The City has determined that your sewer service line is impacting the operating condition of the public system. In accordance with City Code, you must take action to ensure that your service line is in proper operating condition.

The City fully recognizes that you may not have been aware of problems in your service line and that you may not have experienced any service problem. Taking the necessary corrective action to restore your service line to its intended operating condition will protect your interests as well as the public.

In order to provide adequate time for you to address these service line problems, the City will reinvestigate the public main serving your property on or about _____ (sixty (60) days) from the date of this letter. If there is evidence that the condition affecting the public system is not corrected, the City will take appropriate action that may include interruption of water service to this address until such time as the sewer service line problem(s) is corrected. There may also be additional charges for water service disconnection and reinstatement.

COJ is willing to work with you to the extent possible on the correction of your service lateral problems. You may call to make an appointment to discuss by calling (601)-960-1875 and speak to the dispatcher on duty.

SAMPLE SEWER OVERFLOW SIGN

CAUTION!

SEWER OVERFLOW

Avoid Bodily Contact With Water

For More Information Contact

City of Jackson- (601)-960-1875

APPENDIX C – WASTEWATER ASSESSMENT FORMS & MAPS





**CITY OF JACKSON, MISSISSIPPI
SEWER SYSTEM WORK ORDER FORM**

City of Jackson, MS
Dept. of Public Works
P.O. Box 17
Jackson, MS 39205
601-960-2091

Date: _____ Complaint # : _____ Utility Locate # : _____

Reported By: _____ Owners Name: _____

House #: _____ Street: _____ Phone #: _____

Serviced By: _____ Plumber On Site: _____ Time In: _____ Time Out: _____

Complaint Type	
<input type="checkbox"/> Sewer Stopped Up	<input type="checkbox"/> Clean Sewer Line
<input type="checkbox"/> Check Sewer Odor	<input type="checkbox"/> Sewer Tap
<input type="checkbox"/> Sewer Leak	<input type="checkbox"/> Repair Main Line
<input type="checkbox"/> Toilet Overflow	<input type="checkbox"/> Seal Down MH Lid
<input type="checkbox"/> Sewer in Tub	<input type="checkbox"/> Locate Sewer Lines
<input type="checkbox"/> Sewer in Yard	<input type="checkbox"/> Check For Available Sewer Line
<input type="checkbox"/> Cleanout Overflow	<input type="checkbox"/> Disconnect Service Line
<input type="checkbox"/> Manhole Overflow	<input type="checkbox"/> Plug/Disconnect Abandon Sewer
<input type="checkbox"/> Sewer in Ditch	<input type="checkbox"/> TV Sewer Line
<input type="checkbox"/> Sewer in Creek	<input type="checkbox"/> Smoke Test Sewer Line
	<input type="checkbox"/> Check Air Release Valve
	<input type="checkbox"/> Check Stream Crossing
	<input type="checkbox"/> Mainline Row/Easement
	<input type="checkbox"/> Clean/Dress-Up Yard
	<input type="checkbox"/> Disinfect/Flush Yard
	<input type="checkbox"/> Flush Out Ditch
	<input type="checkbox"/> Sanitary Street WWTF
	<input type="checkbox"/> Audit Other Department
	<input type="checkbox"/> Other

Account Type	Location	Problem Type	No City Problem	Service Line Problem	Weather
<input type="checkbox"/> Residential	<input type="checkbox"/> In House	<input type="checkbox"/> Sewer Main	<input type="checkbox"/> Main Line OK	<input type="checkbox"/> City ROW	<input type="checkbox"/> Tap Goes To Manhole
<input type="checkbox"/> Business	<input type="checkbox"/> Under Bldg.	<input type="checkbox"/> Sewer Tap	<input type="checkbox"/> Advised Customer Needs Number	<input type="checkbox"/> Customer	<input type="checkbox"/> Existing City Cleanout
<input type="checkbox"/> Gov. Federal	<input type="checkbox"/> Front Yard	<input type="checkbox"/> Manhole			
<input type="checkbox"/> Gov. State	<input type="checkbox"/> Back Yard	<input type="checkbox"/> Service Line			
<input type="checkbox"/> Gov. County	<input type="checkbox"/> Cleanout	<input type="checkbox"/> Pump Station			
<input type="checkbox"/> Gov. City	<input type="checkbox"/> Manhole	<input type="checkbox"/> Force Main			
<input type="checkbox"/> Other	<input type="checkbox"/> Storm Drain	<input type="checkbox"/> Other			
	<input type="checkbox"/> Ditch/Creek				
	<input type="checkbox"/> Other				

Description of Repairs	
<input type="checkbox"/> Checked Sewer Odor	<input type="checkbox"/> Repaired/Replaced Cleanout
<input type="checkbox"/> Unstopped Sewer Main	<input type="checkbox"/> Install New Cleanout
<input type="checkbox"/> Unstopped Service Line	<input type="checkbox"/> Repaired/Replaced Sewer Tap
<input type="checkbox"/> Unstopped Main and Service	<input type="checkbox"/> Installed New Sewer Tap
<input type="checkbox"/> Rotted Service Line	<input type="checkbox"/> Located Manhole
<input type="checkbox"/> Cleaned Main Line	<input type="checkbox"/> Uncovered Manhole
<input type="checkbox"/> Point Repaired Sewer Line	<input type="checkbox"/> Raised/Lowered Manhole
<input type="checkbox"/> Replaced Section of Line	<input type="checkbox"/> Replaced MH Ring
<input type="checkbox"/> Replaced Entire Line	<input type="checkbox"/> Replaced MH Lid
<input type="checkbox"/> Installed New Sewer Line	<input type="checkbox"/> Sealed MH Lid
	<input type="checkbox"/> Replaced/Removed Abandoned Sewer
	<input type="checkbox"/> Maintained ROW/Easement
	<input type="checkbox"/> Cleaned/Dressed Up Yard
	<input type="checkbox"/> Disinfect/Flushed Yard/Ditch
	<input type="checkbox"/> Put Tag On Door
	<input type="checkbox"/> Assisted Other Dept.
	<input type="checkbox"/> No Action
	<input type="checkbox"/> Other (explain below)

Pipe Material: ☐ Concrete ☐ PVC ☐ DIP ☐ TRUSS ☐ HOPE ☐ Other: _____

Pipe Size: _____ Ins. Pipe Depth: _____ ft. MH Size: _____ Ins. MH Depth: _____ ft.

Other Needs/Explanation of Repairs: _____

Crew Leader _____ Supervisor _____ Complainant's Signature _____ Date _____



City of Jackson, Mississippi
Wastewater Overflow Assessment Form

City of Jackson, Mississippi
Department Of Public Works
Post Office Box 17
Jackson, MS 39205
601-960-2091

Notification Date _____ Time _____ AM
PM Sewer Complaint # _____

Name of Person Reporting Overflow _____

House Number _____ Street _____ Phone _____

House Number of Overflow _____ Street _____

SSO Location _____ Dispatch Date _____ Time _____ AM
PM

Arrival Date _____ Time _____ AM
PM Verification Date _____ Time _____ AM
PM

Latitude _____ Longitude _____ Precinct _____

NPDES System Area (circle) Savannah St. Trahon Presidential Hills
(MS0024295) (MS0044059) (MS030295)

Receiving Waterway: Belhaven Caney Hanging Moss Purple Trahon
(circle) Big Creek Eastover Hardy Three Mile White Oak
Bogue Chitto Eubanks Lynch Town

Did overflow reach waterway? ☐ Yes ☐ No Line Ownership: ☐ Municipal ☐ Private

Overflow Source ☐ Manhole ☐ Constructed Bypass ☐ Pump Station
☐ Ground Surface (defective pipe underground) ☐ Cleanout
☐ Other _____

Date/Time Overflow Began _____ (circle) AM PM Date /Time Overflow End _____ AM
PM

Estimated Volume of Discharge _____ Gallons Estimation Method _____

Cause of Overflow: ☐ Grease ☐ Roots ☐ Solids ☐ Collapsed Pipe
☐ Pump Station Failure ☐ Excessive Flow ☐ Undersized Line
☐ Other (Describe) _____

Temporary Corrective Action: (see Attached Photos) _____

This section to be completed in the field.

MDEQ Notification Date _____ Time _____ AM
PM

Number of Overflows at this Location within Past 12 Months (Including Dates of Overflows): _____

Actions taken to minimize environmental impact (See Attached Photos) _____

If Overflow Cause Due to Rainfall, Number of Inches of Rain _____

Planned Permanent Corrective Action – If Applicable – (Itemization and Schedule) – See attached Detailed Resource Report and Schedule Work Order No.: _____

Public Notification: ☐ Yes ☐ No If yes - ☐ Signs ☐ News Release ☐ Other _____

Customer Satisfaction Response/Additional Comments – If applicable, see Attached. _____

This section to be completed by supervisor.

Signature of City Respondent _____

Signature of Authorized Supervisor _____



**City Of Jackson, Mississippi
Sewer System Overflow Inspection Form**

City of Jackson, Mississippi
Department Of Public Works
Paw Printers Box 17
Jackson, MS 39201
(601) 259-2991

NO.	Address	Inspector	Date	Overflow Observed	Overflow Frequency	PS	Overflow Location	PS Frequency	Overflow Type	Comments
1	15 South					PS	Harty Creek	1		
2	Amanda Lane					PS	Big Creek	1		
3	Brookholme Drive L 160					PS	Trabon Creek	1		
4	6675 Hwy 18					PS	Trabon Creek	1		
5	2102 Thousand Oaks					PS	Trabon Creek	1		
6	Roadway Cove					PS	Trabon Creek	1		
7	461 Greenmount Drive					PS	Trabon Creek	1		
8	201 Cedarwood Drive					PS	Trabon Creek	1		
9	140 Chiswood Avenue					PS	Trabon Creek	1		
10	1453 Country Club Drive					PS	Bogue Chitto Creek	2		
11	125 Delray Avenue					PS	Causey Creek	1		
12	185 Duffinville Drive					PS	Trabon Creek	1		
13	553 Eden Downs					PS	Trabon Creek	1		
14	F-55 Frontage Road					PS	Causey Creek	1		
15	207 Elton Road					PS	Causey Creek	1		
16	J-55 Water Plant					PS	Belhaven Creek	1		
17	717 Flag Chapel Road					PS	Bogue Chitto Creek	2		
18	992 Flag Chapel Road					PS	Bogue Chitto Creek	2		
19	1451 Forest Avenue					PS	Purbaux Creek	3		
20	155 Forest Hill Drive					PS	Trabon Creek	1		
21	3557 Forest Hill Road					PS	Trabon Creek	1		
22	3283 Forest Park Drive					PS	Trabon Creek	1		
23	Greenwing Court					PS	Purple Creek	1		
24	2130 Hickory Drive					PS	Causey Creek	1		
25	561 Hilldale Drive					PS	Trabon Creek	1		
26	174 Lakeside Road					PS	Trabon Creek	1		
27	4055 Vesta Avenue					PS	Trabon Creek	1		
28	4391 Terry Road					PS	Causey Creek	1		
29	201 Red Hill Drive					PS	Trabon Creek	1		
30	160 Marshall Avenue					PS	Trabon Creek	1		
31	Holly Hills Drive					PS	Trabon Creek	1		
32	Robinson Drive					PS	Trabon Creek	1		
33	500 McCluer Road					PS	Causey Creek	1		
34	3890 McCluer Road					PS	Causey Creek	1		
35	687 McCluer Road					PS	Trabon Creek	1		
36	1073 McCluer Road					PS	Trabon Creek	1		
37	1665 McCluer Road					PS	Trabon Creek	1		
38	3694 Moore Drive					PS	Causey Creek	1		
39	1155 Hillview					PS	Causey Creek	1		
40	4813 McRaven Road					PS	Lynch Creek	2		
41	4660 McRaven road					PS	Lynch Creek	2		
42	5186 McRaven road					PS	Lynch Creek	2		
43	600 McRaven road					PS	Lynch Creek	2		
44	6112 Floral Drive					PS	Hanging Moss Creek	2		
45	3702 W. Northside Drive					PS	Bogue Chitto Creek	2		
46	4837 Old Bernon Road					PS	Trabon Creek	1		
47	4681 Old Byron Road					PS	Trabon Creek	1		
48	Palum Street					PS	Bogue Chitto Creek	2		
49	Plantation Court					PS	White Oak Creek	4		
50	155 Portwood Drive					PS	Trabon Creek	1		
51	2108 Raymond Road					PS	Causey Creek	1		
52	3440 River Thames Road					PS	White Oak Creek	4		
53	3407 River Thames Road					PS	White Oak Creek	4		
54	5293 Robinson Road					PS	Causey Creek	1		
55	10 Rob Lane					PS	Trabon Creek	1		
56	2238 Sheffield Drive					PS	Hanging Moss Creek	4		
57	6340 Country Club					PS	Bogue Chitto Creek	3		
58	245 S. Shellrock					PS	Bogue Chitto Creek	3		
59	3438 Devon Sykes Road					PS	Bogue Chitto Creek	3		
60	1466 Short Avenue					PS	Trabon Creek	1		
61	4095 Sneed Road					PS	Big Creek	1		
62	4071 Sneed Road					PS	Trabon Creek	1		
63	139 Stratford Drive					PS	Trabon Creek	1		
64	6065 Clinton Boulevard					PS	Lynch Creek	1		
65	151 Sylvan Trail					PS	Lynch Creek	3		
66	351 Sylvan Trail					PS	Lynch Creek	3		
67	498 Sylvan Trail					PS	Trabon Creek	3		
68	4640 Terry Road					PS	Trabon Creek	3		
69	6115 Hwy. 18					PS	Trabon Creek	1		
70	132 Timberlawn Road					PS	Trabon Creek	1		
71	6159 US Hwy. 49 North					PS	Bogue Chitto Creek	3		
72	Weston Hills Drive					PS	Trabon Creek	1		
73	1900 Wallace Street					PS	Lynch Creek	1		
74	1790 Wallace Street					PS	Lynch Creek	2		
75	1631 Wallace Street					PS	Lynch Creek	2		
76	1914 US Hwy. 30 West					PS	Lynch Creek	2		
77	42111 Church Circle					PS	Lynch Creek	2		
78	500 E. Gumming Drive					PS	Lynch Creek	2		
79	1238 Zephyr Street					PS	Lynch Creek	2		
80	6515 Yarbrough Street					PS	Lynch Creek	2		
81	4130 Wrenhall Road					PS	Lynch Creek	2		
82	Whitestone Road					PS	Hanging Moss Creek	2		
83	Shamoodle Drive					PS	Trabon Creek	1		
84	3855 Yarrow					PS	Lynch Creek	2		
85	W. River Place					PS	Belhaven Creek	2		



City Of Jackson, Mississippi Sewer System Overflow Inspection Form

City of Jackson, Mississippi
Department 11 / Public Works
6000 Old Hwy 17
Jackson, MS 39205
601.955.6001

86	Old River Place				PS	Belhaven Creek	2		
87	Apache Road #1				PS	Big Creek	1		
88	Apache Road #2				PS	Big Creek	1		
89	Presidential Hills				PS	Angusville Creek	1		
90	3010 Chadwick Drive				PS	Caney Creek	1		
91	4235 Echelon Parkway				PS	Hanging Moss Creek	1		
92	677 Woods Dr. Jackson, MS 39212				EPA List	Caney Creek	1		
93	475 Woods Dr. Jackson, MS 39212				EPA List	Caney Creek	1		
94	136 Shiloh Dr. Jackson, MS 39212				EPA List	Handy Creek	1		
95	130 Shiloh Dr. Jackson, MS 39212				EPA List	Handy Creek	1		
96	5400 Interstate 55 Frontage Rd. Jackson, MS 39212				EPA List	Caney Creek	1		
97	5400 Interstate 55 Frontage Rd. Jackson, MS 39212				EPA List	Caney Creek	1		
98	4825 Old Bryant Rd. Jackson, MS 39212				EPA List	Trabon Creek	1		
99	8355 Rivers St 8/26/2010				posted	Handy Creek	1	2010.1	
100	Moore & Charles 8/3/2010				posted	Belhaven Creek	4	2010.2	
101	159 Holly Hill Dr. Jackson, MS 39212				EPA List	Trabon Creek	1		
102	Hanging Moss Creek crossing near JA 9/29/2010				posted	Hanging Moss Creek	4	2010.3	
103	3300 80 near Wiggins Rd & Shaw Rd				posted	Lynch Creek	2	2010.4	
104	155 Holly Hill Dr. Jackson, MS 39212				EPA List	Trabon Creek	1		
105	Adams Ave behind the Grace Homes 10/1/2010				posted	Town Creek	4	2010.5	
106	201 Courtney Circle Dr				posted	Lynch Creek	1	2010.6	
107	2427 Wheatley St. Jackson, MS 39212				EPA List	Caney Creek	1		
108	3725 Jester Ave.				posted	Lynch Creek	2	2010.7	
109	4907 Ramsey Dr. 10/13/2010				posted	Lynch Creek	2	2010.8	
110	2884 Maryland Dr. Jackson, MS 39212				EPA List	Caney Creek	1		
111	Ritchey & Holden St. 10/20/2010				posted	Lynch Creek	2	2010.9	
112	Gahret & South Dr. 10/20/2010				posted	Lynch Creek	2	2010.10	
113	2937 Maryland Dr. Jackson, MS 39212				EPA List	Caney Creek	1		
114	Jayne & Sanford St. 10/20/2010				posted	Lynch Creek	2	2010.11	
115	2926 Greenwood Ave. 10/20/2010				posted	Jenny Creek	1	2010.5420	
116	5982 Napier St. 10/20/2010				posted	Roberts Creek	4	2010.5422	
117	2410 Belvedere Dr. 10/20/2010				posted	Three Mile Creek	1	2010.5440	
118	825 Carver St. 10/25/2010				posted	Town Creek	3	2010.5506	
119	1425 Tapp Ave. 10/25/2010				posted	Lynch Creek	2	2010.5510	
120	2424 Belvedere Dr. Jackson, MS 39204				EPA List	Three Mile Creek	1		
121	1295 Palmyra St. 10/25/2010				posted	Town Creek	3	2010.5542	
122	1613 Dellwood Dr. 10/26/2010				posted	Caney Creek	1	2010.5543	
123	2314 Belvedere Dr. Jackson, MS 39204				EPA List	Three Mile Creek	1		
124	540 Houston Ave. 10/26/2010				posted	Lynch Creek	2	2010.5595	
125	2111 East Dr. Jackson, MS 39204				EPA List	Three Mile Creek	1		
126	150 Lowell Woods Dr. 10/29/2010				posted	Caney Creek	1	2010.5559	
127	2101 East Dr. Jackson, MS 39204				EPA List	Three Mile Creek	1		
128	Alta Woods Blvd. 10/29/2010				posted	Three Mile Creek	1	2010.5562	
129	2984 Skyline Dr. 10/30/2010				posted	Town Creek	3	2010.5585	
130	2012 Willow Way. Jackson, MS 39204				EPA List	Three Mile Creek	1		
131	4540 Woodland Ave. 10/30/2010				posted	Roberts Creek	3	2010.5587	
132	2014 Willow Way. Jackson, MS 39204				EPA List	Three Mile Creek	1		
133	6118 Rand St. 10/30/2010				posted	Hanging Moss Creek	3	2010.5591	
134	311 Ford Ave 10/30/2010				posted	Town Creek	3	2010.5592	
135	4133 South Dr. 10/30/2010				posted	Lynch Creek	2	2010.5600	
136	155 A Boone Dr. 11/1/2010				posted	Hanging Moss Creek	4	2010.5619	
137	2113 East Dr. Jackson, MS 39204				EPA List	Three Mile Creek	1		
138	1942 O'Bannon Dr. 11/1/2010				posted	Town Creek	3	2010.5611	
139	1817 Avenue H 11/1/2010				posted	Town Creek	3	2010.5623	
140	124 Rollingwood Dr. 11/1/2010				posted	Hanging Moss Creek	4	2010.5629	
141	2352 Cornett Pl. Jackson, MS 39204				EPA List	Three Mile Creek	1		
142	124 Rollingwood Dr. 11/2/2010				posted	Hanging Moss Creek	4	2010.5614	
143	2346 Cornett Pl. Jackson, MS 39204				EPA List	Three Mile Creek	1		
144	4461 Marchant Dr. 11/2/2010				posted	Lynch Creek	3	2010.5616	
145	2261 Belvedere Dr. Jackson, MS 39204				EPA List	Three Mile Creek	1		
146	1251 Woodbridge Dr. 11/2/2010				posted	Lynch Creek	2	2010.5619	
147	619 Forest Ave.				posted	Roberts Creek	3	2010.5640	
148	3523 Nashville St.				posted	Town Creek	3	2010.5642	
149	1653 Gammill St. 11/4/2010				posted	Town Creek	3	2010.5673	
150	3142 Sage St. 11/4/2010				posted	Town Creek	3	2010.5680	
151	124 Seward Dr. 11/5/2010				posted	Lynch Creek	2	2010.5708	
152	2231 Forest Glen Ln 11/5/2010				posted	Roberts Creek	3	2010.5721	
153	Birchwood Dr. & State St. 11/6/2010				posted	Hanging Moss Creek	4	2010.5723	
154	1545 Maria Dr. Jackson, MS 39204				EPA List	Handy Creek	1		
155	6245 Moxline Dr. 11/6/2010				posted	Purple Creek	4	2010.5725	
156	Maria Dr. Jackson, MS 39204				EPA List	Caney Creek	1		
157	3996 Skyline Dr. 11/6/2010				posted	Town Creek	3	2010.5726	
158	206 Sheila Dr. 11/6/2010				posted	Lynch Creek	2	2010.5733	
159	314 Rollingwood Dr. 11/6/2010				posted	Hanging Moss Creek	4	2010.5733	
160	540 Briarcliff Cir. 11/7/2010				posted	Caney Creek	1	2010.5739	
161	101 Grover Cleveland Cir. 11/7/2010				posted	Boquet Chino Creek	3	2010.5747	
162	5549 Queen Christina Ln. 11/7/2010				posted	Lynch Creek	3	2010.5750	
163	5916 Skyview Dr.				posted	Town Creek	3	2010.5758	
164	4580 Old Canton Rd				posted	Roberts Creek	4	2010.5759	
165	311 Quin St. Jackson, MS 39204-6300 11/8/2010				posted	Lynch Creek	3	2010.5769	
166	645 Moncrey St. 6/20/09				posted	Three Mile Creek	1	2010.5772	
167	Hasty Ave & Pomer St. 11/8/2010				posted	Lynch Creek	2	2010.5777	
168	145 Lorena Blvd. 11/8/2010				posted	Town Creek	4	2010.5787	
169	1724 Gibraltar Dr. 11/8/2010				posted	Lynch Creek	1	2010.5783	
170	1616 Main St. 11/9/2010				posted	Town Creek	3	2010.5791	



City Of Jackson, Mississippi Sewer System Overflow Inspection Form

City of Jackson, Mississippi
Department of Public Works
Post Office Box 15
Jackson, MS 39201
(601) 955-2000

Address	Inspection Date	Inspector	Overflow Location	Overflow Type	Overflow Volume (gallons)	Overflow Duration (minutes)	Overflow Impact
121 1413 W Northside Dr. 11/9/2010			posted	Fabulous Creek	3	2010 5948	
122 1634 McLean Rd. Jackson, MS 39212			EPA List	Trabon Creek	1		
123 1850 Camilla Dr. 11/11/2010			posted	Casey Creek	1	2010 5815	
124 449 Mason Blvd. 11/11/2010			posted	Casey Creek	1	2010 5844	
125 2255 Forest Park Dr. Pumping Station 11/13/2010			posted	Trabon Creek	1	2010 5860	
126 154 C. J. Coker Rd. 11/13/2010			posted	Town Creek	3	2010 5807	
127 1119 Pittman St. 11/15/2010			posted	Casey Creek	1	2010 5904	
128 1244 Gallatin St. 11/15/10			posted	Lynch Creek	2	2010 5910	
129 2763 Newport St. 11/15/2010			posted	Town Creek	3	2010 5913	
130 131 Oakridge Dr. Jackson, MS 39212			EPA List	Trabon Creek	1		
131 244 Northpointe Place 11/16/2010			posted	Purple Creek	4	2010 5944	
132 Pennington St. & Capital St 11/16/2010			posted	Town Creek	2	2010 5946	
133 2919 Oakmont Dr. 11/19/2010			posted	Lynch Creek	2	2010 5967	
134 1141 Woodfield Dr. 11/19/2010			posted	White Oak Creek	4	2010 5963	
135 439 Woody Dr. 11/20/2010			posted	Casey Creek	1	2010 6012	
136 1114 Woodville Cir. Jackson, MS 39212			EPA List	Casey Creek	1		
137 1720 McCall Rd. 11/21/2010			posted	Trabon Creek	1	2010 6027	
138 404 Canton Cir. 11/22/2010			posted	Casey Creek	1	2010 6041	
139 Churchhill Dr. 11/22/2010			posted	Fabulous Creek	4	2010 6060	
140 1117 Oak St. 11/22/2010			posted	Lynch Creek	2	2010 6020	
141 999 Proctor Dr. 11/22/2010			posted	Lynch Creek	2	2010 6029	
142 3171 Robinson Rd. Jackson, MS 39204			EPA List	Casey Creek	2		
143 335 Cedar Springs Dr. 11/23/2010			posted	Trabon Creek	4	2010 6060	
144 1908 W. Ingfield Cir. Jackson, MS 39209			EPA List	Lynch Creek	2		
145 Woodway Dr. & N. State St. 11/23/2010			posted	Hanging Moss Creek	4	2010 6063	
146 1902 W. Ingfield Cir. Jackson, MS 39209			EPA List	Lynch Creek	2		
147 120 Woody Dr. 11/23/2010			posted	Fabulous Creek	1	2010 6067	
148 124 F. Smith St. Jackson, MS 39201			EPA List	Town Creek	2		
149 1319 Valley St. 11/26/2010			posted	Lynch Creek	2	2010 6119	
150 3150 Raintree Rd. Jackson, MS 39204			EPA List	Casey Creek	2		
151 Wood St. & Bell St. 11/27/2010			posted	Town Creek	1	2010 6136	
152 461 Roland St. Jackson, MS 39204			EPA List	Lynch Creek	2		
153 Woody Dr. (near 461 Woody) 11/27/2010			posted	Casey Creek	1	2010 6137	
154 435 Roland St. Jackson, MS 39209			EPA List	Lynch Creek	2		
155 1037 Wilbur Dr. 11/28/2010			posted	Three Mile Creek	1	2010 6200	
156 811 W Porter St. Jackson, MS 39204			EPA List	Lynch Creek	2		
157 678 S. Valley Path Rd. 11/30/2010			posted	Casey Creek	1	2010 6205	
158 1311 W Pearl St. Jackson, MS 39201			EPA List	Town Creek	2		
159 Hanging Moss & Heather Ln. 11/30/2010			posted	Hanging Moss Creek	3	2010 6217	
160 134 Oakridge Dr. Jackson, MS 39209			EPA List	Lynch Creek	2		
161 1405 James Rd. 11/30/2010			posted	Eastover Creek	4	2010 6219	
162 4205 Oakmont Dr. Jackson, MS 39209			EPA List	Lynch Creek	2		
163 Michael Clay Dr. & Maple Ln. 12/6/2010			posted	Town Creek	2	2010 6229	
164 4205 Oakmont Dr. Jackson, MS 39209			EPA List	Lynch Creek	2		
165 Clinton Ave. & Bryant Ave. 12/10/2010			posted	Lynch Creek	2	2010 6234	
166 North Richard St. Jackson, MS			EPA List	Town Creek	2		
167 435 Houston Ave. 12/2/2010			posted	Lynch Creek	2	2010 6238	
168 4251 Woodmont Dr. Jackson, MS 39209			EPA List	Lynch Creek	2		
169 114 W. Main St. 12/5/2010			posted	Shelby Creek	3	2010 6258	
170 North St. & Foothill St. Jackson, MS			EPA List	Shelby Creek	2		
171 Raymond Rd. & Elm Court Cir. 12/3/2010			posted	Hardy Creek	1	2010 6279	
172 104 1st Victoria Ave. Jackson, MS 39209			EPA List	Lynch Creek	2		
173 1418 Forest Hill Rd. 12/5/2010			posted	Trabon Creek	1	2010 6278	
174 4372 Woodmont Dr. Jackson, MS 39209			EPA List	Lynch Creek	2		
175 5535 Queen Mary Ln. 12/5/2010			posted	Lynch Creek	1	2010 6311	
176 4301 Woodmont Dr. Jackson, MS 39209			EPA List	Lynch Creek	2		
177 395 Cedar Spring Dr. 12/5/2010			posted	Trabon Creek	1	2010 6312	
178 1695 High St. Jackson, MS 39202			EPA List	Beddison Creek	2		
179 610 N. Jefferson St. 12/5/2010			posted	Town Creek	2	2010 6316	
180 744 Georgia Ave. Jackson, MS 39209			EPA List	Town Creek	2		
181 Allen St. & Beatty St. 12/6/2010			posted	Town Creek	2	2010 6310	
182 143 Fairview St. Jackson, MS 39209			EPA List	Lynch Creek	2		
183 Bailey Ave. near 1020 12/6/2010			posted	Town Creek	2	2010 6333	
184 5157 Dwyer Dr. Jackson, MS 39209			EPA List	Lynch Creek	2		
185 1524 Horton Ave. 12/7/2010			posted	Hanging Moss Creek	1	2010 6340	
186 1731 Corbett St. Jackson, MS 39209			EPA List	Lynch Creek	2		
187 162 St. Andrews Dr. 12/7/2010			posted	Purple Creek	4	2010 6347	
188 1236 Carolyn St. Jackson, MS 39209			EPA List	Lynch Creek	2		
189 Hardy St. & Allen St. 12/7/2010			posted	Town Creek	1	2010 6356	
190 177 Oakmont St. Jackson, MS 39209			EPA List	Town Creek	2		
191 477 Meadow Heights Dr. 12/8/2010			posted	Fabulous Creek	4	2010 6366	
192 1102 Canal Dr. Jackson, MS 39209			EPA List	Lynch Creek	2		
193 1408 Brockway Rd. (near 1440) 12/9/2010			posted	Casey Creek	1	2010 6384	
194 434 Peoria St. 12/9/2010			posted	Lynch Creek	2	2010 6387	
195 5541 Capital Dr. 12/11/2010			posted	Lynch Creek	2	2010 6401	
196 112 Longview St. 12/13/2010			posted	Town Creek	4	2010 6402	
197 6100 Oakway Dr. 12/13/2010			posted	Fabulous Creek	4	2010 6415	
198 Shadrigh Dr. & Ashdown St. 12/13/2010			posted	Town Creek	1	2010 6423	
199 463 Canton Ave. 12/13/2010			posted	Casey Creek	1	2010 6430	
200 Bailey Dr. & Crane Blvd. 12/14/2010			posted	Fabulous Creek	4	2010 6469	
201 179 Glimpse Cir. 12/14/2010			posted	Casey Creek	1	2010 6502	
202 Greenwood Dr. & North State St. 12/15/2010			posted	Hanging Moss Creek	4	2010 6514	
203 155 North & Northside Drive 12/15/2010			posted	Eastover Creek	4	2010 6521	
204 1645 Wiggins Rd. 12/16/2010			posted	Lynch Creek	2	2010 6532	
205 200 E. Capital St. 12/17/2010			posted	Town Creek	2	2010 6573	



City Of Jackson, Mississippi Sewer System Overflow Inspection Form

City of Jackson, Mississippi
Department of Public Works
Pest Office Box 11
Jackson, MS 39208
(601) 968-2641

Address	Date	Inspector	Overflow Type	Location	Volume	Notes
256 2430 Alhambra Rd. 12/17/2010			partial	Town Creek	5	2010 6377
257 154 St. Andrews Dr. 12/18/2010			partial	Purple Creek	4	2010 6387
258 185 Woody Dr. 12/20/2010			partial	Hardy Creek	1	2010 6613
259 1244 N. L. King Dr. 12/20/2010			partial	Town Creek	3	2010 6614
260 Avonlea Dr. & Winsell Rd. 12/20/2010			partial	Hubanks Creek	5	2010 6620
261 1253 Woodvillage Dr. 12/21/2010			partial	Lynch Creek	2	2010 6649
262 550 Houston Ave. 12/21/2010			partial	Lynch Creek	2	2010 6655
263 McQuinn Road Pk. (NO ADDRESS GIVEN) 12/23/2010			partial	Caney Creek	1	2010 6655
264 2900 St. Charles St. & Culbertson Ave. 12/24/2010			partial	Lynch Creek	2	2010 6737
265 595 Cedar Springs Rd. 12/28/2010			partial	Caney Creek	1	2010 6817
266 Dead end Pear Orchard Pt 12/29/2010			partial	Purple Creek	4	2010 6818
267 Holly Hill Dr 12/29/2010			partial	Hubanks Creek	1	2010 6822
268 1068 Cumbe St. 12/28/2010			partial	Hardy Creek	1	2010 6822
269 668 Chelsea Dr 1/1/2011			partial	Caney Creek	1	2010 6901
270 1754 Broom Dr. 1/3/2011			partial	Hardy Creek	4	2010 6942
271 508 Will O Wisp Way 1/4/2011			partial	Three Mile Creek	1	2010 6973
272 618 Lowder Dr. 1/4/2011			partial	Lynch Creek	5	2010 6979
273 540 Delacoff Cir. 1/5/2011			partial	Caney Creek	1	2010 7000
274 1754 Broom Dr. 1/27/2011			partial	Hardy Creek	4	2010 6769
275 1800 Walter Dutch Weith Dr. 1/4/2011			partial	Town Creek	3	2010 6971
276 8102 Wayland Dr. 1/4/2011			partial	Hanging Moss Creek	4	2010 6976
277 415 Armour Dr. 1/5/2011			partial	Hanging Moss Creek	4	2011 8
278 120 Calhoun Dr. 1/5/2011			partial	Three Mile Creek	1	2011 8
279 3475 1/5 S Timber Ridge Apts. 1/5/2011			partial	Caney Creek	1	2011 14
280 Belvedere Dr. & Fremont St. 1/6/2011			partial	Hardy Creek	1	2011 43
281 2625 Belvedere Dr. 1/7/2011			partial	Hardy Creek	1	2011 72
282 6893 State Highway 16 1/7/2011			partial	Caney Creek	1	2011 82
283 5749 Queen Christina Ln. 1/10/2011			partial	Lynch Creek	5	2011 128
284 540 Branch Cir. 1/10/2011			partial	Caney Creek	1	2011 129
285 McWillie Dr. & Garvin St. 1/10/2011			partial	Hanging Moss Creek	6	2011 156
286 Goodwood Dr. 1/13/2011			partial	Hanging Moss Creek	3	2011 166
287 500 Wilman St. 1/13/2011			partial	Lynch Creek	2	2011 189
288 2961 McDowell Dr. 1/14/2011			partial	Caney Creek	1	2011 201
289 Bailey Ave. & Woodrow Wilson Ave. 1/15/2011			partial	Town Creek	3	2011 216
290 5549 Queen Christina Ln 1/17/2011			partial	Lynch Creek	3	2011 241
291 431 Olive St. 1/18/2011			partial	Town Creek	2	2011 281
292 Bailey Ave. & Woodrow Wilson Ave. 1/20/2011			partial	Town Creek	2	2011 313
293 4829 Sheridan Dr. 1/20/2011			partial	Hubanks Creek	4	2011 325
294 104 Elmore St. 1/23/2011			partial	Lynch Creek	3	2011 472
295 834 Combs St. 1/28/2011			partial	Three Mile Creek	1	2011 507
296 540 Branch Cir. 1/31/2011			partial	Caney Creek	1	2011 559
297 2424 Bailey Ave. 2/1/2011			partial	Town Creek	2	2011 592
298 724 Raymond Rd. 2/2/2011			partial	Three Mile Creek	1	2011 616
299 462 Floyd Ave. 2/2/2011			partial	Hardy Creek	1	2011 617
300 4025 Marham St. Jackson, MS 39209			EPA List	Town Creek	2	
301 2971 McDowell Rd. 2/3/2011			partial	Caney Creek	1	2011 635
302 430 Browning St. 2/3/2011			partial	Lynch Creek	2	2011 686
303 51 Northview Rd 2/6/2011			partial	Purple Creek	4	2011 702
304 513 Queen Isabella Ln. Jackson, MS 39208			EPA List	Lynch Creek	2	
305 301 Elton Rd. 2/9/2011			partial	Caney Creek	1	2011 722
306 1072 Cooper Rd. 2/11/2011			partial	Caney Creek	1	2011 726
307 425 Merigold St (in the park) 2/16/2011			partial	Three Mile Creek	1	2011 888
308 5435 Queen Mary Ln. Jackson, MS 39209			EPA List	Lynch Creek	3	
309 1119 McLenn St. 2/17/2011			partial	Lynch Creek	2	2011 909
310 519 Queen Juliana Ln. Jackson, MS 39208			EPA List	Lynch Creek	3	
311 3715 Jayne Ave.			partial	Lynch Creek	2	2011 947
312 491 Clifton Drive 2/2/2011			partial	Caney Creek	1	2011 1024
313 5408 Queen Mary Ln. Jackson, MS 39209			EPA List	Lynch Creek	3	
314 207 Houston Ave. 2/22/2011			partial	Lynch Creek	2	2011 1038
315 1540 Sunset Drive 2/28/2011			partial	Town Creek	3	2011 1141
316 3113 Lincoln Ave. 2/28/2011			partial	Lynch Creek	3	2011 1157
317 340 Branch Cir. 2/25/2011			partial	Caney Creek	1	2011 1161
318 Garvin St. & McWillie Dr. 2/25/2011			partial	Hanging Moss Creek	4	2011 1099
319 2937 Maryland Dr. 2/24/2011			partial	Caney Creek	1	2011 1065
320 415 E. Capitol St 2/24/2011			partial	Town Creek	2	2011 1080
321 117 Clinton Park Dr. 2/23/2011			partial	Lynch Creek	3	2011 1044
322 5124 Queen Eleanor Ln. Jackson, MS 39209			EPA List	Lynch Creek	3	
323 West Bank Interceptor Dead End at N Cheryl Dr. 2/24/2011			partial	Hanging Moss Creek	4	2011 1159
324 5148 Queen Eleanor Ln. Jackson, MS 39209			EPA List	Lynch Creek	3	
325 5349 Queen Christina Lane 3/1/2011			partial	Lynch Creek	3	2011 1155
326 125 Taylor Street 1/30/2011			partial	Town Creek	4	2011 1197
327 417 Windsor Dr. Jackson, MS 39209			EPA List	Lynch Creek	3	
328 109 Glen Elm St. 3/2/2011			partial	Caney Creek	1	2011 1185
329 behind ballfield on Lakeland Dr. 3/9/2011			partial	Hubanks Creek	4	2011 1374
330 260 Coldbrook Ave. Jackson, MS 39209			EPA List	Lynch Creek	3	
331 225 Meadowbrook Rd. 3/10/2011			partial	Hubanks Creek	4	2011 1394
332 259 Coldbrook Ave. Jackson, MS 39209			EPA List	Lynch Creek	3	
333 905 Fairview Rd. 3/16/2011			partial	Three Mile Creek	1	2011 1494
334 Dean end of N Cheryl (West Bank Interceptor) 3/21/2011			partial	Hanging Moss Creek	4	2011 1590
335 207 County Club Dr. Jackson, MS 39209			EPA List	Lynch Creek	3	
336 154 Houston Ave. 3/23/2011			partial	Lynch Creek	2	2011 1635
337 County Club Dr. Jackson, MS			EPA List	Regus Chitim Creek	3	
338 6210 Briard Oak Dr. 3/28/2011			partial	Purple Creek	4	2011 1700
339 County Club Dr. Jackson, MS			EPA List	Lynch Creek	3	
340 2728 Bailey Ave. 3/29/2011			partial	Town Creek	3	2011 1723



City Of Jackson, Mississippi
Sewer System Overflow Inspection Form

City of Jackson, Mississippi
Department of Public Works
1000 Main Street, 2nd Floor
Jackson, MS 39201
201-950-5301

NO.	Address	Inspector	Date	Time	Flow	Location	Flow	Location	Flow	Location
341	4021 Wicks Dr, Jackson, MS 39208					EPA List	Lynch Creek	3		
342	Wm Cheryl Dr. & Heritage Hill Dr. 4/18/2011					posted	Hanging Moss Creek	4	2011 2099	
343	Queen Mary Ln. 4/21/2011					posted	Lynch Creek	3	2011 2102	
344	3171 Santa Clara Cir. 4/21/2011					posted	Hardy Creek	1	2011 2111	
345	1339 Maple Ridge Dr. 4/19/2011					posted	Hardy Creek	1	2011 2118	
346	1100 J.R. Lynch St. 4/20/2011					posted	Town Creek	2	2011 2131	
347	Wired St. & Bell St. 11/16/2010					posted	Town Creek	2		
348	Ford Dr & Willow Way 4/20/2011					posted	Three Mile Creek	1	2011 2162	
349	202 Ridgeway St. 4/23/2011					posted	Town Creek	4	2011 2182	
350	Bailey Ave/Madison Eves Blvd, Jackson, MS					EPA List	Town Creek	3		
351	Parker St. & Walnut St. 4/23/2011					posted	Lynch Creek	2	2011 2183	
352	Ford Dr. & Willow Way 4/25/2011					posted	Three Mile Creek	1	2011 2192	
353	901 E. Fairmount St. 4/25/2011					posted	Town Creek	2	2011 2194	
354	3334 Riverside Dr. 4/25/2011					posted	Town Creek	1	2011 2203	
355	311 John St, Jackson, MS 39203					EPA List	Town Creek	3		
356	2182 Maple Lane Rd. 4/25/2011					posted	Caney Creek	1	2011 2206	
357	Bailey Ave James St., Jackson, MS					EPA List	Town Creek	3		
358	Madison St. & Bay St. 4/25/2011					posted	Town Creek	3	2011 2214	
359	Dead end of N. Cheryl Dr. (West Bank Interceptor) 4/23/2011					posted	Hanging Moss Creek	4	2011 2188	
360	Delmar St. & J.R. Lynch St. 4/27/2011					posted	Town Creek	2	2011 2219	
361	1852 Boulder Washington St. Jackson, MS 39213					EPA List	Town Creek	3		
362	Pennington St. & J.R. Lynch St. 4/27/2011					posted	Town Creek	2	2011 2233	
363	1852 Boulder Washington St. Jackson, MS 39213					EPA List	Town Creek	3		
364	3334 Queen Mary Lane 4/27/2011					posted	Lynch Creek	5	2011 2238	
365	1852 Boulder Washington St. Jackson, MS 39213					EPA List	Town Creek	3		
366	1113 Longwood Dr. 4/28/2011					posted	Caney Creek	1	2011 2248	
367	804 US Highway 90 W 4/28/2011					posted	Lynch Creek	2	2011 2255	
368	112 Acorn Dale Dr. 4/27/2011					posted	Town Creek	1	2011 9000	
369	4445 Madigan Eves Blvd. 4/28/2011					posted	Town Creek	3	2011 2271	
370	1319 S. Gallatin St. 4/29/2011					posted	Lynch Creek	2	2011 2275	
371	West Bank Interceptor, dead end of N. Cheryl 3/9/2011					posted	Hanging Moss Creek	4	2011 9001	
372	2822 Marion Dunbar St. 4/28/2011					posted	Town Creek	3	2011 2256	
373	Lorain Blvd & Winkler Ave. 4/28/2011					posted	Town Creek	4	2011 2260	
374	1303 Beechridge Dr. 5/2/2011					posted	Town Creek	3	2011 2292	
375	1314 Livingston Rd. 5/2/2011					posted	Town Creek	3	2011 2291	
376	1314 Livingston Rd. 5/2/2011					posted	Caney Creek	1	2011 9004	
377	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9005	
378	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9006	
379	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
380	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
381	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
382	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
383	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
384	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
385	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
386	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
387	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
388	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
389	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
390	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
391	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
392	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
393	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
394	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
395	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
396	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
397	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
398	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
399	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
400	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
401	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
402	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
403	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
404	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
405	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
406	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
407	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
408	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
409	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
410	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
411	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
412	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
413	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
414	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
415	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
416	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
417	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
418	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
419	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
420	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
421	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
422	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
423	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
424	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
425	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
426	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
427	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
428	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
429	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
430	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
431	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
432	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
433	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
434	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	
435	1314 Livingston Rd. 5/2/2011					posted	Town Creek	1	2011 9007	



City of Jackson, Mississippi
Sewer System Overflow Inspection Form

City of Jackson, Mississippi
Department of Public Works
P.O. Box 100, 1st
Jackson, MS 39201
(601) 258-2000

426.	Wainwright St. & Forest St. 5/21/2011	posted	Lynch Creek	2	2011 2527
427.	No. 7, Thurmerville Row 6/12/2011	posted G Huff	Town Creek	3	2011 2756
428.	5227 Commercial Ln. 6/1/2011	posted G Huff	Town Creek	1	2011 2765
429.	1044 Greyhound Ave. 6/1/2011	posted G Huff	Bedlam Creek	2	2011 2907
430.	1001 Beale St. 6/2/2011	posted G Huff	Beale Creek	3	2011 2774
431.	1001 Olympia Field, Jackson, MS 39211	EPA List	Beale Creek	4	
432.	Greyhound St. & 65th St. 6/2/2011	posted G Huff	Bedlam Creek	2	2011 2784
433.	817 Oakwood St. 6/3/2011	posted G Huff	Bedlam Creek	4	2011 2808
434.	4612 Bedlam St. 6/3/2011	posted G Huff	Bedlam Creek	3	2011 2819
435.	Glenn St. & Bayberry Dr. 6/10/2011	posted G Huff	Lynch Creek	3	2011 2815
436.	4144 Locust Blvd. 6/6/2012	posted G Huff	Town Creek	4	2011 2814
437.	950 Bedlam St. 6/6/2011	posted G Huff	Bedlam Creek	4	2011 2821
438.	4942 Orchard View Dr. Jackson, MS 39211	EPA List	Purple Creek	4	
439.	1480 Fairview Rd. 6/7/2011	posted G Huff	Purple Creek	1	2011 2829
440.	1381 Colonial Cir. Jackson, MS 39211	EPA List	Purple Creek	4	
441.	Livingston Rd. & Howell St.	posted G Huff	Town Creek	7	10/11 2841
442.	121 Oak Canyon Hill Dr. Jackson, MS 39211	EPA List	Purple Creek	4	
443.	1014 Greyhound Ave. 6/7/2011	posted G Huff	Bedlam Creek	2	2011 2808
444.	Blk. St. & Ridgeway St. 6/10/2011	posted G Huff	Town Creek	3	2011 2822
445.	1913 Irving St. 6/12/2011	posted G Huff	Bayou Creek	3	2011 2832
446.	5113 Fairview Dr. Jackson, MS 39211	EPA List	Hanging Moss Creek	4	
447.	1491 Elm Cir. 6/12/2011	posted G Huff	Town Creek	1	2011 2893
448.	3540 Herrow Dr. Jackson, MS 39211	EPA List	Hanging Moss Creek	4	
449.	1066 Macklowe Heights Dr. 6/17/2011	posted G Huff	Bedlam Creek	4	2011 2902
450.	375 Hollingsworth Dr. Jackson, MS 39211	EPA List	Hanging Moss Creek	4	
451.	Stoddard Rd. & McClellan Rd. 6/23/2011	posted G Huff	Town Creek	1	2011 2911
452.	563 Hollingsworth Dr. Jackson, MS 39211	EPA List	Hanging Moss Creek	4	
453.	240 Preston Pl. 6/14/2011	posted G Huff	Hanging Moss Creek	4	2011 2922
454.	201 E. Northside Cir. 6/14/2011	posted G Huff	Hanging Moss Creek	4	2011 2922
455.	300 E. Cleveland St. 6/14/2011	posted G Huff	Town Creek	3	2011 2923
456.	200 Chatham St. 6/14/2011	posted G Huff	Town Creek	2	2011 2926
457.	5545 Ruffin Dr. Jackson, MS 39211	posted G Huff	Three Mile Creek	1	2011 2927
458.	170 Trevelyan Dr. 6/14/2011	EPA List	Hanging Moss Creek	4	
459.	5200 Delmar Dr. 6/15/2011	posted G Huff	Hanging Moss Creek	1	2011 2929
460.	Home Ave. & Lacey Dr. in creek 6/16/2011	posted G Huff	Lynch Creek	2	2011 2936
461.	210 Pimlico Pl. Jackson, MS 39211	EPA List	Hanging Moss Creek	4	2011 2937
462.	4920 N. Wood St. 6/16/2011	posted G Huff	Bedlam Creek	3	2011 2962
463.	374 Queen Mary Lane 6/17/2011	posted G Huff	Lynch Creek	3	2011 2980
464.	250 Wacker Dr. 6/18/2011	posted G Huff	Bedlam Creek	3	2011 2982
465.	3861 McDowell Rd. 6/19/2011	posted G Huff	Town Creek	1	2011 3002
466.	1770 Shady Lane 6/22/2011	posted G Huff	Town Creek	1	2011 3002
467.	371 Barnes St. 6/20/2011	posted G Huff	Lynch Creek	1	2011 3008
468.	1125 Station Dr. 6/21/2011	posted G Huff	Hanging Moss Creek	4	2011 3015
469.	5125 Canale St. 6/23/2011	posted G Huff	White Oak Creek	4	2011 3020
470.	1211 Pelham St. 6/24/2011	posted G Huff	Three Mile Creek	1	2011 3051
471.	1012 Oakmont Dr. 6/24/2011	posted G Huff	Town Creek	3	2011 3064
472.	1700 Oak Cir. 6/24/2011	posted G Huff	Lynch Creek	2	2011 3070
473.	Quail Run Rd. Jackson, MS	posted G Huff	Town Creek	1	2011 3084
474.	8211 Winton St. 6/28/2011	EPA List	Hanging Moss Creek	4	
475.	8211 Winton St. 6/28/2011	posted G Huff	Bedlam Creek	2	2011 3084
476.	1030 Sackville Dr. Jackson, MS 39211	posted G Huff	Bedlam Creek	2	2011 3084
477.	1111 Walker Ave. 6/28/2011	EPA List	Bedlam Creek	4	
478.	1113 E. Northside Cir. Jackson, MS 39211	posted G Huff	Town Creek	3	2011 3086
479.	592 Osborn Dr. 6/29/2011	EPA List	Bedlam Creek	4	
480.	625 Crestline Ave. 6/29/2011	posted G Huff	Three Mile Creek	1	2011 3107
481.	4570 Oak Canyon Rd. Jackson, MS 39211	posted G Huff	Town Creek	1	2011 3108
482.	2840 Redmont Rd. 6/29/2011	EPA List	Bedlam Creek	4	
483.	5160 E. Frontage Rd. 6/29/2011	posted G Huff	Lynch Creek	2	2011 3109
484.	4580 Oak Canyon Rd. & Northside, Jackson, MS 39211	posted G Huff	White Oak Creek	4	2011 3110
485.	3920 Lane Dr. 6/29/2011	EPA List	Bedlam Creek	4	
486.	1220 E. Northside Cir. Jackson, MS 39211	posted G Huff	Town Creek	1	2011 3111
487.	520 Breckinridge Cir. 6/29/2011	EPA List	Bedlam Creek	4	
488.	1741 Winton St. 6/30/2011	posted G Huff	Town Creek	1	2011 3116
489.	1207 McDaniel St. 6/30/2011	posted G Huff	Lynch Creek	1	2011 3162
490.	Jefferson St. & Tremblay St. 6/29/2011	posted G Huff	Town Creek	2	2011 3168
491.	1210 McDaniel St. Jackson, MS 39211	posted G Huff	Bedlam Creek	2	2011 3172
492.	5000 1/2 W. & Wacker Dr. 7/5/2011	EPA List	Bedlam Creek	4	
493.	5000 1/2 W. & Wacker Dr. 7/5/2011	posted G Huff	Bedlam Creek	4	2011 3204
494.	4400 Haddam Dr. 7/5/2011	posted G Huff	Bedlam Creek	2	2011 3206
495.	613 Newland Ave. 7/5/2011	posted G Huff	Town Creek	1	2011 3211
496.	1918 Willow St. 7/5/2011	posted G Huff	Hanging Moss Creek	4	2011 3210
497.	4115 Harrow Dr. 7/5/2011	posted G Huff	Three Mile Creek	1	2011 3199
498.	111 Glenhurst Cir. 7/5/2011	posted G Huff	Hanging Moss Creek	4	2011 3164
499.	4130 Oak Blvd. Jackson, MS 39211	EPA List	Bedlam Creek	3	2011 3202
500.	4000 S. & High St. 7/6/2011	posted G Huff	Bedlam Creek	2	2011 3206
501.	3212 Crawford St. 7/7/2011	posted G Huff	Town Creek	3	2011 3214
502.	1400 S. & Tremblay St. Jackson, MS 39211	posted G Huff	Hanging Moss Creek	4	2011 3224
503.	4631 Church St. Jackson, MS 39211	EPA List	Bedlam Creek	4	
504.	3015 Northside Cir. 7/6/2011	posted G Huff	Bedlam Creek	3	2011 3224
505.	1015 Church St. Jackson, MS 39211	EPA List	Bedlam Creek	4	
506.	543 Woodmont Dr. 7/7/2011	posted G Huff	Hanging Moss Creek	4	2011 3227
507.	Forest Ave. & Wacker Dr. 7/7/2011	posted G Huff	Bedlam Creek	3	2011 3230
508.	4800 Winton St. Jackson, MS 39211	EPA List	Bedlam Creek	4	
509.	1331 Timp Ave. 7/7/2011	posted G Huff	Lynch Creek	2	2011 3232
510.	1812 Winton St. Jackson, MS 39211	EPA List	Bedlam Creek	4	



City Of Jackson, Mississippi
Sewer System Overflow Inspection Form

City of Jackson, Mississippi
Department of Public Works
Sewer Office (Box 17)
Jackson, MS 39201
800-769-2811

NO.	ADDRESS	DATE	INSPECTOR	STATUS	OVERFLOW	LOCATION	DATE
511	124 Nighthawk Dr. 7/8/2011			posted G Huff	Caney Creek	1	2011 1213
512	621 Overton Ave. 7/8/2011			posted G Huff	Lynch Creek	2	2011 1214
513	Palmyra St. & Elm St. 7/14/2011			posted G Huff	Town Creek	1	2011 1265
514	901 Pearl St. 7/17/2011			posted G Huff	Town Creek	2	2011 1281
515	4521 Ridgewood Rd. 7/19/2011			posted G Huff	Eastover Creek	4	2011 1349
516	715 E. Northside Dr. Jackson, MS 39206			EPA List	Eastover Creek	4	
517	1100 Block Palmyra St. 7/19/2011			posted G Huff	Town Creek	1	2011 1374
518	4148 Robin Dr. Jackson, MS 39206			EPA List	Eastover Creek	4	
519	Point Ave. & Watkins Dr. 7/8/2011			posted G Huff	Eastover Creek	1	2011 1345
520	4106 Robin Dr. Jackson, MS 39206			EPA List	Eastover Creek	4	
521	1130 Harrison Ave. 7/12/2011			posted G Huff	Lynch Creek	1	2011 1212
522	2015 McAllen Rd. - Dead end of Bordenridge Rd. 7/8/2011			posted G Huff	Hardy Creek	1	2011 1325
523	Mississippi St. & Jefferson St. 7/12/2011			posted G Huff	Belhaven Creek	2	2011 1249
524	3134 Harlow Dr. 7/13/2011			posted G Huff	Hanging Moss Creek	4	2011 1367
525	Memphis St. & Valencia St. 7/13/2011			posted G Huff	Three Mile Creek	1	2011 1308
526	744 Posthumus Pl. 7/13/2011			posted G Huff	Belhaven Creek	4	2011 1311
527	5011 Overton Dr. - Pump Station 7/13/2011			posted G Huff	Caney Creek	1	2011 1328
528	2614 Oakleaf Dr. 7/13/2011			posted G Huff	Three Mile Creek	1	2011 1350
529	2611 Greenwood Ave. 7/14/2011			posted G Huff	Hardy Creek	1	2011 1345
530	2136 Livingston Rd. 7/13/2011			posted G Huff	Town Creek	1	2011 1343
531	Queen Christina Lane 7/14/2011			posted G Huff	Lynch Creek	1	2011 1343
532	Blanchard St. & Fairview St. 7/14/2011			posted G Huff	Belhaven Creek	4	2011 1326
533	2100 N. State St. Jackson, MS 39204			EPA List	Belhaven Creek	4	
534	501 Commerce Ave. 7/13/2011			posted G Huff	Lynch Creek	2	2011 1372
535	1111 Riverside Dr. Jackson, MS 39202			EPA List	Belhaven Creek	4	
536	914 Brookman Rd. 7/13/2011			posted G Huff	Town Creek	1	2011 1372
537	1401 Ogilvie St. / Highway 20 Frontage 7/13/2011			posted G Huff	Lynch Creek	2	2011 1375
538	710 McJannet Ave. Jackson, MS 39202			EPA List	Town Creek	4	
539	1000 Block Richman Dr. 7/17/2011			posted G Huff	Caney Creek	1	2011 1377
540	706 McJannet Ave. Jackson, MS 39202			EPA List	Town Creek	4	
541	Churchill Dr. & Belvidere Rd. 7/18/2011			posted G Huff	Belhaven Creek	4	2011 1392
542	212 McJannet Ave. Jackson, MS 39202			EPA List	Town Creek	4	
543	160 Carter Ave. 7/18/2011			posted G Huff	Town Creek	2	2011 1391
544	Yacht Inn near 1011 Gentry St. 7/18/2011			posted G Huff	Town Creek	1	2011 1380
545	Mayfield Dr. near 4452 7/18/2011			posted G Huff	Lynch Creek	1	2011 1395
546	1130 Riverside Dr. - Water Plant - Pearl River 7/18/2011			posted G Huff	Belhaven Creek	4	2011 1400
547	1011 N. State St. & Marsh St. Jackson, MS 39202			EPA List	Town Creek	4	
548	Tang Rd. & Carlton St. 7/18/2011			posted G Huff	Hardy Creek	1	2011 1394
549	1024 N. State St. & Marsh St. Jackson, MS 39202			EPA List	Town Creek	4	
550	152 E. Woodland Dr. 7/18/2011			posted G Huff	Caney Creek	1	2011 1387
551	Apple Blvd. & Kennard Pl. 8/5/2011			posted G Huff	Belhaven Creek	4	2011 1372
552	1492 Lumb Rd. 8/5/2011			posted G Huff	Town Creek	2	2011 1320
553	1215 Foreman Dr. 8/5/2011			posted G Huff	Purple Creek	4	2011 1331
554	8844 Old Cannon Rd. 8/9/2011			posted G Huff	Purple Creek	4	2011 1259
555	8151 133 North 9/2/2011			posted G Huff	White Oak Creek	4	2011 1313
556	1851 Shady Ln. 9/2/2011			posted G Huff	Three Mile Creek	1	2011 1287
557	1413 Kensington Ave. 9/2/2011			posted G Huff	Town Creek	1	2011 1312
558	1515 First Ave. 9/2/2011			posted G Huff	Lynch Creek	2	2011 1368
559	6146 Granada Dr. 9/2/2011			posted G Huff	Caney Creek	1	2011 1319
560	5913 Pearl Dr. 9/2/2011			posted G Huff	Hanging Moss Creek	1	2011 1371
561	5549 Queen Christina Ln. Queen Eleanor Ln. 9/2/2011			posted G Huff	Lynch Creek	2	2011 1367
562	801 McJannet Ave. 9/2/2011			posted G Huff	Town Creek	4	2011 1323
563	3031 Woodside Dr. 9/4/2011			posted G Huff	Caney Creek	1	2011 1391
564	8015 Bayard Blvd. & Kennard Pl. 9/4/2011			posted G Huff	Belhaven Creek	4	2011 1361
565	2224 Overton Dr. 8/8/2011			posted G Huff	Eastover Creek	4	2011 1398
566	2319 Livingston Rd. 8/7/2011			posted G Huff	Town Creek	1	2011 1373
567	848 Chelsea Dr. 8/7/2011			posted G Huff	Caney Creek	1	2011 1369
568	104 E. Pumphrey St. 8/3/2011			posted G Huff	Belhaven Creek	4	2011 1367
569	728 Pine Lawn Pl. 8/2/2011			posted G Huff	Three Mile Creek	1	2011 1310
570	731 Valencia St. 8/2/2011			posted G Huff	Three Mile Creek	1	2011 1313
571	1610 Rainey Rd. 8/2/2011			posted G Huff	Caney Creek	1	2011 1317
572	1644 Camilla Dr. 8/2/2011			posted G Huff	Lynch Creek	1	2011 1325
573	4715 Heritage Manor 8/2/2011			posted G Huff	Town Creek	1	2011 1310
574	Asbury Dr. & Old Canton Rd. 8/1/2011			posted G Huff	Hanging Moss Creek	4	2011 1301
575	1644 Camilla Dr. 8/1/2011			posted G Huff	Lynch Creek	1	2011 1301
576	735 Ross St. 8/1/2011			posted G Huff	Town Creek	2	2011 1302
577	1300 N. Charles St. 8/1/2011			posted G Huff	Lynch Creek	2	2011 1301
578	801 East Fortification 8/1/2011			posted G Huff	Belhaven Creek	2	2011 1303
579				posted G Huff	Town Creek	1	2011 1311
580				posted G Huff	Town Creek	1	Unlisted Placement
581				posted G Huff	Lynch Creek	1	Unlisted Placement
582	1672 Shady Lane 8/4/2011			posted G Huff	Three Mile Creek	1	2011 1300
583	1407 Overton Ave. 7/24/2011			posted G Huff	Town Creek	2	2011 1301
584	1331 Cherokee Dr. 7/24/2011			posted G Huff	Belhaven Creek	4	2011 1349
585	732 Woodland Dr. 7/22/2011			posted G Huff	Three Mile Creek	1	2011 1301
586	149 E. Cox 7/22/2011			posted G Huff	Caney Creek	1	2011 1345
587	735 W. McDowell Rd. 7/21/2011			posted G Huff	Hardy Creek	1	2011 1349
588	1428 Bailey Ave. 7/21/2011			posted G Huff	Town Creek	1	2011 1349
589	735 W. McDowell Rd. 7/20/2011			posted G Huff	Hardy Creek	1	2011 1349
590	120 Colonial Dr. 7/15/2011			posted G Huff	Three Mile Creek	1	2011 1304
591	6960 Moody Dr. 7/15/2011			posted G Huff	Caney Creek	4	2011 1310
592	Calhoun Dr. & Woodbury Rd. 7/26/2011			posted G Huff	Belhaven Creek	4	2011 1327
593	1944 Overton Ave. 7/26/2011			posted G Huff	Town Creek	1	2011 1325
594	1020 Woodside Dr. 7/27/2011			posted G Huff	Caney Creek	1	2011 1347
595	4848 Highway 15 7/27/2011			posted G Huff	Caney Creek	1	2011 1358
596	227 Cooper Rd. 7/27/2011			posted G Huff	Caney Creek	1	2011 1352
597	2907 Angela Ck. 7/27/2011			posted G Huff	Lynch Creek	0	2011 1327
598	139 Woodland Terrace 7/27/2011			posted G Huff	Caney Creek	1	2011 1359




City Of Jackson, Mississippi Sewer System Overflow Inspection Form

City of Jackson, Mississippi
Department of Public Works
Sewer Office Box 17
Jackson, MS 39201
601-968-2651

599	4156 Crane Blvd. 7/21/2011	posted G. Huff	Humana Creek	4	2011 9639
600	3007 Lamar St. 7/20/2011	posted G. Huff	Town Creek	4	2011 1567
601	1654 Carmilla Dr. 7/30/2011	posted G. Huff	Lynch Creek	1	2011 9972
602	2811 Bay Ave. 7/26/2011	posted G. Huff	Town Creek	5	2011 9939
603	178 E. Woodcrest Dr. 8/2/2011	posted G. Huff	Caney Creek	1	2011 1650
604	178 E. Woodcrest Dr. 7/27/2011	posted G. Huff	Caney Creek	1	2011 22015
605	3111 Lee Cir. 7/31/2011	posted G. Huff	Hardy Creek	1	2011 9996
606	Catalina Dr. & Bonadire Rd. 7/31/2011	posted G. Huff	Eubanks Creek	4	2011 10000
607	184 056 Franklin D Roosevelt Dr. 7/14/2011	posted G. Huff			2011 20015
608	184 056 Franklin D Roosevelt Dr. 7/5/2011	posted G. Huff			2011 20016
609	184 044 Westside * 1 1907 Wallace St. 7/14/2011	posted G. Huff	Lynch Creek	2	2011 99018
610		posted G. Huff	Lynch Creek	2	2011 10022
611	209 E. McDaniel Rd. 8/5/2011	posted G. Huff	Three Mile Creek	1	2011 1711
612	Adelle St. & Adelle Ct. 8/5/2011	posted G. Huff	Town Creek	4	2011 1708
613	5136 Gertrude Dr. 8/7/2011	posted G. Huff	Caney Creek	1	2011 1727
614	5136 Gertrude Dr. 8/9/2011	posted G. Huff	Caney Creek	1	2011 1731
615	2749 Woodside Dr. 8/8/2011	posted G. Huff	Caney Creek	1	2011 1750
616	887 Brandon Ave. 8/9/2011	posted G. Huff	Lynch Creek	2	2011 1741
617	California Ave. & Ohio St. 8/8/2011	posted G. Huff	Town Creek	5	2011 1740
618	Willow Way 8/9/2011	posted G. Huff	Three Mile Creek	1	2011 10563
619	5951 California Ave. 8/12/2011	posted G. Huff	Town Creek	5	2011 1815
620	4111 W Capital St. 8/13/2011	posted G. Huff	Lynch Creek	2	2011 1814
621	3411 M. L. King Dr. 8/10/2011	posted G. Huff	Town Creek	5	2011 1175
622	1644 Camellian Ln. 8/19/2011	posted G. Huff	Lynch Creek	1	2011 1770
623	270 Lee Cir. 8/10/2011	posted G. Huff	Hardy Creek	1	2011 1784
624	2840 Robinson Rd. 8/19/2011	posted G. Huff	Lynch Creek	1	2011 1548
625	689 Woody Dr. 8/15/2011	posted G. Huff	Caney Creek	1	2011 1852
626	138 Valley St. 8/15/2011	posted G. Huff	Lynch Creek	2	2011 1857
627	715 Barkley Dr. 8/16/2011	posted G. Huff	Eubanks Creek	3	2011 1863
628	1593 Whiting Rd. 8/16/2011	posted G. Huff	Lynch Creek	2	2011 1872
629	1725 Camilla Dr. 8/16/2011	posted G. Huff	Lynch Creek	1	2011 1870
630	1812 Williams Dr. 8/19/2011	posted G. Huff	Three Mile Creek	1	2011 1895
631	1011 Hefley Circle 8/19/2011	posted G. Huff	Eastover Creek	4	2011 1899
632	Phasing Ave & Bell St. 8/17/2011	posted G. Huff	Town Creek	3	2011 1899
633	Monument St. & Capitol St. 8/17/2011	posted G. Huff	Town Creek	2	2011 1899
634	1444 Kensington Ave. 8/18/2011	posted G. Huff	Town Creek	1	2011 1893
635	212 Lee Cir. 8/19/2011	posted G. Huff	Hardy Creek	1	2011 1111
636	2692 Key St. 8/19/2011	posted G. Huff	Hardy Creek	1	2011 1109
637	1720 Camilla Dr. 8/23/2011	posted G. Huff	Lynch Creek	1	2011 1139
638	1918 Cantha Dr. 8/22/2011	posted G. Huff	Three Mile Creek	1	2011 1138
639	1657 McDaniel Rd. 8/22/2011	posted G. Huff	Caney Creek	1	2011 1145
640	Dead End of Eleanor Ave. 8/23/2011	posted G. Huff	Town Creek	7	2011 1157
641	1025 Lanier Ave. 8/23/2011	posted G. Huff	Town Creek	3	2011 1163
642	855 Sumner Ave. 8/23/2011	posted G. Huff	Three Mile Creek	1	2011 1164
643	1411 Belle Glade 8/24/2011	posted G. Huff	Eastover Creek	6	2011 1175
644	Behind Westland Plaza 8/24/2011	posted G. Huff	Lynch Creek	2	2011 1150
645	595 Cedar Springs Dr. 8/24/2011	posted G. Huff	Trabon Creek	1	2011 1152
646	823 Walnut Rd. 8/28/2011	posted G. Huff	Eubanks Creek	1	2011 1101
647	5145 Ridgeway Rd. 8/28/2011	posted G. Huff	Hanging Moss Creek	4	2011 1403
648	102 E. Ridgeway St. 8/29/2011	posted G. Huff	Town Creek	4	2011 1402
649	117 Clinton Park Dr. 8/29/2011	posted G. Huff	Lynch Creek	1	2011 1402
650	1451 Shady Lane Dr. 8/29/2011	posted G. Huff	Three Mile Creek	1	2011 1404
651	1681 Rainey Rd. 8/29/2011	posted G. Huff	Caney Creek	1	2011 1406
652	Dorgan St. & Gunda St. 8/29/2011	posted G. Huff	Hardy Creek	1	2011 1403
653	6112 Floral Dr. 8/29/2011	posted G. Huff	Hanging Moss Creek	1	2011 1402
654	636 Robinson Dr. 8/29/2011	posted G. Huff	Trabon Creek	1	2011 1405
655	826 North St. 8/30/2011	posted G. Huff	Town Creek	2	2011 1406
656	1251 Wood Village Dr. 8/30/2011	posted G. Huff	Lynch Creek	2	2011 1404
657	3111 Castle Hill Dr. 8/29/2011	posted G. Huff	Hardy Creek	1	2011 1770
658	4004 Northeast Dr. 8/27/2011	posted G. Huff	Eubanks Creek	4	2011 1778
659	4615 Southside Dr. 8/11/2011	posted G. Huff	Hanging Moss Creek	4	2011 1664
660	4358 California Ave. 7/28/2011	posted G. Huff	Town Creek	3	2011 1590
661	4358 California Ave. 7/29/2011	posted G. Huff	Town Creek	7	2011 20019
662	5112 Floral Dr. 8/30/2011	posted G. Huff	Hanging Moss Creek	1	2011 20018
663	Broadmoor Dr. 8/31/2011	posted G. Huff	Eubanks Creek	4	2011 12010
664	7816 Quatern Road Ave. 8/31/2011	posted G. Huff	Town Creek	3	2011 17028
665	1200 Newman Ave. 8/31/2011	posted G. Huff	Eubanks Creek	7	2011 17082
666	US 90 & 106 Overwing Ct & River Hills Blvd. 8/4/2011	posted G. Huff	Purple Creek	4	2011 17023
667	US 90 & 107 Westside 44 4919 Hwy 80 West & Westhaven Blvd.	posted G. Huff	Lynch Creek	2	2011 17024
668	359 Magnolia Rd. 9/5/2011	posted G. Huff	Lynch Creek	2	2011 1414
669	150 Carter Ave. 9/5/2011	posted G. Huff	Town Creek	3	2011 1413
670	241 Stokes Robinson Rd. 9/5/2011	posted G. Huff	Caney Creek	1	2011 1417
671	1005 Auburn Dr. 9/5/2011	posted G. Huff	White Oak Creek	4	2011 1415
672	3441 Martin Luther King Jr. Drive 9/5/2011	posted G. Huff	Town Creek	7	2011 14120
673	525 Northside Cir. 9/5/2011	posted G. Huff	Eubanks Creek	3	2011 14117
674	2025 Raymond Rd. 9/5/2011	posted G. Huff	Caney Creek	1	2011 14119
675	3005 Raymond Rd. 9/5/2011	posted G. Huff	Caney Creek	1	2011 14121
676	3245 Westgate Oaks Blvd. 9/4/2011	posted G. Huff	Town Creek	7	2011 14114
677	Hartfield St. & West St. 9/1/2011	posted G. Huff	Town Creek	4	2011 12065
678	976 Motarie Rd. 9/6/2011	posted G. Huff	Lynch Creek	2	2011 12377
679	N Watson Ave. & Ridgeway St. 9/6/2011	posted G. Huff	Town Creek	1	2011 12486
680	617 N Park Ln. 9/6/2011	posted G. Huff	Eubanks Creek	1	2011 12481
681	145 Lake of Pines Dr. 9/6/2011	posted G. Huff	Hanging Moss Creek	7	2011 1461

City of Jackson, MS
Sewer System
SSO Inspection Locations





City Of Jackson, Mississippi **Pump Station Potential Overflow Locations**

City of Jackson, Mississippi
 Department Of Public Works
 Post Office Box 17
 Jackson, MS 39205
 601-455-2001

PS#	Address/Property Owner	PS#	Address/Property Owner	Flow	Receiving Waterbody	Flow Potential
1	3539 Shellrock Drive	PS61	255 S. Shellrock	Potential	Bogue Chitto Creek	3
2	Cynthia Road	PS93	Presidential Hills	Potential	Bogue Chitto Creek	3
3	966 Flag Chapel Road	PS18	992 Flag Chapel Road	Potential	Bogue Chitto Creek	3
4	1820 Greenway Drive	PS39	2694 Moore Drive	Potential	Caney Creek	1
5	158 Hillview Drive	PS40	155 Hillview	Potential	Caney Creek	1
6	2117 Hickory Drive	PS24	2110 Hickory Drive	Potential	Caney Creek	1
7	2101 Raymond Road	PS53	2108 Raymond Road	Potential	Caney Creek	1
8	150 Timberlawn Road	PS73	132 Timberlawn Road	Potential	Trahan Creek	1
9	Highway 18	PS72	6115 Hwy. 18	Potential	Trahan Creek	1
10	120 Delray Drive	PS12	125 Delray Avenue	Potential	Caney Creek	1
11	1405 Canterbury Lane	PS87	Shannondale Drive	Potential	Trahan Creek	1
12	430 McCluer Road	PS34	500 McCluer Road	Potential	Caney Creek	1
13	4318 Lake Vista	PS15B	207 Elton Road	Potential	Caney Creek	1
14	893 Winthrop Circle	PS86	Whitestone Road	Potential	Hanging Moss Creek	3
15	6054 Floral Drive	PS46	6112 Floral Drive	Potential	Hanging Moss Creek	3
16	1396 Forest Avenue	PS19	1851 Forest Avenue	Potential	Eubanks Creek	3
17	2248 Sheffield Drive	PS59	2238 Sheffield Drive	Potential	Hanging Moss Creek	4
18	2 Old River Place	PS90	Old River Place	Potential	Belhaven Creek	2
19	1236 Zephyr Road	PS83	1914 US Hwy. 80 West	Potential	Lynch Creek	2
20	5551 Shaw Road	PS82	500 E. Browning Drive	Potential	Lynch Creek	2
21	Yarbrough Street	PS84	6325 Yarbrough Street	Potential	Lynch Creek	2
22	4218 Church Circle	PS81	4210 Church Circle	Potential	Lynch Creek	2
23	1801 Wallace Street	PS78	1790 Wallace Street	Potential	Lynch Creek	2
24	1885 Wallace Street	PS77	1900 Wallace Street	Potential	Lynch Creek	2
25	1911 Siwell Road	PS43	6186 McRaven Road	Potential	Lynch Creek	2
26	4862 McRaven Road	PS41	4813 McRaven Road	Potential	Lynch Creek	2
27	4706 McRaven Road	PS42	4660 McRaven Road	Potential	Lynch Creek	2
29	1139 Plantation Court	PS51	Plantation Court	Potential	White Oak Creek	4
30	10 Greenwing Court	PS23	Greenwing Court	Potential	Purple Creek	4
31	1728 Brookhollow Circle	PS4	6675 Hwy 18	Potential	Trahan Creek	1
32	313 Woodcliff Drive	PS8	201 Cedarwood Drive	Potential	Trahan Creek	1
33	253 Western Hills Drive	PS25	561 Hillandale Drive	Potential	Trahan Creek	1
34	170 Duranville	PS13	185 Duranville Drive	Potential	Trahan Creek	1
35	135 Stratford Drive	PS66A	139 Stratford Drive	Potential	Trahan Creek	1
36	137 Marshall Drive	PS31	166 Marshall Avenue	Potential	Trahan Creek	1
37	15 Nelson Circle	PS38	1665 McCluer	Potential	Trahan Creek	1
38	883 McCluer	PS36	887 McCluer	Potential	Trahan Creek	1
39	1074 McCluer	PS37	1077 McCluer	Potential	Trahan Creek	1
40	4052 Venus Drive	PS27	4058 Venus Avenue	Potential	Trahan Creek	1
41	201 Red Hill	PS29	201 Red Hill Drive	Potential	Trahan Creek	1
42	176 Lakeshore Drive	PS26	174 Lakeshore Road	Potential	Trahan Creek	1
71	4630 Terry Road	PS71	174 Lakeshore Road	Potential	Trahan Creek	1
44	154 Holly Hill Drive	PS32	Holly Hill Drive	Potential	Trahan Creek	1
45	4838 Old Byram	PS48	4837 Old Byram Road	Potential	Trahan Creek	1
46	113 Scottdale Drive	PS57	112 Scottdale Drive	Potential	Trahan Creek	1
47	7 Rob Lane	PS58	10 Rob Lane	Potential	Trahan Creek	1
48	342 Amanda Lane	PS2	Amanda Lane	Potential	Big Creek	1
49	837 Robinwood Drive	PS33	Robinwood Drive	Potential	Trahan Creek	1
50	4351 Patton Street	PS50	Patton Street	Potential	Bogue Chitto Creek	3
51	3844 Northside Drive	PS47	3700 W. Northside Drive	Potential	Bogue Chitto Creek	3
52	1205 Country Club Drive	PS11	1452 Country Club Drive	Potential	Bogue Chitto Creek	3
53	15 South	TP1	15 South	TP	Hardy Creek	1
54	Amanda Lane	PS2	Amanda Lane	PS	Big Creek	1
55	Brookhollow Drive L 160	PS3	Brookhollow Drive L 160	PS	Trahan Creek	1
56	6675 Hwy 18	PS4	6675 Hwy 18	PS	Trahan Creek	1
57	2102 Thousand Oak	PS5	2102 Thousand Oak	PS	Trahan Creek	1
58	Robway Cove	PS6A	Robway Cove	PS	Trahan Creek	1
59	201 Cedarwood Drive	PS6B	201 Cedarwood Drive	PS	Trahan Creek	1
60	461 Greenmount Drive	PS7	461 Greenmount Drive	PS	Trahan Creek	1
61	201 Cedarwood Drive	PS8	201 Cedarwood Drive	PS	Trahan Creek	1
62	140 Chasewood Avenue	PS9	140 Chasewood Avenue	PS	Trahan Creek	1



City Of Jackson, Mississippi **Pump Station Potential Overflow Locations**

City of Jackson, Mississippi
 Department of Public Works
 Post Office Box 17
 Jackson, MS 39201
 601-450-2000

PS#	Private/Harding Address	PS#	Public/Harding Address	Type	Receiving Water Body (Basin)	Potential Overflow
63	1452 Country Club Drive	PS11	1452 Country Club Drive	PS	Bogue Chitto Creek	3
64	125 Delray Avenue	PS12	125 Delray Avenue	PS	Caney Creek	1
65	185 Duranville Drive	PS13	185 Duranville Drive	PS	Trahan Creek	1
66	553 Eden Downs	PS14	553 Eden Downs	PS	Trahan Creek	1
67	1-55 Frontage Road	PS15A	1-55 Frontage Road	PS	Caney Creek	1
68	207 Elton Road	PS15B	207 Elton Road	PS	Caney Creek	1
69	1-55 Water Plant	PS16	1-55 Water Plant	PS	Belhaven Creek	4
70	717 Flag Chapel Road	PS17	717 Flag Chapel Road	PS	Bogue Chitto Creek	3
71	992 Flag Chapel Road	PS18	992 Flag Chapel Road	PS	Bogue Chitto Creek	3
72	1851 Forest Avenue	PS19	1851 Forest Avenue	PS	Eubank Creek	3
73	155 Forest Hill Drive	PS20	155 Forest Hill Drive	PS	Trahan Creek	1
74	3557 Forest Hill Road	PS21	3557 Forest Hill Road	PS	Trahan Creek	1
75	3285 Forest Park Drive	PS22	3285 Forest Park Drive	PS	Trahan Creek	1
76	Groeswing Court	PS23	Groeswing Court	PS	Purple Creek	4
77	2130 Hickory Drive	PS24	2130 Hickory Drive	PS	Caney Creek	1
78	561 Hillandale Drive	PS25	561 Hillandale Drive	PS	Trahan Creek	1
79	174 Lakeshore Road	PS26	174 Lakeshore Road	PS	Trahan Creek	1
80	4058 Venus Avenue	PS27	4058 Venus Avenue	PS	Trahan Creek	1
81	4395 Terry Road	PS28	4395 Terry Road	PS	Caney Creek	1
82	201 Red Hill Drive	PS29	201 Red Hill Drive	PS	Trahan Creek	1
83	160 Marshall Avenue	PS31	160 Marshall Avenue	PS	Trahan Creek	1
84	Holly Hills Drive	PS32	Holly Hills Drive	PS	Trahan Creek	1
85	Robinwood Drive	PS33	Robinwood Drive	PS	Trahan Creek	1
86	500 McCluer Road	PS34	500 McCluer Road	PS	Caney Creek	1
87	3890 McCluer Road	PS35	3890 McCluer Road	PS	Caney Creek	1
88	887 McCluer Road	PS36	887 McCluer Road	PS	Trahan Creek	1
89	1077 McCluer Road	PS37	1077 McCluer Road	PS	Trahan Creek	1
90	1605 McCluer Road	PS38	1605 McCluer Road	PS	Trahan Creek	1
91	2694 Moore Drive	PS39	2694 Moore Drive	PS	Caney Creek	1
92	135 Hillview	PS40	135 Hillview	PS	Caney Creek	1
93	4813 McKaven Road	PS41	4813 McKaven Road	PS	Lynch Creek	2
94	4660 McKaven Road	PS42	4660 McKaven Road	PS	Lynch Creek	2
95	6186 McKaven Road	PS43	6186 McKaven Road	PS	Lynch Creek	2
96	600 McKaven Road	PS44	600 McKaven Road	PS	Lynch Creek	2
97	6112 Floral Drive	PS46	6112 Floral Drive	PS	Hanging Moss Creek	3
98	3700 W. Northside Drive	PS47	3700 W. Northside Drive	PS	Bogue Chitto Creek	3
99	4837 Old Byram Road	PS48	4837 Old Byram Road	PS	Trahan Creek	1
100	4681 Old Byram Road	PS49	4681 Old Byram Road	PS	Trahan Creek	1
101	Palmer Street	PS50	Palmer Street	PS	Bogue Chitto Creek	3
102	Plantation Court	PS51	Plantation Court	PS	White Oak Creek	4
103	155 Portwood Drive	PS52	155 Portwood Drive	PS	Trahan Creek	1
104	2108 Raymond Road	PS53	2108 Raymond Road	PS	Caney Creek	1
105	5440 River Thames Road	PS54	5440 River Thames Road	PS	White Oak Creek	4
106	5407 River Thames Road	PS55	5407 River Thames Road	PS	White Oak Creek	4
107	5297 Robinson Road	PS56	5297 Robinson Road	PS	Caney Creek	1
108	112 Seaside Drive	PS57	112 Seaside Drive	PS	Trahan Creek	1
109	10 Rob Lane	PS58	10 Rob Lane	PS	Trahan Creek	1
110	2238 Sheffield Drive	PS59	2238 Sheffield Drive	PS	Hanging Moss Creek	4
111	6340 Country Club	PS60	6340 Country Club	PS	Bogue Chitto Creek	3
112	255 S. Shellrock	PS61	255 S. Shellrock	PS	Bogue Chitto Creek	3
113	3458 Dixie Syles Road	PS62	3458 Dixie Syles Road	PS	Bogue Chitto Creek	3
114	1465 Short Avenue	PS63	1465 Short Avenue	PS	Trahan Creek	1
115	4095 Sewell Road	PS64	4095 Sewell Road	PS	Big Creek	1
116	4071 Sewell Road	PS65	4071 Sewell Road	PS	Trahan Creek	1
117	139 Stratford Drive	PS66A	139 Stratford Drive	PS	Trahan Creek	1
118	2010 Chadwick Drive	PS66B	2010 Chadwick Drive	PS	Caney Creek	1
119	6065 Clinton Boulevard	PS67	6065 Clinton Boulevard	PS	Lynch Creek	3
120	151 Sylvan Trail	PS68	151 Sylvan Trail	PS	Lynch Creek	3
121	351 Sylvan Trail	PS69	351 Sylvan Trail	PS	Lynch Creek	3
122	498 Sylvan Trail	PS70	498 Sylvan Trail	PS	Trahan Creek	3
123	4640 Terry Road	PS71	4640 Terry Road	PS	Trahan Creek	1



City Of Jackson, Mississippi
Pump Station Potential Overflow Locations


City of Jackson, Mississippi
 Department Of Public Works
 Post Office Box 17
 Jackson, MS 39205
 601-981-2091

No.	Potential Overflow Location	PS No.	Pump Station Location	Type	Receiving Waterway (Basin)	Index Assigned
124	6115 Hwy. 18	PS72	6115 Hwy. 18	PS	Trahan Creek	1
125	132 Timberlawn Road	PS73	132 Timberlawn Road	PS	Trahan Creek	1
126	6159 US Hwy. 49 North	PS74	6159 US Hwy. 49 North	PS	Bogue Chitto Creek	3
127	Western Hills Drive	PS75	Western Hills Drive	PS	Trahan Creek	1
128	1900 Wallace Street	PS76	1900 Wallace Street	PS	Lynch Creek	1
129	1790 Wallace Street	PS77	1790 Wallace Street	PS	Lynch Creek	2
130	1651 Wallace Street	PS78	1651 Wallace Street	PS	Lynch Creek	2
131	1914 US Hwy. 80 West	PS79	1914 US Hwy. 80 West	PS	Lynch Creek	2
132	4210 Church Circle	PS80	4210 Church Circle	PS	Lynch Creek	2
133	500 E. Browning Drive	PS81	500 E. Browning Drive	PS	Lynch Creek	2
134	1238 Zephyr Street	PS82	1238 Zephyr Street	PS	Lynch Creek	2
135	6325 Yarbrough Street	PS83	6325 Yarbrough Street	PS	Lynch Creek	2
136	4180 Whitehall Road	PS84	4180 Whitehall Road	PS	Lynch Creek	2
137	Whitestone Road	PS85	Whitestone Road	PS	Hanging Moss Creek	2
138	Shannondale Drive	PS86	Shannondale Drive	PS	Trahan Creek	3
139	3855 Yarbrough	PS88	3855 Yarbrough	PS	Lynch Creek	2
140	E. River Place	PS89	E. River Place	PS	Bethaven Creek	2
141	Old River Place	PS90	Old River Place	PS	Bethaven Creek	2
142	Apache Road #1	PS91	Apache Road #1	PS	Big Creek	1
143	Apache Road #2	PS92	Apache Road #2	PS	Big Creek	1
144	Presidential Hills	PS93	Presidential Hills	PS	Bogue Chitto Creek	3
145	1235 Echelon Parkway	PS95	1235 Echelon Parkway	PS	Hanging Moss Creek	3



APPENDIX D – SEWER OVERFLOW RESPONSE INTERNAL NOTIFICATION AND TRACKING PROTOCOL

SEWER OVERFLOW INTERNAL NOTIFICATION FLOW CHART



SEWER OVERFLOW (SSO) RESPONSE TRACKING PROTOCOL

1. Report of possible SSO received by the COJ personnel.
2. COJ dispatch office deploys maintenance personnel to confirm reported SSO.
3. Maintenance personnel report back to the supervisor the significance of the overflow.
4. The COJ Superintendent, Wastewater Collections Engineer or authorized designee shall provide oral report to MDEQ within 24 hours. MDEQ becomes aware of the SSO notifying them of the location by street address or any other appropriate method (i.e. latitude-longitude)
5. If the overflow will affect recreational areas, public drinking water intakes, or results in a fish kill the COJ shall notify the MDEQ contact person and the HCDH contact person orally, and MEMA if after normal business hours, immediately upon confirming the discharge.
6. Within 5 days the COJ Superintendent, Wastewater Collections Engineer or authorized designee prepares the Wastewater SSO Assessment Form. The Utilities Manager is responsible for submission to MDEQ.
7. Data from Wastewater SSO Assessment Form are entered into a permanent record on file at the Sewer Maintenance Division. Records are maintained for a minimum of five years.
8. Detailed resource plan and milestone schedule for permanent corrective action are submitted with the monthly Discharge Monitoring Report.

City of Jackson, MS

Sewer Response Zone Map



Countyline Road

Bozley Road

Northside Drive

Madge Evers Blvd

Canton Blvd

Lakeland Drive

Robinson Road

High Street

McDowell Road

McCluer Road

Tony Road

Raymond Road

Legend

Sewer Response Zone



0 5,000 10,000 20,000 Feet

45

City of Jackson, MS

Swimming Areas Map



Map Document: P:\Jackson City\GIS\Bentley\Bentley.mxd, 11/17/2010 11:03:09 AM - 10:52:45 AM


0 4,950 9,900 19,800 Feet

Legend

Swimming Areas

Sewer Response Zone

1
2
3
4



APPENDIX E - REGULATORY AGENCY CONTACT INFORMATION AND NOTIFICATION PERIOD

Overflows requiring 24-Hour Verbal Notification (MDEQ, HCDH, & MEMA)

- impact or closure of swimming area during swimming season
- impact of closure of public drinking water intake
- results in a fish kill

Overflows Requiring 24-Hour Verbal Notification (MDEQ only)

- gravity sewer manhole
- pump station
- sewer siphon
- treatment plant bypass

MDEQ

During Normal Operating Hours – 8:00 a.m. – 5:00 p.m.

MDEQ Operator – 601-961-5171

MDEQ ECED Municipal & Private Facilities Branch Manager – 601-961-5588

MDEQ ECED Engineer for Jackson – 601-961-5319

After Normal Operating Hours (non-emergency)

(Voice Mail)

MDEQ ECED Municipal & Private Facilities Branch Manager – 601-961-5588

MDEQ ECED Engineer for Jackson – 601-961-5319

After Normal Operating Hours (emergency)

MEMA 24-hour State Warning Point – 1-800-222-6362

HCDH

Hinds County Health Department

Environmental Health

539 E Beasley Road

PO Box 20

Jackson, MS 39205-0020

Phone: (601)-957-1026

Fax: (601)-957-1053

Sherrie Payne, Regional Environmentalist

sherrie.payne@msdh.state.ms.us

Marvin Bolden, County Environmentalist

Lakeshia Paige, County Environmentalist

marvin.bolden@msdh.state.ms.us

lakeshia.paige@msdh.state.ms.us

Emergency Contact Numbers:

- Mississippi Department of Environmental Quality (MDEQ): - (601) 961 5171
- Entergy (Power Loss); Customer service and emergencies: 1-800-368-3749 (1-800-ENTERGY).
Power outages: 1-800-968-8243 (1-800-9OUTAGE).
- Highway Patrol & Fire Department: - 911
- United States Environmental Services (USES): - (601) 372 3232
- Hinds County - (601)957-1026

City of Jackson

- Wastewater Operations Engineer: Anthony Harkless: – (601) 720-5944
- Wastewater Collections Engineer: Vacant
- Sewer Maintenance Superintendent: Butch Mayfield – (601)-960-1875

United Water

- Project Manager: - Jerry Jones - (317) 490-6854
- Operations Manager: Ralph Gorenflo - (601) 340-2803
- Maintenance Manager: - Jackie Kiser - (601) 287-6116
- Maintenance Assistant Manager: - Darnell Gray (601) 896-6365
- Lift Station Supervisor: - Willie Wilson (601) 896-6380

APPENDIX F – PERSONNEL TRAINING DOCUMENTS

Sewer Overflow Response Plan (SORP) Training Plan

Training Topics

- I. What are Sanitary Sewer Overflows?
- II. Why do Sewers Overflow?
 1. Infiltration and Inflow
 2. Undersized Systems
 3. Pipe Failures
 4. Equipment Failures
 5. Lack of Maintenance
 6. Deteriorating Sewer System
- III. Why Control Sanitary Sewer Overflows?
 - I. Environmental Concerns and Health Risk
 - A. Contaminated Drinking Water Supply
 - B. Contaminated Fish and Shellfish
 - C. Direct Contact
 - Recreation Activities in Contaminated Waters
 - Sewer Backups in Homes
 - SSOs in Streets and Public Access Areas (e.g. Parks, Schoolyards, etc.)
 - D. Natural Resources Impacted
 - Waterways
 - Aquatic Life
- IV. What is SORP?
- V. Who needs SORP Training?
- VI. SORP Requirements
 1. Preventive Maintenance
 - A. Collection System Maintenance
 - B. Equipment Maintenance
 2. Overflow Response, Containment, and Recovery
 - A. Sewer Overflow Response Tracking Protocol
 - B. Directions for Completing Wastewater Assessment Forms
 - Sewer System Work Order Form
 - Wastewater Overflow Assessment Form

- C. Estimating Sanitary Sewer Overflow Volume
 - San Diego Method
 - Measured Volume
 - i. Units
 - ii. Conversion factors
 - iii. Wastewater Formulas (Area, Volume, Flow, etc.)
 - Duration and Flow
- 3. Reporting and Record Keeping
 - A. Notification – When, Who, and How?
 - B. Importance of Proper Record Keeping

Training Sessions

4 Hr Session Covering Overflow Response Procedures


2 Hr Session Covering Reporting Procedures

Training Sessions shall begin within 60 days of MDEQ's approval of this SORP

Training Attendees

The attached personnel chart shows all positions in the Wastewater Division. All employees from Public Works Director to Crew Leader will receive SORP Training.

Public Works Department



APPENDIX F

APPENDIX F

SUPPLEMENTAL ENVIRONMENTAL PROJECT

A. PURPOSE OF THE SEP

The purpose of the Supplemental Environmental Project ("SEP") is to reduce extraneous flows entering the WCTS through defective residential Private Laterals and through illicit connections from residential properties of eligible property owners. For purposes of this SEP, an illicit connection is any residential connection to the WCTS that discharges any substance or solution that is not intended to be transferred via the WCTS, such as stormwater, surface water runoff and roof runoff. The WCTS becomes a conduit for stormwater when defective Private Laterals or illicit connections allow rain or groundwater to enter the WCTS. Certain components of the WCTS Evaluation Plan required by Section VIII. of the Consent Decree will assist the City in identifying defective Private Laterals in need of repair or replacement and illicit connections to the WCTS.

B. SEP WORK

The City may perform the repair or replacement of defective Residential Private Laterals of eligible property owners itself or may use contractors or consultants in implementing this SEP.

In implementing this SEP, the City shall do the following, in accordance with the schedule set forth below:

- Draft and submit a proposed Escrow Agreement for EPA review.
- Establish and fund the Escrow Account and provide EPA with a copy of the Escrow.

- Provide information to residential property owners advising of the potential availability of the SEP work and contact information if they are interested in participating; develop financial hardship qualifications to identify eligible residential property owners for work under this SEP, using 2010 census information to identify moderate, low and very low income levels eligible; and determine which residential property owners meet the financial hardship qualifications and are accepted to participate in the SEP and notify the owners. In the event that more eligible residents apply for the SEP than there are funds available, preference shall be given to eligible very low income residents, then eligible low income residents and then eligible moderate income residents.
- Direct the Contractor performing the repair or replacement of a Private Lateral under this SEP to secure appropriate permits for the work.
- Determine actions necessary to repair or replace Private Laterals or remove illicit connections pursuant to this SEP and ensure that all work is undertaken in a timely manner and in conformity with appropriate standards.
- Ensure SEP completion on time.
- Report as required by Consent Decree.
- Maintain records of deposits into the SEP Escrow; work performed; and payments made from the Escrow.
- Prepare monthly status reports to provide City program manager with pertinent information for preparation of Consent Decree progress reports to allow City program manager to monitor compliance with SEP.

C. SEP COSTS

The City shall spend at least \$875,000.00 in eligible SEP costs for the repair and/or replacement of Private Laterals or removal of illicit connections for eligible residential property owners. Eligible SEP costs cover only the costs of actual plumbing services on Private Laterals and illicit connections owned by private residential customers only. If the City utilizes its own employees and equipment to perform the SEP, the City shall only be given credit against the total funding obligation if the activity is not something that otherwise would have been performed by the City's employees and if any such work is supported by time and expense records which are subject to review by EPA. The credit received by the City for using its own employees and equipment to perform the SEP will be reflected as a reduction in the next

scheduled Escrow deposit following the performance of the SEP activities. The intention is that the funds deposited into Escrow for the SEP, combined with any eligible SEP costs for SEP activities performed using City employees and equipment will total at least \$875,000.00.

The average cost of the Services on each private residential property is expected to range from \$1,500 to \$2,500 for repair or replacement of a defective Private Lateral and \$750 to \$1,000 for removal of an illicit connection. Actual costs will depend on negotiated costs with Plumbers, length of Private Lateral, surface and sub-surface interferences to the Private Lateral, and other pertinent factors. While initial expectations anticipate repair or replacement of 394 Private Laterals and removal of 100 illicit connections, the actual number of Private Laterals repaired or replaced and illicit connections removed pursuant to this SEP may be higher or lower.

D. PROGRAM SCHEDULE

1. Payments into the SEP Escrow

The City shall deposit \$875,000.00 to an interest-bearing escrow account ("SEP Escrow") to be used for performance of the SEP, in accordance with the schedule below, and subject to any credit for eligible SEP costs of City employees or equipment under Paragraph C. The City shall allow the United States to review the proposed Escrow Agreement prior to depositing any funds in the SEP Escrow. The City shall provide a copy of the executed Escrow Agreement within thirty (30) Days of the City's initial deposit to the SEP Escrow. The City shall provide EPA with documentation of the deposits to the SEP Escrow within thirty (30) Days of each such deposit. The interest earned on the SEP Escrow funds, along with the City's deposits

equaling \$875,000.00 shall be used in performance of this SEP. The City shall make deposits to the SEP Escrow according to the following schedule:

Six (6) Months after Date of Entry	\$175,000.00
Eighteen (18) Months after Date of Entry	\$100,000.00
Thirty (30) Months after Date of Entry	\$100,000.00
Forty-two (42) Months after Date of Entry	\$100,000.00
Fifty-four (54) Months after Date of Entry	\$100,000.00
Sixty-six (66) Months after Date of Entry	\$100,000.00
Seventy-eight (78) Months after Date of Entry	\$100,000.00
Ninety (90) Months after Date of Entry	\$100,000.00

Provided, however, that the City shall make accelerated deposit of an upcoming payment if the amount of funds in the SEP Escrow account drops below \$100,000.00 due to disbursements.

2. Project Implementation

The City shall perform the following tasks according to the following schedule:

Months 1 through 24 after Date of Entry:

- Develop list of Plumbers who will perform Services at agreed-upon costs for standard scopes of work and in accordance with current plumbing code requirements.
- Develop scopes of work, fee schedule, forms, and contracts to be used in implementation of the SEP.
- Notify property owners of the program.
- Develop financial hardship qualifications for eligibility for the SEP.
- Determine which residents will be included in the SEP and notify those residents.
- Develop a system to maintain records of disbursement of funds from escrow and records of location data of residential property owners who have had Services performed on their property as part of the SEP program.

No later than 25 Months after Date of Entry and ongoing until completion of the SEP:

- Begin performing work under the SEP.

- Track work performed pursuant to the SEP and maintain records of all work performed, including, at a minimum, the names and addresses of all property owners receiving services.
- Track amounts disbursed from the SEP Escrow and maintain records of all deposits to the SEP Escrow, disbursements from the SEP Escrow, and eligible SEP Costs for SEP activities performed using City employees and equipment which may be eligible for a credit towards the SEP Escrow under Paragraph C.

No Later than 72 Months after Date of Entry:

- The City shall use best efforts to ensure that the SEP is performed expeditiously and that approximately 50% (\$437,500) of the SEP funds are made available to eligible participants within 72 months after the Date of Entry.

3. Reporting Schedule

The City shall provide semiannual reports to EPA within one (1) Month after the second and fourth Calendar Quarters of each year on the status of implementation of the SEP, including documentation of the following that has occurred during the preceding six (6) Months:

- Deposit of funds to the SEP Escrow by the City.
- Disbursement of funds from the SEP Escrow by the Escrow Agent to pay Plumbers for Services completed.
- The balance of funds in the SEP Escrow.
- Locations of private residential properties where Services have been performed under the SEP program, including the property address and the name and address of the owner of the property.
- Description of other tasks required performed to implement the SEP during the past two (2) Calendar Quarters.

On or before nine (9) years after Date of Entry, the City shall submit a Final Completion Report to EPA as provided in the Consent Decree, Paragraph 50.