

EPA Contacts

US EPA Pacific Southwest/Region 9
75 Hawthorne St.
San Francisco, CA 94105

phone inquiries: 415-947-8000 or
866-EPA-WEST (toll free)

email inquiries: r9.info@epa.gov

Internet: www.epa.gov/region09

Emergency Spill Response

Contact the National Response
Center at 800-424-8802
to report any explosions
or major fuel spills.



Underground Storage Tanks

- Perform required periodic tests: line tightness, line leak detector, and cathodic protection, if applicable.
- Organize and maintain records of release detection, periodic tests, financial responsibility.
- Perform regular walk-through inspections of your facility. Look at sumps, piping, hoses for any leaks.

Aboveground Storage Tanks

- Develop and implement an SPCC plan.
- Provide secondary containment and proper security.
- Routinely monitor for leaks.



Used Oil

- Store used oil in containers that are in good condition.
- Clearly label containers as "USED OIL."
- Do not mix other fluids or waste with used oil.
- Clean up any spills or leaks.

GAS STATIONS

Do Your Part to Protect Our Environment

Motor Vehicle Waste Disposal Wells

- Notify EPA and your local authority about any existing Motor Vehicle Waste Disposal Wells (these wells may be prohibited.)
- Provide well inventory information to EPA and your local authority.
- Do not create any new Motor Vehicle Waste Disposal Wells.



Air Conditioning Units

- Technician and facility must be certified by an EPA-approved testing organization.
- Do not vent and release CFCs into the atmosphere. They must be recovered during servicing.

